

CEM - 2022 (Quarterly)

Parkland Refining (B.C.) Ltd.
Permit: 1217 / Due Date: October 31, 2022

22R - Sulphur recovery unit (SRU) incinerator	
Sulphur Oxides	
Test Date Range:	July 1 - September 30
Total Hours of Data Collected:	2178.00 hours
Permitted Flow Limit:	96.00 m3/min
Contaminant Permit Limit:	500.0000 mg/m3
Minimum Hourly Average Test Result:	1476.000 mg/m3
Date/Time of Minimum Hourly Average Test Result:	July 11, 2022
Maximum Hourly Average Test Result:	14798.000 mg/m3
Date/Time of Maximum Hourly Average Test Result:	July 31, 2022
Average of Test Results Over the Quarter:	2258.000 mg/m3
98th Percentile Value:	2853.000 mg/m3
Data Recovery:	99.000 %
Out of Compliance Explanation:	No out of compliance: permit limit 5000 mg/m3
Plan of Action to Obtain Compliance:	No out of compliance: permit limit 5000 mg/m3
Comments:	