

# Stack - 2009 (Yearly)

British Columbia Hydro and Power Authority  
Permit: 0363 / Due Date: Oct 31 2009

01 - PCB in oil decontamination vessel					
Polychlorinated Biphenyls					
Test Dates:	Sep 22 2009	Sep 23 2009	Sep 24 2009		
Test Results:	0.001 mg/m3	0.001 mg/m3	0.001 mg/m3		
Average of Test Results:	0.001 mg/m3				
Contaminant Permit Limit Value:	0.002 mg/m3				
Comments of Test Results:	All contaminant test results <0.001 mg/m3				
Flow Results:	0.001 m3/min	0.001 m3/min	0.001 m3/min		
Average of Flow Results:	0.001 m3/min				
Permitted Flow Limit:	0.1 m3/min				
Comments of Flow Results:	All results <0.001 mg/m3				
02 - Oil degassifier					
Polychlorinated Biphenyls					
Test Dates:	Sep 28 2009	Sep 29 2009	Sep 30 2009		
Test Results:	0.001 mg/m3	0.001 mg/m3	0.001 mg/m3		
Average of Test Results:	0.001 mg/m3				
Contaminant Permit Limit Value:	0.002 mg/m3				
Comments of Test Results:	All results <.001 mg/m3				
Flow Results:	0.001 m3/min	0.001 m3/min	0.001 m3/min		
Average of Flow Results:	0.001 m3/min				
Permitted Flow Limit:	0.03 m3/min				
Comments of Flow Results:	All results <.001 mg/m3				
03 - PCB in solid's decontamination vessel					
Polychlorinated Biphenyls					
Test Dates:	Oct 30 2009	Oct 30 2009	Oct 30 2009		
Test Results:	0 mg/m3	0 mg/m3	0 mg/m3		
Average of Test Results:	mg/m3				
Contaminant Permit Limit Value:	0.002 mg/m3				
Comments of Test Results:	Solids plant not in operation				
Flow Results:	0 m3/min	0 m3/min	0 m3/min		
Average of Flow Results:	m3/min				
Permitted Flow Limit:	0.19 m3/min				
Comments of Flow Results:	Solids plant not in operation				