

Stack - 2012 (Quarterly)

Chevron Canada Ltd.

Permit: 0117 / Due Date: July 30, 2012

19R - Fluid catalytic cracker (FCC) regenerator and waste heat boiler (WHB)					
Particulate Matter					
Test Dates:	May 01, 2012	May 01, 2012	May 01, 2012		
Test Results:	11.400 kg/h	13.300 kg/h	13.400 kg/h		
Average of Test Results:	12.7 kg/h				
Contaminant Permit Limit:	26.0000 kg/h				
Test Result Comments:					
Flow Results:	1683.000 m3/min	1718.000 m3/min	1702.000 m3/min		
Average of Flow Results:	1701 m3/min				
Permitted Flow Limit:	2450.00 m3/min				
Flow Result Comments:					