

Stack - 2017 (Every 2 Years)

Tree Island Industries Ltd.
Permit: 0184 / Due Date: September 30, 2017

| 06 - Pickling systems associated with the No. 1, No. 2 and No. 3 wire galvanizing lines | | | | | |
|---|---------------|--|--|--|--|
| Hydrogen Chloride | | | | | |
| Test Dates: | Jun 14, 2017 | | | | |
| Test Results: | 9.9000 mg/m3 | | | | |
| Average of Test Results: | 9.9 mg/m3 | | | | |
| Contaminant Permit Limit: | 10.0000 mg/m3 | | | | |
| Test Result Comments: | | | | | |
| Flow Results: | 64.000 m3/min | | | | |
| Average of Flow Results: | 64 m3/min | | | | |
| Permitted Flow Limit: | 150.00 m3/min | | | | |
| Flow Result Comments: | | | | | |
| Particulate Matter | | | | | |
| Test Dates: | Jun 14, 2017 | | | | |
| Test Results: | 2.6000 mg/m3 | | | | |
| Average of Test Results: | 2.6 mg/m3 | | | | |
| Contaminant Permit Limit: | 20.0000 mg/m3 | | | | |
| Test Result Comments: | | | | | |
| Flow Results: | 64.000 m3/min | | | | |
| Average of Flow Results: | 64 m3/min | | | | |
| Permitted Flow Limit: | 150.00 m3/min | | | | |
| Flow Result Comments: | | | | | |
| Zinc | | | | | |
| Test Dates: | Jun 14, 2017 | | | | |
| Test Results: | 0.0170 mg/m3 | | | | |
| Average of Test Results: | 0.017 mg/m3 | | | | |
| Contaminant Permit Limit: | 7.0000 mg/m3 | | | | |
| Test Result Comments: | | | | | |
| Flow Results: | 64.000 m3/min | | | | |
| Average of Flow Results: | 64 m3/min | | | | |
| Permitted Flow Limit: | 150.00 m3/min | | | | |
| Flow Result Comments: | | | | | |