

# Stack - 2022 (Yearly)

Weyerhaeuser Company Limited  
Permit: 0278 / Due Date: September 30, 2022

13 - Natural Gas and/or Woodwaste Fired Furnace					
<b>Formaldehyde</b>					
<b>Test Dates:</b>	May 26, 2022	May 26, 2022	May 26, 2022		
<b>Test Results:</b>	10.3000 mg/m3	2.0000 mg/m3	0.3000 mg/m3		
<b>Average of Test Results:</b>	4.2 mg/m3				
<b>Contaminant Permit Limit:</b>	6.0000 mg/m3				
<b>Test Result Comments:</b>					
<b>Flow Results:</b>	238.000 m3/min	242.000 m3/min	237.000 m3/min		
<b>Average of Flow Results:</b>	239 m3/min				
<b>Permitted Flow Limit:</b>	325.00 m3/min				
<b>Flow Result Comments:</b>					
<b>Particulate Matter</b>					
<b>Test Dates:</b>	May 26, 2022	May 26, 2022	May 26, 2022		
<b>Test Results:</b>	6.2000 mg/m3	3.4000 mg/m3	3.3000 mg/m3		
<b>Average of Test Results:</b>	4.3 mg/m3				
<b>Contaminant Permit Limit:</b>	20.0000 mg/m3				
<b>Test Result Comments:</b>					
<b>Flow Results:</b>	238.000 m3/min	242.000 m3/min	237.000 m3/min		
<b>Average of Flow Results:</b>	239 m3/min				
<b>Permitted Flow Limit:</b>	325.00 m3/min				
<b>Flow Result Comments:</b>					
<b>Phenol</b>					
<b>Test Dates:</b>	May 26, 2022	May 26, 2022	May 26, 2022		
<b>Test Results:</b>	0.2000 mg/m3	0.1000 mg/m3	0.1000 mg/m3		
<b>Average of Test Results:</b>	0.133 mg/m3				
<b>Contaminant Permit Limit:</b>	5.0000 mg/m3				
<b>Test Result Comments:</b>	Actual Phenol concentration was 0.171, 0.045 and 0.013 respectively.				
<b>Flow Results:</b>	238.000 m3/min	242.000 m3/min	237.000 m3/min		
<b>Average of Flow Results:</b>	239 m3/min				
<b>Permitted Flow Limit:</b>	325.00 m3/min				
<b>Flow Result Comments:</b>					