

# Stack - 2023 (Yearly)

Parkland Refining (B.C.) Ltd.  
Permit: 1217 / Due Date: August 01, 2023

11R - Steam plant boilers					
Sulphur Oxides					
<b>Test Dates:</b>	Apr 11, 2023	Apr 11, 2023	Apr 11, 2023		
<b>Test Results:</b>	8.0000 mg/m3	7.0000 mg/m3	7.0000 mg/m3		
<b>Average of Test Results:</b>	7.333 mg/m3				
<b>Contaminant Permit Limit:</b>	35.0000 mg/m3				
<b>Test Result Comments:</b>					
<b>Flow Results:</b>	433.000 m3/min	435.000 m3/min	436.000 m3/min		
<b>Average of Flow Results:</b>	434.667 m3/min				
<b>Permitted Flow Limit:</b>	650.00 m3/min				
<b>Flow Result Comments:</b>					