

Stack - 2026 (Every 2 Years)

Weir Canada Inc.

Permit: 1081 / Due Date: March 31, 2026

08 - Grit Blast Booth					
Particulate Matter					
Test Dates:	Jan 23, 2026	Jan 23, 2026	Jan 23, 2026		
Test Results:	< 0.7500 mg/m3	< 0.7700 mg/m3	< 0.2800 mg/m3		
Average of Test Results:	0.6 mg/m3				
Contaminant Permit Limit:	5.0000 mg/m3				
Test Result Comments:	Standard conditions (S) of 20 °C and 101.325 kPa (dry)				
Flow Results:	490.000 m3/min	489.000 m3/min	489.000 m3/min		
Average of Flow Results:	489.333 m3/min				
Permitted Flow Limit:	566.00 m3/min				
Flow Result Comments:	Standard conditions (S) of 20 °C and 101.325 kPa (dry)				