

Stack - 2011 (Yearly)

Weyerhaeuser Company Ltd.
Permit: 0278 / Due Date: Sep 30 2011

13 - Natural Gas and/or Woodwaste Fired Furnace					
Particulate Matter					
Test Dates:	Aug 12 2011	Aug 12 2011	Aug 12 2011		
Test Results:	16.8 mg/m3	6.6 mg/m3	12 mg/m3		
Average of Test Results:	11.8 mg/m3				
Contaminant Permit Limit Value:	230 mg/m3				
Comments of Test Results:					
Flow Results:	246 m3/min	262 m3/min	239 m3/min		
Average of Flow Results:	249 m3/min				
Permitted Flow Limit:	325 m3/min				
Comments of Flow Results:	The Particulate Matter concentration test results are adjusted to 12% CO2 (mg/dscm).				