

Stack - 2013 (Yearly)

International Forest Products Limited
Permit: 0589 / Due Date: March 31, 2013

| 01 - Wood burning power boiler | | | | | |
|--------------------------------|---|---------------|---------------|--|--|
| Particulate Matter | | | | | |
| Test Dates: | Jun 05, 2013 | Jun 05, 2013 | Jun 05, 2013 | | |
| Test Results: | 16.2000 mg/m3 | 18.0000 mg/m3 | 15.2000 mg/m3 | | |
| Average of Test Results: | 16.467 mg/m3 | | | | |
| Contaminant Permit Limit: | 20.0000 mg/m3 | | | | |
| Test Result Comments: | All results reported at standard conditions and corrected to 8% O2. | | | | |
| Flow Results: | 77.000 m3/min | 85.000 m3/min | 74.000 m3/min | | |
| Average of Flow Results: | 78.667 m3/min | | | | |
| Permitted Flow Limit: | 350.00 m3/min | | | | |
| Flow Result Comments: | | | | | |