Stack - 2022 (Every 5 Years)

Kruger Products LP
Permit: 0034 / Due Date: October 31, 2022

01 - Gasifier and No. 2 boiler					
Carbon Monoxide					
Test Dates:	Oct 25, 2022	Oct 25, 2022	Oct 25, 2022		
Test Results:	3.3000 mg/m3	2.8000 mg/m3	2.9000 mg/m3		
Average of Test Results:	3 mg/m3				
Contaminant Permit Limit:					
Test Result Comments:					
Flow Results:	355.000 m3/min	362.000 m3/min	362.000 m3/min		
Average of Flow Results:	359.667 m3/min				
Permitted Flow Limit:	1585.00 m3/min				
Flow Result Comments:					
Nitrogen Oxides					
Test Dates:	Oct 25, 2022	Oct 25, 2022	Oct 25, 2022		
Test Results:	263.0000 mg/m3	264.0000 mg/m3	267.0000 mg/m3		
Average of Test Results:	264.667 mg/m3				
Contaminant Permit Limit:					
Test Result Comments:					
Flow Results:	355.000 m3/min	362.000 m3/min	362.000 m3/min		
Average of Flow Results:	359.667 m3/min				
Permitted Flow Limit:	1585.00 m3/min				
Flow Result Comments:					
Sulphur Oxides					
Test Dates:	Oct 25, 2022	Oct 25, 2022	Oct 25, 2022		
Test Results:	32.7000 mg/m3	30.4000 mg/m3	26.5000 mg/m3		
Average of Test Results:	29.867 mg/m3				
Contaminant Permit Limit:					
Test Result Comments:					
Flow Results:	355.000 m3/min	362.000 m3/min	362.000 m3/min		
Average of Flow Results:	359.667 m3/min				
Permitted Flow Limit:	1585.00 m3/min				
Flow Result Comments:					

Total Volatile Organic Compounds					
Test Dates:	Oct 25, 2022	Oct 25, 2022	Oct 25, 2022		
Test Results:	0.5500 mg/m3	0.1800 mg/m3	0.1600 mg/m3		
Average of Test Results:	0.297 mg/m3				
Contaminant Permit Limit:					
Test Result Comments:					
Flow Results:	355.000 m3/min	362.000 m3/min	362.000 m3/min		
Average of Flow Results:	359.667 m3/min				
Permitted Flow Limit:	1585.00 m3/min				
Flow Result Comments:					