

# Stack - 2022 (Yearly)

Kruger Products LP

Permit: 0034 / Due Date: March 31, 2022

01 - Gassifier and No. 2 Boiler					
<b>Particulate Matter</b>					
<b>Test Dates:</b>	Jan 14, 2021	Jan 14, 2021	Jan 14, 2021		
<b>Test Results:</b>	4.5000 mg/m3	1.2000 mg/m3	1.0000 mg/m3		
<b>Average of Test Results:</b>	2.233 mg/m3				
<b>Contaminant Permit Limit:</b>	20.0000 mg/m3				
<b>Test Result Comments:</b>	Particulate (mg/Sm3 @ 11% O2)				
<b>Flow Results:</b>	394.000 m3/min	393.000 m3/min	389.000 m3/min		
<b>Average of Flow Results:</b>	392 m3/min				
<b>Permitted Flow Limit:</b>	1585.00 m3/min				
<b>Flow Result Comments:</b>					