

Stack - 2023 (Every 2 Years)

Richmond Plywood Corporation Ltd.
Permit: 0032 / Due Date: September 30, 2023

01 - Wood waste boiler					
Particulate Matter					
Test Dates:	Jul 12, 2023	Jul 12, 2023	Jul 12, 2023		
Test Results:	21.6000 mg/m3	14.2000 mg/m3	17.4000 mg/m3		
Average of Test Results:	17.733 mg/m3				
Contaminant Permit Limit:	20.0000 mg/m3				
Test Result Comments:					
Flow Results:	1348.000 m3/min	1346.000 m3/min	1335.000 m3/min		
Average of Flow Results:	1343 m3/min				
Permitted Flow Limit:	2421.00 m3/min				
Flow Result Comments:					