

Stack - 2023 (Yearly)

Produits Kruger Inc. Kruger Products Inc.

Permit: 0034 / Due Date: March 31, 2023

01 - Gasifier and No. 2 boiler					
Particulate Matter					
Test Dates:	Oct 25, 2022	Oct 25, 2022	Oct 25, 2022		
Test Results:	1.4500 mg/m3	1.7400 mg/m3	0.5400 mg/m3		
Average of Test Results:	1.243 mg/m3				
Contaminant Permit Limit:	15.0000 mg/m3				
Test Result Comments:					
Flow Results:	355.000 m3/min	362.000 m3/min	362.000 m3/min		
Average of Flow Results:	359.667 m3/min				
Permitted Flow Limit:	1585.00 m3/min				
Flow Result Comments:					