Stack - 2023 (Yearly)

University of British Columbia Permit: 1047 / Due Date: March 31, 2023

03 - IC Engine					
Nitrogen Oxides					
Test Dates:	Dec 01, 2021	Dec 01, 2021	Dec 01, 2021		
Test Results:	175.0000 mg/m3	143.0000 mg/m3	143.0000 mg/m3		
Average of Test Results:	153.667 mg/m3				
Contaminant Permit Limit:	115.0000 mg/m3				
Out of Compliance Explanation:	Nitrogen Oxide concentrations are consistent with manufacturer specification for this engine when running on natural gas				
Plan of Action to Obtain Compliance:	UBC has decommissioned this model of IC engine (Jenbacher J620) and is currently installing the J612 model whose NOx amount is <95mg/Nm3 (15% O2). It has a much lower NOx production which meets UBC's BRDF current permit requirements and will also have an upgraded control system to improve NOx emissions. Once installed in 2023 May, a stack test will be performed to validate the manufacturer's data.				
Test Result Comments:					
Flow Results:	169.000 m3/min	175.000 m3/min	177.000 m3/min		
Average of Flow Results:	173.667 m3/min				
Permitted Flow Limit:	188.00 m3/min				
Flow Result Comments:					
Particulate Matter					
Test Dates:	Dec 01, 2021	Dec 01, 2021	Dec 01, 2021		
Test Results:	1.9000 mg/m3	1.9000 mg/m3	0.6000 mg/m3		
Average of Test Results:	1.467 mg/m3				
Contaminant Permit Limit:	7.0000 mg/m3				
Test Result Comments:	UBC has decommissioned this model of IC engine (Jenbacher J620) and is currently installing the J612 model whose NOx amount is <95mg/Nm3 (15% O2). It has a much lower NOx production which meets UBC's BRDF current permit requirements and will also have an upgraded control system to improve NOx emissions. Once installed in 2023 May, a stack test will be performed to validate the manufacturer's data.				
Flow Results:	169.000 m3/min	175.000 m3/min	177.000 m3/min		
Average of Flow Results:	173.667 m3/min				
Permitted Flow Limit:	188.00 m3/min				
Flow Result Comments:					

Report date: 3/15/2023 1:12:24 PM Page 1 of 1