

Stack - 2026 (Quarterly)

Parkland Refining (B.C.) Ltd.
Permit: 1217 / Due Date: January 31, 2026

19R - Fluid catalytic cracker (FCC) regenerator and waste heat boiler (WHB)					
Metals					
Test Dates:	Dec 02, 2025	Dec 02, 2025	Dec 03, 2025		
Test Results:	0.3824 mg/m3	0.3849 mg/m3	0.3526 mg/m3		
Average of Test Results:	0.373 mg/m3				
Contaminant Permit Limit:					
Test Result Comments:	Reported as sum of Class I metals. For more information please see attached report.				
Flow Results:	1830.000 m3/min	1820.000 m3/min	1810.000 m3/min		
Average of Flow Results:	1820 m3/min				
Permitted Flow Limit:	2450.00 m3/min				
Flow Result Comments:					
Particulate Matter					
Test Dates:	Dec 02, 2025	Dec 02, 2025	Dec 03, 2025		
Test Results:	5.0000 kg/h	4.0000 kg/h	5.0000 kg/h		
Average of Test Results:	4.667 kg/h				
Contaminant Permit Limit:	20.0000 kg/h				
Test Result Comments:					
Flow Results:	1830.000 m3/min	1820.000 m3/min	1810.000 m3/min		
Average of Flow Results:	1820 m3/min				
Permitted Flow Limit:	2450.00 m3/min				
Flow Result Comments:					