

Stack - 2023 (Yearly)

Parkland Refining (B.C.) Ltd.
Permit: 1217 / Due Date: September 30, 2023

19R - Fluid catalytic cracker (FCC) regenerator and waste heat boiler (WHB)					
Particulate Matter					
Test Dates:	Sep 05, 2023	Sep 06, 2023	Sep 07, 2023		
Test Results:	6.0000 kg/h	5.0000 kg/h	6.0000 kg/h		
Average of Test Results:	5.667 kg/h				
Contaminant Permit Limit:	20.0000 kg/h				
Test Result Comments:					
Flow Results:	1460.000 m3/min	1470.000 m3/min	1530.000 m3/min		
Average of Flow Results:	1486.667 m3/min				
Permitted Flow Limit:	2450.00 m3/min				
Flow Result Comments:					