

Stack - 2019 (Yearly)

University of British Columbia
 Permit: 1047 / Due Date: March 31, 2019

01 - Biomass Belt Dryer					
Particulate Matter					
Test Dates:	Dec 04, 2018	Dec 04, 2018	Dec 04, 2018		
Test Results:	7.6000 mg/m3	10.7000 mg/m3	8.1000 mg/m3		
Average of Test Results:	8.8 mg/m3				
Contaminant Permit Limit:	15.0000 mg/m3				
Test Result Comments:					
Flow Results:	266.100 m3/min	266.600 m3/min	266.900 m3/min		
Average of Flow Results:	266.533 m3/min				
Permitted Flow Limit:	1086.00 m3/min				
Flow Result Comments:					
Total Volatile Organic Compounds					
Test Dates:	Dec 04, 2018	Dec 04, 2018	Dec 04, 2018		
Test Results:	5.9000 mg/m3	3.8000 mg/m3	4.4000 mg/m3		
Average of Test Results:	4.7 mg/m3				
Contaminant Permit Limit:	10.4000 mg/m3				
Test Result Comments:					
Flow Results:	266.100 m3/min	266.600 m3/min	266.900 m3/min		
Average of Flow Results:	266.533 m3/min				
Permitted Flow Limit:	1086.00 m3/min				
Flow Result Comments:					