

# Stack - 2019 (Yearly)

University of British Columbia  
Permit: 1047 / Due Date: March 31, 2019

02 - Steam Boiler					
<b>Nitrogen Oxides</b>					
<b>Test Dates:</b>	Dec 05, 2018	Dec 05, 2018	Dec 05, 2018		
<b>Test Results:</b>	171.3000 mg/m3	151.5000 mg/m3	153.0000 mg/m3		
<b>Average of Test Results:</b>	158.6 mg/m3				
<b>Contaminant Permit Limit:</b>	271.7000 mg/m3				
<b>Test Result Comments:</b>					
<b>Flow Results:</b>	272.300 m3/min	237.900 m3/min	223.500 m3/min		
<b>Average of Flow Results:</b>	244.567 m3/min				
<b>Permitted Flow Limit:</b>	259.00 m3/min				
<b>Flow Result Comments:</b>					
<b>Particulate Matter</b>					
<b>Test Dates:</b>	Dec 05, 2018	Dec 05, 2018	Dec 05, 2018		
<b>Test Results:</b>	6.9000 mg/m3	4.8000 mg/m3	2.4000 mg/m3		
<b>Average of Test Results:</b>	4.7 mg/m3				
<b>Contaminant Permit Limit:</b>	15.0000 mg/m3				
<b>Test Result Comments:</b>					
<b>Flow Results:</b>	272.300 m3/min	237.900 m3/min	223.500 m3/min		
<b>Average of Flow Results:</b>	244.567 m3/min				
<b>Permitted Flow Limit:</b>	259.00 m3/min				
<b>Flow Result Comments:</b>					
<b>Total Volatile Organic Compounds</b>					
<b>Test Dates:</b>	Dec 05, 2018	Dec 05, 2018	Dec 05, 2018		
<b>Test Results:</b>	0.1000 mg/m3	0.4000 mg/m3	0.3000 mg/m3		
<b>Average of Test Results:</b>	0.267 mg/m3				
<b>Contaminant Permit Limit:</b>	13.6500 mg/m3				
<b>Test Result Comments:</b>					
<b>Flow Results:</b>	272.300 m3/min	237.900 m3/min	223.500 m3/min		
<b>Average of Flow Results:</b>	244.567 m3/min				
<b>Permitted Flow Limit:</b>	259.00 m3/min				
<b>Flow Result Comments:</b>					