

Stack - 2020 (Yearly)

University of British Columbia
 Permit: 1047 / Due Date: March 31, 2020

02 - Steam Boiler					
Nitrogen Oxides					
Test Dates:	Dec 03, 2019				
Test Results:	197.9000 mg/m3				
Average of Test Results:	197.9 mg/m3				
Contaminant Permit Limit:	271.7000 mg/m3				
Test Result Comments:					
Flow Results:	259.000 m3/min				
Average of Flow Results:	259 m3/min				
Permitted Flow Limit:	259.00 m3/min				
Flow Result Comments:					
Particulate Matter					
Test Dates:	Dec 03, 2019				
Test Results:	3.9000 mg/m3				
Average of Test Results:	3.9 mg/m3				
Contaminant Permit Limit:	15.0000 mg/m3				
Test Result Comments:					
Flow Results:	259.000 m3/min				
Average of Flow Results:	259 m3/min				
Permitted Flow Limit:	259.00 m3/min				
Flow Result Comments:					
Total Volatile Organic Compounds					
Test Dates:	Dec 03, 2019				
Test Results:	0.2800 mg/m3				
Average of Test Results:	0.28 mg/m3				
Contaminant Permit Limit:	13.6500 mg/m3				
Test Result Comments:					
Flow Results:	259.000 m3/min				
Average of Flow Results:	259 m3/min				
Permitted Flow Limit:	259.00 m3/min				
Flow Result Comments:					