



**A.Lanfranco
& Associates Inc.**

Environmental Consultants

Prepared for

METRO VANCOUVER

Metrotower III 4730 Kingsway

Burnaby, BC V5H 0C6

**Annual Trace Organics Emission Report
Waste-to-Energy Facility**

August 2020 Survey

Operational Certificate 107051

Report Issued: September 25, 2020

CERTIFICATION

The field monitoring for this survey was conducted by certified stack test technicians as required by the British Columbia Ministry of Environment (BC MOE) Field Sampling Manual.

The field crew consisted of:

Mr. L. Agassiz (certified), Mr. C. Lanfranco (certified), Mr. J. Gibbs (certified) and Mr. S. Baker.

The report was prepared by Mr. L. Agassiz using reporting principles and guidelines generally acceptable to Metro Vancouver (MV).

The field crew and A. Lanfranco and Associates Inc. certify that the test methods used were BC MOE/MV approved reference methods for the parameters investigated.



Mark Lanfranco, CST

President | Owner

Table of Contents

TEST PROGRAM ORGANIZATION	1
SUMMARY	2
1.0 INTRODUCTION	3
2.0 METHODOLOGY	3
2.1 Sampling and Analytical Methods	4
2.2 Calculations	10
2.2.1 Contaminant Concentration Calculations	10
2.2.2 Isokinetic Variation Calculations	12
2.2.3 Volumetric Flowrate Calculations	14
2.3 Quality Assurance/Quality Control (QA/QC) Techniques	14
3.0 TEST RESULTS	15
4.0 DISCUSSION	20

APPENDICES

Appendix 1 - Analytical Data

Appendix 2 - Computer Outputs of Measured and Calculated Data

Appendix 3 - Field Data Sheets

Appendix 4 - Calibration Data and Certification

TEST PROGRAM ORGANIZATION

Primary Stakeholders:	Brent Kirkpatrick and Sarah Wellman Metro Vancouver – Solid Waste Services Metrotower III - 4730 Kingsway Burnaby, B.C. Canada Email: brent.kirkpatrick@metrovancouver.org Email: sarah.wellman@metrovancouver.org
Facility Coordinator:	Stephen McKinney Facility Manager Covanta Burnaby Renewable Energy ULC 5150 Riverbend Drive Burnaby, BC Canada V3N 4V3 Email: smckinney@covanta.com
Project Manager/Sampling Contractor:	Mr. Mark L.A. Lanfranco President Owner A. Lanfranco and Associates Inc. 101 – 9488 189 St Surrey, BC Canada V4N 4W7 Tel: (604) 881-2582 Email: mark.lanfranco@alanfranco.com
Sampling Crew:	Mr. L. Agassiz – A. Lanfranco and Associates Inc. Mr. C. Lanfranco – A. Lanfranco and Associates Inc. Mr. J. Gibbs – A. Lanfranco and Associates Inc. Mr. S. Baker – A. Lanfranco and Associates Inc.

SUMMARY

The following tables present the average of triplicate test results on Unit 3 for various trace organics on August 18-19, 2020. Additional emission parameters were measured by the facility's certified continuous emission monitoring system.

Parameter		Unit 3	Limit
PCDD/PCDF	(TEQ ng/Sm ³ @ 11% O ₂)	0.0018	0.08
PCDD/PCDF Mass Emission	(TEQ g/day)	3.26E-06	
PAH	(µg/Sm ³ @ 11% O ₂)	0.0884	5.0
HCB*	(µg/Sm ³ @ 11% O ₂)	0.0012	
Total CB	(µg/Sm ³ @ 11% O ₂)	0.2490	1.0
Total CP*	(µg/Sm ³ @ 11% O ₂)	0.0062	1.0
Total PCB	(µg/Sm ³ @ 11% O ₂)	0.0025	1.0
Flowrate	(Sm ³ /min)	1148	
Temperature	(°C)	153	
O ₂	(vol % dry)	9.9	

Standard conditions (S) of 20 °C and 101.325 kPa (dry)

*Calculated using half DL convention.

Note: PCDD/PCDF results are in nanograms per cubic meter and grams/day, PAH/HCB/CB/CP are reported in micrograms per cubic meter.

1 INTRODUCTION

Metro Vancouver (MV) commissioned an emissions monitoring survey at the Waste-to-Energy Facility (WTEF) in Burnaby, B.C. This report documents the results of a semi-volatile organics survey for dioxin/furan (PCDD/PCDF), polychlorinated biphenyl (PCB), polycyclic aromatic hydrocarbons (PAH), hexachlorobenzenes (HCB), chlorobenzenes (CB), and chlorophenols (CP) during normal operations at the facility.

This report includes detailed emission results, a brief outline of methods employed, equipment used, and a discussion of the survey. Supporting data is presented in the appendices section of this report.

The individual source monitored for 2020 was Unit 3.

2 METHODOLOGY

All services provided by A. Lanfranco and Associates were conducted in accordance with approved reference methods as issued by:

- Metro Vancouver
- BC Ministry of Environment & Climate Change Strategy
- Environment Canada (EC)
- US Environmental Protection Agency (EPA)

2.1 Sampling and Analytical Methods

The following table lists the test methods used for the different parameters measured. The subsequent paragraphs briefly describe each method.

<u>Parameter</u>	<u>Reference Method</u>
Sample and Velocity traverse points	EPS 1/RM/8 A Determination of Sampling Site and Traverse Points
Velocity and flowrate	EPS 1/RM/8 B Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)
Gas molecular weight (O ₂ /CO ₂)	EPS 1/RM/8 C Determination of Molecular Weight by Gas Analysis
Flue gas Moisture	EPS 1/RM/8 D Determination of Moisture Content
Dioxin/Furan (sampling)	EPS 1/RM/2 Reference Method for Source Testing - Measurement of Releases of Semi-Volatile Organic Compounds from Stationary Sources EPA Method 23 Determination of Polychlorinated Dibenzo-p-Dioxins and Polychlorinated Dibenzofurans from Stationary Sources supporting
Dioxin/Furan (analytical)	Methodology for Organic Analysis - A Method for the Analysis of Polychlorinated Dibenzopara-Dioxins (PCDD's), Polychlorinated Dibenzofurans (PCDF's) Environment Canada, December 1989

Sampling Site and Traverse Points

Primary: EPS 1/RM/8 Method A
Supporting: EPA Method 1

This method is designed to aid in the representative measurement of pollutant emissions and/or total volumetric flow rate from a stationary source. A measurement site where the effluent stream is flowing in a known direction is selected, and the cross-section of the stack is divided into a number of equal areas. Traverse points are then located within each of these equal areas.




Figure 1. Example showing circular stack cross section divided into 12 equal areas, with location of traverse points.

Stack Gas Velocity
and Volumetric Flow Rate

Primary: EPS 1/RM/8 Method B
 Supporting: EPA Method 2

The average gas velocity in a stack or duct is determined from the gas density and from the measurement of velocity pressure with an S-type pitot tube. A standard pitot tube may be used where plugging of the tube openings due to particulate matter and/or moisture is not likely to occur. Stack gas volumetric flow rate is determined from measurements of stack gas velocity, temperature, absolute pressure, dry gas composition, moisture content, and stack diameter.




Figure 2. Type S Pitot Tube Manometer Assembly

Molecular Weight by Gas Analysis

Primary: EPS 1/RM/8 Method C
 Supporting: EPA Method 3

An integrated or grab sample is extracted from a single point in the gas stream and analyzed for its components using a Fyrite analyzer, a gas chromatograph, or calibrated continuous analyzers.

Moisture Content

Primary: EPS 1/RM/8 Method D
 Supporting: EPA Method 4

A gas sample is extracted from a single point in the enclosed gas stream being sampled. The moisture is condensed and its weight measured. This weight, together with the volume of gas sampled, enables the stack gas moisture content to be calculated.

Dioxins / Furans

Primary: EPS 1/RM/2, 1/RM/3, 1/RM/23
 Supporting: EPA Method 23

This method is applicable to the determination of emissions of polychlorinated dibenzo-pa-dioxins (PCDDs), polychlorinated dibenzofurans (PCDFs), polychlorinated biphenyls (PCBs), polycyclic aromatic hydrocarbons (PAHs), and other semi-volatile organic compounds from stationary sources. An integrated gas sample is isokinetically withdrawn from the stack similar to Method 5. Semi-volatile organic compounds associated with particulate matter are collected in the front half components with remaining compounds not collected by the filter, being absorbed in an Amberlite XAD-2 resin trap.





Figure 3 - Dioxin / Furan Sampling Train

Due to the sensitivity of this test method, extra care and precautions are used. All sample trains were cleaned professionally at an accredited laboratory. A solvent proof of the glassware and XAD was archived as suggested by the method.



The train was operated for duration of 240 minutes. Upon completion, it was removed to a clean area for recovery. The recovered sample consists of 6 individual components:

• Filter Rinses	• Front Half Rinses
• XAD Trap	• Soak
• Impingers	• Final Rinse

Container or Sample	Component(s)	Recovery Procedure
1	1, 2, 3, 4	Wash and brush 3 times each with hexane (H) and acetone (A). Rinse 3 times each with H and A.
2	5	Remove carefully from holder. Place on pre-cleaned foil. Fold in half. Place in pre-cleaned glass petri dish.
3	6, 7	Soak 5 minutes each with H and A. Rinse 3 times each with H and A.
4	8	Cap ends and wrap in foil.
5	9, 12	Empty contents into container and rinse each 3 times with HPLC water.
6	6 to 15 except 8	Rinse 3 times each with H and A.

Mark liquid levels on all bottles.
All sample containers are pre-cleaned amber glass bottles with pre-cleaned Teflon lid liners.

Figure 4 Recovery Procedures for Semi-Volatile Organics

Complete sampling and recovery procedures can be supplied upon request.

Samples are analyzed on a high-resolution GS/MS at Pacific Rim Laboratories Inc. of Surrey, BC. Following is a description, in very simplified terms, of the basic procedures used to process the sample train and blank train components.

Initially the sample components are separated into liquid (containers 1, 4, 5 and 6) or solid phases (containers 2 and 3) and surrogate compounds (for recovery calculations) are injected into the solid phases of the front and back half samples. Liquid and solid samples are extracted with various solvents (usually benzene), sometimes under acid conditions. Figure 5 and Figure 6 demonstrate the step by step procedures used to extract the components of interest into a solvent phase which is ready for detailed splitting and clean-up. The concentrated extracts from Figure 5 are combined and are processed per procedures detailed in Figure 6.

When each target group has been isolated, as indicated in Figure 4, the extract volumes are dried, concentrated, and analysed by GC/MS analytical instrumentation. Prior to actual analysis, all samples were spiked with a performance standard for laboratory QA/QC purposes.




Figure 5 - Semi-Volatile Organics XAD and Filter Recovery Schematic




Figure 6 - Schematic of analytical methodology for dioxins and furans

2.2 Calculations

The following sections show the equations and define the variables that were used for this survey. The equations are organized in three sections. Equations 1-11 were used to calculate particulate concentration at standard conditions on a dry basis. Equations 12-26 were used to sample within the $100 \pm 10\%$ isokinetic variation and to confirm that sampling meets this isokinetic variation threshold. Equations 27-29 were used to calculate the volumetric flowrate of the stack flue gas.

2.2.1 Contaminant Concentration Calculations

$$c = \frac{m}{V_{std}} \quad \text{Equation 1}$$

$$m_{part} = m_{filter} + m_{pw} \quad \text{Equation 2}$$

$$m_i = m_{ana,i} - m_{blank} \quad \text{Equation 3}$$

$$m_{HF} = \frac{20.006}{18.998} (m_F - m_{blank}) / 1000 \quad \text{Equation 4}$$

$$V_{std} = \frac{V_{std(imp)}}{35.315} \quad \text{Equation 5}$$

$$V_{std(imp)} = \frac{V_{samp} \times y \times P_m \times (T_{std} + 459.67)}{P_{std} \times (T_{m(ave)} + 459.67)} \quad \text{Equation 6}$$

$$V_{samp} = V_{final} - V_{init} \quad \text{Equation 7}$$

$$P_m = P_B + \frac{\Delta H_{ave}}{13.6} \quad \text{Equation 8}$$

$$\Delta H_{ave} = \frac{1}{n} \sum_{i=1}^n \Delta H_{i(act)}, \text{ where } n = \text{the number of points} \quad \text{Equation 9}$$

$$OC = \frac{20.9 - \%O_{2c}}{20.9 - \%O_{2m}} \quad \text{Equation 10}$$

$$\%O_{2m} = \frac{1}{n} \sum_{i=1}^n \%O_{2i}, \text{ where } n = \text{the number of } O_2 \text{ measurements} \quad \text{Equation 11}$$

Where,

c	= Contaminant concentration
m	= Contaminant mass
m_i	= Net analytical mass (mg, ng, or μg)
$m_{ana,i}$	= Analytical mass (mg, ng, or μg)
m_{blank}	= Blank analytical mass (mg, ng, or μg)
$V_{std(imp)}$	= Sample volume at standard conditions (ft^3)
V_{std}	= Sample volume at standard conditions (m^3)
V_{samp}	= Sample volume at actual conditions (ft^3)
V_{final}	= Final gas meter reading (ft^3)
V_{init}	= Initial gas meter reading (ft^3)
T_{std}	= Standard temperature (68 °F)
T_m	= Gas meter temperature (°F)
$T_{m(ave)}$	= Average gas meter temperature (°F)
P_m	= Absolute meter pressure (inches of Hg)
P_B	= Barometric pressure (inches of Hg)
ΔH_{ave}	= Average of individual point orifice pressures (inches of H_2O)
$\Delta H_{i(act)}$	= Individual recorded point orifice pressures (inches of H_2O)
OC	= Oxygen correction factor (dimensionless)
$\%O_{2c}$	= Oxygen concentration to correct to (% dry basis)
$\%O_{2m}$	= Average measured stack gas oxygen concentration (% dry basis)

Equation 1 is the general concentration calculation used for all contaminants. The contaminant mass, m , is the net analytic mass for the given contaminant.

The dioxins/furans and other semi-volatile organic compounds were treated slightly different. The blank results for all trace organic species are used as a Quality Assurance check and are not used to correct the analytic results. Also, according to the terms of the service agreement, individual trace organic species were reported as “non-detect” (ND) if all three tests for that species are below the detection limit. If one (or more) of the triplicate samples has a reportable value, the corresponding ND samples from the other test runs were reported at half the detection limit. For calculating of summarized results (PCDD& PCDF TEQ, Total PAHs, Total Chlorobenzenes, Total Chlorophenols, and Total PCBs) the substitution of half DL for each individual species, as detailed above, was performed prior to calculating the sums.

All results are reported in the units outlined in the service agreement. The following unit conversions were used throughout:

$$1 \text{ mg} = 10^{-3} \text{ g}$$

$$1 \text{ } \mu\text{g} = 10^{-6} \text{ g}$$

$$1 \text{ ng} = 10^{-9} \text{ g}$$

$$1 \text{ tonne} = 10^6 \text{ g}$$

Oxygen corrections were applied by multiplying the result of Equation 1 by the result of Equation 10 for each individual result.

2.2.2 Isokinetic Variation Calculations

$$\Delta H_i = \frac{2.62 \times 10^7 \times c_p \times A_n \times (1 - B_{wo}) \times M_D \times (T_m + 459.67) \times \Delta p_i}{k_o \times M_w \times (T_{stk} + 459.67)} \quad \text{Equation 12}$$

$$R_m = 85.49 \times c_p \times \sqrt{\Delta p_i} \times \sqrt{\frac{(T_{stk_i} + 459.67)}{M_w \times P_B}} \times 60 \times A_n \times \frac{(T_{m_i} + 459.67) \times (1 - B_{wo})}{(T_{stk_i} + 459.67) \times y} \quad \text{Equation 13}$$

$$A_n = \pi \left(\frac{d_n}{24} \right)^2 \quad \text{Equation 14}$$

$$M_w = M_D \times (1 - B_{wo}) + 18 \times B_{wo} \quad \text{Equation 15}$$

$$M_D = 0.44 \times \%CO_2 + 0.32 \times \%O_2 + 0.28 \times (100 - \%CO_2 - \%O_2) \quad \text{Equation 16}$$

$$T_{stk} = \frac{1}{n} \sum_{i=1}^n T_{stk_i}, \text{ where } n = \text{the number of points} \quad \text{Equation 17}$$

$$B_{wo} = \frac{V_{cond}}{V_{cond} + V_{std(imp)}} \quad \text{Equation 18}$$

$$V_{cond} = 0.04707 \times V_{gain} \quad \text{Equation 19}$$

$$Iso = \frac{1}{n} \sum_{i=1}^n Iso_i, \text{ where } n = \text{the number of points} \quad \text{Equation 20}$$

$$ISO_i = \frac{v_{nzi}}{v_i} \quad \text{Equation 21}$$

$$v_i = 85.49 \times c_p \times \sqrt{\Delta p_i} \times \sqrt{\frac{(T_{Stk_i} + 459.67)}{(P_{Stk} \times M_w)}} \quad \text{Equation 22}$$

$$v_{nzi} = \frac{(V_i - V_{i-1}) \times y \times (T_{Stk_i} + 459.67) \times (P_B + \frac{\Delta H_{i(act)}}{13.6})}{A_n \times t_i \times 60 \times (T_{m(i)} + 459.67) \times P_{Stk} \times (1 - B_{wo})} \quad \text{Equation 23}$$

$$P_{Stk} = P_B + \frac{P_g}{13.6} \quad \text{Equation 24}$$

$$v_{Stk} = \frac{1}{n} \sum_{i=1}^n v_i, \text{ where } n = \text{the number of points} \quad \text{Equation 25}$$

$$v_{nz} = \frac{1}{n} \sum_{i=1}^n v_{nzi}, \text{ where } n = \text{the number of points} \quad \text{Equation 26}$$

Where,

A_n	= Nozzle area (ft ²)
d_n	= Diameter of nozzle (inches)
c_p	= Pitot coefficient (dimensionless)
Δp_i	= Individual point differential pressures (inches of H ₂ O)
T_{Stk}	= Average flue gas temperature (°F), second subscript <i>i</i> , indicates individual point measurements
$\Delta H_{i(act)}$	= Calculated individual point orifice pressures (inches of H ₂ O)
P_g	= Stack Static pressure (inches of H ₂ O)
P_{Stk}	= Absolute stack pressure (inches of Hg)
M_w	= Wet gas molecular weight (g/gmol)
M_D	= Dry gas molecular weight (g/gmol)
%CO ₂	= Stack gas carbon dioxide concentration (% dry basis)
%O ₂	= Stack gas oxygen concentration (% dry basis)
B_{wo}	= Stack gas water vapour, proportion by volume
V_{cond}	= Total volume of water vapor collected, corrected to standard conditions (ft ³)
V_{gain}	= Condensate gain of impinger contents (mL)
P_{std}	= Standard pressure (29.92 inches of Hg)
V_{Stk}	= Average flue gas velocity (ft/sec)

V_i	= Individual point flue gas velocity (ft/sec)
V_{nz}	= Average velocity at nozzle(ft/sec)
V_{nzi}	= Individual point velocity at nozzle(ft/sec)
ISO_i	= Individual point isokinetic variation (%)
ISO	= Average isokinetic variation (%)
R_m	= Isokinetic sampling rate (ft ³ /min)

2.2.3 Volumetric Flowrate Calculations

$$Q_S = Q_A \times \frac{(T_{Std} + 459.67)}{(T_{Stk} + 459.67)} \times \frac{P_{Stk}}{P_{Std}} \quad \text{Equation 27}$$

$$Q_A = \frac{v_{stk} \times 60 \times A_{stk}}{35.315} \quad \text{Equation 28}$$

$$A_{stk} = \pi \left(\frac{d}{24} \right)^2 \quad \text{Equation 29}$$

Where,

Q_A	= Actual flowrate (Am ³ /min)
Q_S	= Flowrate (m ³ /min) at standard conditions on a dry basis
A_{stk}	= Area of stack (ft ²)
d	= Diameter of stack (inches)

2.3 Quality Assurance/Quality Control (QA/QC) Techniques

QA/QC of this survey was accomplished by the following mechanisms.

1. Pre and Post-test leak checks.
2. Calibration of volume measuring and monitoring instrumentation.
3. Proofing of organic glassware and supplies.
4. Analysis of all blank solutions and materials.
5. Surrogate spiking of XAD using EPA protocols
6. Internal standard spiking and recovery analysis of organic trains to Env. Canada specs
7. Blank train sampling of leak check average volume

3 TEST RESULTS

The results of stack emissions were calculated using a “STACK” computer program developed by A. Lanfranco and Associates to meet BC MOE/MV requirements.

Table 1 presents summarized trace organic results using the Hazardous Waste Regulation TEQ’s, as well as additional organic species. Table 2 presents detailed PCDD/PCDF data and Table 3 presents trace organics results as a mass emission (not corrected for O₂). Detailed PAH and additional chlorinated organic species emission concentrations are presented in Table 4 and Appendix 2.

Trace organic results were recovery corrected according to surrogate recovery efficiencies determined for each organic analysis. Surrogates added and the recoveries determined are listed in the analytical data presented in the Appendices.

A stratification check was performed in 2018 and a cyclonic flow check was performed in 2006. Neither condition was present at the Unit 3 sampling location.

TABLE 1: UNIT 3 TRACE ORGANICS RESULTS TABLE

Parameter		Test 1	Test 2	Test 3	Average
Test Date		18-Aug-20	19-Aug-20	19-Aug-20	
Test Time		08:55 - 12:57	08:28 - 12:30	13:40 - 17:42	
Duration	(minutes)	240	240	240	240
PCDD & PCDF TEQ	(ng/Sm ³)	0.0023	0.0014	0.0022	0.0020
PCDD & PCDF TEQ	(ng/Sm³ @ 11% O₂)	0.0020	0.0012	0.0021	0.0018
Total PAH	(µg/Sm ³)	0.0910	0.0468	0.1536	0.0971
Total PAH	(µg/Sm³ @ 11% O₂)	0.0798	0.0422	0.1431	0.0884
Total HCB*	(µg/Sm ³)	0.0013	0.0014	0.0014	0.0014
Total HCB*	(µg/Sm³ @ 11% O₂)	0.0012	0.0012	0.0013	0.0012
Total CB	(µg/Sm ³)	0.2363	0.2692	0.3183	0.2746
Total CB	(µg/Sm³ @ 11% O₂)	0.2073	0.2430	0.2966	0.2490
Total CP*	(µg/Sm ³)	0.0067	0.0069	0.0071	0.0069
Total CP*	(µg/Sm³ @ 11% O₂)	0.0059	0.0062	0.0066	0.0062
Total PCB	(µg/Sm ³)	0.0033	0.0024	0.0024	0.0027
Total PCB	(µg/Sm³ @ 11% O₂)	0.0029	0.0022	0.0023	0.0025
Stack Temperature	(°C)	150	153	158	153
Flowrate	(Sm ³ /min)	1151	1136	1157	1148
Oxygen (O ₂)	(vol % dry)	9.6	9.9	10.3	9.9
Carbon Dioxide (CO ₂)	(vol % dry)	10.4	10.2	10.0	10.2
Moisture	(vol %)	14.9	13.8	14.6	14.4
Isokinetic Variation	(%)	103	101	100	101

Standard conditions (S) of 20 °C and 101.325 kPa (dry)

*Calculated using half DL convention.

TABLE 2: Detailed PCDD/PCDF Emission Results

Component	TEF	Test 1		Test 2		Test 3	
		Analyzed (ng)	TEQ (ng)	Analyzed (ng)	TEQ (ng)	Analyzed (ng)	TEQ (ng)
Test Date:		18-Aug-20		19-Aug-20		19-Aug-20	
Test Time:		08:55 - 12:57		08:28 - 12:30		13:40 - 17:42	
2378 TCDD	1.0000	0.0000	ND	0.0000	ND	0.0000	ND
12378 PCDD	0.5000	0.0000	ND	0.0000	ND	0.0000	ND
123478 HxCDD	0.1000	0.0000	ND	0.0000	ND	0.0000	ND
123678 HxCDD	0.1000	0.0057	0.0006	0.0020	0.0002	0.0150	0.0015
123789 HxCDD	0.1000	0.0000	ND	0.0000	ND	0.0000	ND
1234678 HpCDD	0.0100	0.0430	0.0004	0.0230	0.0002	0.0600	0.0006
OCDD	0.0010	0.0700	0.00007	0.1100	0.00011	0.1100	0.00011
2378 TCDF	0.1000	0.0000	ND	0.0000	ND	0.0000	ND
12378 PCDF	0.0500	0.0000	ND	0.0000	ND	0.0000	ND
23478 PCDF	0.5000	0.0100	0.0050	0.0020	0.0010	0.0020	0.0010
123478 HxCDF	0.1000	0.0020	0.0002	0.0130	0.0013	0.0170	0.0017
123678 HxCDF	0.1000	0.0067	0.0007	0.0062	0.0006	0.0079	0.0008
234678 HxCDF	0.1000	0.0140	0.0014	0.0120	0.0012	0.0140	0.0014
123789 HxCDF	0.1000	0.0000	ND	0.0000	ND	0.0000	ND
1234678 HpCDF	0.0100	0.0390	0.00039	0.0260	0.00026	0.0670	0.00067
1234789 HpCDF	0.0100	0.0000	ND	0.0000	ND	0.0000	ND
OCDF	0.0010	0.0000	ND	0.0000	ND	0.0000	ND
Summed PCDD & PCDF TEQ (ng)			0.0087		0.0049		0.0078
Sample Volume (dscm)			3.7375		3.6329		3.5153
PCDD & PCDF TEQ ng/dscm			0.00234		0.00135		0.00221
PCDD & PCDF TEQ ng/dscm @ 11% O₂			0.00205		0.00122		0.00206
PCDD & PCDF TEQ grams/day			0.000004		0.000002		0.000004

TABLE 3: UNIT 3 TRACE ORGANICS MASS EMISSIONS RESULTS

Parameter		Test 1	Test 2	Test 3	Average
PCDD & PCDF TEQ	(g/sec)	4.48E-11	2.56E-11	4.26E-11	3.77E-11
PCDD & PCDF TEQ	(tonnes/annum)	1.41E-09	8.09E-10	1.34E-09	1.19E-09
Total PAH	(g/sec)	1.74E-06	8.86E-07	2.96E-06	1.86E-06
Total PAH	(tonnes/annum)	5.50E-05	2.79E-05	9.34E-05	5.88E-05
Total HCB*	(g/sec)	2.57E-08	2.61E-08	2.74E-08	2.64E-08
Total HCB*	(tonnes/annum)	8.09E-07	8.22E-07	8.65E-07	8.32E-07
Total CB	(g/sec)	4.53E-06	5.10E-06	6.14E-06	5.26E-06
Total CB	(tonnes/annum)	1.43E-04	1.61E-04	1.94E-04	1.66E-04
Total CP*	(g/sec)	1.28E-07	1.30E-07	1.37E-07	1.32E-07
Total CP*	(tonnes/annum)	4.05E-06	4.11E-06	4.32E-06	4.16E-06
Total PCB	(g/sec)	6.31E-08	4.64E-08	4.72E-08	5.22E-08
Total PCB	(tonnes/annum)	1.99E-06	1.46E-06	1.49E-06	1.65E-06

Standard conditions (S) of 20 °C and 101.325 kPa (dry)

*Calculated using half DL convention.

Note - tonnes/annum based on 8760 operating hours

TABLE 4: Detailed PCB/PAH/CB/CP Emission Results

	Test 1	Test 2	Test 3
Test Date:	18-Aug-20	19-Aug-20	19-Aug-20
Test Time:	08:55 - 12:57	08:28 - 12:30	13:40 - 17:42
Component	Analyzed	Analyzed	Analyzed
	(ug)	(ug)	(ug)
Benz(a)anthracene	ND	ND	ND
Benzo(a)pyrene	ND	ND	ND
Benzo(b,j) fluoranthene	ND	ND	ND
Benzo(e)pyrene	0.010	0.005	0.040
Benzo(g,h,i)perylene	0.040	0.005	0.060
Benzo(k)fluoranthene	ND	ND	ND
Chrysene	ND	ND	ND
Dibenz(a,j)acridine	ND	ND	ND
Dibenz(a,h)acridine	ND	ND	ND
Dibenz(a,h)anthracene	ND	ND	ND
Dibenzo(a,i)pyrene	ND	ND	ND
Fluoranthene	0.040	0.020	0.110
Indeno(1,2,3-c,d)pyrene	ND	ND	ND
Phenanthrene	0.160	0.080	0.230
Pyrene	0.050	0.030	0.060
7H-dibenzo(c,g)carbazole	ND	ND	ND
Acenaphthene	ND	ND	ND
Acenaphthylene	ND	ND	ND
Fluorene	0.040	0.030	0.040
Dibenzo(a,e) fluoranthene	ND	ND	ND
3-Methylcholanthrene	ND	ND	ND
5-Methylchrysene	ND	ND	ND
7,12-Dimethylbenz(a)anthracene	ND	ND	ND
Dibenzo(a,h)pyrene	ND	ND	ND
Dibenzo(a,e)pyrene	ND	ND	ND
Dibenzo(a,l)pyrene	ND	ND	ND
Quinoline	ND	ND	ND
Total CP	0.0250	0.0250	0.0250
Total CB	0.8830	0.9780	1.1190
HCB	0.0050	0.0050	0.0050
* ND = Less than detection limit			
PCB Total (ng)	12.3	8.9	8.6
Total PAH (ug)	0.340	0.170	0.540
Sample Volume (dscm)	3.74	3.63	3.52

4 DISCUSSION

The emissions monitoring for this survey was performed during normal processing of municipal solid waste at the Waste-to-Energy facility. Three sample runs for each test parameter were conducted over three days to determine final results.

Results from this survey indicate that emissions are below the operational certificate limits for each pollutant.

Trace organics results are similar to data from 2018 and 2019; however, there was a notable decrease in total chlorobenzenes (CB) and in total polychlorinated biphenyl (PCB).

Dioxin/Furan results are expressed using the International Toxic Equivalents (I-TEQ). In this report, individual species that were measured below detection limits were reported as zero or “non-detect” if there was no detection in any of the three test runs.

In the blank sample, no dioxin/furan congeners were detected, and minimal congeners were detected at levels only very slightly above the detection limit for PCB, CB and CP. There were a number of PAH’s detected in the blank sample. Primarily phenanthrene, fluoranthene and pyrene. It is likely that the samples were not impacted; however, it is possible that the average result for PAH this survey has some positive bias related to the elevated blank.

The QA/QC program showed very low or non-detectable levels of target contaminants in the blank sample, which used the same solid sorbent resin and clean-up solvents as those used for samples. Additionally, the proof analysis of the glassware and XAD (prior recent blanks) showed no significant PCDD/PCDF.

For all tests and the blank test, internal standard recoveries ranged from 57 to 90%.

EPA Method 23 surrogate recoveries ranged from 80 to 124% for each sample. The recovery QA/QC data is expected to meet EPA performance specifications (M23) of 70 to 130% for pre-test spiked surrogates. The M23 spiking protocol is not required in Canada and is included in the sampling/analytical protocol for additional QA/QC and information purposes only.

There were no problems associated with sample collection or analysis. Sampling was conducted in accordance with the respective reference methods and passed all appropriate quality assurance and quality control criteria. It is therefore stated that these results are reported with a high degree of confidence and are an accurate representation of emission characteristics for the operating conditions maintained on the test dates.

APPENDIX 1

ANALYTICAL DATA and

QA/QC RESULTS

SAMPLE RECEIPT FORM / CHEMICAL ANALYSIS FORM

FILE #: PR201666

CLIENT: A. Lanfranco & Associates
 Unit 101 9488 – 189 St.
 Surrey, BC
 V4N 4W7

Phone: (604) 881-2582
 Email: mark.lanfranco@alanfranco.com

RECEIVED BY: M. MacLennan
 CONDITION: Okay, 13.8°C

DATE/TIME: August 21, 2020 (12:30 p.m.)

# of Containers	Sample Type	Sample (Client Codes)	Lab Codes	Test Requested
5	Stack	MV Unit 3 - DF - Blank	PR201666	PCDD/F, PCB, PAH/HCB, CB, CP
5	Stack	MV Unit 3 - DF - Run 1	PR201667	PCDD/F, PCB, PAH/HCB, CB, CP
5	Stack	MV Unit 3 - DF - Run 2	PR201668	PCDD/F, PCB, PAH/HCB, CB, CP
5	Stack	MV Unit 3 - DF - Run 3	PR201669	PCDD/F, PCB, PAH/HCB, CB, CP

STORAGE: XAD and filter stored at 4°C, rinses stored at ambient temperature.

ANALYTES: HRGC/HRMS analysis for polychlorinated dibenzo(p)dioxins and dibenzofurans (PCDD/F), polychlorinated biphenyls (PCB) and polycyclic aromatic hydrocarbons (PAH).

SPECIAL INSTRUCTIONS: none

METHODOLOGY

Reference Method: PCDD/F: SOP LAB01; EPA Method 23, Environment Canada 1-RM-3
 PCB: SOP LAB02; EPA Method 1668C
 PAH/HCB/CB/CP: SOP LAB13; in house

Data summarized in Data Report attached.

Report sent to: Mark Lanfranco

Date: September 22, 2020

Comments: Results relate only to items tested.

Digitally signed by
 Patrick Pond
 DN: cn=Patrick
 Pond, o=Pacific Rim
 Laboratories Inc.,
 ou=CTO,
 email=Pat@pacificri
 mlabs.com, c=CA
 Date: 2020.09.22
 14:26:21 -07'00'

Patrick Pond, C.Chem, CTO



METHOD 23/1-RM-3 DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: MV Unit 3 - DF - Blank
 PRL ID: PR201666

Sample Date: 18-Aug-20
 Date Extracted: 31-Aug-20
 Date Analysed: 19-Sep-20
 Filter Wt.: 0.35g

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	ND	2	
Total TCDD	ND	2	0
1,2,3,7,8-PeCDD	ND	4	
Total PeCDD	19	4	1
1,2,3,4,7,8-HxCDD	ND	4	
1,2,3,6,7,8-HxCDD	5.7	4	
1,2,3,7,8,9-HxCDD	ND	4	
Total HxCDD	100	4	3
1,2,3,4,6,7,8-HpCDD	36	4	
Total HpCDD	82	4	2
OCDD	100	15	1
Total Dioxin TEQ			

I-TEQs		
(ND=0) pg	(ND=1/2DL) pg	(ND=DL) pg
ND	1	2
ND	1	2
ND	0.2	0.4
0.57	0.57	0.57
ND	0.2	0.4
0.36	0.36	0.36
0.1	0.1	0.1
1.0	3.4	5.8

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	ND	2	
Total TCDF	ND	2	0
1,2,3,7,8-PeCDF	ND	4	
2,3,4,7,8-PeCDF	7.8	4	
Total PeCDF	40	4	3
1,2,3,4,7,8-HxCDF	ND	4	
1,2,3,6,7,8-HxCDF	8.9	4	
1,2,3,7,8,9-HxCDF	4	4	
2,3,4,6,7,8-HxCDF	15	4	
Total HxCDF	69	4	4
1,2,3,4,6,7,8-HpCDF	29	4	
1,2,3,4,7,8,9-HpCDF	ND	4	
Total HpCDF	51	4	2
OCDF	ND	15	0
Total Furan TEQ			

I-TEQs		
(ND=0) pg	(ND=1/2DL) pg	(ND=DL) pg
ND	0.1	0.2
ND	0.1	0.2
3.9	3.9	3.9
ND	0.2	0.4
0.89	0.89	0.89
0.4	0.4	0.4
1.5	1.5	1.5
0.29	0.29	0.29
ND	0.02	0.04
ND	0.0075	0.015
7.0	7.4	7.8

Total PCDD/PCDF Toxic Equivalent (pg)

8.0 10.8 13.7

Surrogate Recoveries (%)

³⁷ Cl ₄ -2,3,7,8-TCDD	102
¹³ C ₁₂ -2,3,4,7,8-PeCDF	120
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	127
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	119
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	100

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	65
¹³ C ₁₂ -1,2,3,7,8-PeCDD	85
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	69
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	79
¹³ C ₁₂ -OCDD	82
¹³ C ₁₂ -2,3,7,8-TCDF	58
¹³ C ₁₂ -1,2,3,7,8-PeCDF	76
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	68
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	76

METHOD 23/1-RM-3 DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: MV Unit 3 - DF - Run 1
 PRL ID: PR201667

Sample Date: 18-Aug-20
 Date Extracted: 31-Aug-20
 Date Analysed: 19-Sep-20
 Filter Wt.: 0.35g

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	ND	2	
Total TCDD	ND	2	0
1,2,3,7,8-PeCDD	ND	4	
Total PeCDD	16	4	1
1,2,3,4,7,8-HxCDD	ND	4	
1,2,3,6,7,8-HxCDD	5.7	4	
1,2,3,7,8,9-HxCDD	ND	4	
Total HxCDD	93	4	3
1,2,3,4,6,7,8-HpCDD	43	4	
Total HpCDD	79	4	2
OCDD	70	15	1
Total Dioxin TEQ			

I-TEQs		
(ND=0)	(ND=1/2DL)	(ND=DL)
pg	pg	pg
ND	1	2
ND	1	2
ND	0.2	0.4
0.57	0.57	0.57
ND	0.2	0.4
0.43	0.43	0.43
0.07	0.07	0.07
1.1	3.5	5.9

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	ND	2	
Total TCDF	ND	2	0
1,2,3,7,8-PeCDF	ND	4	
2,3,4,7,8-PeCDF	10	4	
Total PeCDF	25	4	2
1,2,3,4,7,8-HxCDF	ND	4	
1,2,3,6,7,8-HxCDF	6.7	4	
1,2,3,7,8,9-HxCDF	ND	4	
2,3,4,6,7,8-HxCDF	14	4	
Total HxCDF	36	4	3
1,2,3,4,6,7,8-HpCDF	39	4	
1,2,3,4,7,8,9-HpCDF	ND	4	
Total HpCDF	42	4	2
OCDF	ND	15	0
Total Furan TEQ			

I-TEQs		
(ND=0)	(ND=1/2DL)	(ND=DL)
pg	pg	pg
ND	0.1	0.2
ND	0.1	0.2
5	5	5
ND	0.2	0.4
0.67	0.67	0.67
ND	0.2	0.4
1.4	1.4	1.4
0.39	0.39	0.39
ND	0.02	0.04
ND	0.0075	0.015
7.5	8.1	8.7

Total PCDD/PCDF Toxic Equivalent (pg)

8.5 11.6 14.6

Surrogate Recoveries (%)

³⁷ Cl ₄ -2,3,7,8-TCDD	112
¹³ C ₁₂ -2,3,4,7,8-PeCDF	111
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	101
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	124
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	101

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	63
¹³ C ₁₂ -1,2,3,7,8-PeCDD	79
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	72
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	84
¹³ C ₁₂ -OCDD	84
¹³ C ₁₂ -2,3,7,8-TCDF	57
¹³ C ₁₂ -1,2,3,7,8-PeCDF	74
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	66
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	84

METHOD 23/1-RM-3 DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: MV Unit 3 - DF - Run 2
 PRL ID: PR201668

Sample Date: 19-Aug-20
 Date Extracted: 31-Aug-20
 Date Analysed: 19-Sep-20
 Filter Wt.: 0.36g

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	ND	2	
Total TCDD	ND	2	0
1,2,3,7,8-PeCDD	ND	4	
Total PeCDD	ND	4	0
1,2,3,4,7,8-HxCDD	ND	4	
1,2,3,6,7,8-HxCDD	ND	4	
1,2,3,7,8,9-HxCDD	ND	4	
Total HxCDD	120	4	3
1,2,3,4,6,7,8-HpCDD	23	4	
Total HpCDD	64	4	2
OCDD	110	15	1
Total Dioxin TEQ			

I-TEQs		
(ND=0) pg	(ND=1/2DL) pg	(ND=DL) pg
ND	1	2
ND	1	2
ND	0.2	0.4
ND	0.2	0.4
ND	0.2	0.4
0.23	0.23	0.23
0.11	0.11	0.11
0.3	2.9	5.5

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	ND	2	
Total TCDF	ND	2	0
1,2,3,7,8-PeCDF	ND	4	
2,3,4,7,8-PeCDF	ND	4	
Total PeCDF	ND	4	0
1,2,3,4,7,8-HxCDF	13	4	
1,2,3,6,7,8-HxCDF	6.2	4	
1,2,3,7,8,9-HxCDF	ND	4	
2,3,4,6,7,8-HxCDF	12	4	
Total HxCDF	31	4	3
1,2,3,4,6,7,8-HpCDF	26	4	
1,2,3,4,7,8,9-HpCDF	ND	4	
Total HpCDF	33	4	2
OCDF	ND	15	0
Total Furan TEQ			

I-TEQs		
(ND=0) pg	(ND=1/2DL) pg	(ND=DL) pg
ND	0.1	0.2
ND	0.1	0.2
ND	1	2
1.3	1.3	1.3
0.62	0.62	0.62
ND	0.2	0.4
1.2	1.2	1.2
0.26	0.26	0.26
ND	0.02	0.04
ND	0.0075	0.015
3.4	4.8	6.2

Total PCDD/PCDF Toxic Equivalent (pg)

3.7 7.7 11.8

Surrogate Recoveries (%)

³⁷ Cl ₄ -2,3,7,8-TCDD	106
¹³ C ₁₂ -2,3,4,7,8-PeCDF	111
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	96
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	117
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	80

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	64
¹³ C ₁₂ -1,2,3,7,8-PeCDD	72
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	77
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	86
¹³ C ₁₂ -OCDD	90
¹³ C ₁₂ -2,3,7,8-TCDF	58
¹³ C ₁₂ -1,2,3,7,8-PeCDF	70
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	72
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	86

METHOD 23/1-RM-3 DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: MV Unit 3 - DF - Run 3
 PRL ID: PR201669

Sample Date: 19-Aug-20
 Date Extracted: 31-Aug-20
 Date Analysed: 19-Sep-20
 Filter Wt.: 0.36g

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	ND	2	
Total TCDD	ND	2	0
1,2,3,7,8-PeCDD	ND	4	
Total PeCDD	17	4	1
1,2,3,4,7,8-HxCDD	ND	4	
1,2,3,6,7,8-HxCDD	15	4	
1,2,3,7,8,9-HxCDD	ND	4	
Total HxCDD	190	4	3
1,2,3,4,6,7,8-HpCDD	60	4	
Total HpCDD	120	4	2
OCDD	110	15	1
Total Dioxin TEQ			

I-TEQs		
(ND=0)	(ND=1/2DL)	(ND=DL)
pg	pg	pg
ND	1	2
ND	1	2
ND	0.2	0.4
1.5	1.5	1.5
ND	0.2	0.4
0.6	0.6	0.6
0.11	0.11	0.11
2.2	4.6	7.0

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	ND	2	
Total TCDF	ND	2	0
1,2,3,7,8-PeCDF	ND	4	
2,3,4,7,8-PeCDF	ND	4	
Total PeCDF	74	4	3
1,2,3,4,7,8-HxCDF	17	4	
1,2,3,6,7,8-HxCDF	7.9	4	
1,2,3,7,8,9-HxCDF	ND	4	
2,3,4,6,7,8-HxCDF	14	4	
Total HxCDF	71	4	5
1,2,3,4,6,7,8-HpCDF	67	4	
1,2,3,4,7,8,9-HpCDF	ND	4	
Total HpCDF	85	4	2
OCDF	ND	15	0
Total Furan TEQ			

I-TEQs		
(ND=0)	(ND=1/2DL)	(ND=DL)
pg	pg	pg
ND	0.1	0.2
ND	0.1	0.2
ND	1	2
1.7	1.7	1.7
0.79	0.79	0.79
ND	0.2	0.4
1.4	1.4	1.4
0.67	0.67	0.67
ND	0.02	0.04
ND	0.0075	0.015
4.6	6.0	7.4

Total PCDD/PCDF Toxic Equivalent (pg)

6.8 10.6 14.4

Surrogate Recoveries (%)

³⁷ Cl ₄ -2,3,7,8-TCDD	106
¹³ C ₁₂ -2,3,4,7,8-PeCDF	108
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	107
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	111
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	91

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	64
¹³ C ₁₂ -1,2,3,7,8-PeCDD	86
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	62
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	86
¹³ C ₁₂ -OCDD	86
¹³ C ₁₂ -2,3,7,8-TCDF	56
¹³ C ₁₂ -1,2,3,7,8-PeCDF	74
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	67
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	79

METHOD 23/1-RM-3 DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: BLANK
 PRL ID: DF200527B

Contact: Mark Lanfranco
 Date Extracted: 31-Aug-20
 Date Analyzed: 19-Sep-20

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	ND	2	
Total TCDD	ND	2	0
1,2,3,7,8-PeCDD	ND	4	
Total PeCDD	ND	4	0
1,2,3,4,7,8-HxCDD	ND	4	
1,2,3,6,7,8-HxCDD	ND	4	
1,2,3,7,8,9-HxCDD	ND	4	
Total HxCDD	ND	4	0
1,2,3,4,6,7,8-HpCDD	ND	4	
Total HpCDD	ND	4	0
OCDD	ND	15	0
Total Dioxin TEQ			

I-TEQs		
(ND=0) pg	(ND=1/2DL) pg	(ND=DL) pg
ND	1	2
ND	1	2
ND	0.2	0.4
ND	0.2	0.4
ND	0.2	0.4
ND	0.02	0.04
ND	0.0075	0.015
0.0	2.6	5.3

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	ND	2	
Total TCDF	ND	2	0
1,2,3,7,8-PeCDF	ND	4	
2,3,4,7,8-PeCDF	ND	4	
Total PeCDF	ND	4	0
1,2,3,4,7,8-HxCDF	ND	4	
1,2,3,6,7,8-HxCDF	ND	4	
1,2,3,7,8,9-HxCDF	ND	4	
2,3,4,6,7,8-HxCDF	ND	4	
Total HxCDF	ND	4	0
1,2,3,4,6,7,8-HpCDF	ND	4	
1,2,3,4,7,8,9-HpCDF	ND	4	
Total HpCDF	ND	4	0
OCDF	ND	15	0
Total Furan TEQ			

I-TEQs		
(ND=0) pg	(ND=1/2DL) pg	(ND=DL) pg
ND	0.1	0.2
ND	0.1	0.2
ND	1	2
ND	0.2	0.4
ND	0.2	0.4
ND	0.2	0.4
ND	0.2	0.4
ND	0.02	0.04
ND	0.02	0.04
ND	0.0075	0.015
0.0	2.0	4.1

Total PCDD/PCDF Toxic Equivalent (pg)

0.0 4.7 9.4

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	63
¹³ C ₁₂ -1,2,3,7,8-PeCDD	82
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	62
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	79
¹³ C ₁₂ -OCDD	86
¹³ C ₁₂ -2,3,7,8-TCDF	56
¹³ C ₁₂ -1,2,3,7,8-PeCDF	71
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	63
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	84



QC REPORT - SPIKE

Client: A. Lanfranco & Associates
 Client ID: SPIKE
 PRL ID: DF200528S

Contact: Mark Lanfranco
 Date Extracted: 31-Aug-20
 Date Analysed: 19-Sep-20

DIOXINS	LOF	Recovery	Acceptable Recovery		Pass/Fail	Int. Std Recoveries %
			Min	Max		
Congeners	pg	%	%	%		
2,3,7,8-TCDD	200	91	80	120	Pass	62
1,2,3,7,8-PeCDD	200	96	80	120	Pass	87
1,2,3,4,7,8-HxCDD	400	114	80	120	Pass	-
1,2,3,6,7,8-HxCDD	400	99	80	120	Pass	73
1,2,3,7,8,9-HxCDD	400	114	80	120	Pass	-
1,2,3,4,6,7,8-HpCDD	400	97	80	120	Pass	99
OCDD	1000	108	80	120	Pass	106

FURANS	LOF	Recovery	Acceptable Recovery		Pass/Fail	Int. Std Recoveries %
			Min	Max		
Congeners	pg	%	%	%		
2,3,7,8-TCDF	200	91	80	120	Pass	58
1,2,3,7,8-PeCDF	200	107	80	120	Pass	76
2,3,4,7,8-PeCDF	200	100	80	120	Pass	-
1,2,3,4,7,8-HxCDF	400	118	80	120	Pass	-
1,2,3,6,7,8-HxCDF	400	104	80	120	Pass	68
1,2,3,7,8,9-HxCDF	400	108	80	120	Pass	-
2,3,4,6,7,8-HxCDF	400	119	80	120	Pass	-
1,2,3,4,6,7,8-HpCDF	400	95	80	120	Pass	97
1,2,3,4,7,8,9-HpCDF	400	92	80	120	Pass	-
OCDF	1000	101	80	120	Pass	-

LOF - Level of Fortification



DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: MV Unit 3 - DF - Blank
 PRL ID: PR201666

Contact: Mark Lanfranco
 Date Extracted: 31-Aug-20
 Date Analysed: 16-Sep-20

Dioxin-like PCBs				DL	Surrogate Recoveries
Chemical Name	IUPAC #	ng	ng		%
3,4,4',5-TeCB	PCB 81	ND	0.02		80
3,3',4,4'-TeCB	PCB 77	ND	0.02		80
2,3',4,4',5'-PeCB	PCB 123	ND	0.02		84
2,3',4,4',5-PeCB	PCB 118	0.05	0.02		88
2,3,4,4',5-PeCB	PCB 114	ND	0.02		88
2,3,3',4,4'-PeCB	PCB 105	0.021	0.02		92
3,3',4,4',5-PeCB	PCB 126	ND	0.02		92
2,3',4,4',5,5'-HxCB	PCB 167	ND	0.02		68
2,3,3',4,4',5-HxCB	PCB 156	ND	0.02		80
2,3,3',4,4',5'-HxCB	PCB 157	ND	0.02		80
3,3',4,4',5,5'-HxCB	PCB 169	ND	0.02		76
2,3,3',4,4',5,5'-HpCB	PCB 189	ND	0.02		88
Toxic Equivalent (WHO-TEQ)					

WHO-TEQs (2005)	
(ND=0)	(ND=DL)
ng	ng
ND	6.00E-06
ND	2.00E-06
ND	6.00E-07
1.46E-06	1.46E-06
ND	6.00E-07
6.22E-07	6.22E-07
ND	2.00E-03
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	6.00E-04
ND	6.00E-07
2.08E-06	2.61E-03

Total PCB		
Homologs	ng	DL
Monochlorobiphenyls	ND	0.05
Dichlorobiphenyls	2.89	0.05
Trichlorobiphenyls	1.06	0.05
Tetrachlorobiphenyls	0.44	0.05
Pentachlorobiphenyls	0.095	0.05
Hexachlorobiphenyls	0.053	0.05
Heptachlorobiphenyls	ND	0.05
Octachlorobiphenyls	ND	0.05
Nonachlorobiphenyls	ND	0.05
Decachlorobiphenyl	ND	0.05
Total PCB	4.54	

ND - none detected

Surrogate Recoveries		
Chemical Name	IUPAC #	%
¹³ C12-2-MoCB	1L	28
¹³ C12-4,4'-DiCB	15L	64
¹³ C12-2,2',6'-TrCB	19L	56
¹³ C12-3,4,4'-TrCB	37L	80
¹³ C12-2,2',6,6'-TeCB	54L	56
¹³ C12-2,2',4,6,6'-PeCB	104L	68
¹³ C12-2,2',4,4',6,6'-HxCB	155L	64
¹³ C12-2,2',3,4',5,6,6'-HpCB	188L	80
¹³ C12-2,2',3,3',5,5',6,6'-OcCB	202L	76
¹³ C12-2,3,3',4,4',5,5',6-OcCB	205L	72
¹³ C12-2,2',3,3',4,4',5,5',6-NeCB	206L	92
¹³ C12-DeCB	209L	96

DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: MV Unit 3 - DF - Run 1
 PRL ID: PR201667

Contact: Mark Lanfranco
 Date Extracted: 31-Aug-20
 Date Analysed: 16-Sep-20

Dioxin-like PCBs				Surrogate Recoveries
Chemical Name	IUPAC #	ng	DL ng	%
3,4,4',5-TeCB	PCB 81	ND	0.02	80
3,3',4,4'-TeCB	PCB 77	ND	0.02	84
2,3',4,4',5'-PeCB	PCB 123	ND	0.02	88
2,3',4,4',5-PeCB	PCB 118	ND	0.02	88
2,3,4,4',5-PeCB	PCB 114	ND	0.02	88
2,3,3',4,4'-PeCB	PCB 105	ND	0.02	88
3,3',4,4',5-PeCB	PCB 126	ND	0.02	92
2,3',4,4',5,5'-HxCB	PCB 167	ND	0.02	84
2,3,3',4,4',5-HxCB	PCB 156	ND	0.02	80
2,3,3',4,4',5'-HxCB	PCB 157	ND	0.02	80
3,3',4,4',5,5'-HxCB	PCB 169	ND	0.02	72
2,3,3',4,4',5,5'-HpCB	PCB 189	ND	0.02	96
Toxic Equivalent (WHO-TEQ)				

WHO-TEQs (2005)	
(ND=0)	(ND=DL)
ng	ng
ND	6.00E-06
ND	2.00E-06
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	2.00E-03
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	6.00E-04
ND	6.00E-07
0.00E+00	2.61E-03

Total PCB		
Homologs	ng	DL ng
Monochlorobiphenyls	0.428	0.05
Dichlorobiphenyls	8.89	0.05
Trichlorobiphenyls	2.18	0.05
Tetrachlorobiphenyls	0.80	0.05
Pentachlorobiphenyls	ND	0.05
Hexachlorobiphenyls	ND	0.05
Heptachlorobiphenyls	ND	0.05
Octachlorobiphenyls	ND	0.05
Nonachlorobiphenyls	ND	0.05
Decachlorobiphenyl	ND	0.05
Total PCB	12.3	

ND - none detected

Surrogate Recoveries		
Chemical Name	IUPAC #	%
¹³ C12-2-MoCB	1L	20
¹³ C12-4,4'-DiCB	15L	52
¹³ C12-2,2',6'-TrCB	19L	48
¹³ C12-3,4,4'-TrCB	37L	72
¹³ C12-2,2',6,6'-TeCB	54L	48
¹³ C12-2,2',4,6,6'-PeCB	104L	52
¹³ C12-2,2',4,4',6,6'-HxCB	155L	64
¹³ C12-2,2',3,4',5,6,6'-HpCB	188L	84
¹³ C12-2,2',3,3',5,5',6,6'-OcCB	202L	76
¹³ C12-2,3,3',4,4',5,5',6-OcCB	205L	76
¹³ C12-2,2',3,3',4,4',5,5',6-NoCB	206L	96
¹³ C12-DeCB	209L	112

DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: MV Unit 3 - DF - Run 2
 PRL ID: PR201668

Contact: Mark Lanfranco
 Date Extracted: 31-Aug-20
 Date Analysed: 16-Sep-20

Dioxin-like PCBs				Surrogate Recoveries
Chemical Name	IUPAC #	ng	DL ng	%
3,4,4',5-TeCB	PCB 81	ND	0.02	60
3,3',4,4'-TeCB	PCB 77	ND	0.02	64
2,3',4,4',5'-PeCB	PCB 123	ND	0.02	72
2,3',4,4',5-PeCB	PCB 118	ND	0.02	76
2,3,4,4',5-PeCB	PCB 114	ND	0.02	80
2,3,3',4,4'-PeCB	PCB 105	ND	0.02	80
3,3',4,4',5-PeCB	PCB 126	ND	0.02	80
2,3',4,4',5,5'-HxCB	PCB 167	ND	0.02	80
2,3,3',4,4',5-HxCB	PCB 156	ND	0.02	76
2,3,3',4,4',5'-HxCB	PCB 157	ND	0.02	76
3,3',4,4',5,5'-HxCB	PCB 169	ND	0.02	64
2,3,3',4,4',5,5'-HpCB	PCB 189	ND	0.02	84
Toxic Equivalent (WHO-TEQ)				

WHO-TEQs (2005)	
(ND=0)	(ND=DL)
ng	ng
ND	6.00E-06
ND	2.00E-06
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	2.00E-03
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	6.00E-04
ND	6.00E-07
0.00E+00	2.61E-03

Total PCB		
Homologs	ng	DL ng
Monochlorobiphenyls	0.663	0.05
Dichlorobiphenyls	7.10	0.05
Trichlorobiphenyls	0.82	0.05
Tetrachlorobiphenyls	0.30	0.05
Pentachlorobiphenyls	ND	0.05
Hexachlorobiphenyls	ND	0.05
Heptachlorobiphenyls	ND	0.05
Octachlorobiphenyls	ND	0.05
Nonachlorobiphenyls	ND	0.05
Decachlorobiphenyl	ND	0.05
Total PCB	8.9	

ND - none detected

Surrogate Recoveries		
Chemical Name	IUPAC #	%
¹³ C12-2-MoCB	1L	16
¹³ C12-4,4'-DiCB	15L	40
¹³ C12-2,2',6'-TrCB	19L	48
¹³ C12-3,4,4'-TrCB	37L	56
¹³ C12-2,2',6,6'-TeCB	54L	44
¹³ C12-2,2',4,6,6'-PeCB	104L	56
¹³ C12-2,2',4,4',6,6'-HxCB	155L	56
¹³ C12-2,2',3,4',5,6,6'-HpCB	188L	76
¹³ C12-2,2',3,3',5,5',6,6'-OcCB	202L	80
¹³ C12-2,3,3',4,4',5,5',6-OcCB	205L	76
¹³ C12-2,2',3,3',4,4',5,5',6-NgCB	206L	100
¹³ C12-DeCB	209L	104



DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: MV Unit 3 - DF - Run 3
 PRL ID: PR201669

Contact: Mark Lanfranco
 Date Extracted: 31-Aug-20
 Date Analysed: 16-Sep-20

Dioxin-like PCBs				DL	Surrogate Recoveries
Chemical Name	IUPAC #	ng	ng		%
3,4,4',5-TeCB	PCB 81	ND	0.02		72
3,3',4,4'-TeCB	PCB 77	ND	0.02		68
2,3',4,4',5'-PeCB	PCB 123	ND	0.02		68
2,3',4,4',5'-PeCB	PCB 118	ND	0.02		72
2,3,4,4',5'-PeCB	PCB 114	ND	0.02		76
2,3,3',4,4'-PeCB	PCB 105	ND	0.02		76
3,3',4,4',5'-PeCB	PCB 126	ND	0.02		88
2,3',4,4',5,5'-HxCB	PCB 167	ND	0.02		80
2,3,3',4,4',5'-HxCB	PCB 156	ND	0.02		80
2,3,3',4,4',5'-HxCB	PCB 157	ND	0.02		84
3,3',4,4',5,5'-HxCB	PCB 169	ND	0.02		72
2,3,3',4,4',5,5'-HpCB	PCB 189	ND	0.02		76
Toxic Equivalent (WHO-TEQ)					

WHO-TEQs (2005)	
(ND=0)	(ND=DL)
ng	ng
ND	6.00E-06
ND	2.00E-06
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	2.00E-03
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	6.00E-04
ND	6.00E-07
0.00E+00	2.61E-03

Total PCB		
Homologs	ng	DL
Monochlorobiphenyls	0.339	0.05
Dichlorobiphenyls	6.83	0.05
Trichlorobiphenyls	1.10	0.05
Tetrachlorobiphenyls	0.31	0.05
Pentachlorobiphenyls	ND	0.05
Hexachlorobiphenyls	ND	0.05
Heptachlorobiphenyls	ND	0.05
Octachlorobiphenyls	ND	0.05
Nonachlorobiphenyls	ND	0.05
Decachlorobiphenyl	ND	0.05
Total PCB	8.6	

ND - none detected

Surrogate Recoveries		
Chemical Name	IUPAC #	%
13C12-2-MoCB	1L	16
13C12-4,4'-DiCB	15L	40
13C12-2,2',6'-TrCB	19L	44
13C12-3,4,4'-TrCB	37L	48
13C12-2,2',6,6'-TeCB	54L	44
13C12-2,2',4,6,6'-PeCB	104L	56
13C12-2,2',4,4',6,6'-HxCB	155L	56
13C12-2,2',3,4',5,6,6'-HpCB	188L	84
13C12-2,2',3,3',5,5',6,6'-OcCB	202L	80
13C12-2,3,3',4,4',5,5',6-OcCB	205L	76
13C12-2,2',3,3',4,4',5,5',6-NgCB	206L	100
13C12-DeCB	209L	104

DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: BLANK
 PRL ID: PC200527B

Contact: Mark Lanfranco
 Date Extracted: 31-Aug-20
 Date Analysed: 16-Sep-20

Dioxin-like PCBs				DL	Surrogate Recoveries
Chemical Name	IUPAC #	ng	ng		%
3,4,4',5-TeCB	PCB 81	ND	0.02		52
3,3',4,4'-TeCB	PCB 77	ND	0.02		60
2,3',4,4',5'-PeCB	PCB 123	ND	0.02		68
2,3',4,4',5-PeCB	PCB 118	ND	0.02		72
2,3,4,4',5-PeCB	PCB 114	ND	0.02		72
2,3,3',4,4'-PeCB	PCB 105	ND	0.02		76
3,3',4,4',5-PeCB	PCB 126	ND	0.02		88
2,3',4,4',5,5'-HxCB	PCB 167	ND	0.02		76
2,3,3',4,4',5-HxCB	PCB 156	ND	0.02		80
2,3,3',4,4',5'-HxCB	PCB 157	ND	0.02		80
3,3',4,4',5,5'-HxCB	PCB 169	ND	0.02		76
2,3,3',4,4',5,5'-HpCB	PCB 189	ND	0.02		88
Toxic Equivalent (WHO-TEQ)					

WHO-TEQs (2005)	
(ND=0)	(ND=DL)
ng	ng
ND	6.00E-06
ND	2.00E-06
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	2.00E-03
ND	6.00E-07
ND	6.00E-07
ND	6.00E-07
ND	6.00E-04
ND	6.00E-07
0.00E+00	2.61E-03

Total PCB		
Homologs	ng	DL
Monochlorobiphenyls	ND	0.05
Dichlorobiphenyls	ND	0.05
Trichlorobiphenyls	ND	0.05
Tetrachlorobiphenyls	ND	0.05
Pentachlorobiphenyls	ND	0.05
Hexachlorobiphenyls	ND	0.05
Heptachlorobiphenyls	ND	0.05
Octachlorobiphenyls	ND	0.05
Nonachlorobiphenyls	ND	0.05
Decachlorobiphenyl	ND	0.05
Total PCB	ND	

ND - none detected

Surrogate Recoveries		
Chemical Name	IUPAC #	%
¹³ C12-2-MoCB	1L	12
¹³ C12-4,4'-DiCB	15L	24
¹³ C12-2,2',6'-TrCB	19L	24
¹³ C12-3,4,4'-TrCB	37L	40
¹³ C12-2,2',6,6'-TeCB	54L	28
¹³ C12-2,2',4,6,6'-PeCB	104L	32
¹³ C12-2,2',4,4',6,6'-HxCB	155L	40
¹³ C12-2,2',3,4',5,6,6'-HpCB	188L	60
¹³ C12-2,2',3,3',5,5',6,6'-OcCB	202L	72
¹³ C12-2,3,3',4,4',5,5',6-OcCB	205L	76
¹³ C12-2,2',3,3',4,4',5,5',6-NgCB	206L	96
¹³ C12-D8CB	209L	104

QC REPORT - SPIKE

Client: A. Lanfranco & Associates
 Client ID: SPIKE
 PRL ID: PC200528S

Contact: Mark Lanfranco
 Date Extracted: 31-Aug-20
 Date Analysed: 16-Sep-20

Dioxin-like PCBs	LOF	Recovery	Acceptable Recovery		Pass/Fail	Surrogate Recoveries
			Min	Max		
Chemical Name	ng	%	%	%		%
3,4,4',5-TeCB (81)	1	76	50	150	Pass	51
3,3',4,4'-TeCB (77)	1	75	50	150	Pass	56
2,3',4,4',5'-PeCB (123)	1	89	50	150	Pass	53
2,3',4,4',5'-PeCB (118)	1	88	50	150	Pass	56
2,3,4,4',5'-PeCB (114)	1	85	50	150	Pass	55
2,3,3',4,4'-PeCB (105)	1	88	50	150	Pass	63
3,3',4,4',5'-PeCB (126)	1	82	50	150	Pass	68
2,3',4,4',5,5'-HxCB (167)	1	76	50	150	Pass	64
2,3,3',4,4',5'-HxCB (156)	1	75	50	150	Pass	67
2,3,3',4,4',5'-HxCB (157)	1	82	50	150	Pass	72
3,3',4,4',5,5'-HxCB (169)	1	78	50	150	Pass	68
2,3,3',4,4',5,5'-HpCB (189)	1	73	50	150	Pass	63

Total PCB	LOF	Recovery	Acceptable Recovery		Pass/Fail
			Min	Max	
Homologs	ng	%	%	%	
Monochlorobiphenyls	2	89			
Dichlorobiphenyls	4	77			
Trichlorobiphenyls	6	91			
Tetrachlorobiphenyls	12	92			
Pentachlorobiphenyls	13	74			
Hexachlorobiphenyls	15	66			
Heptachlorobiphenyls	11	74			
Octachlorobiphenyls	6	78			
Nonachlorobiphenyls	2	79			
Decachlorobiphenyl	1	110			
Total PCB	72	78	50	150	Pass

LOF - Level of Fortification



DATA REPORT

Client: A. Lanfranco & Associates
 Contact: Mark Lanfranco

Date Extracted: 31-Aug-20
 Date Analysed: 15-Sep-20

Client ID:		MV Unit 3 - DF - Blank	MV Unit 3 - DF - Run 1	MV Unit 3 - DF - Run 2	MV Unit 3 - DF - Run 3		BLANK
PRL ID:		PR201666	PR201667	PR201668	PR201669		PH200527B
NPRI PAH	DL						
	µg	µg	µg	µg	µg		µg
Acenaphthylene	0.05	ND	ND	ND	ND		ND
Acenaphthene	0.05	ND	ND	ND	ND		ND
Fluorene	0.02	0.03	0.04	0.03	0.03		ND
Phenanthrene	0.02	0.13	0.16	0.08	0.23		ND
Fluoranthene	0.01	0.05	0.04	0.02	0.11		ND
Pyrene	0.01	0.06	0.05	0.03	0.06		ND
Benz(a)anthracene	0.02	ND	ND	ND	ND		ND
Chrysene	0.02	ND	ND	ND	ND		ND
Benzo(b)fluoranthene	0.01	ND	ND	ND	ND		ND
Benzo(k)fluoranthene	0.01	ND	ND	ND	ND		ND
Benzo(a)pyrene	0.01	ND	ND	ND	ND		ND
Indeno(1,2,3-cd)pyrene	0.01	ND	ND	ND	ND		ND
Dibenz(a,h)anthracene	0.01	ND	ND	ND	ND		ND
Benzo(ghi)perylene	0.01	0.08	0.04	ND	0.06		ND
1-Nitropyrene	0.05	ND	ND	ND	ND		ND
5-Methylchrysene	0.05	ND	ND	ND	ND		ND
7,12-Dimethylbenz(a)anthr	0.05	ND	ND	ND	ND		ND
3-Methylcholanthrene	0.05	ND	ND	ND	ND		ND
Benzo(e)pyrene	0.01	0.04	0.01	ND	0.04		ND
Perylene	0.05	ND	ND	ND	ND		ND
Dibenz(a,h)acridine	0.05	ND	ND	ND	ND		ND
Dibenz(a,j)acridine	0.05	ND	ND	ND	ND		ND
7H-Dibenzo(c,g)carbazole	0.05	ND	ND	ND	ND		ND
Dibenzo(a,e)fluoranthene	0.05	ND	ND	ND	ND		ND
Dibenzo(a,e)pyrene	0.05	ND	ND	ND	ND		ND
Dibenzo(a,h)pyrene	0.05	ND	ND	ND	ND		ND
Dibenzo(a,l)pyrene	0.05	ND	ND	ND	ND		ND
Dibenzo(a,i)pyrene	0.05	ND	ND	ND	ND		ND
Quinoline	0.05	ND	ND	ND	ND		ND
Other PAH							
Naphthalene	0.05	2.20	2.50	2.70	2.00		ND
Anthracene	0.05	ND	ND	ND	ND		ND
Chlorobenzenes							
Hexachlorobenzene	0.01	ND	ND	ND	ND		ND

DATA REPORT

Client: A. Lanfranco & Associates
 Contact: Mark Lanfranco

Date Extracted: 31-Aug-20
 Date Analysed: 15-Sep-20

Client ID:		MV Unit 3 - DF - Blank	MV Unit 3 - DF - Run 1	MV Unit 3 - DF - Run 2	MV Unit 3 - DF - Run 3		BLANK
PRL ID:		PR201666	PR201667	PR201668	PR201669		PH200527B
NPRI PAH	DL						
Surrogate Recoveries (%)							
d8-Naphthalene		76	64	60	76		68
d10-Acenaphthylene		76	80	72	88		72
d10-Acenaphthene		84	80	72	92		80
d10-Fluorene		84	80	72	88		76
d10-Phenanthrene		68	68	76	80		88
d10-Fluoranthene		92	96	96	104		96
d10-Pyrene		92	100	96	104		92
d12-Chrysene		72	88	80	80		116
d12-Benzo(b)fluoranthene		88	92	88	96		112
d12-Benzo(a)pyrene		88	92	88	92		92
d14-Dibenz(a,h)anthracene		88	92	88	96		96
13C6-Hexachlorobenzene		72	72	84	92		92

ND - none detected

DATA REPORT

Client: A. Lanfranco & Associates
 Contact: Mark Lanfranco

Date Extracted: 31-Aug-20
 Date Analysed: 15-Sep-20

Client ID: **SPIKE**
 PRL ID: **PH200528S**

NPRI PAH

	$\mu\text{g/g}$	LOF	Recovery	Acceptable	Pass/Fail
Acenaphthene	1.22	1	122%	50-150%	pass
Acenaphthylene	1.16	1	116%	50-150%	pass
Benz(a)anthracene	0.95	1	95%	50-150%	pass
Benzo(a)pyrene	0.97	1	97%	50-150%	pass
Benzo(b)fluoranthene	1.01	1	101%	50-150%	pass
Benzo(ghi)perylene	1.11	1	111%	50-150%	pass
Benzo(k)fluoranthene	1.02	1	102%	50-150%	pass
Chrysene	0.95	1	95%	50-150%	pass
Dibenz(a,h)anthracene	0.98	1	98%	50-150%	pass
Fluoranthene	1.12	1	112%	50-150%	pass
Fluorene	1.19	1	119%	50-150%	pass
Indeno(1,2,3-cd)pyrene	1.06	1	106%	50-150%	pass
Phenanthrene	1.07	1	107%	50-150%	pass
Pyrene	1.01	1	101%	50-150%	pass
Dibenz(a,h)acridine	1.10	1	110%		
Dibenz(a,j)acridine	0.97	1	97%		
7H-Dibenzo(c,g)carbazole	1.01	1	101%		
Dibenzo(a,e)fluoranthene	1.18	1	118%		
Dibenzo(a,h)pyrene	1.21	1	121%		
Dibenzo(a,e)pyrene	1.16	1	116%		
Dibenzo(a,i)pyrene	1.15	1	115%		
Dibenzo(a,l)pyrene	1.18	1	118%		
7,12-Dimethylbenz(a)anthracene	0.71	1	71%		
3-Methylcholanthrene	1.13	1	113%		
5-Methylchrysene	1.07	1	107%		
1-Nitropyrene	0.97	1	97%		
Perylene	1.09	1	109%		
Other PAH					
Naphthalene	1.16	1	116%	50-150%	pass
Chlorobenzenes					
Hexachlorobenzene	0.66	1	66%	50-150%	pass

DATA REPORT

Client: A. Lanfranco & Associates
 Contact: Mark Lanfranco

Date Extracted: 31-Aug-20
 Date Analysed: 18-Sep-20

Compound	DL µg	Client ID: MV Unit 3 - DF - Blank	MV Unit 3 - DF - Run 1	MV Unit 3 - DF - Run 2	MV Unit 3 - DF - Run 3	BLANK CP200527B
		PRL ID: PR201666	PR201667	PR201668	PR201669	
Trichlorobenzenes	0.05	ND	0.677	0.753	0.858	ND
Tetrachlorobenzenes	0.05	ND	0.206	0.225	0.261	ND
Pentachlorobenzene	0.05	ND	ND	ND	ND	ND
Hexachlorobenzene	0.01	ND	ND	ND	ND	ND

Surrogate Recoveries (%)

13C6-Hexachlorobenzene	140	112	104	108	72
------------------------	-----	-----	-----	-----	----

Compound	DL µg	µg	µg	µg	µg	µg
Trichlorophenols	0.05	ND	ND	ND	ND	ND
Tetrachlorophenols	0.05	ND	ND	ND	ND	ND
Pentachlorophenol	0.05	ND	ND	ND	ND	ND

Surrogate Recoveries (%)

13C6-Trichlorophenol	52	71	34	78	133
13C6-Tetrachlorophenol	97	108	50	122	86
13C6-Pentachlorophenol	42	101	104	104	81

ND - none detected

QC REPORT - SPIKE

Client: A. Lanfranco & Associates
 Contact: Mark Lanfranco

Date Extracted: 31-Aug-20
 Date Analysed: 18-Sep-20

Client ID: **SPIKE**
 PRL ID: **CP200528S**

Compound	LOF		Recovery
	μg	μg	
Trichlorobenzenes	2.0	1.45	72%
Tetrachlorobenzenes	3.0	2.68	89%
Pentachlorobenzene	1.0	0.75	75%
Hexachlorobenzene	1.0	0.72	72%
Trichlorophenols	0.2	0.16	82%
Tetrachlorophenols	0.2	0.17	86%
Pentachlorophenol	0.2	0.22	109%

LOF - level of fortification

Acronyms used in reporting dioxins and furans:

TCDD = Tetrachlorodibenzo-*p*-dioxin
 PeCDD = Pentachlorodibenzo-*p*-dioxin
 HxCDD = Hexachlorodibenzo-*p*-dioxin
 HpCDD = Heptachlorodibenzo-*p*-dioxin
 OCDD = Octachlorodibenzo-*p*-dioxin

TCDF = Tetrachlorodibenzofuran
 PeCDF = Pentachlorodibenzofuran
 HxCDF = Hexachlorodibenzofuran
 HpCDF = Heptachlorodibenzofuran
 OCDF = Octachlorodibenzofuran

Acceptable recoveries for surrogates

	EPA Method 23	
	Min (%)	Max (%)
³⁷ Cl ₄ -2,3,7,8-TCDD	70	130
¹³ C ₁₂ -2,3,4,7,8-PeCDF	70	130
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	70	130
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	70	130
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	70	130

Acceptable recoveries for Internal Standards

	EPA Method 23		Env. Can. 1-RM-3	
	Min (%)	Max (%)	Min (%)	Max (%)
¹³ C ₁₂ -2,3,7,8-TCDD	40	130	40	130
¹³ C ₁₂ -1,2,3,7,8-PeCDD	40	130	40	130
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	40	130	40	130
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	25	130	40	130
¹³ C ₁₂ -OCDD	25	130	40	130
¹³ C ₁₂ -2,3,7,8-TCDF	40	130	40	130
¹³ C ₁₂ -1,2,3,7,8-PeCDF	40	130		
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	40	130		
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	25	130		

Acronyms used in reporting Polychlorinated Biphenyls (PCBs)

MoCB = Monochlorobiphenyl
 DiCB = Dichlorobiphenyl
 TrCB = Trichlorobiphenyl
 TeCB = Tetrachlorobiphenyl
 PeCB = Pentachlorobiphenyl

HxCB = Hexachlorobiphenyl
 HpCB = Heptachlorobiphenyl
 OcCB = Octachlorobiphenyl
 NoCB = Nonachlorobiphenyl
 DeCB = Decachlorobiphenyl

Acceptable recoveries for PCB Internal Standards - EPA 1668C

Chemical Name	IUPAC #	Min	Max
¹³ C ₁₂ -2-MoCB	1L	5	145
¹³ C ₁₂ -4-MoCB	3L	5	145
¹³ C ₁₂ -2,2'-DiCB	4L	5	145
¹³ C ₁₂ -4,4'-DiCB	15L	5	145
¹³ C ₁₂ -2,2',6'-TrCB	19L	5	145
¹³ C ₁₂ -3,4,4'-TrCB	37L	5	145
¹³ C ₁₂ -2,2',6,6'-TeCB	54L	5	145
¹³ C ₁₂ -3,4,4',5'-TeCB	81L	10	145
¹³ C ₁₂ -3,3',4,4'-TeCB	77L	10	145
¹³ C ₁₂ -2,2',4,6,6'-PeCB	104L	10	145
¹³ C ₁₂ -2',3,4,4',5'-PeCB	123L	10	145
¹³ C ₁₂ -2,3',4,4',5'-PeCB	118L	10	145
¹³ C ₁₂ -2,3,4,4',5'-PeCB	114L	10	145
¹³ C ₁₂ -2,3,3',4,4'-PeCB	105L	10	145
¹³ C ₁₂ -3,3',4,4',5'-PeCB	126L	10	145
¹³ C ₁₂ -2,2',4,4',6,6'-HxCB	155L	10	145
¹³ C ₁₂ -2,3',4,4',5,5'-HxCB	167L	10	145
¹³ C ₁₂ -2,3,3',4,4',5'-HxCB	156L	10	145
¹³ C ₁₂ -2,3,3',4,4',5'-HxCB	157L	10	145
¹³ C ₁₂ -3,3',4,4',5,5'-HxCB	169L	10	145
¹³ C ₁₂ -2,2',3,4',5,6,6'-HpCB	188L	10	145
¹³ C ₁₂ -2,3,3',4,4',5,5'-HpCB	189L	10	145
¹³ C ₁₂ -2,2',3,3',5,5',6,6'-OcCB	202L	10	145
¹³ C ₁₂ -2,3,3',4,4',5,5',6'-OcCB	205L	10	145
¹³ C ₁₂ -2,2',3,3',4',5,5',6,6'-NoCB	208L	10	145
¹³ C ₁₂ -2,2',3,3',4,4',5,5',6'-NoCB	206L	10	145
¹³ C ₁₂ -DeCB	209L	10	145
¹³ C ₁₂ -2,4,4'-TrCB	28L	5	145
¹³ C ₁₂ -2,3,3',5,5'-PeCB	111L	10	145
¹³ C ₁₂ -2,2',3,3',5,5',6'-HpCB	178L	10	145

Acceptable recoveries for Polycyclic Aromatic Hydrocarbon Standards in Environmental Samples

	Surrogate Recovery	
	Min (%)	Max (%)
Naphthalene-d8	0	135
Biphenyl-d10	15	135
Acenaphthene-d10	15	135
Fluorene-d10	30	135
Phenanthrene-d10	30	135
Fluoranthene-d10	30	135
Pyrene-d10	30	135
Chrysene-d12	30	150
Benzo(b)fluoranthene-d12	30	150
Benzo(a)pyrene-d12	15	150
Dibenz(a,h)anthracene-d14	30	150



CHAIN OF CUSTODY RECORD / ANALYSIS REQUEST

Pacific Rim Laboratories Inc. #103, 19575 - 55A Avenue, Surrey, BC V3S 8P8 Tel: 604-532-8711 Fax: 604-532-8712

COMPANY: A. Lanfranco & Associates Inc. CONTACT: Mark Lanfranco
101-9488 189 Street
Surrey, BC Canada V4N 4W7
 PHONE: 604-881-2582
 DATE: 21-Aug-20 EMAIL: mark.lanfranco@alanfranco.com
 CLIENT: Metro Vancouver WTE SOURCE: Unit - 3

SAMPLE ID	PRL ID	DATE SAMPLED	SAMPLE MATRIX	NUMBER OF CONTAINERS										COMMENTS	
				DIOXIN/FURAN	PCB	dioxin-like (12)	PAH	HCB	TBT	Nonylphenol	PBDE	CB, CP			
MV Unit 3 - DF - Blank	PR201666 1705	18-Aug-20		5	X	X		X	X					X	3 bottles, 2 1 bag
MV Unit 3 - DF - Run 1	PR201667	18-Aug-20		5	X	X		X	X					X	3 bottles, filter, bag
MV Unit 3 - DF - Run 2	1668	19-Aug-20		5	X	X		X	X					X	--
MV Unit 3 - DF - Run 3	1669	19-Aug-20		5	X	X		X	X					X	--

Sampler's Signature	Relinquished by	Company	Date	Time	Received by
			Aug 21, 2020	12:30pm	M-MacLennan
Comments	Method of Shipment	Waybill No.	Rec'd for PRL	Date	Time
				Aug 21, 2020	12:30pm
	Shipment Condition	Temp.	Cooler Opened By		
		13.8°C Trays	Matthew MacLennan		



APPENDIX 2

**COMPUTER OUTPUTS OF MEASURED
and CALCULATED DATA**

Client: Metro Vancouver
Jobsite: WTE (Burnaby, BC)
Source: Unit 3

Date: 18-Aug-20
Run: 1 PCDD-PCDF
Run Time: 08:55 - 12:57

Control Unit (Y) 1.0019
Nozzle Diameter (in.) 0.2575
Pitot Factor 0.8525
Baro. Press. (in. Hg) 30.02
Static Press. (in. H2O) -18.10
Stack Height (ft) 30
Stack Diameter (in.) 70.9
Stack Area (sq.ft.) 27.417
Minutes Per Reading 5.0
Minutes Per Point 10.0

Gas Analysis (Vol. %):

	CO2	O2
Trav 1	10.25	9.70
Trav 2	10.50	9.53
Average = <u>10.38</u>		<u>9.62</u>

Condensate Collection:

Impinger 1 (grams)	471.0
Impinger 2 (grams)	12.0
Impinger 3 (grams)	0.0
Impinger 4 (grams)	8.4
Total Gain (grams)	<u>491.4</u>

Collection:

D/F TEQ (ng)	<u>0.0087</u>
---------------------	----------------------

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature			Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)	Stack (oF)		
1	1	0.0	504.249							
		5.0	507.330	0.480	1.45	71	71	299	1.5	102.8
	2	10.0	510.430	0.485	1.47	71	71	298	1.5	102.8
		15.0	513.480	0.470	1.43	72	72	298	4.7	102.5
	3	20.0	516.550	0.475	1.44	72	72	298	4.7	102.7
		25.0	519.790	0.530	1.61	72	72	298	8.4	102.6
	4	30.0	522.980	0.510	1.55	73	73	298	8.4	102.8
		35.0	526.110	0.490	1.49	74	74	298	12.5	102.7
	5	40.0	529.270	0.500	1.52	74	74	298	12.5	102.6
		45.0	532.340	0.470	1.44	75	75	298	17.7	102.6
	6	50.0	535.400	0.465	1.42	76	76	297	17.7	102.6
		55.0	538.350	0.430	1.32	77	77	297	25.2	102.6
7	60.0	541.260	0.420	1.29	77	77	298	25.2	102.5	
	65.0	543.690	0.290	0.89	78	78	298	45.6	102.7	
8	70.0	546.070	0.280	0.86	78	78	298	45.6	102.4	
	75.0	548.420	0.270	0.83	79	79	298	53.2	102.7	
9	80.0	550.720	0.260	0.80	79	79	299	53.2	102.5	
	85.0	552.960	0.245	0.75	80	80	300	58.3	102.7	
10	90.0	555.260	0.260	0.80	80	80	301	58.3	102.5	
	95.0	557.480	0.240	0.74	80	80	297	62.5	102.6	
11	100.0	559.690	0.240	0.74	81	81	300	62.5	102.2	
	105.0	561.860	0.230	0.71	81	81	300	66.1	102.5	
12	110.0	564.050	0.235	0.72	81	81	301	66.1	102.4	
	115.0	566.170	0.220	0.68	82	82	302	69.4	102.3	
		120.0	568.290	0.220	0.68	82	82	301	69.4	102.3
		0.0	568.290							
2	1	5.0	570.730	0.290	0.89	82	82	301	1.5	102.6
		10.0	573.290	0.320	0.98	82	82	303	1.5	102.6
	2	15.0	575.970	0.350	1.08	83	83	303	4.7	102.5
		20.0	578.680	0.360	1.11	82	82	303	4.7	102.4
	3	25.0	581.240	0.320	0.98	83	83	305	8.4	102.5
		30.0	583.880	0.340	1.04	83	83	305	8.4	102.6
	4	35.0	586.370	0.300	0.92	84	84	304	12.5	102.7

A. Lanfranco and Associates Inc. - Emission Report

		40.0	588.810	0.290	0.89	83	83	305	12.5	102.6
	5	45.0	591.170	0.270	0.83	83	83	303	17.7	102.7
		50.0	593.550	0.275	0.85	83	83	303	17.7	102.7
	6	55.0	596.040	0.300	0.93	84	84	303	25.2	102.7
		60.0	598.530	0.300	0.93	84	84	303	25.2	102.7
	7	65.0	601.740	0.500	1.54	84	84	303	45.6	102.7
		70.0	605.010	0.520	1.60	84	84	303	45.6	102.6
	8	75.0	608.380	0.550	1.69	84	84	304	53.2	102.9
		80.0	611.780	0.560	1.73	84	84	304	53.2	102.9
	9	85.0	615.240	0.580	1.73	85	85	305	58.3	102.8
		90.0	618.700	0.580	1.73	85	85	306	58.3	102.8
	10	95.0	622.040	0.540	1.66	85	85	306	62.5	102.8
		100.0	625.420	0.550	1.70	86	86	305	62.5	102.9
	11	105.0	628.670	0.510	1.58	86	86	305	66.1	102.7
		110.0	631.890	0.500	1.54	86	86	306	66.1	102.8
	12	115.0	635.070	0.490	1.51	86	86	306	69.4	102.6
		120.0	638.260	0.490	1.52	87	87	305	69.4	102.6
			Average:	0.392	1.200	80.5	80.5	301.4		102.6

Client: Metro Vancouver
Jobsite: WTE (Burnaby, BC)
Source: Unit 3

Date: 19-Aug-20
Run: 2 PCDD-PCDF
Run Time: 08:28 - 12:30

Dioxin Concentration:	1.35 pg/dscm	0.0006 gr/dscf
	0.8 pg/dscm	0.0003 gr/Acf
	1.22 pg/dscm (@ 11% O2)	0.0005 gr/dscf (@ 11% O2)

Emission Rate: see D/F data Table 2

Sample Gas Volume:	3.6329 dscm	128.295 dscf
Total Sample Time:	240.0 minutes	

Average Isokineticity: 100.9 %

Flue Gas Characteristics

Moisture:	13.82 %	
Temperature	152.6 oC	306.7 oF
Flow	1136.3 dscm/min 18.94 dscm/sec 2003.1 Acf/min	40129 dscf/min 668.8 dscf/sec 70740 Acf/min
Velocity	13.107 m/sec	43.00 f/sec
Gas Analysis	9.93 % O2	10.17 % CO2
	30.024 Mol. Wt (g/gmole) Dry	28.363 Mol. Wt (g/gmole) Wet

* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa
 Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, BC)
Source: Unit 3

Date: 19-Aug-20
Run: 2 PCDD-PCDF
Run Time: 08:28 - 12:30

Control Unit (Y) 1.0019
 Nozzle Diameter (in.) 0.2575
 Pitot Factor 0.8525
 Baro. Press. (in. Hg) 29.95
 Static Press. (in. H2O) -18.30
 Stack Height (ft) 30
 Stack Diameter (in.) 70.9
 Stack Area (sq.ft.) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 10.0

Gas Analysis (Vol. %):

	CO2	O2
Trav 1	10.25	9.85
Trav 2	10.08	10.02
Average =		10.17 9.93

Condensate Collection:

Impinger 1 (grams)	417.0
Impinger 2 (grams)	12.0
Impinger 3 (grams)	0.0
Impinger 4 (grams)	8.0
Total Gain (grams)	437.0

Collection:

D/F TEQ (ng) 0.0049

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature			Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)	Stack (oF)		
		0.0	639.818							
1	1	5.0	642.910	0.490	1.47	69	69	305	1.5	101.7
		10.0	646.000	0.490	1.46	69	69	306	1.5	101.7
	2	15.0	649.070	0.480	1.44	70	70	304	4.7	101.7
		20.0	652.140	0.480	1.44	70	70	304	4.7	101.7
	3	25.0	655.240	0.490	1.47	71	71	304	8.4	101.5
		30.0	658.410	0.510	1.53	71	71	304	8.4	101.7
	4	35.0	661.490	0.480	1.45	72	72	303	12.5	101.6
		40.0	664.600	0.490	1.48	72	72	304	12.5	101.6
	5	45.0	667.840	0.530	1.60	73	73	303	17.7	101.6
		50.0	670.930	0.480	1.45	74	74	303	17.7	101.6
	6	55.0	673.990	0.470	1.42	74	74	304	25.2	101.7
		60.0	677.070	0.475	1.44	75	75	304	25.2	101.6
7	65.0	679.510	0.300	0.91	75	75	306	45.6	101.3	
	70.0	681.810	0.290	0.88	76	76	306	45.6	96.9	
8	75.0	683.850	0.250	0.76	77	77	306	53.2	92.4	
	80.0	685.930	0.260	0.79	77	77	306	53.2	92.4	
9	85.0	687.930	0.240	0.73	78	78	306	58.3	92.3	
	90.0	690.080	0.220	0.70	78	78	305	58.3	103.5	
10	95.0	692.230	0.230	0.70	78	78	304	62.5	101.2	
	100.0	694.390	0.230	0.70	79	79	303	62.5	101.4	
11	105.0	696.450	0.210	0.64	79	79	304	66.1	101.3	
	110.0	698.460	0.200	0.64	79	79	304	66.1	101.3	
12	115.0	700.430	0.190	0.58	80	80	303	69.4	101.6	
	120.0	702.400	0.190	0.58	80	80	304	69.4	101.6	
		0.0	702.400							
2	1	5.0	704.740	0.270	0.83	81	81	306	1.5	101.3
		10.0	707.130	0.280	0.86	81	81	306	1.5	101.6
	2	15.0	709.560	0.290	0.89	81	81	307	4.7	101.5
		20.0	711.990	0.290	0.89	82	82	306	4.7	101.3
	3	25.0	714.460	0.300	0.92	82	82	307	8.4	101.3
		30.0	717.020	0.320	0.98	82	82	307	8.4	101.7
	4	35.0	719.490	0.300	0.91	82	82	310	12.5	101.5
		40.0	721.940	0.295	0.90	82	82	311	12.5	101.6

A. Lanfranco and Associates Inc. - Emission Report

	5	45.0	724.430	0.305	0.93	83	83	311	17.7	101.4
		50.0	726.880	0.295	0.90	83	83	311	17.7	101.4
	6	55.0	729.310	0.290	0.88	83	83	310	25.2	101.4
		60.0	731.780	0.300	0.92	83	83	310	25.2	101.3
	7	65.0	734.880	0.470	1.44	83	83	311	45.6	101.8
		70.0	737.950	0.460	1.40	84	84	311	45.6	101.7
	8	75.0	741.020	0.460	1.41	84	84	310	53.2	101.6
		80.0	744.220	0.500	1.53	84	84	310	53.2	101.6
	9	85.0	747.420	0.500	1.53	84	84	310	58.3	101.6
		90.0	750.590	0.490	1.50	84	84	309	58.3	101.6
	10	95.0	753.950	0.550	1.69	84	84	308	62.5	101.7
		100.0	757.280	0.540	1.65	84	84	309	62.5	101.7
	11	105.0	760.510	0.510	1.56	84	84	309	66.1	101.5
		110.0	763.710	0.500	1.53	84	84	310	66.1	101.6
	12	115.0	766.890	0.490	1.50	85	85	309	69.4	101.8
		120.0	770.030	0.480	1.47	85	85	310	69.4	101.6
			Average:	0.378	1.152	79.0	79.0	306.7		100.9

Client:	Metro Vancouver	Date:	19-Aug-20
Jobsite:	WTE (Burnaby, BC)	Run:	3 - PCDD-PCDF
Source:	Unit 3	Run Time:	13:40 - 17:42

Dioxin Concentration:	2.2 pg/dscm	0.0010 gr/dscf
	1.2 pg/Acm	0.0005 gr/Acf
	2.1 pg/dscm (@ 11% O2)	0.0009 gr/dscf (@ 11% O2)

Emission Rate: see D/F data Table 2

Sample Gas Volume:	3.5153 dscm	124.142 dscf
Total Sample Time:	240.0 minutes	
Average Isokineticity:	100.1 %	

Flue Gas Characteristics

Moisture:	14.59 %	
Temperature	157.6 oC	315.7 oF
Flow	1156.7 dscm/min	40850 dscf/min
	19.28 dscm/sec	680.8 dscf/sec
	2091.0 Acm/min	73842 Acf/min
Velocity	13.682 m/sec	44.89 f/sec
Gas Analysis	10.28 % O2	10.00 % CO2
	30.011 Mol. Wt (g/gmole) Dry	28.258 Mol. Wt (g/gmole) Wet

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
 Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, BC)
Source: Unit 3

Date: 19-Aug-20
Run: 3 - PCDD-PCDF
Run Time: 13:40 - 17:42

Control Unit (Y) 0.9977
 Nozzle Diameter (in.) 0.2523
 Pitot Factor 0.8328
 Baro. Press. (in. Hg) 29.91
 Static Press. (in. H2O) -19.50
 Stack Height (ft) 30
 Stack Diameter (in.) 70.9
 Stack Area (sq.ft.) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 10.0

Gas Analysis (Vol. %):

	CO2	O2
Trav 1	10.00	10.25
Trav 2	10.00	10.30
Average =		10.00 10.28

Condensate Collection:

Impinger 1 (grams)	430.0
Impinger 2 (grams)	9.0
Impinger 3 (grams)	0.0
Impinger 4 (grams)	11.6
Total Gain (grams)	450.6

Collection:

D/F TEQ (ng) 0.0078

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
		0.0	534.000							
1	1	5.0	537.010	0.540	1.14	90	90	316	1.5	97.7
		10.0	540.020	0.540	1.14	91	91	316	1.5	97.5
	2	15.0	542.980	0.520	1.10	92	92	316	4.7	97.5
		20.0	545.820	0.480	1.02	92	92	316	4.7	97.4
	3	25.0	548.780	0.520	1.10	93	93	314	8.4	97.2
		30.0	551.690	0.500	1.06	94	94	314	8.4	97.3
	4	35.0	554.580	0.500	1.06	94	94	315	12.5	96.7
		40.0	557.420	0.480	1.02	95	95	315	12.5	96.8
	5	45.0	560.260	0.480	1.02	96	96	314	17.7	96.6
		50.0	563.100	0.480	1.02	96	96	314	17.7	96.6
	6	55.0	566.110	0.540	1.14	97	97	314	25.2	96.3
		60.0	569.070	0.520	1.10	98	98	315	25.2	96.4
7	65.0	571.460	0.340	0.72	99	99	316	45.6	96.1	
	70.0	573.780	0.320	0.68	99	99	316	45.6	96.1	
8	75.0	576.170	0.300	0.64	99	99	316	53.2	102.3	
	80.0	578.490	0.280	0.59	100	100	316	53.2	102.6	
9	85.0	580.670	0.250	0.58	101	101	316	58.3	101.8	
	90.0	582.850	0.250	0.58	102	102	316	58.3	101.6	
10	95.0	584.890	0.220	0.51	102	102	315	62.5	101.3	
	100.0	586.940	0.220	0.51	102	102	316	62.5	101.8	
11	105.0	588.990	0.220	0.51	102	102	308	66.1	101.3	
	110.0	591.040	0.220	0.51	103	103	305	66.1	100.9	
12	115.0	593.090	0.220	0.51	104	104	303	69.4	100.6	
	120.0	595.040	0.200	0.46	106	106	302	69.4	100.0	
		0.0	595.040							
2	1	5.0	597.870	0.420	0.97	104	104	318	1.5	101.6
		10.0	600.630	0.400	0.92	105	105	316	1.5	101.3
	2	15.0	603.390	0.400	0.92	104	104	319	4.7	101.6
		20.0	606.150	0.400	0.92	105	105	320	4.7	101.5
	3	25.0	608.800	0.370	0.85	104	104	319	8.4	101.4
		30.0	611.450	0.370	0.85	104	104	320	8.4	101.5
	4	35.0	614.030	0.350	0.81	104	104	320	12.5	101.6
		40.0	616.500	0.320	0.74	104	104	320	12.5	101.7

A. Lanfranco and Associates Inc. - Emission Report

	5	45.0	618.970	0.320	0.74	104	104	319	17.7	101.6
		50.0	621.440	0.320	0.74	104	104	318	17.7	101.6
	6	55.0	623.830	0.300	0.69	104	104	318	25.2	101.5
		60.0	626.220	0.300	0.69	104	104	318	25.2	101.5
	7	65.0	629.300	0.500	1.16	104	104	318	45.6	101.4
		70.0	632.370	0.490	1.13	104	104	319	45.6	102.2
	8	75.0	635.800	0.620	1.43	104	104	317	53.2	101.4
		80.0	639.180	0.600	1.39	104	104	317	53.2	101.6
	9	85.0	642.560	0.600	1.39	104	104	317	58.3	101.6
		90.0	645.940	0.600	1.39	105	105	317	58.3	101.4
	10	95.0	649.460	0.650	1.50	105	105	316	62.5	101.4
		100.0	653.030	0.670	1.55	105	105	316	62.5	101.4
	11	105.0	656.360	0.580	1.34	105	105	317	66.1	101.6
		110.0	659.590	0.550	1.27	106	106	317	66.1	101.0
	12	115.0	662.820	0.550	1.27	105	105	316	69.4	101.1
		120.0	665.970	0.520	1.20	105	105	316	69.4	101.4
			Average:	0.424	0.950	101.1	101.1	315.7		100.1

APPENDIX 3
FIELD DATA SHEETS

CLIENT		NOZZLE		DIAMETER, IN.		IMPINGER		INITIAL		FINAL		TOTAL GAIN																
MV-WTE		P		0.2575				(mL)		(mL)		(mL)																
SOURCE		PROBE		Cp		VOLUMES		Imp. #1		Imp. #2		Imp. #3																
Unit 3		70		0.8525				9		471																		
PARAMETER / RUN No		PORT LENGTH		STATIC PRESSURE, IN. H2O		Imp. #4		Imp. #5		Imp. #6																		
DF Run 1				-18.1		0		0																				
DATE		STACK DIAMETER		STACK HEIGHT																								
18 Aug 2020		70.9"																										
OPERATOR:		CONTROL UNIT		Y		1.0019		ΔH@		2.051																		
LA		DU 14																										
BAROMETRIC PRESSURE, IN. Hg		INITIAL LEAK TEST		Upstream Diameters																								
30.02		0.003@15"																										
ASSUMED MOISTURE, Bw		FINAL LEAK TEST		Downstream Diameters																								
15.1%		0.002@15"																										
Point		Clock Time		Dry Gas Meter ft ³		Pitot ΔP IN. H ₂ O		Orifice ΔH IN. H ₂ O		Temperature °F		Pump Vac. IN. Hg		Fyrites		CO ₂ Vol. %		O ₂ Vol. %		CO (ppm)		NO _x (ppm)		XAD Temp (°F)				
		0855		504.249						Dry Gas Outlet		Stack		Probe		Box		Impinger Exit										
1				507.33	0.48	1.45	71	299	256	255	59	3																
1				510.43	0.485	1.47	71	298																			43	
2				513.48	0.47	1.43	72	298	237	254	35	6	10.5	9.5	49	72											44	
2				516.55	0.475	1.44	72	298																			44	
3				519.79	0.53	1.61	72	298	254	252	55	7															44	
3				522.98	0.51	1.55	73	298					10.5	9.3	39	74											43	
4				526.11	0.49	1.49	74	298	232	251	57	7															43	
4				529.37	0.50	1.52	74	298																				43
5				532.34	0.47	1.44	75	298	231	251	53	7															43	
5				535.40	0.465	1.42	76	297					10	9.6	39	71											45	
6				538.35	0.43	1.32	77	297	250	250	55	7															45	
6				541.26	0.42	1.29	77	298																				45
7				543.69	0.29	0.89	78	298	250	251	55	6															45	
7				546.07	0.28	0.86	78	298					10	10.2	42	68											43	
8				548.42	0.27	0.83	79	298	231	251	56	6															43	
8				550.72	0.26	0.80	79	299																				43
9				552.96	0.245	0.75	80	300	250	250	57	6															44	
9				555.26	0.26	0.80	80	301					10	10.0	50	66											44	
10				557.48	0.24	0.74	80	297	250	251	57	6															45	
10				559.69	0.24	0.74	81	300																			45	
11				561.86	0.23	0.71	81	300	230	231	58	6															46	
11				564.05	0.235	0.72	81	301																			46	
12				566.17	0.22	0.68	82	302	249	250	57	6	10.5	9.6	53	80											45	
12	1055			568.29	0.22	0.68	82	301																			45	

Initial LC start: 503.658

2052
44

A. Lanfranco and Associates Inc.

CLIENT					NOZZLE DIAMETER, IN.					IMPINGER	INITIAL	FINAL	TOTAL GAIN		
MV-WTE					Cp					VOLUMES	(mL)	(mL)	(mL)		
SOURCE					PORT LENGTH					Imp. #1	0	471			
PARAMETER / RUN No					STATIC PRESSURE, IN. H2O					Imp. #2	100	112			
DATE					STACK DIAMETER					Imp. #3	0	0			
OPERATOR					STACK HEIGHT					Imp. #4	6.1				
CONTROL UNIT					INITIAL LEAK TEST					Imp. #5					
ΔH@					FINAL LEAK TEST					Imp. #6					
BAROMETRIC PRESSURE, IN. Hg					Upstream Diameters										
ASSUMED MOISTURE, Bw					Downstream Diameters										
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites		CO (ppm)	NO _x (ppm)	XAD Temp (°F)
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %			
1	1057	568.29	0.29	0.89	82	301	250	251	55	6					41
1		570.73	0.32	0.98	82	303	250	251	56	6.5	10.5	9.6	65	77	44
2		575.97	0.35	1.08	83	303	250	251	56	6.5					44
2		578.68	0.36	1.11	82	303	250	250	57	6.5					45
3		581.24	0.32	0.98	83	305	250	251	57	6.5	11	9.0	53	75	43
3		583.88	0.34	1.04	83	305	250	251	57	6.5					43
4		586.37	0.30	0.92	84	304	250	251	57	6.5					43
4		588.81	0.29	0.89	83	305	250	250	57	6					44
5		591.17	0.27	0.83	83	303	250	250	57	6					44
5		593.55	0.275	0.85	83	303	250	250	57	6	10.5	9.2	54	84	42
6		596.04	0.30	0.93	84	303	250	250	57	6					42
6		599.53	0.30	0.93	84	303	250	250	57	6					42
7		601.74	0.30	1.04	84	303	250	251	55	7.5					41
7		605.01	0.32	1.60	84	303	250	251	55	7.5	10.5	9.7	55	78	41
8		608.38	0.55	1.69	84	304	250	249	55	8.0					41
8		611.78	0.56	1.73	84	304	250	249	55	8.0					41
9		615.24	0.58	1.79	85	305	250	250	55	8					42
9		618.70	0.59	1.79	85	306	250	250	55	8	10.5	9.6	45	70	42
10		622.04	0.54	1.66	85	306	250	250	55	8					42
10		625.42	0.55	1.70	86	305	250	250	55	8					42
11		628.67	0.51	1.58	86	305	251	251	56	8					43
11		631.89	0.50	1.54	86	306	251	251	56	8	10.0	10.1	43	76	43
12		635.07	0.49	1.51	86	306	250	250	56	8					43
12	1257	638.26	0.49	1.52	87	305									

Final W/C end: 638.534

CLIENT				NOZZLE	DIAMETER, IN.		IMPINGER	INITIAL	FINAL	TOTAL GAIN						
MV WTE				P	0.2575			(mL)	(mL)	(mL)						
SOURCE				PROBE	Cp		VOLUMES									
Unit 3				7C	0.8925		Imp. #1	0	417							
PARAMETER / RUN No				PORT LENGTH			Imp. #2									
DF Run 2							100	112								
DATE				STATIC PRESSURE, IN. H2O			Imp. #3									
19 Aug 2020				-18.3			0	0								
OPERATOR				STACK DIAMETER			Imp. #4									
LA							Rel									
CONTROL UNIT				STACK HEIGHT			Imp. #5									
JW 14																
							Imp. #6									
BAROMETRIC PRESSURE, IN. Hg				INITIAL LEAK TEST			Upstream Diameters									
29.45				0.002 @ 15"												
ASSUMED MOISTURE, Bw				FINAL LEAK TEST			Downstream Diameters									
15%				0.003 @ 15"												
Test 1																
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites		CO (ppm)	NOx (ppm)	XAD Temp (°F)	
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %				
1	0828	639.818														
1		642.91	0.49	1.47	69	305	251	253	57	6						42
2		646.00	0.49	1.46	69	306										
2		649.07	0.48	1.44	70	304	251	252	54	7	10.5	9.5	38	63		41
3		652.14	0.48	1.44	70	304										
3		655.24	0.49	1.47	71	304	251	252	53	7						40
4		659.41	0.51	1.53	71	304					10	10.1	45	78		41
4		661.49	0.48	1.45	72	303	250	251	52	7						41
5		664.60	0.49	1.48	72	304										
5		667.84	0.33	1.60	73	303	250	249	52	7						39
5		670.93	0.48	1.45	74	303					10	10.1	40	80		40
6		673.99	0.47	1.42	74	304	250	250	53	7						40
6		677.07	0.473	1.44	75	304										
7		679.51	0.30	0.91	75	306	251	250	54	5						41
7		681.81	0.29	0.88	76	306					10	10.2	41	71		41
8		683.85	0.25	0.76	77	306	250	251	55	6						41
8		685.93	0.26	0.79	77	306										
9		687.93	0.24	0.73	78	306	250	252	56	6						41
9		690.08	0.23	0.70	78	303					10.5	9.6	40	58		41
10		692.23	0.23	0.70	78	304	251	250	57	5						41
10		694.39	0.23	0.70	79	303										
11		696.45	0.21	0.64	79	304	250	250	57	5						41
11		698.46	0.20	0.61	79	304					10.5	9.6	40	63		41
12		700.43	0.19	0.58	80	303	251	251	57	5						41
12	1028	702.40	0.19	0.58	80	304										

Initial GC Start: 638.534
 Final GC Stop: 770.181

24.10 2.12 ΔH
 4.24 - 2.31
 4.36

CLIENT	MURD	NOZZLE	G-253	DIAMETER, IN.	0.623	IMPINGER	INITIAL	FINAL	TOTAL GAIN
SOURCE	Unit #3	PROBE	AL GVPD	Cp	0.8328	VOLUMES	(mL)	(mL)	(mL)
PARAMETER / RUN No	3 PDD/PDF	PORT LENGTH				Imp. #1	0	250	250
DATE	Aug. 19/20	STATIC PRESSURE, IN. H2O	-19.50			Imp. #2	100	180	80
OPERATOR:	J.C.I.	STACK DIAMETER	70.9			Imp. #3	0	109	109
CONTROL UNIT	G105	STACK HEIGHT	30'			Imp. #4			
	ΔH@					Imp. #5			
BAROMETRIC PRESSURE, IN. Hg	29.91	INITIAL LEAK TEST	0.002 @ 15"			Imp. #6			
ASSUMED MOISTURE, Bw	15%	FINAL LEAK TEST	0.002 @ 15"			Upstream Diameters			
						Downstream Diameters			

Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites		XAD
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %	
1	13:40	534.00	.54	1.14	90	316	250	250	49	5			52
1		540.02	.54	1.14	91	316							
2		542.98	.52	1.10	92	316	250	250	49	5	10.0	10.0	46
2		545.82	.48	1.02	92	316							
3		548.78	.52	1.10	93	314	250	250	54	5			48
3		551.69	.50	1.06	94	314							
4		554.58	.50	1.06	94	315	250	250	58	5	10.0	10.5	47
4		557.42	.48	1.02	95	315							
5		560.26	.48	1.02	96	314	250	250	62	5			48
5		563.10	.48	1.02	96	314							
6		566.11	.54	1.14	97	314	250	250	64	5			48
6		569.07	.52	1.10	98	315					10.0	10.5	
7		571.46	.31	1.72	99	316	250	250	66	5			50
7		575.78	.32	1.68	99	316							
8		576.17	.30	1.64	99	316	250	250	67	5			52
8		578.49	.28	1.59	100	316							
9		580.67	.25	1.58	101	316	250	250	68	5			51
9		582.85	.25	1.58	102	316					10.0	10.0	
10		584.89	.22	1.51	102	315	250	250	68	5			50
10		586.94	.22	1.51	102	316							
11		588.99	.22	1.51	102	308	250	250	60	4			50
11		591.04	.22	1.51	103	305							
12		593.09	.22	1.51	104	303	250	250	62	4	10.0	10.5	52
12		595.04	.20	1.46	106	322							
1		597.87	.42	.97	104	318	250	250	60	5			50
1		600.63	.40	.92	105	316							
2		603.39	.40	.92	104	319	250	250	62	5	10.0	10.0	52
2		606.15	.40	.92	105	320							
3		608.60	.37	.85	104	319	250	250	64	5			

√4.36 2.31ΔH

4

CLIENT		NOZZLE		DIAMETER, IN.		IMPINGER	INITIAL	FINAL	TOTAL GAIN				
MVRD		PROBE		Cp		VOLUMES	(mL)	(mL)	(mL)				
SOURCE		PORT LENGTH		STATIC PRESSURE, IN. H2O		Imp. #1							
PARAMETER / RUN No		STACK DIAMETER		STACK HEIGHT		Imp. #2							
DATE		INITIAL LEAK TEST		FINAL LEAK TEST		Imp. #3							
OPERATOR:		Upstream Diameters				Imp. #4							
CONTROL UNIT		Downstream Diameters				Imp. #5							
BAROMETRIC PRESSURE, IN. Hg						Imp. #6							
ASSUMED MOISTURE, Bw													
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac.	Fyrites		XAD
	Continued.	608.80			Dry Gas Outlet	Stack	Probe	Box	Impinger Exit	IN. Hg	CO ₂ Vol. %	O ₂ Vol. %	
3		611.45	1.37	1.85	104	320	250	250	66	5			47
4		614.03	1.35	1.81	104	320					10.0	10.5	48
4		616.50	1.32	1.74	104	320	250	250	66	5			48
5		618.97	1.32	1.74	104	319							48
5		621.44	1.32	1.74	104	318	250	250	67	5			48
6		623.83	1.30	1.69	104	318							49
6		626.32	1.30	1.69	104	318	250	250	68	5	10.0	10.5	49
7		629.30	1.50	1.16	104	318							47
7		632.37	1.49	1.13	104	319	250	250	66	5			47
8		635.80	1.62	1.43	104	317							47
8		639.18	1.60	1.39	104	317	250	250	64	6			47
9		642.53	1.60	1.39	104	317							47
9		645.94	1.60	1.39	105	317	250	250	63	6	10.0	10.0	47
10		649.46	1.65	1.50	105	316							46
10		653.03	1.67	1.55	105	316	250	250	62	6			46
11		656.36	1.58	1.31	105	317							45
11		659.59	1.55	1.27	106	317	250	250	62	6			45
12	17.42	662.82	1.55	1.27	105	316					10.0	10.5	
12		665.97	1.52	1.20	105	316	250	250	63	6			

APPENDIX 4
CALIBRATION DATA and
CERTIFICATION

A.Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: CAE G10J
Serial #: 0028-1X1310-1

Date: 29-Jun-20
Barometric Pressure: 29.99 (in. Hg)
Theoretical Critical Vacuum: 14.15 (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}/(in.Hg)²(min).
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume		Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
		Initial (cu ft)	Final (cu ft)		Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.65	15.00	55.900	72.111	16.211	76.0	76.0	82.0	82.0	73	0.8185	16.5	74.0	78.0	76.0
1.90	16.00	72.800	85.357	12.557	83.0	83.0	86.0	86.0	63	0.5956	19.0	79.0	84.0	81.5
1.10	28.00	85.500	102.637	17.137	83.0	83.0	88.0	88.0	55	0.4606	20.5	82.0	86.0	84.0
0.64	17.00	102.700	110.649	7.949	87.0	87.0	87.0	87.0	48	0.3560	22.0	86.0	89.0	87.5
0.33	15.00	110.700	115.535	4.835	89.0	89.0	89.0	89.0	40	0.2408	23.0	87.0	87.0	87.0

***** RESULTS *****											
--- DRY GAS METER ---		----- ORIFICE -----			-- DRY GAS METER --		----- ORIFICE -----				
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y		CALIBRATION FACTOR dH@			Ko	
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)	(value)	
16.053	454.6	15.904	450.4	16.114	0.991	-0.007	1.793	45.55	0.030	0.719	
12.257	347.1	12.282	347.8	12.571	1.002	0.004	1.763	44.78	0.000	0.719	
16.664	471.9	16.583	469.6	17.052	0.995	-0.003	1.711	43.47	-0.052	0.735	
7.700	218.1	7.757	219.7	8.028	1.007	0.010	1.673	42.49	-0.091	0.735	
4.663	132.1	4.632	131.2	4.789	0.993	-0.004	1.877	47.67	0.113	0.704	
Average Y----->					0.9977	Average dH@---->		1.764	44.8	Average Ko----> 0.723	

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Results		
		Variation (degF)	Percent of Absolute	
32	32	0	0.00%	
100	100	0	0.00%	
300	300	0	0.00%	
500	500	0	0.00%	
1000	1000	0	0.00%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Devices, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: 

Date: June 29, 2020

A.Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: JU 14
Serial #: 0028-030615-1

Date: 30-Jun-20
Barometric Pressure: 29.80 (in. Hg)
Theoretical Critical Vacuum: 14.06 (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}/(in.Hg)²(min).
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume			Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
		Initial (cu ft)	Final (cu ft)	Total (cu ft)	Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
4.10	22.00	574.500	597.911	23.411	71.0	71.0	73.0	73.0	73	0.8185	15.5	69.0	74.0	71.5
2.20	18.00	598.600	612.539	13.939	73.0	73.0	74.0	74.0	63	0.5956	17.0	75.0	75.0	75.0
1.40	18.00	613.100	623.930	10.830	74.0	74.0	74.0	74.0	55	0.4606	18.5	80.0	76.0	78.0
0.76	27.00	624.500	636.842	12.342	74.0	74.0	75.0	75.0	48	0.3560	20.0	76.0	80.0	78.0
0.36	17.00	636.900	642.251	5.351	75.0	75.0	75.0	75.0	40	0.2408	21.0	75.0	76.0	75.5

***** RESULTS *****												
--- DRY GAS METER ---		----- ORIFICE -----		-- DRY GAS METER --		----- ORIFICE -----						
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y		CALIBRATION FACTOR dH@			Ko		
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)	(value)		
23.367	661.7	23.276	659.2	23.534	0.996	-0.006	2.037	51.73	-0.044	0.674		
13.809	391.1	13.812	391.2	14.057	1.000	-0.002	2.072	52.62	-0.009	0.667		
10.698	303.0	10.652	301.7	10.902	0.996	-0.006	2.215	56.25	0.134	0.649		
12.161	344.4	12.349	349.7	12.639	1.015	0.014	2.011	51.07	-0.070	0.668		
5.262	149.0	5.272	149.3	5.370	1.002	0.000	2.070	52.58	-0.011	0.668		
Average Y----->					1.0019	Average dH@---->		2.081	52.8	Average Ko---->		0.665

TEMPERATURE CALIBRATION				
Reference Temperature		Temperature Device		Results
Set-Point (deg F)		Reading (deg F)	Variation (deg F)	Percent of Absolute
32		32	0	0.00%
100		100	0	0.00%
300		300	0	0.00%
500		500	0	0.00%
1000		1000	0	0.00%

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Devices, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: 

Date: June 30, 2020

A. LANFRANCO and ASSOCIATES INC.

ENVIRONMENTAL CONSULTANTS

GLASS NOZZLE DIAMETER CALIBRATION FORM

Calibrated by: Justin Ching
Date: June 29th, 2020

Signature: 

Nozzle I.D.	d1 (inch)	d2 (inch)	d3 (inch)	difference (inch)	average dia. (inch)	average area (ft ²)
A	0.1250	0.1240	0.1245	0.0010	0.1245	0.0000845
G-165	0.1640	0.1655	0.1660	0.0020	0.1652	0.0001488
G-178	0.1780	0.1780	0.1790	0.0010	0.1783	0.0001735
J	0.1880	0.1880	0.1880	0.0000	0.1880	0.0001928
E	0.1880	0.1895	0.1882	0.0015	0.1886	0.0001939
L	0.2112	0.2120	0.2105	0.0015	0.2112	0.0002434
Q	0.2190	0.2170	0.2185	0.0020	0.2182	0.0002596
G-218	0.2180	0.2175	0.2190	0.0015	0.2182	0.0002596
G-223	0.2220	0.2230	0.2225	0.0010	0.2225	0.0002700
G-225	0.2245	0.2250	0.2240	0.0010	0.2245	0.0002749
G-2251	0.2230	0.2260	0.2245	0.0030	0.2245	0.0002749
P-18	0.2375	0.2370	0.2380	0.0010	0.2375	0.0003076
G-247	0.2450	0.2470	0.2470	0.0020	0.2463	0.0003310
G-253	0.2525	0.2520	0.2525	0.0005	0.2523	0.0003473
G-257	0.2570	0.2570	0.2570	0.0000	0.2570	0.0003602
P	0.2580	0.2570	0.2575	0.0010	0.2575	0.0003616
G-275	0.2750	0.2740	0.2750	0.0010	0.2747	0.0004115
G-278	0.2780	0.2770	0.2780	0.0010	0.2777	0.0004205
P-2	0.2787	0.2790	0.2785	0.0005	0.2787	0.0004237
G-287	0.2870	0.2880	0.2860	0.0020	0.2870	0.0004493
G-292	0.2922	0.2920	0.2926	0.0006	0.2923	0.0004659
G-304	0.3040	0.3050	0.3040	0.0010	0.3043	0.0005052
MV-02	0.3050	0.3040	0.3055	0.0015	0.3048	0.0005068
MV-01	0.3050	0.3045	0.3055	0.0010	0.3050	0.0005074
G-3071	0.3075	0.3070	0.3070	0.0005	0.3072	0.0005146
G-3072	0.3070	0.3070	0.3080	0.0010	0.3073	0.0005152
G-310	0.3090	0.3105	0.3095	0.0015	0.3097	0.0005230
G-316	0.3160	0.3160	0.3170	0.0010	0.3163	0.0005458
V-06	0.3200	0.3210	0.3210	0.0010	0.3207	0.0005608
G-337	0.3380	0.3365	0.3380	0.0015	0.3375	0.0006213
P-27	0.3387	0.3385	0.3390	0.0005	0.3387	0.0006258
I	0.3785	0.3785	0.3785	0.0000	0.3785	0.0007814
P-14	0.3910	0.3935	0.3920	0.0025	0.3922	0.0008388
C	0.4255	0.4225	0.4235	0.0030	0.4238	0.0009798
G-437	0.4350	0.4345	0.4355	0.0010	0.4350	0.0010321
G-468	0.4677	0.4670	0.4670	0.0007	0.4672	0.0011907
P-29	0.4680	0.4680	0.4690	0.0010	0.4683	0.0011963
P-7	0.4965	0.4940	0.4930	0.0035	0.4945	0.0013337
B	0.5015	0.5030	0.5025	0.0015	0.5023	0.0013763
G-540	0.5405	0.5400	0.5405	0.0005	0.5403	0.0015924

Where:

- (a) D1, D2, D3 = three different nozzle diameters; each diameter must be measured to within (0.025mm) 0.001 in.
- (b) Difference = maximum difference between any two diameters; must be less than or equal to (0.1mm) 0.004 in.
- (c) Average = average of D1, D2 and D3

Pitot Tube Calibration

Date: 29-Jun-20
Pbar (in.Hg): 29.69

Temp (R): 530
Dn (in.): 0.25

Pitot ID: **7A-1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.050	0.070	14.9	0.8367	0.0024
0.100	0.140	21.0	0.8367	0.0024
0.150	0.210	25.7	0.8367	0.0024
0.350	0.490	39.3	0.8367	0.0024
0.590	0.850	51.0	0.8248	0.0095
Average :			0.8343	0.0038

Pitot ID: **ST 8A**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.040	0.055	13.3	0.8443	0.0027
0.080	0.110	18.8	0.8443	0.0027
0.180	0.250	28.2	0.8400	0.0016
0.300	0.420	36.4	0.8367	0.0049
0.500	0.690	47.0	0.8427	0.0011
Average :			0.8416	0.0026

Pitot ID: **7B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.030	0.040	11.5	0.8574	0.0056
0.120	0.160	23.0	0.8574	0.0056
0.200	0.270	29.7	0.8521	0.0003
0.380	0.520	41.0	0.8463	0.0055
0.730	1.000	56.8	0.8459	0.0059
Average :			0.8518	0.0046

Pitot ID: **ST 8B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.060	0.080	16.3	0.8574	0.0039
0.090	0.120	19.9	0.8574	0.0039
0.190	0.260	29.0	0.8463	0.0072
0.320	0.430	37.6	0.8540	0.0006
0.630	0.850	52.8	0.8523	0.0012
Average :			0.8535	0.0033

Pitot ID: **AL GVRD 1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.060	0.085	16.3	0.8318	0.0011
0.090	0.125	19.9	0.8400	0.0072
0.145	0.200	25.3	0.8430	0.0101
0.290	0.420	35.8	0.8226	0.0102
0.530	0.760	48.4	0.8267	0.0061
Average :			0.8328	0.0069

Pitot ID: **ST 8C**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.050	0.070	14.9	0.8367	0.0053
0.085	0.120	19.4	0.8332	0.0018
0.190	0.270	29.0	0.8305	0.0009
0.420	0.600	43.1	0.8283	0.0031
0.630	0.900	52.8	0.8283	0.0031
Average :			0.8314	0.0028

Pitot ID: **7C**


Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.030	0.040	11.5	0.8574	0.0048
0.060	0.080	16.3	0.8574	0.0048
0.110	0.150	22.0	0.8478	0.0047
0.210	0.280	30.5	0.8574	0.0048
0.500	0.690	47.0	0.8427	0.0098
Average :			0.8525	0.0058

Pitot ID:

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
Average :				

* Average absolute deviation must not exceed 0.01.

Calibrated by: Michael Goods

Signature: 

Date:

June 29, 2020

BAROMETER CALIBRATION FORM

Device	Cal Date	Pbar Env Canada		Device (inches of Hg)		Difference
		(kPa)	(inches of Hg)	Reading	Elevation Corrected	(Env Can - Elv Corr)
LA	July 6, 2020	101.8	30.07	29.94	30.01	0.05
DS	July 6, 2020	101.8	30.07	29.94	30.01	0.05
CL	July 6, 2020	101.8	30.07	29.96	30.03	0.03
ML	July 6, 2020	101.8	30.07	29.92	29.99	0.07
SB	July 6, 2020	101.8	30.07	29.94	30.01	0.05
SH	July 6, 2020	101.8	30.07	29.95	30.02	0.04
JB	July 6, 2020	101.8	30.07	29.99	30.06	0.00
SF	July 6, 2020	101.8	30.07	29.92	29.99	0.07
JG	July 6, 2020	101.8	30.07	29.96	30.03	0.03

Calibrated by: Louis Agassiz Signature:  Date: July 6, 2020

Performance Specification is

Device Corrected for Elevation must be +/- 0.1 " Hg of ENV CANADA SEA-LEVEL Pbar

Enter Environment Canada Pressure from their website for Vancouver (link below) and the reading from your barometer on the ground floor of the office.

http://www.weatheroffice.gc.ca/city/pages/bc-74_metric_e.html

A. LANFRANCO and ASSOCIATES INC.
ENVIRONMENTAL CONSULTANTS

TEMPERATURE CALIBRATION FORM

Calibrated by: Scott Ferguson

Date: 6-Jul-20

Signature:



TEMPERATURE DEVICE CALIBRATIONS

Reference Device			Temperature Settings (degrees F)													
Model CL23A Calibrator			32		100		200		300		500		800		1700	
Device	ALA #	Serial #	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation
Omega HH11A	3	300132	33	0.20%	101	0.18%	200	0.00%	300	0.00%	499	-0.10%	800	0.00%	1700	0.00%
Omega HH11A	4	200167	33	0.20%	101	0.18%	200	0.00%	301	0.13%	500	0.00%	801	0.08%	1699	-0.05%
Omega HH11A	6	600059	32	0.00%	100	0.00%	199	-0.15%	299	-0.13%	501	0.10%	799	-0.08%	1699	-0.05%
TPI 341K	7	2.0315E+10	29.8	-0.45%	98	-0.36%	197	-0.45%	297	-0.39%	496.4	-0.38%	796	-0.32%	1693	-0.32%
TPI 341K	8	2.0313E+10	31	-0.20%	98	-0.36%	200	0.00%	300	0.00%	500	0.00%	800	0.00%	1697	-0.14%
Cont Cmpny	10	102008464	32	0.00%	99	-0.18%	199	-0.15%	299	-0.13%	498.6	-0.15%	796	-0.32%	1698	-0.09%
Omega HH11	14	409426	33	0.20%	100	0.00%	202	0.30%	302	0.26%	500	0.00%	799	-0.08%	1699	-0.05%
TPI 341K	16	400120029	32	0.00%	99	-0.18%	200	0.00%	301	0.13%	500	0.00%	800	0.00%	1700	0.00%
TPI 341K	18	2.0329E+10	32	0.00%	101	0.18%	200	0.00%	300	0.00%	501	0.10%	799	-0.08%	1699	-0.05%
TPI 341K	20	2.0329E+10	30	-0.41%	98	-0.36%	198	-0.30%	298	-0.26%	497.1	-0.30%	797	-0.24%	1695	-0.23%

Reference device is a NIST certified digital thermocouple calibrator

Variation expressed as a percentage of the absolute temperature must be within 1.5 %

Calibration Certificate

Date: 07-Jul-20
 Calibrated by: Louis Agassiz
 Authorizing Signature: 

Instrument Calibrated: Testo 1 (330-2LL)
 Serial #: 03101345
 Customer: ALA

Ambient Conditions: Temperature: 15 °C Barometric Pressure: 101.7 kPa Relative Humidity: 63%

A. Lanfranco and Associates Inc. certifies that the described instrument has been inspected and tested following calibration procedures in the Environment Canada Report EPS 1/PG/7 (Revised 2005). Below are the observed readings after calibrations are complete. Calibration checks should be completed at least every 6 months.

O ₂ Gas	Initial Evaluation				After Calibration				Certified Value (vol %)
	Instrument Reading (vol %)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (vol %)	% Calibration Error	Pass/Fail	Notes	
Zero	0.1	0.10	Pass		0	0.00	Pass		0
O ₂	11.2	0.23	Pass	Recal on Amb	11.0	0.03	Pass		10.97
Ambient	21.1	0.14	Pass		21.0	0.04	Pass		20.96

Performance Specification: +/- 1% O₂ (absolute diff)

CO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	1940	1.9%	Pass	Recal w 3 gas	1904	0.0%	Pass		1904
2 Gas	1950	1.9%	Pass		1910	0.2%	Pass		1914
3 Gas	470	4.9%	Pass		449	0.2%	Pass		448
4 Gas	258	2.7%	Pass		251	0.1%	Pass		251

Performance Specification: +/- 5% of Certified Gas Value

NO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	247	4.3%	Pass	Recal w 3 gas	258	0.0%	Pass		258
2 Gas	103	3.9%	Pass		99	0.1%	Pass		99.13
3 Gas	448	3.4%	Pass		465	0.2%	Pass		464
4 Gas	47.5	4.1%	Pass		46	0.9%	Pass		45.61

Performance Specification: +/- 5% of Certified Gas Value

NIST Traceable Calibration Gases:

Cylinder	Cylinder ID Number	Certification Date	Expiration Date	Cylinder Pressure (PSI)	O ₂ (Vol. %)	CO (ppm)	NO (ppm)
Zero Gas (N ₂)	340943	21-Jan-2020	20-Jan-2025	2150	0	0	0
1 Gas	CC320634	23-Mar-2018	23-Mar-2026	1420	-	1904	258
2 Gas	CC336011	24-Feb-2020	25-Feb-2028	1480	-	1914	99.13
3 Gas	CC222743	13-Jan-2017	13-Jan-2025	5400	-	448	464
4 Gas	CC14093	5-Aug-2019	6-Aug-2027	1850	-	251.3	45.61
O ₂ /CO ₂	CC28009	5-Dec-2018	5-Dec-2026	580	10.97	-	-

Note: National Institute of Standards and Technology traceable certificates are available upon request.



MOUNT ROYAL COLLEGE

Faculty of Continuing Education and Extension

Carter Lanfranco

has successfully completed

Stack Sampling

May 2009

Date

Dean
Faculty of Continuing Education and Extension

MOUNT ROYAL UNIVERSITY

Faculty of Continuing Education and Extension

Jeremy Shawn Gibbs

has successfully completed

Stack Sampling

35 Hours / 2019

May 22, 2019

Date

BSU
Dean

Faculty of Continuing Education and Extension



Walter Smith & Associates, Inc.


is hereby granted to:

Louis Agassiz

to certify that they have completed to satisfaction

Source Sampling & CEMS Workshop

Granted: March 11, 2011



Walter S. Smith

Walter S. Smith, PE, DEE 3.5 CEU