



**A.Lanfranco
& Associates Inc.**

Environmental Consultants

Prepared for
METRO VANCOUVER

Metrotower III 4730 Kingsway
Burnaby, BC V5H 0C6

The background of the cover features a photograph of a tall, cylindrical smokestack with alternating red and white horizontal bands. The smokestack is positioned on the right side of the frame, extending from the bottom towards the top. The sky is a clear blue with scattered white clouds. The entire image is overlaid with large, diagonal, semi-transparent blue geometric shapes that create a modern, architectural feel.

WASTE TO ENERGY FACILITY
Appendices of Compliance Emissions Testing Report
February 2019 Survey

Table of Contents

Appendix

- A Quality Assurance / Quality Control Results
- B Laboratory Results
- C Computer Generated Results
- D Field Data Sheets
- E Calibration Sheets and Technician Certificates

APPENDIX – A

QUALITY ASSURANCE / QUALITY CONTROL RESULTS

Quality assurance / quality control (QA/QC) is divided into four categories: administration, preparation, testing, and analysis. The following sections detail results found for the above four categories.

Administration:

- All field, process, and analytical data was reviewed to ensure data integrity and accuracy.
- Duplicate proof of draft and final report, including data entry, conducted.

Preparation:

- All glassware cleaned
- Blank samples of reagents collected.

Testing:

- Stack diameter and absence of cyclonic flow confirmed
- Calibrated magnehelic used for all velocity measurements
- All trains past pre- and post- leak checks.
- Isokinetics all within $100\% \pm 10\%$.

Analysis:

- Trace Metals and Mercury analysis conducted at Exova Labs, Surrey, B.C.
- Fluoride (HF) analysis conducted at ALS Environmental in Burnaby, B.C.
- Nitrous Oxide (N₂O) analysis conducted at Maxxam Analytics, Mississauga, Ont.
- Particulate analysis conducted at A. Lanfranco and Associates Inc., Surrey, BC.
- THC/VOC analysis conducted at ALS Environmental in Simi Valley, California
- Ammonium (for ammonia NH₃) conducted at Exova Labs, Surrey, B.C.
- Chain of Custody protocols followed for all samples.
- Excellent blank values for all sample types. All samples blank corrected.

Sample Type	Blank Value		
First Survey 2019	Unit 1	Unit 2	Unit 3
Filter	0.5 mg	0.9 mg	0.5 mg
Front Half Washings	-0.7 mg	-0.8 mg	-0.8 mg
Mercury Front	<0.02 ug	<0.02 ug	<0.02 ug
Mercury Back	<0.25 ug	<0.23 ug	<0.17 ug
Trace Metals Front *	<31.1 ug	<44.3 ug	<34.4 ug
Trace Metals Back*	<27.0 ug	<33.1 ug	<20.0 ug
Fluoride	<1.7 ug	<1.8 ug	<1.8 ug

Sum of all reported elements except Hg*

APPENDIX - B

LABORATORY RESULTS

Report Transmission Cover Page

Bill To:	A. Lanfranco & Associates	Project ID:		Lot ID:	1334427
	#101, 9488 - 189 Street	Project Name:	Metro Vancouver WTE	Control Number:	
	Surrey, BC, Canada	Project Location:	Reagent Blanks	Date Received:	Feb 21, 2019
	V4N 4W7	LSD:		Date Reported:	Mar 6, 2019
Attn:	Missy	P.O.:		Report Number:	2381208
Sampled By:		Proj. Acct. code:			
Company:					

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com

<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge Reports	PDF	COC / Test Report
Email - Multiple Reports By Agreement	PDF	COA
Email - Single Report	PDF	COR

Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential.
If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited.
If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Analytical Report

Bill To: A. Lanfranco & Associates	Project ID:	Lot ID: 1334427
#101, 9488 - 189 Street	Project Name: Metro Vancouver WTE	Control Number:
Surrey, BC, Canada	Project Location: Reagent Blanks	Date Received: Feb 21, 2019
V4N 4W7	LSD:	Date Reported: Mar 6, 2019
Attn: Missy	P.O.:	Report Number: 2381208
Sampled By:	Proj. Acct. code:	
Company:		

		Reference Number	1334427-1	1334427-2	1334427-3
		Sample Date	Feb 11, 2019	Feb 11, 2019	Feb 11, 2019
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Reagent Blank Unit 1	Reagent Blank Unit 2	Reagent Blank Unit 3
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	1	2	<1.0	5
Antimony	µg	<0.5	0.5	<0.5	2.5
Arsenic	µg	0.63	<0.2	0.4	1
Cadmium	µg	<0.05	<0.05	<0.05	0.25
Chromium	µg	0.12	0.19	<0.04	0.2
Cobalt	µg	0.2	0.1	0.1	0.25
Copper	µg	0.06	0.4	0.08	0.25
Lead	µg	<0.3	1.5	<0.3	1.5
Manganese	µg	0.06	0.1	<0.05	0.25
Nickel	µg	<0.1	11	<0.1	0.5
Phosphorus	µg	<0.5	<0.5	<0.5	2.5
Selenium	µg	<0.3	<0.3	<0.3	1.5
Tellurium	µg	<0.4	<0.4	<0.4	2
Thallium	µg	<0.3	<0.3	<0.3	1.5
Vanadium	µg	<0.2	<0.2	<0.2	1
Zinc	µg	<0.1	<0.1	<0.1	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	<5	8	10	5
Antimony	µg	<3	4	<2	2.5
Arsenic	µg	<1	<1	<1.0	1
Cadmium	µg	<0.3	<0.3	<0.2	0.25
Chromium	µg	<0.2	0.54	<0.2	0.2
Cobalt	µg	0.3	0.7	<0.2	0.25
Copper	µg	<0.3	<0.3	<0.2	0.25
Lead	µg	<2	2	<1	1.5
Manganese	µg	0.4	0.8	0.4	0.25
Nickel	µg	<0.5	<0.5	<0.5	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	<2	<2	<1	1.5
Tellurium	µg	2.7	4.1	3.5	2
Thallium	µg	<2	<2	6.2	1.5
Vanadium	µg	<1	<1	<1.0	1
Zinc	µg	<0.5	0.8	<0.5	0.5
Volume	Sample	mL	200	198	295
Volume	aliquot volume	mL	150	148	245
Mercury by CVAA					
Mercury	As Tested	µg/L	0.08	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	250	250	250

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID:
Project Name: Metro Vancouver WTE
Project Location: Reagent Blanks
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1334427**
Control Number:
Date Received: Feb 21, 2019
Date Reported: Mar 6, 2019
Report Number: 2381208

		Reference Number	1334427-1	1334427-2	1334427-3	
		Sample Date	Feb 11, 2019	Feb 11, 2019	Feb 11, 2019	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Reagent Blank Unit 1	Reagent Blank Unit 2	Reagent Blank Unit 3	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Mercury by CVAA - Continued						
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	0.03	<0.02	<0.02	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	200	198	295	
Volume	aliquot volume	mL	5	5	5	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	<0.08	<0.08	<0.1	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	98	100	98	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.008	<0.008	<0.008	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	250	257	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	0.06	8.58	3.74	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.02	3	1	

Approved by: 
Mathieu Simoneau
Operations Manager

Data have been validated by Analytical Quality Control and Exova's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7

Attn: Missy

Sampled By:

Company:

Project ID:
Project Name: Metro Vancouver WTE
Project Location: Reagent Blanks
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1334427**
Control Number:
Date Received: Feb 21, 2019
Date Reported: Mar 6, 2019
Report Number: 2381208

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (Surrey) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Feb 26, 2019	Exova Surrey
Mercury in Air (Surrey) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Feb 26, 2019	Exova Surrey
Mercury in Air (Surrey) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Feb 27, 2019	Exova Surrey
Mercury in Air (Surrey) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2019	Exova Surrey
Mercury in Air (Surrey) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Feb 28, 2019	Exova Surrey
Metals in Stack Samples - Back half (Surrey)	EMC	* Metals Emissions from Stationary Sources, 29	Feb 22, 2019	Exova Surrey
Metals in Stack Samples - Front half (Surrey)	EMC	* Metals Emissions from Stationary Sources, 29	Feb 22, 2019	Exova Surrey

** Reference Method Modified*

References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services Group or to the Operations Manager at the coordinates indicated at the top left of this page.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Exova



Testing
Advising
Assuring

Lot: 1334427 COC



Number

ation Sheet

er to proceed with analysis

Billing Address:

Company: A. Lanfranco and Associates
Address: Unit 101 9488 189 St
Surrey, BC V4N 4W7

QA/QC Report ☐

Attention: Mark Lanfranco
Phone: 604-881-2582
Fax: 604-881-2581
Cell:
e-mail: mark.lanfranco@alanfranco.com

Report Result:

Fax ☐
Mail ☐
Courier ☐
e-mail ☐
e-Service ☐

Copy of Report To:

Company:
Address:

Attention:
Phone:
Fax:
Cell:
e-mail:

Copy of invoice:

Mail invoice to this
address for approval ☐

Report Result:

Fax ☐
Mail ☐
Courier ☐
e-mail ☐
e-Service ☐

Information to be included on Report and Invoice

Project ID:
Project Name: Metro Vancouver WTE
Project Location: Reagent Blanks
Legal Location:
PO#:
Proj. Acct. Code:
Agreement ID:

RUSH Please contact the laboratory
to confirm rush dates and times
before submitting samples.

Upon filling out this section, client accepts that
surcharges will be attached to this analysis

RUSH All Analysis As indicated

required on: ☐ or ☐

Date Required: _____

Signature: _____

Exova Authorization: _____

Sample Custody (Please Print)

Sampled by:

Company Signature

I authorize Exova to proceed with the work
work indicated on this form:

Date: Initial:

Received by: Sample

Temp. 22.2°C

Waybill #: FEB 21 13 12 15 Date

Company Time

Special Instructions / Comments

*Front and Back ICAP as per EPA Method 29

*Hg analysis as per EPA Method 29

* Please report ug/sample

FOR LAB USE ONLY

Condition of containers/coolers
upon arrival at lab

Please indicate which regulations you are required to meet: _____

☐ Check here if Exova is required
to report results directly to a regulatory body
(Please include contact information)

☐ Check here if you are testing **POTABLE**
WATER for **HUMAN CONSUMPTION**

Number of Containers	Front ICAP	Back ICAP	Front Hg	Back Hg	5A Hg	5B Hg								

	Sample Identification	Location	Depth			Date/Time Sampled	Matrix	Sampling Method	↓	Enter tests above (✓ relevant samples below)																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
			IN	CM	M					✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
1	Reagent Blank Unit 1					11-Feb-19			5	✓	✓	✓	✓	✓	✓																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								

NOTE: All hazardous samples must be labelled according to WHIMIS guidelines.

Page ____ of ____

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Project Name: Metro Vancouver WTE Project Location: Filter Reagent Blanks LSD: P.O.: Proj. Acct. code:	Lot ID: 1334451 Control Number: Date Received: Feb 21, 2019 Date Reported: Feb 28, 2019 Report Number: 2381232
Attn: Missy Sampled By: Company:		

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com

Delivery	Format	Deliverables
Email - Merge Reports	PDF	COC / Test Report
Email - Multiple Reports By Agreement	PDF	COA
Email - Single Report	PDF	COR

Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential.
If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited.
If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID:
Project Name: Metro Vancouver WTE
Project Location: Filter Reagent Blanks
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1334451**
Control Number:
Date Received: Feb 21, 2019
Date Reported: Feb 28, 2019
Report Number: 2381232

		Reference Number	1334451-1	1334451-2	1334451-3
		Sample Date	Feb 11, 2019	Feb 11, 2019	Feb 11, 2019
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Reagent Blank Unit 1 Container 1 (filter)	Reagent Blank Unit 2 Container 1 (filter)	Reagent Blank Unit 3 Container 1 (filter)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	1	<1.0	1	5
Antimony	µg	<0.5	<0.5	<0.5	2.5
Arsenic	µg	<0.2	0.2	<0.2	1
Cadmium	µg	<0.05	<0.05	<0.05	0.25
Chromium	µg	0.085	<0.04	<0.04	0.2
Cobalt	µg	0.1	0.2	0.2	0.25
Copper	µg	<0.05	<0.05	<0.05	0.25
Lead	µg	<0.3	<0.3	<0.3	1.5
Manganese	µg	<0.05	<0.05	<0.05	0.25
Nickel	µg	<0.1	<0.1	<0.1	0.5
Phosphorus	µg	25	24	25	2.5
Selenium	µg	1.2	<0.3	<0.3	1.5
Tellurium	µg	<0.4	<0.4	<0.4	2
Thallium	µg	<0.3	<0.3	<0.3	1.5
Vanadium	µg	<0.2	<0.2	<0.2	1
Zinc	µg	<0.1	<0.1	0.3	0.5
Mercury by CVAA					
Mercury	As Tested	µg/L	<0.05	0.33	0.68
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	200	200	200
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	0.1	0.2

Approved by: 
Mathieu Simoneau
Operations Manager

Methodology and Notes

Bill To:	A. Lanfranco & Associates	Project ID:		Lot ID:	1334451
	#101, 9488 - 189 Street	Project Name:	Metro Vancouver WTE	Control Number:	
	Surrey, BC, Canada	Project Location:	Filter Reagent Blanks	Date Received:	Feb 21, 2019
	V4N 4W7	LSD:		Date Reported:	Feb 28, 2019
Attn:	Missy	P.O.:		Report Number:	2381232
Sampled By:		Proj. Acct. code:			
Company:					

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (Surrey) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Feb 26, 2019	Exova Surrey
Metals in Stack Samples - Front half (Surrey)	EMC	* Metals Emissions from Stationary Sources, 29	Feb 22, 2019	Exova Surrey
* Reference Method Modified				

References

EMC	Emission Measurement Center of EPA
-----	------------------------------------

Please direct any inquiries regarding this report to our Client Services Group or to the Operations Manager at the coordinates indicated at the top left of this page.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Report Transmission Cover Page

Bill To:	A. Lanfranco & Associates	Project ID:		Lot ID:	1334447
	#101, 9488 - 189 Street	Project Name:	Metro Vancouver WTE	Control Number:	
	Surrey, BC, Canada	Project Location:	Field Blanks	Date Received:	Feb 21, 2019
	V4N 4W7	LSD:		Date Reported:	Mar 6, 2019
Attn:	Missy	P.O.:		Report Number:	2381229
Sampled By:		Proj. Acct. code:			
Company:					

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com

<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge Reports	PDF	COC / Test Report
Email - Multiple Reports By Agreement	PDF	COA
Email - Single Report	PDF	COR

Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential.
If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited.
If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID:
Project Name: Metro Vancouver WTE
Project Location: Field Blanks
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1334447**
Control Number:
Date Received: Feb 21, 2019
Date Reported: Mar 6, 2019
Report Number: 2381229

		Reference Number	1334447-1	1334447-2	1334447-3
		Sample Date	Feb 13, 2019	Feb 14, 2019	Feb 15, 2019
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Field Blank Unit 1 (Beaker (MV Unit 1 Blank) + 4 Bottles)	Field Blank Unit 2 (Beaker (MV Unit 2 Blank) + 4 Bottles)	Field Blank Unit 3 (Beaker (MV Unit 3 Blank) + 4 Bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	2	14	2	5
Antimony	µg	<0.5	<0.5	<0.5	2.5
Arsenic	µg	<0.2	0.3	0.3	1
Cadmium	µg	<0.05	<0.05	<0.05	0.25
Chromium	µg	0.098	<0.04	0.05	0.2
Cobalt	µg	0.06	0.1	<0.05	0.25
Copper	µg	<0.05	<0.05	<0.05	0.25
Lead	µg	<0.3	<0.3	<0.3	1.5
Manganese	µg	<0.05	0.05	<0.05	0.25
Nickel	µg	<0.1	<0.1	<0.1	0.5
Phosphorus	µg	29	30	32	2.5
Selenium	µg	<0.3	<0.3	<0.3	1.5
Tellurium	µg	<0.4	<0.4	<0.4	2
Thallium	µg	<0.3	<0.3	<0.3	1.5
Vanadium	µg	<0.2	<0.2	<0.2	1
Zinc	µg	0.2	0.2	0.2	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	7	9	<5	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<1.0	3.5	<1.0	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	<0.2	0.62	<0.2	0.2
Cobalt	µg	0.3	<0.2	<0.2	0.25
Copper	µg	<0.2	<0.2	<0.2	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	0.4	0.8	0.4	0.25
Nickel	µg	<0.5	<0.5	<0.5	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	2	<1	1	1.5
Tellurium	µg	2.6	6.0	3.5	2
Thallium	µg	3.1	1	2	1.5
Vanadium	µg	<1.0	<1.0	<1.0	1
Zinc	µg	<0.5	<0.5	<0.5	0.5
Volume	Sample	mL	285	280	282
Volume	aliquot volume	mL	235	230	232
Mercury by CVAA					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID:
Project Name: Metro Vancouver WTE
Project Location: Field Blanks
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1334447**
Control Number:
Date Received: Feb 21, 2019
Date Reported: Mar 6, 2019
Report Number: 2381229

		Reference Number	1334447-1	1334447-2	1334447-3	
		Sample Date	Feb 13, 2019	Feb 14, 2019	Feb 15, 2019	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Field Blank Unit 1 (Beaker (MV Unit 1 Blank) + 4 Bottles)	Field Blank Unit 2 (Beaker (MV Unit 2 Blank) + 4 Bottles)	Field Blank Unit 3 (Beaker (MV Unit 3 Blank) + 4 Bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Mercury by CVAA - Continued						
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	285	280	282	
Volume	aliquot volume	mL	5	5	5	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	<0.1	<0.1	<0.1	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	164	164	126	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.01	<0.01	<0.01	
Mercury	As Tested	µg/L	<0.05	0.18	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	500	500	500	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.04	0.1	<0.04	
Mercury	As Tested	µg/L	0.36	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.1	<0.02	<0.02	

Approved by: 
Mathieu Simoneau

Operations Manager

Data have been validated by Analytical Quality Control and Exova's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To:	A. Lanfranco & Associates	Project ID:		Lot ID:	1334447
	#101, 9488 - 189 Street	Project Name:	Metro Vancouver WTE	Control Number:	
	Surrey, BC, Canada	Project Location:	Field Blanks	Date Received:	Feb 21, 2019
	V4N 4W7	LSD:		Date Reported:	Mar 6, 2019
Attn:	Missy	P.O.:		Report Number:	2381229
Sampled By:		Proj. Acct. code:			
Company:					

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (Surrey) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Feb 26, 2019	Exova Surrey
Mercury in Air (Surrey) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Feb 26, 2019	Exova Surrey
Mercury in Air (Surrey) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Feb 27, 2019	Exova Surrey
Mercury in Air (Surrey) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2019	Exova Surrey
Mercury in Air (Surrey) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Feb 28, 2019	Exova Surrey
Metals in Stack Samples - Back half (Surrey)	EMC	* Metals Emissions from Stationary Sources, 29	Feb 22, 2019	Exova Surrey
Metals in Stack Samples - Front half (Surrey)	EMC	* Metals Emissions from Stationary Sources, 29	Feb 22, 2019	Exova Surrey

** Reference Method Modified*

References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services Group or to the Operations Manager at the coordinates indicated at the top left of this page.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Exova



Testi
Adv
Assl

Lot: 1334447 ^{COC}



Number

Information Sheet

Order to proceed with analysis

Billing Address: Company: A. Lanfranco and Associates Address: Unit 101 9488 189 St Surrey, BC V4N 4W7 Attention: Mark Lanfranco Phone: 604-881-2582 Fax: 604-881-2581 Cell: e-mail: mark.lanfranco@alanfranco.com		Copy of Report To: Company: Address: Attention: Phone: Fax: Cell: e-mail:	Copy of invoice: Mail invoice to this address for approval Report Result: Fax Mail Courier e-mail e-Service
QA/QC Report ☐			

Information to be included on Report and Invoice

Project ID:
 Project Name: Metro Vancouver WTE
 Project Location: Field Blanks
 Legal Location:
 PO#:
 Proj. Acct. Code:
 Agreement ID:

RUSH Please contact the laboratory to confirm rush dates and times before submitting samples.

Upon filling out this section, client accepts that surcharges will be attached to this analysis
 RUSH required on: ☐ All Analysis ☐ or ☐ As indicated
 Date Required: _____
 Signature: _____
 Exova Authorization: _____

Sample Custody (Please Print)
 Sampled by: _____
 Company _____ Signature _____
 I authorize Exova to proceed with the work work indicated on this form:
 Date: _____ Initial: _____
 Received by: _____ Sample Temp. **22.2°C**
 Waybill #: **EB 21 '18 12** Date _____
 Company _____ Time _____

Special Instructions / Comments

- *Front and Back ICAP as per EPA Method 29
- *Hg analysis as per EPA Method 29
- * Please report ug/sample

FOR LAB USE ONLY

Condition of containers/coolers upon arrival at lab

☐ Check here if Exova is required to report results directly to a regulatory body (Please include contact information)
☐ Check here if you are testing **POTABLE WATER** for **HUMAN CONSUMPTION**

Number of Containers	Front ICAP	Back ICAP	Front Hg	Back Hg	5A Hg	5B Hg						
5	✓	✓	✓	✓	✓	✓						

Please indicate which regulations you are required to meet: _____

	Sample Identification	Location	Depth			Date/Time Sampled	Matrix	Sampling Method	↓	Enter tests above (✓ relevant samples below)											
			IN	CM	M																
1	Field Blank Unit 1 (Beaker (MV Unit-1 Blank)+ 4 Bottles)					13-Feb-19			5	✓	✓	✓	✓	✓	✓						
2																					
3	Field Blank Unit 2 (Beaker (MV Unit 2 Blank) + 4 Bottles)					14-Feb-19			5	✓	✓	✓	✓	✓	✓						
4																					
5	Field Blank Unit 3 (Beaker (MV Unit 3 Blank) + 4 Bottles)					15-Feb-19			5	✓	✓	✓	✓	✓	✓						
6																					
7																					
8																					
9																					
10																					
11																					
12																					
13																					
14																					
15																					

NOTE: All hazardous samples must be labelled according to WHIMIS guidelines.

Page ____ of ____

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Project Name: Metro Vancouver WTE Project Location: Metals and Hg LSD: P.O.: Proj. Acct. code:	Lot ID: 1334430 Control Number: Date Received: Feb 21, 2019 Date Reported: Mar 6, 2019 Report Number: 2381210
Attn: Missy Sampled By: Company:		

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com

Delivery	Format	Deliverables
Email - Merge Reports	PDF	COC / Test Report
Email - Multiple Reports By Agreement	PDF	COA
Email - Single Report	PDF	COR

Notes To Clients:

- Feb 28, 2019 - Sample 1334430-4; 6502397: Reduction of analytical volume was necessary for mercury analysis to bring results within the analytical range for sample. Detection limits are adjusted accordingly.

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID:
Project Name: Metro Vancouver WTE
Project Location: Metals and Hg
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1334430**
Control Number:
Date Received: Feb 21, 2019
Date Reported: Mar 6, 2019
Report Number: 2381210

		Reference Number	1334430-1	1334430-2	1334430-3
		Sample Date	Feb 11, 2019	Feb 13, 2019	Feb 13, 2019
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit 1 Run 1 (beaker (MV Unit 1 R-1) + 4 bottles)	Unit 1 Run 2 (beaker (MV Unit 1 R-2) + 4 bottles)	Unit 1 Run 3 (beaker (MV Unit 1 R-3) + 4 bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	6.9	7.7	3	5
Antimony	µg	<0.5	0.6	0.6	2.5
Arsenic	µg	<0.2	0.4	<0.2	1
Cadmium	µg	0.06	0.06	<0.05	0.25
Chromium	µg	0.32	0.17	0.50	0.2
Cobalt	µg	0.2	0.05	0.2	0.25
Copper	µg	0.53	0.3	0.1	0.25
Lead	µg	3.4	0.4	0.5	1.5
Manganese	µg	0.4	0.3	0.2	0.25
Nickel	µg	0.3	0.2	0.71	0.5
Phosphorus	µg	34	28	29	2.5
Selenium	µg	<0.3	<0.3	<0.3	1.5
Tellurium	µg	<0.4	<0.4	<0.4	2
Thallium	µg	<0.3	<0.3	<0.3	1.5
Vanadium	µg	<0.2	<0.2	<0.2	1
Zinc	µg	6.0	5.6	3.9	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	39	20	9	5
Antimony	µg	2	<2	3	2.5
Arsenic	µg	<0.9	<0.9	<0.9	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	0.59	0.98	0.61	0.2
Cobalt	µg	0.5	<0.2	0.3	0.25
Copper	µg	0.8	<0.2	<0.2	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	11	1	1	0.25
Nickel	µg	<0.4	0.5	<0.4	0.5
Phosphorus	µg	25	23	20	2.5
Selenium	µg	6.6	<1	<1	1.5
Tellurium	µg	2	3.5	2.9	2
Thallium	µg	<1	2	<1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	4.0	9.3	2	0.5
Volume	Sample	mL	722	685	710
Volume	aliquot volume	mL	672	635	660
Mercury by CVAA					
Mercury	As Tested	µg/L	0.55	0.44	0.17
					0.05

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID:
Project Name: Metro Vancouver WTE
Project Location: Metals and Hg
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1334430**
Control Number:
Date Received: Feb 21, 2019
Date Reported: Mar 6, 2019
Report Number: 2381210

		Reference Number	1334430-1	1334430-2	1334430-3		
		Sample Date	Feb 11, 2019	Feb 13, 2019	Feb 13, 2019		
		Sample Time	NA	NA	NA		
		Sample Location					
		Sample Description	Unit 1 Run 1 (beaker (MV Unit 1 R-1) + 4 bottles)	Unit 1 Run 2 (beaker (MV Unit 1 R-2) + 4 bottles)	Unit 1 Run 3 (beaker (MV Unit 1 R-3) + 4 bottles)		
		Matrix	Stack Samples	Stack Samples	Stack Samples		
Analyte		Units	Results	Results	Results	Nominal Detection Limit	
Mercury by CVAA - Continued							
Dilution Factor	As Tested		1	1	1		
Volume	Sample	mL	250	250	250		
Volume	aliquot volume	mL	25	25	25		
Volume	Final	mL	40	40	40		
Mercury	Fraction 1B	µg/sample	0.2	0.2	0.07		
Mercury	As Tested	µg/L	1.26	1.12	0.50	0.05	
Dilution Factor	As Tested		1	1	1		
Volume	Sample	mL	722	685	710		
Volume	aliquot volume	mL	5	5	5		
Volume	Final	mL	40	40	40		
Mercury	Fraction 2B	µg/sample	7	6	3		
Mercury	As Tested	µg/L	0.48	1.80	0.34	0.05	
Dilution Factor	As Tested		1	1	1		
Volume	Sample	mL	180	122	140		
Volume	aliquot volume	mL	25	25	25		
Volume	Final	mL	40	40	40		
Mercury	Fraction 3A	µg/sample	0.1	0.4	0.08		
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05	
Dilution Factor	As Tested		1	1	1		
Volume	Sample	mL	1000	1000	1000		
Volume	aliquot volume	mL	25	25	25		
Volume	Final	mL	40	40	40		
Mercury	Fraction 3B	µg/sample	<0.08	<0.08	<0.08		
Mercury	As Tested	µg/L	1.48	2.27	0.52	0.05	
Dilution Factor	As Tested		1	1	1		
Volume	Sample	mL	200	200	200		
Volume	aliquot volume	mL	25	25	25		
Volume	Final	mL	40	40	40		
Mercury	Fraction 3C	µg/sample	0.5	0.7	0.2		

Analytical Report

Bill To: A. Lanfranco & Associates	Project ID:	Lot ID: 1334430
#101, 9488 - 189 Street	Project Name: Metro Vancouver WTE	Control Number:
Surrey, BC, Canada	Project Location: Metals and Hg	Date Received: Feb 21, 2019
V4N 4W7	LSD:	Date Reported: Mar 6, 2019
Attn: Missy	P.O.:	Report Number: 2381210
Sampled By:	Proj. Acct. code:	
Company:		

		Reference Number	1334430-4	1334430-5	1334430-6
		Sample Date	Feb 13, 2019	Feb 14, 2019	Feb 14, 2019
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit 2 Run 1 (beaker (MV Unit 2 R-1) + 4 bottles)	Unit 2 Run 2 (beaker (MV Unit 2 R-2) + 4 bottles)	Unit 2 Run 3 (beaker (MV Unit 2 R-3) + 4 bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	2	2	4	5
Antimony	µg	<0.5	<0.5	<0.5	2.5
Arsenic	µg	0.58	<0.2	<0.2	1
Cadmium	µg	<0.05	0.05	<0.05	0.25
Chromium	µg	0.46	0.36	0.39	0.2
Cobalt	µg	0.2	0.08	0.1	0.25
Copper	µg	0.09	<0.05	0.1	0.25
Lead	µg	<0.3	<0.3	<0.3	1.5
Manganese	µg	0.1	0.2	0.4	0.25
Nickel	µg	0.4	0.50	1.2	0.5
Phosphorus	µg	31	31	31	2.5
Selenium	µg	<0.3	<0.3	<0.3	1.5
Tellurium	µg	<0.4	<0.4	<0.4	2
Thallium	µg	<0.3	<0.3	<0.3	1.5
Vanadium	µg	<0.2	<0.2	<0.2	1
Zinc	µg	1.1	1.1	3.6	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	44	10	20	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<0.9	<0.9	<0.9	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	2.44	0.78	0.88	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	<0.2	<0.2	1	0.25
Lead	µg	2	1	<1	1.5
Manganese	µg	14	1	5.4	0.25
Nickel	µg	1	<0.4	<0.4	0.5
Phosphorus	µg	20	20	23	2.5
Selenium	µg	<1	<1	<1	1.5
Tellurium	µg	6.3	2	2.2	2
Thallium	µg	<1	<1	6.1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	15	2.1	10	0.5
Volume	Sample	mL	735	740	835
Volume	aliquot volume	mL	685	690	785
Mercury by CVAA					
Mercury	As Tested	µg/L	0.08	0.13	0.18
					0.05

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID:
Project Name: Metro Vancouver WTE
Project Location: Metals and Hg
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1334430**
Control Number:
Date Received: Feb 21, 2019
Date Reported: Mar 6, 2019
Report Number: 2381210

		Reference Number	1334430-4	1334430-5	1334430-6		
		Sample Date	Feb 13, 2019	Feb 14, 2019	Feb 14, 2019		
		Sample Time	NA	NA	NA		
		Sample Location					
		Sample Description	Unit 2 Run 1 (beaker (MV Unit 2 R-1) + 4 bottles)	Unit 2 Run 2 (beaker (MV Unit 2 R-2) + 4 bottles)	Unit 2 Run 3 (beaker (MV Unit 2 R-3) + 4 bottles)		
		Matrix	Stack Samples	Stack Samples	Stack Samples		
Analyte		Units	Results	Results	Results	Nominal Detection Limit	
Mercury by CVAA - Continued							
Dilution Factor	As Tested		1	1	1		
Volume	Sample	mL	250	250	250		
Volume	aliquot volume	mL	25	25	25		
Volume	Final	mL	40	40	40		
Mercury	Fraction 1B	µg/sample	0.03	0.05	0.07		
Mercury	As Tested	µg/L	1.20	0.46	0.41	0.05	
Dilution Factor	As Tested		1	1	1		
Volume	Sample	mL	735	740	835		
Volume	aliquot volume	mL	5	5	5		
Volume	Final	mL	40	40	40		
Mercury	Fraction 2B	µg/sample	7	3	3		
Mercury	As Tested	µg/L	73.5	0.21	1.09	0.05	
Dilution Factor	As Tested		1	1	1		
Volume	Sample	mL	152	190	158		
Volume	aliquot volume	mL	25	25	25		
Volume	Final	mL	40	40	40		
Mercury	Fraction 3A	µg/sample	2	0.06	0.3		
Mercury	As Tested	µg/L	0.05	<0.05	<0.05	0.05	
Dilution Factor	As Tested		1	1	1		
Volume	Sample	mL	1000	1000	1000		
Volume	aliquot volume	mL	25	25	25		
Volume	Final	mL	40	40	40		
Mercury	Fraction 3B	µg/sample	0.08	<0.08	<0.08		
Mercury	As Tested	µg/L	17.9	0.24	<0.05	0.05	
Dilution Factor	As Tested		1	1	1		
Volume	Sample	mL	200	200	200		
Volume	aliquot volume	mL	25	25	25		
Volume	Final	mL	40	40	40		
Mercury	Fraction 3C	µg/sample	0.6	0.08	<0.02		

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID:
Project Name: Metro Vancouver WTE
Project Location: Metals and Hg
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1334430**
Control Number:
Date Received: Feb 21, 2019
Date Reported: Mar 6, 2019
Report Number: 2381210

		Reference Number	1334430-7	1334430-8	1334430-9
		Sample Date	Feb 14, 2019	Feb 15, 2019	Feb 15, 2019
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit 3 Run 1 (beaker (MV Unit 3 R-1) + 4 bottles)	Unit 3 Run 2 (beaker (MV Unit 3 R-2) + 4 bottles)	Unit 3 Run 3 (beaker (MV Unit 3 R-3) + 4 bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	6.6	2	3	5
Antimony	µg	<0.5	<0.5	0.5	2.5
Arsenic	µg	<0.2	<0.2	0.4	1
Cadmium	µg	<0.05	<0.05	0.05	0.25
Chromium	µg	0.51	0.24	0.23	0.2
Cobalt	µg	0.10	0.1	0.1	0.25
Copper	µg	0.08	0.2	0.2	0.25
Lead	µg	<0.3	<0.3	<0.3	1.5
Manganese	µg	0.2	0.1	0.2	0.25
Nickel	µg	0.4	0.2	0.4	0.5
Phosphorus	µg	34	28	35	2.5
Selenium	µg	<0.3	0.3	0.3	1.5
Tellurium	µg	<0.4	<0.4	<0.4	2
Thallium	µg	<0.3	<0.3	<0.3	1.5
Vanadium	µg	<0.2	<0.2	<0.2	1
Zinc	µg	2.3	1.4	1.4	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	10	20	20	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<0.9	<0.9	2	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	0.42	<0.2	0.50	0.2
Cobalt	µg	<0.2	0.3	<0.2	0.25
Copper	µg	<0.2	2.7	<0.2	0.25
Lead	µg	<1	2.2	2.3	1.5
Manganese	µg	0.8	1	6.0	0.25
Nickel	µg	<0.4	5.0	0.9	0.5
Phosphorus	µg	20	20	24	2.5
Selenium	µg	<1	<1	<1	1.5
Tellurium	µg	3.2	3.6	4.1	2
Thallium	µg	<1	2	2	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	3.8	8.5	5.3	0.5
Volume	Sample	mL	840	755	820
Volume	aliquot volume	mL	790	705	770
Mercury by CVAA					
Mercury	As Tested	µg/L	0.23	0.06	<0.05

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID:
Project Name: Metro Vancouver WTE
Project Location: Metals and Hg
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1334430**
Control Number:
Date Received: Feb 21, 2019
Date Reported: Mar 6, 2019
Report Number: 2381210

		Reference Number	1334430-7	1334430-8	1334430-9	Nominal Detection Limit
		Sample Date	Feb 14, 2019	Feb 15, 2019	Feb 15, 2019	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 3 Run 1 (beaker (MV Unit 3 R-1) + 4 bottles)	Unit 3 Run 2 (beaker (MV Unit 3 R-2) + 4 bottles)	Unit 3 Run 3 (beaker (MV Unit 3 R-3) + 4 bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results		
Mercury by CVAA - Continued						
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	0.09	0.02	<0.02	
Mercury	As Tested	µg/L	0.94	1.12	0.47	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	740	755	820	
Volume	aliquot volume	mL	5	5	5	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	6	7	3	
Mercury	As Tested	µg/L	0.20	0.23	0.90	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	172	178	188	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	0.06	0.07	0.3	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	1000	1000	1000	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.08	<0.08	<0.08	
Mercury	As Tested	µg/L	0.24	0.51	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.08	0.2	<0.02	

Approved by: 

Mathieu Simoneau
Operations Manager

Data have been validated by Analytical Quality Control and Exova's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To:	A. Lanfranco & Associates	Project ID:		Lot ID:	1334430
	#101, 9488 - 189 Street	Project Name:	Metro Vancouver WTE	Control Number:	
	Surrey, BC, Canada	Project Location:	Metals and Hg	Date Received:	Feb 21, 2019
	V4N 4W7	LSD:		Date Reported:	Mar 6, 2019
Attn:	Missy	P.O.:		Report Number:	2381210
Sampled By:		Proj. Acct. code:			
Company:					

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (Surrey) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Feb 26, 2019	Exova Surrey
Mercury in Air (Surrey) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Feb 26, 2019	Exova Surrey
Mercury in Air (Surrey) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Feb 27, 2019	Exova Surrey
Mercury in Air (Surrey) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2019	Exova Surrey
Mercury in Air (Surrey) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Feb 28, 2019	Exova Surrey
Metals in Stack Samples - Back half (Surrey)	EMC	* Metals Emissions from Stationary Sources, 29	Feb 22, 2019	Exova Surrey
Metals in Stack Samples - Front half (Surrey)	EMC	* Metals Emissions from Stationary Sources, 29	Feb 22, 2019	Exova Surrey

** Reference Method Modified*

References

EMC Emission Measurement Center of EPA

Comments:

- Feb 28, 2019 - Sample 1334430-4; 6502397: Reduction of analytical volume was necessary for mercury analysis to bring results within the analytical range for sample. Detection limits are adjusted accordingly.

Please direct any inquiries regarding this report to our Client Services Group or to the Operations Manager at the coordinates indicated at the top left of this page.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Exova



Testing
Advising
Assuring

Lot: 1334430 COC

Number



Information Sheet

to proceed with analysis

Billing Address: Company: A. Lanfranco and Associates Address: Unit 101 9488 189 St Surrey, BC V4N 4W7 Attention: Mark Lanfranco Phone: 604-881-2582 Fax: 604-881-2581 Cell: e-mail: mark.lanfranco@alanfranco.com		Copy of Report To: Company: Address: Attention: Phone: Fax: Cell: e-mail:	Copy of invoice: Mail invoice to this address for approval ☐ Report Result: Fax ☐ Mail ☐ Courier ☐ e-mail ☐ e-Service ☐
--	--	---	---

Information to be included on Report and Invoice Project ID: Project Name: Metro Vancouver WTE Project Location: Metals and Hg Legal Location: PO#: Proj. Acct. Code: Agreement ID:	RUSH Please contact the laboratory to confirm rush dates and times before submitting samples. Upon filling out this section, client accepts that surcharges will be attached to this analysis RUSH required on: ☐ All Analysis ☐ or ☐ As indicated Date Required: _____ Signature: _____ Exova Authorization: _____	Sample Custody (Please Print) Sampled by: _____ Company _____ Signature _____ I authorize Exova to proceed with the work work indicated on this form: Date: _____ Initial: _____ Received by: _____ Sample Temp. 22.2°C Waybill #: _____ Date: _____ Company _____ Time: _____
---	--	--

Special Instructions / Comments *Front and Back ICAP as per EPA Method 29 *Hg analysis as per EPA Method 29 * Please report ug/sample Please indicate which regulations you are required to meet: _____	FOR LAB USE ONLY Condition of containers/coolers upon arrival at lab	☐ Check here if Exova is required to report results directly to a regulatory body (Please include contact information) ☐ Check here if you are testing <u>POTABLE</u> WATER for <u>HUMAN CONSUMPTION</u>
--	--	---

	Sample Identification	Location	Depth			Date/Time Sampled	Matrix	Sampling Method	Number of Containers	Enter tests above (✓ relevant samples below)											
			IN	CM	M					Front ICAP	Back ICAP	Front Hg	Back Hg	5A Hg	5B Hg						
1	Unit 1 Run 1 (Beaker (MV Unit 1 R-1) + 4 Bottles)					11-Feb-18			5	✓	✓	✓	✓	✓	✓						
2	Unit 1 Run 2 (Beaker (MV Unit 1 R-2) + 4 Bottles)					13-Feb-19			5	✓	✓	✓	✓	✓	✓						
3	Unit 1 Run 3 (Beaker (MV Unit 1 R-3) + 4 Bottles)					13-Feb-19			5	✓	✓	✓	✓	✓	✓						
4																					
5	Unit 2 Run 1 (Beaker (MV Unit 2 R-1) + 4 Bottles)					13-Feb-19			5	✓	✓	✓	✓	✓	✓						
6	Unit 2 Run 2 (Beaker (MV Unit 2 R-2) + 4 Bottles)					14-Feb-19			5	✓	✓	✓	✓	✓	✓						
7	Unit 2 Run 3 (Beaker (MV Unit 2 R-3) + 4 Bottles)					14-Feb-19			5	✓	✓	✓	✓	✓	✓						
8																					
9	Unit 3 Run 1 Beaker (MV Unit 3 R-1) + 4 Bottles)					14-Feb-19			5	✓	✓	✓	✓	✓	✓						
10	Unit 3 Run 2 Beaker (MV Unit 3 R-2) + 4 Bottles)					15-Feb-19			5	✓	✓	✓	✓	✓	✓						
11	Unit 3 Run 3 Beaker (MV Unit 3 R-3) + 4 Bottles)					15-Feb-19			5	✓	✓	✓	✓	✓	✓						
12																					
13																					
14																					
15																					



A. Lanfranco & Associates Inc.
ATTN: Mark Lanfranco
Unit # 101 9488 - 189 St.
Surrey BC V4N 4W7

Date Received: 19-FEB-19
Report Date: 26-FEB-19 12:10 (MT)
Version: FINAL

Client Phone: 604-881-2582

Certificate of Analysis

Lab Work Order #: L2234202

Project P.O. #: HF

Job Reference: METRO VANCOUVER WTE

C of C Numbers:

Legal Site Desc:

Brent Mack, B.Sc.
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700
ALS CANADA LTD Part of the ALS Group An ALS Limited Company

		Sample ID Description Sampled Date Sampled Time Client ID	L2234202-1 Water 13-FEB-19 UNIT 1 HF BLANK	L2234202-2 Water 14-FEB-19 UNIT 2 HF BLANK	L2234202-3 Water 15-FEB-19 UNIT 3 HF BLANK		
Grouping	Analyte						
STACK							
Anions and Nutrients	Fluoride (F) (ug/sample)	<1.7	<1.8	<1.8			
	Volume (Anions) (mL)	170	175	175			

Reference Information

Test Method References:

ALS Test Code	Matrix	Test Description	Method Reference**
F-IMP-UG-VA	Stack	Fluoride in Water from Impinger	EPA 300.1 (mod)
Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.			

** ALS test methods may incorporate modifications from specified reference methods to improve performance.

The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:

Laboratory Definition Code	Laboratory Location
VA	ALS ENVIRONMENTAL - VANCOUVER, BRITISH COLUMBIA, CANADA

Chain of Custody Numbers:

GLOSSARY OF REPORT TERMS

Surrogate - A compound that is similar in behaviour to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

mg/kg - milligrams per kilogram based on dry weight of sample.

mg/kg ww - milligrams per kilogram based on wet weight of sample.

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight of sample.

mg/L - milligrams per litre.

< - Less than.

D.L. - The reported Detection Limit, also known as the Limit of Reporting (LOR).

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.



www.alsglobal.com

Page 1 of

GENF 20.00 Front



A. Lanfranco & Associates Inc.
ATTN: Mark Lanfranco
Unit # 101 9488 - 189 St.
Surrey BC V4N 4W7

Date Received: 19-FEB-19
Report Date: 26-FEB-19 12:09 (MT)
Version: FINAL

Client Phone: 604-881-2582

Certificate of Analysis

Lab Work Order #: L2234201

Project P.O. #: HF

Job Reference: METRO VANCOUVER WTE

C of C Numbers:

Legal Site Desc:

Brent Mack, B.Sc.
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700
ALS CANADA LTD Part of the ALS Group An ALS Limited Company

* Please refer to the Reference Information section for an explanation of any qualifiers detected.

ALS ENVIRONMENTAL ANALYTICAL REPORT

Sample ID Description Sampled Date Sampled Time Client ID		L2234201-6 Water 14-FEB-19 UNIT 2 HF RUN 3	L2234201-7 Water 15-FEB-19 UNIT 3 HF RUN 1	L2234201-8 Water 15-FEB-19 UNIT 3 HF RUN 2	L2234201-9 Water 15-FEB-19 UNIT 3 HF RUN 3	
Grouping	Analyte					
STACK						
Anions and Nutrients	Fluoride (F) (ug/sample)	8.7	<34 ^{DLDS}	<18 ^{DLDS}	<33 ^{DLDS}	
	Volume (Anions) (mL)	325	335	365	330	

* Please refer to the Reference Information section for an explanation of any qualifiers detected.

Reference Information

Qualifiers for Individual Parameters Listed:

Qualifier	Description
DLDS	Detection Limit Raised: Dilution required due to high Dissolved Solids / Electrical Conductivity.

Test Method References:

ALS Test Code	Matrix	Test Description	Method Reference**
F-IMP-UG-VA	Stack	Fluoride in Water from Impinger	EPA 300.1 (mod)
Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.			

** ALS test methods may incorporate modifications from specified reference methods to improve performance.

The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:

Laboratory Definition Code	Laboratory Location
VA	ALS ENVIRONMENTAL - VANCOUVER, BRITISH COLUMBIA, CANADA

Chain of Custody Numbers:

GLOSSARY OF REPORT TERMS

Surrogate - A compound that is similar in behaviour to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

mg/kg - milligrams per kilogram based on dry weight of sample.

mg/kg ww - milligrams per kilogram based on wet weight of sample.

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight of sample.

mg/L - milligrams per litre.

< - Less than.

D.L. - The reported Detection Limit, also known as the Limit of Reporting (LOR).

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.



L2234201-COFC

Chain of Custody / Analytical Request Form

Canada Toll Free: 1 800 668 9878

www.alsglobal.com

COC #

Page 1 of

Company: A. Lanfranco and Associates			Report Format / Distribution			Service Requested (Rush for routine analysis subject to availability)																																
Contact: Mark Lanfranco			☒ Standard ☐ Other			☒ Regular (Standard Turnaround) ☐ Priority (2-4 Business Days) - 5 ☐ Emergency (1-2 BUS. Days) - 1																																
Address: Unit 101 9488 189 St Surrey BC V4N 4W7			Email 1: mark.lanfranco@alanfranco.com			☐ Digital ☐ Fax																																
Phone: 604-881-2582 Fax: 604-881-2581			Email 2:			Analysis Request ☐ Standard ☐ Rush																																
Invoice To Same as Report ?			Client / Project Information			Please indicate below Filtered, Priority, and Quantity																																
Hardcopy of Invoice with Report?			Job #: Metro Vancouver WTE																																			
Company: ☒ Yes ☐ No			PO / AFE: HF																																			
Contact: ☒ Yes ☐ No			LSD:																																			
Address:			Quote #:																																			
Phone:			ALS Contact: Brent Mack			Sampler: A. Lanfranco and																																
Lab Work Order # (lab use only)																																						
Sample Identification (This description will appear on the report)																		Date (dd-mmm-yy)		Time (hh:mm)		Sample Type																
Sample #																																						
Unit 1 HF Run 1																		13-Feb-19				Water		X														
Unit 1 HF Run 2																		13-Feb-19				Water		X														
Unit 1 HF Run 3																		13-Feb-19				Water		X														
Unit 2 HF Run 1																		14-Feb-19				Water		X														
Unit 2 HF Run 2																		14-Feb-19				Water		X														
Unit 2 HF Run 3																		14-Feb-19				Water		X														
Unit 3 HF Run 1																		15-Feb-19				Water		X														
Unit 3 HF Run 2																		15-Feb-19				Water		X														
Unit 3 HF Run 3																		15-Feb-19				Water		X														
Special Instructions / Regulations with water or land use (CCME-Freshwater Aquatic Life/BC CSR - Commercial/AB Tier 1 - Natural, etc) / Hazardous Details																																						
Please report ug/sample																																						
Failure to complete all portions of this form may delay analysis. Please fill in this form LEGIBLY.																																						
By the use of this form the user acknowledges and agrees with the Terms and Conditions as provided on a separate Excel tab.																																						
Also provided on another Excel tab are the ALS location addresses, phone numbers and sample container / preservation / holding time table for common analyses.																																						
SHIPMENT RELEASE (client use)											SHIPMENT RECEPTION (lab use only)											SHIPMENT VERIFICATION (lab use only)																
Released by:			Date (dd-mmm-yy)			Time (hh-mm)			Received by:			Date:			Time:			Temperature:			Verified by:			Date:			Time:			Observations: Yes / No ? If Yes add SIF								
									CW			Feb 19			15:35			16.9 °C																				

GENF 20.00 Front

Your Project #: METRO-VAN WTE
Site Location: BURNABY B.C.
Your C.O.C. #: G126817

Attention: Mark Lanfranco

A. LANFRANCO & ASSOCIATES INC.
#101, 9488 - 189th STREET
SURREY, BC
Canada V4N 4W7

Report Date: 2019/02/22

Report #: R2688640

Version: 1 - Final

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B910991

Received: 2019/02/13, 15:15

Sample Matrix: Air
Samples Received: 9

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Nitrous Oxide (1)	9	N/A	2019/02/19	CAM SOP-00203	GC/ECD

Remarks:

Maxxam Analytics' laboratories are accredited to ISO/IEC 17025:2005 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by Maxxam are based upon recognized Provincial, Federal or US method compendia such as CCME, MDDELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in Maxxam's profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and Maxxam in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

Maxxam Analytics' liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. Maxxam has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by Maxxam, unless otherwise agreed in writing. Maxxam is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.

Results relate to samples tested. When sampling is not conducted by Maxxam, results relate to the supplied samples tested.

This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) This test was performed by Maxxam Ontario (From Burnaby)

Your Project #: METRO-VAN WTE
Site Location: BURNABY B.C.
Your C.O.C. #: G126817

Attention: Mark Lanfranco

A. LANFRANCO & ASSOCIATES INC.
#101, 9488 - 189th STREET
SURREY, BC
Canada V4N 4W7

Report Date: 2019/02/22
Report #: R2688640
Version: 1 - Final

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B910991

Received: 2019/02/13, 15:15

Encryption Key



Maxxam

22 Feb 2019 14:22:42

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

Tanya Eugene, M.Sc., Project Manager

Email: TEugine@maxxam.ca

Phone# (604)639-2609

=====

This report has been generated and distributed using a secure automated process.

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Job #: B910991
Report Date: 2019/02/22

A. LANFRANCO & ASSOCIATES INC.
Client Project #: METRO-VAN WTE
Site Location: BURNABY B.C.

COMPRESSED GAS PARAMETERS (AIR)

Maxxam ID		VF5995	VF5996	VF5997	VF5998	VF5999	VF6000	VF6001		
Sampling Date		2019/02/13 09:55	2019/02/13 10:57	2019/02/13 12:00	2019/02/13 09:30	2019/02/13 10:31	2019/02/13 11:32	2019/02/13 09:01		
COC Number		G126817	G126817	G126817	G126817	G126817	G126817	G126817		
	UNITS	UNIT #1 R-1	UNIT #1 R-2	UNIT #1 R-3	UNIT #2 R-1	UNIT #2 R-2	UNIT #2 R-3	UNIT #3 R-1	RDL	QC Batch

GAS

Nitrous Oxide	ppm v/v	4.5	0.8	0.8	0.6	3.0	0.4	6.4	0.1	9329906
---------------	---------	-----	-----	-----	-----	-----	-----	-----	-----	---------

RDL = Reportable Detection Limit

Maxxam ID		VF6002	VF6003		
Sampling Date		2019/02/13 10:10	2019/02/13 11:12		
COC Number		G126817	G126817		
	UNITS	UNIT #3 R-2	UNIT #3 R-3	RDL	QC Batch

GAS

Nitrous Oxide	ppm v/v	5.2	9.7	0.1	9329906
---------------	---------	-----	-----	-----	---------

RDL = Reportable Detection Limit

Maxxam Job #: B910991
Report Date: 2019/02/22

A. LANFRANCO & ASSOCIATES INC.
Client Project #: METRO-VAN WTE
Site Location: BURNABY B.C.

GENERAL COMMENTS

Sample VF5995 [UNIT #1 R-1] : The sample was analysed 6 days after the date of sampling. The recommended holding time is 2 days.

Sample VF5996 [UNIT #1 R-2] : The sample was analysed 6 days after the date of sampling. The recommended holding time is 2 days.

Sample VF5997 [UNIT #1 R-3] : The sample was analysed 6 days after the date of sampling. The recommended holding time is 2 days.

Sample VF5998 [UNIT #2 R-1] : The sample was analysed 6 days after the date of sampling. The recommended holding time is 2 days.

Sample VF5999 [UNIT #2 R-2] : The sample was analysed 6 days after the date of sampling. The recommended holding time is 2 days.

Sample VF6000 [UNIT #2 R-3] : The sample was analysed 6 days after the date of sampling. The recommended holding time is 2 days.

Sample VF6001 [UNIT #3 R-1] : The sample was analysed 6 days after the date of sampling. The recommended holding time is 2 days.

Sample VF6002 [UNIT #3 R-2] : The sample was analysed 6 days after the date of sampling. The recommended holding time is 2 days.

Sample VF6003 [UNIT #3 R-3] : The sample was analysed 6 days after the date of sampling. The recommended holding time is 2 days.

Results relate only to the items tested.

Maxxam Job #: B910991
Report Date: 2019/02/22

QUALITY ASSURANCE REPORT

A. LANFRANCO & ASSOCIATES INC.
Client Project #: METRO-VAN WTE
Site Location: BURNABY B.C.


QC Batch	Parameter	Date	Method Blank		RPD	
			Value	UNITS	Value (%)	QC Limits
9329906	Nitrous Oxide	2019/02/19	<0.1	ppm v/v	6.3	N/A
N/A = Not Applicable Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement. Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.						

Maxxam Job #: B910991
Report Date: 2019/02/22

A. LANFRANCO & ASSOCIATES INC.
Client Project #: METRO-VAN WTE
Site Location: BURNABY B.C.

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



Tom Mitchell, B.Sc, Supervisor, Compressed Gases

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Invoice Information		Report Information (If differs from invoice)		Project Information (where applicable)		Turnaround Time (TAT) Required	
Company Name: <u>A. Lanfranco Assoc</u>	Company Name: _____	Quotation #: _____	Turnaround Time (TAT) Required		☒ Regular TAT 5 days (Most analyses)		
Contact Name: <u>Mark Lanfranco</u>	Contact Name: _____	P.O. #/ AF#: _____	PLEASE PROVIDE ADVANCE NOTICE FOR RUSH PROJECTS				
Address: <u>101-9488 199th St.</u>	Address: _____	Project #: <u>Metro-Van WTE</u>	Rush TAT (Surcharges will be applied)		☐ Same Day ☐ 2 Days		
Phone: <u>604-881-2582</u>	Phone: _____	Site Location: <u>Burnaby B.C.</u>	☐ 1 Day ☐ 3 Days				
Email: <u>mark.lanfranco@alfranco.com</u>	Email: _____	Sampled By: _____	Date Required: _____				
Regulatory Criteria		Special Instructions		Analysis Requested		Rush Confirmation #:	
☐ BC CSR Soil ☐ BC CSR Water ☐ YK CSR Soil ☐ YK CSR Water ☐ CCME (Specify) ☐ Other (Specify) ☐ Drinking Water ☐ BC Water Quality		☐ Return Cooler ☐ Ship Sample Bottles (Please Specify)		☐ VOC / BTX / VPH ☐ MTBE ☐ VOC / BTX / F1 ☐ VOC / BTX / PAH ☐ LEPA / NEPA / PAH ☐ F2 - FA ☐ TEH ☐ F1 ☐ F2 ☐ Disolved Metals ☐ Filtered? ☐ Preserved? ☐ Dissolved Mercury ☐ Filtered? ☐ Preserved? ☐ Total Metals ☐ Field Preserved? ☐ Total Mercury ☐ Field Preserved? ☐ Chloride ☐ Fluoride ☐ Sulphate ☐ TDS ☐ BOD ☐ COD ☐ pH ☐ Conductivity ☐ Alkalinity ☐ Nitrate ☐ Nitrite ☐ Ammonia		LABORATORY USE ONLY CUSTODY SEAL Y / N Present Intact COOLING MEDIA PRESENT Y / N COMMENTS	
SAMPLES MUST BE KEPT COOL (< 10 °C) FROM TIME OF SAMPLING UNTIL DELIVERY TO MAXXAM							
Sample Identification	Date Sampled (YYYY/MM/DD)	Time Sampled (HH:MM)	Matrix				
1 Unit #1 1	R-1 Feb 13, 19	7:55-10:55					
2	R-2 19, 02, 13	10:57-11:57					
3	R-3 19, 02, 13	12:00-1:00pm					
4 Unit #2	R-1 19, 02, 13	7:30-10:30					
5	R-2 19, 02, 13	10:31-11:31					
6	R-3 19, 02, 13	11:32-12:32					
7 Unit #3	R-1 19, 02, 13	9:08-10:08					
8	R-2 19, 02, 13	10:10-11:10					
9	R-3 19, 02, 13	11:12-12:12					
10							
RELINQUISHED BY: (Signature/Print)		DATE: (YYYY/MM/DD)	TIME: (HH:MM)	RECEIVED BY: (Signature/Print)		DATE: (YYYY/MM/DD)	TIME: (HH:MM)
<u>Michael Coors</u>		<u>Feb-13-19 (15:15)</u>	<u>15:15</u>	<u>John Peters</u>		<u>2019/02/13</u>	<u>15:15</u>

Unless otherwise agreed to in writing, work submitted on this Chain of Custody is subject to Maxxam's standard Terms and Conditions. Signing of this Chain of Custody document is acknowledgment and acceptance of our terms which are available for viewing at w



B910991_COC

COC-1020 1281

APPENDIX - C

COMPUTER GENERATED RESULTS

Client: Metro Vancouver
Jobsite: WTE (Burnaby, BC)
Source: Unit 1

Date: 11-Feb-19
Run: 1 - Particulate / Metals
Run Time: 12:25 - 14:28

Concentrations:

Particulate	9.38 mg/dscm	0.00410 gr/dscf
	5.80 mg/Acm	0.00254 gr/Acf
	8.62 mg/dscm (@ 11% O ₂)	0.00377 gr/dscf (@ 11% O ₂)

Emission Rates:

Particulate	0.709 Kg/hr	1.563 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1260 dscm/min	44501 dscf/min
	21.00 dscm/sec	742 dscf/sec
	2037 Acm/min	71938 Acf/min

Velocity	13.329 m/sec	43.73 f/sec
-----------------	--------------	-------------

Temperature	151.2 oC	304.2 oF
--------------------	----------	----------

Moisture	14.1 %
-----------------	--------

Gas Analysis	10.1 % O ₂
	10.1 % CO ₂

30.019 Mol. Wt (g/gmole) Dry
28.322 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.6547 dscm	93.751 dscf
Sample Time	120.0 minutes	
Isokineticity	95.0 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, BC)
Source: Unit 1

Date: 11-Feb-19
Run: 1 - Particulate / Metals
Run Time: 12:25 - 14:28

Control Unit (Y) 1.0232
 Nozzle Diameter (in.) 0.3048
 Pitot Factor 0.8660
 Baro. Press. (in. Hg) 29.80
 Static Press. (in. H2O) 19.00
 Stack Height (ft) 30
 Stack Diameter (in.) 70.90
 Stack Area (sq.ft.) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 5.0

Collection:
 Filter (grams) 0.00050
 Washings (grams) 0.02440
Total (grams) 0.02490

Traverse 1
 Traverse 2

Gas Analysis (Vol. %):

CO2	O2
10.00	10.25
10.17	10.00

10.09 **10.13**

Condensate Collection:

Impinger 1	142.0
Impinger 2	100.0
Impinger 3	55.0
Impinger 4	10.0
Impinger 5	5.0
Impinger 6	3.0
Gel	12.5

Gain (grams) 327.5

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	886.252								
1	5.0	889.890	0.40	1.95	42	42	4	300	1.5	95.5
2	10.0	893.620	0.42	2.05	43	43	4	300	4.7	95.3
3	15.0	897.350	0.42	2.05	43	43	4	303	8.4	95.5
4	20.0	900.990	0.40	1.95	44	44	4	305	12.5	95.4
5	25.0	904.860	0.45	2.19	44	44	4	305	17.7	95.7
6	30.0	908.820	0.47	2.29	46	46	4	306	25.2	95.5
7	35.0	913.010	0.53	2.58	46	46	6	308	45.6	95.4
8	40.0	917.090	0.50	2.44	47	47	6	308	53.2	95.4
9	45.0	920.920	0.44	2.14	46	46	6	307	58.3	95.5
10	50.0	924.470	0.38	1.85	47	47	6	308	62.5	95.1
11	55.0	927.880	0.35	1.70	46	46	7	300	66.1	94.8
12	60.0	931.190	0.33	1.61	47	47	7	295	69.4	94.3
Traverse 2	0.0	931.190								
1	5.0	934.640	0.36	1.75	47	47	6	308	1.5	94.9
2	10.0	938.280	0.40	1.95	47	47	6	308	4.7	95.1
3	15.0	941.690	0.35	1.70	47	47	6	310	8.4	95.3
4	20.0	945.100	0.35	1.70	48	48	6	312	12.5	95.2
5	25.0	948.090	0.27	1.31	48	48	6	307	17.7	94.6
6	30.0	951.080	0.27	1.31	48	48	6	307	25.2	94.6
7	35.0	955.120	0.49	2.39	48	48	6	306	45.6	95.1
8	40.0	959.270	0.52	2.53	48	48	6	306	53.2	94.9
9	45.0	963.340	0.50	2.44	49	49	6	304	58.3	94.6
10	50.0	967.420	0.50	2.44	49	49	6	302	62.5	94.7
11	55.0	970.840	0.35	1.70	49	49	6	295	66.1	94.2
12	60.0	974.090	0.32	1.56	50	50	6	290	69.4	93.1
Average:			0.407	1.983	46.6	46.6	5.6	304.2		95.0

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 1

Date: 13-Feb-19
Run: 2 - Particulate / Metals
Run Time: 09:40 - 11:44

Concentrations:

Particulate	5.28 mg/dscm	0.00231 gr/dscf
	2.94 mg/Acm	0.00129 gr/Acf
	4.98 mg/dscm (@ 11% O2)	0.00218 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.401 Kg/hr	0.885 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1268 dscm/min	44775 dscf/min
	21.13 dscm/sec	746 dscf/sec
	2271 Acm/min	80215 Acf/min

Velocity	14.863 m/sec	48.76 f/sec
-----------------	--------------	-------------

Temperature	149.3 oC	300.7 oF
--------------------	----------	----------

Moisture	14.9 %
-----------------	--------

Gas Analysis	10.4 % O2
	10.0 % CO2

30.017 Mol. Wt (g/gmole) Dry
28.225 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.7867 dscm	98.411 dscf
Sample Time	120.0 minutes	
Isokineticity	99.1 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 1

Date: 13-Feb-19
Run: 2 - Particulate / Metals
Run Time: 09:40 - 11:44

Control Unit (Y) 1.0232
Nozzle Diameter (in.) 0.3048
Pitot Factor 0.8660
Baro. Press. (in. Hg) 29.70
Static Press. (in. H2O) -19.25
Stack Height (ft) 30
Stack Diameter (in.) 70.90
Stack Area (sq.ft.) 27.417
Minutes Per Reading 5.0
Minutes Per Point 5.0

Collection:
 Filter (grams) 0.00030
 Washings (grams) 0.01440
Total (grams) 0.01470

Gas Analysis (Vol. %):

CO2	O2
10.00	10.50
10.00	10.33

Condensate Collection:

Impinger 1	150.0
Impinger 2	130.0
Impinger 3	44.0
Impinger 4	16.0
Impinger 5	12.0
Impinger 6	4.0
Gel	10.5

10.00 10.42

Gain (grams) 366.5

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	992.150								
1	5.0	995.460	0.33	1.61	48	48	4	299	1.5	99.5
2	10.0	998.720	0.32	1.56	49	49	4	298	4.7	99.2
3	15.0	1002.040	0.33	1.61	49	49	4	300	8.4	99.7
4	20.0	1005.290	0.32	1.56	48	48	4	300	12.5	99.3
5	25.0	1008.780	0.37	1.80	48	48	6	301	17.7	99.3
6	30.0	1012.430	0.40	1.95	48	48	6	302	25.2	99.9
7	35.0	1016.620	0.53	2.58	48	48	6	303	45.6	99.9
8	40.0	1020.890	0.55	2.68	49	49	6	303	53.2	99.8
9	45.0	1025.310	0.59	2.87	49	49	6	303	58.3	99.7
10	50.0	1029.840	0.62	3.02	50	50	6	303	62.5	99.6
11	55.0	1034.370	0.62	3.02	50	50	6	303	66.1	99.6
12	60.0	1038.720	0.57	2.78	51	51	6	304	69.4	99.5
Traverse 2	0.0	1038.720								
1	5.0	1042.660	0.47	2.29	51	51	6	299	1.5	98.8
2	10.0	1046.480	0.44	2.14	52	52	6	299	4.7	98.8
3	15.0	1050.220	0.42	2.05	52	52	6	300	8.4	99.0
4	20.0	1054.200	0.48	2.34	52	52	6	299	12.5	98.6
5	25.0	1058.350	0.52	2.53	52	52	6	300	17.7	98.9
6	30.0	1062.500	0.52	2.53	53	53	6	302	25.2	98.8
7	35.0	1066.570	0.50	2.44	53	53	6	302	45.6	98.8
8	40.0	1070.540	0.48	2.34	53	53	6	300	53.2	98.2
9	45.0	1074.470	0.46	2.24	53	53	6	299	58.3	99.2
10	50.0	1078.210	0.42	2.05	54	54	6	298	62.5	98.5
11	55.0	1081.850	0.40	1.95	54	54	6	300	66.1	98.4
12	60.0	1085.380	0.38	1.85	55	55	6	300	69.4	97.7
Average:			0.460	2.241	50.9	50.9	5.7	300.7		99.1

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 1

Date: 13-Feb-19
Run: 3 - Particulate / Metals
Run Time: 12:05 - 14:07

Concentrations:

Particulate	0.9 mg/dscm	0.0004 gr/dscf
	0.5 mg/Acm	0.0002 gr/Acf
	0.8 mg/dscm (@ 11% O2)	0.0004 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.066 Kg/hr	0.146 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1248 dscm/min	44072 dscf/min
	20.80 dscm/sec	735 dscf/sec
	2284 Acm/min	80646 Acf/min

Velocity	14.943 m/sec	49.02 f/sec
-----------------	--------------	-------------

Temperature	151.7 oC	305.1 oF
--------------------	----------	----------

Moisture	16.2 %
-----------------	--------

Gas Analysis	10.3 % O2
	10.1 % CO2

30.027 Mol. Wt (g/gmole) Dry
28.077 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.7717 dscm	97.882 dscf
Sample Time	120.0 minutes	
Isokineticity	100.1 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 1

Date: 13-Feb-19
Run: 3 - Particulate / Metals
Run Time: 12:05 - 14:07

Control Unit (Y) 1.0232
 Nozzle Diameter (in.) 0.3048
 Pitot Factor 0.8660
 Baro. Press. (in. Hg) 29.70
 Static Press. (in. H2O) -19.25
 Stack Height (ft) 30
 Stack Diameter (in.) 70.90
 Stack Area (sq.ft.) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 5.0

Collection:
 Filter (grams) 0.00005
 Washings (grams) 0.00240
Total (grams) 0.00245

Traverse 1
 Traverse 2

Gas Analysis (Vol. %):
 CO2 O2
 10.00 10.50
 10.17 10.17

10.09 10.34

Condensate Collection:
 Impinger 1 198.0
 Impinger 2 136.0
 Impinger 3 28.0
 Impinger 4 14.0
 Impinger 5 10.0
 Impinger 6 4.0
 Gel 12.5
Gain (grams) 402.5

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	87.201								
1	5.0	91.140	0.47	2.29	52	52	4	306	1.5	100.3
2	10.0	94.990	0.45	2.19	52	52	4	305	4.7	100.1
3	15.0	99.020	0.49	2.39	53	53	4	305	8.4	100.3
4	20.0	102.880	0.45	2.19	52	52	4	305	12.5	100.4
5	25.0	106.700	0.44	2.14	52	52	5	304	17.7	100.4
6	30.0	110.520	0.44	2.14	52	52	5	304	25.2	100.4
7	35.0	114.500	0.48	2.34	52	52	5	301	45.6	100.0
8	40.0	118.690	0.53	2.58	52	52	5	303	53.2	100.4
9	45.0	122.760	0.50	2.44	53	53	6	304	58.3	100.2
10	50.0	126.830	0.50	2.44	53	53	6	306	62.5	100.4
11	55.0	130.770	0.47	2.29	53	53	6	306	66.1	100.2
12	60.0	134.590	0.44	2.14	54	54	6	306	69.4	100.1
Traverse 2	0.0	134.590								
1	5.0	138.230	0.40	1.95	54	54	6	305	1.5	100.0
2	10.0	141.740	0.37	1.80	55	55	6	306	4.7	100.1
3	15.0	145.390	0.40	1.95	54	54	6	306	8.4	100.3
4	20.0	149.040	0.40	1.95	55	55	6	306	12.5	100.1
5	25.0	152.490	0.36	1.75	54	54	6	306	17.7	99.9
6	30.0	155.800	0.33	1.61	54	54	6	306	25.2	100.1
7	35.0	159.960	0.52	2.53	54	54	5	306	45.6	100.4
8	40.0	164.190	0.54	2.63	55	55	5	307	53.2	100.1
9	45.0	168.260	0.50	2.44	55	55	6	306	58.3	100.0
10	50.0	172.220	0.47	2.29	56	56	6	305	62.5	100.0
11	55.0	176.370	0.52	2.53	56	56	6	305	66.1	99.7
12	60.0	180.440	0.50	2.44	56	56	6	304	69.4	99.6
Average:			0.457	2.227	53.7	53.7	5.4	305.1		100.1

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 2

Date: 13-Feb-19
Run: 1 - Particulate / Metals
Run Time: 12:20 - 14:22

Concentrations:

Particulate	0.2 mg/dscm	0.0001 gr/dscf
	0.1 mg/Acm	0.0001 gr/Acf
	0.2 mg/dscm (@ 11% O2)	0.0001 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.017 Kg/hr	0.037 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1136 dscm/min	40133 dscf/min
	18.94 dscm/sec	669 dscf/sec
	2075 Acfm/min	73289 Acf/min

Velocity	13.580 m/sec	44.55 f/sec
-----------------	--------------	-------------

Temperature	157.4 oC	315.3 oF
--------------------	----------	----------

Moisture	15.0 %
-----------------	--------

Gas Analysis	9.3 % O2
	10.8 % CO2

	30.090 Mol. Wt (g/gmole) Dry
	28.282 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.6414 dscm	93.280 dscf
Sample Time	120.0 minutes	
Isokineticity	101.8 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 2

Date: 13-Feb-19
Run: 1 - Particulate / Metals
Run Time: 12:20 - 14:22

Control Unit (Y) 0.9870
 Nozzle Diameter (in.) 0.3092
 Pitot Factor 0.8480
 Baro. Press. (in. Hg) 29.69
 Static Press. (in. H2O) -19.00
 Stack Height (ft) 30
 Stack Diameter (in.) 70.90
 Stack Area (sq.ft) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 5.0

Collection:
 Filter (grams) 0.00005
 Washings (grams) 0.00060
Total (grams) 0.00065

Traverse 1
 Traverse 2

Gas Analysis (Vol. %):
 CO2 O2
 10.75 9.50
 10.75 9.00

10.75 9.25

Condensate Collection:
 Impinger 1 82.0
 Impinger 2 126.0
 Impinger 3 78.0
 Impinger 4 38.0
 Impinger 5 8.0
 Impinger 6 4.0
 Cel 12.5
Gain (grams) 348.5

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	987.000								
1	5.0	991.410	0.53	2.70	44	44	7	308	1.5	101.9
2	10.0	995.860	0.54	2.74	44	44	7	310	4.7	102.0
3	15.0	1000.010	0.47	2.38	44	44	7	311	8.4	101.9
4	20.0	1004.370	0.52	2.64	44	44	7	311	12.5	101.9
5	25.0	1008.730	0.52	2.63	44	44	7	312	17.7	102.0
6	30.0	1012.970	0.49	2.48	45	45	12	314	25.2	102.0
7	35.0	1016.340	0.31	1.57	45	45	12	315	45.6	101.8
8	40.0	1019.540	0.28	1.42	45	45	12	315	53.2	101.7
9	45.0	1022.630	0.26	1.32	45	45	14	313	58.3	101.7
10	50.0	1025.720	0.26	1.32	46	46	14	314	62.5	101.6
11	55.0	1028.630	0.23	1.17	46	46	14	313	66.1	101.6
12	60.0	1031.490	0.22	1.12	47	47	14	311	69.4	101.8
Traverse 2	0.0	1031.490								
1	5.0	1035.200	0.37	1.89	48	48	10	311	1.5	101.8
2	10.0	1038.740	0.34	1.72	48	48	10	319	4.7	101.8
3	15.0	1042.130	0.31	1.57	49	49	10	319	8.4	101.9
4	20.0	1045.290	0.27	1.37	49	49	10	321	12.5	101.8
5	25.0	1048.500	0.28	1.42	49	49	11	321	17.7	101.6
6	30.0	1051.940	0.32	1.62	49	49	11	320	25.2	101.8
7	35.0	1056.640	0.60	3.03	49	49	11	321	45.6	102.0
8	40.0	1061.390	0.61	3.09	50	50	8	321	53.2	102.1
9	45.0	1066.110	0.60	3.04	50	50	8	320	58.3	102.2
10	50.0	1070.300	0.47	2.40	51	51	7	316	62.5	101.9
11	55.0	1074.300	0.43	2.19	51	51	7	319	66.1	101.8
12	60.0	1078.030	0.37	1.90	51	51	7	312	69.4	101.8
Average:			0.400	2.030	47.2	47.2	9.9	315.3		101.8

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 2

Date: 14-Feb-19
Run: 2 - Particulate / Metals
Run Time: 09:35 - 11:37

Concentrations:

Particulate	1.00 mg/dscm	0.00044 gr/dscf
	0.54 mg/Acm	0.00024 gr/Acf
	0.91 mg/dscm (@ 11% O2)	0.00040 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.068 Kg/hr	0.150 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1135 dscm/min	40067 dscf/min
	18.91 dscm/sec	668 dscf/sec
	2087 Acm/min	73715 Acf/min

Velocity	13.659 m/sec	44.81 f/sec
-----------------	--------------	-------------

Temperature	150.4 oC	302.8 oF
--------------------	----------	----------

Moisture	15.6 %
-----------------	--------

Gas Analysis	10.0 % O2
	10.3 % CO2

30.046 Mol. Wt (g/gmole) Dry
28.165 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.4448 dscm	86.338 dscf
Sample Time	120.0 minutes	
Isokineticity	101.1 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client:

Jobsite:

Source:

Metro Vancouver
WTE (Burnaby, B.C)
Unit 2

Date:

Run:

Run Time:

14-Feb-19
2 - Particulate / Metals
09:35 - 11:37

Control Unit (Y)	0.9870	Collection: Filter (grams) 0.00005 Washings (grams) 0.00240 Total (grams) 0.00245	Traverse 1 Traverse 2	Gas Analysis (Vol. %):		Condensate Collection:	
Nozzle Diameter (in.)	0.3048			CO2	O2	Impinger 1	146.0
Pitot Factor	0.8660			10.33	10.00	Impinger 2	132.0
Baro. Press. (in. Hg)	29.28			10.25	10.00	Impinger 3	24.0
Static Press. (in. H2O)	-19.50					Impinger 4	14.0
Stack Height (ft)	30					Impinger 5	6.0
Stack Diameter (in.)	70.90					Impinger 6	2.0
Stack Area (sq.ft.)	27.417					Gel	15.5
Minutes Per Reading	5.0			10.29	10.00	Gain (grams)	339.5
Minutes Per Point	5.0						

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	108.100								
1	5.0	112.150	0.45	2.19	40	40	4	299	1.5	102.4
2	10.0	116.280	0.47	2.29	42	42	4	299	4.7	101.8
3	15.0	120.540	0.50	2.48	42	42	4	303	8.4	102.1
4	20.0	124.800	0.50	2.48	42	42	4	309	12.5	102.5
5	25.0	128.930	0.47	2.29	43	43	4	305	17.7	102.0
6	30.0	132.340	0.32	1.59	43	43	5	304	25.2	101.8
7	35.0	135.530	0.28	1.39	44	44	5	300	45.6	101.3
8	40.0	138.550	0.25	1.24	45	45	5	298	53.2	101.1
9	45.0	141.390	0.22	1.09	45	45	7	299	58.3	101.4
10	50.0	144.910	0.34	1.69	46	46	7	300	62.5	101.1
11	55.0	148.110	0.28	1.39	47	47	8	304	66.1	101.3
12	60.0	151.190	0.26	1.29	48	48	8	304	69.4	101.0
Traverse 2	0.0	151.190								
1	5.0	154.600	0.32	1.59	48	48	8	296	1.5	100.3
2	10.0	158.170	0.35	1.74	49	49	8	299	4.7	100.4
3	15.0	161.300	0.27	1.34	49	49	8	303	8.4	100.4
4	20.0	164.490	0.28	1.39	50	50	8	308	12.5	100.6
5	25.0	167.680	0.28	1.39	49	49	8	308	17.7	100.8
6	30.0	170.990	0.30	1.49	50	50	8	309	25.2	101.0
7	35.0	175.340	0.52	2.58	50	50	8	307	45.6	100.9
8	40.0	180.170	0.64	3.17	52	52	6	307	53.2	100.8
9	45.0	184.840	0.60	2.98	52	52	6	303	58.3	100.3
10	50.0	189.020	0.48	2.38	52	52	6	302	62.5	100.2
11	55.0	193.070	0.45	2.23	53	53	4	300	66.1	99.9
12	60.0	196.980	0.42	2.08	54	54	4	300	69.4	99.6
Average:			0.385	1.907	47.3	47.3	6.1	302.8		101.1

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 2

Date: 14-Feb-19
Run: 3 - Particulate / Metals
Run Time: 11:50 - 13:52

Concentrations:

Particulate	1.2 mg/dscm	0.0005 gr/dscf
	0.6 mg/Acm	0.0003 gr/Acf
	1.1 mg/dscm (@ 11% O2)	0.0005 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.08 Kg/hr	0.186 lb/hr
--------------------	------------	-------------

Flue Gas Characteristics:

Flow	1177 dscm/min	41572 dscf/min
	19.62 dscm/sec	693 dscf/sec
	2216 Acm/min	78251 Acf/min

Velocity	14.499 m/sec	47.57 f/sec
-----------------	--------------	-------------

Temperature	154.8 oC	310.7 oF
--------------------	----------	----------

Moisture	16.7 %
-----------------	--------

Gas Analysis	10.0 % O2
	10.3 % CO2

30.040 Mol. Wt (g/gmole) Dry
28.034 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.6429 dscm	93.335 dscf
Sample Time	120.0 minutes	
Isokineticity	101.3 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client:

Jobsite:

Source:

Metro Vancouver
WTE (Burnaby, B.C)
Unit 2

Date:

Run:

Run Time:

14-Feb-19
3 - Particulate / Metals
11:50 - 13:52

Control Unit (Y)	0.9870	Collection: Filter (grams) 0.00005 Washings (grams) 0.00310 Total (grams) 0.0032		Gas Analysis (Vol. %):		Condensate Collection:	
Nozzle Diameter (in.)	0.3048			CO2	O2	Impinger 1	152.0
Pitot Factor	0.8660		Traverse 1	10.33	10.00	Impinger 2	129.0
Baro. Press. (in. Hg)	29.28		Traverse 2	10.17	10.00	Impinger 3	66.0
Static Press. (in. H2O)	-19.50					Impinger 4	22.0
Stack Height (ft)	30					Impinger 5	8.0
Stack Diameter (in.)	70.90					Impinger 6	3.0
Stack Area (sq.ft.)	27.417					Gel	16.5
Minutes Per Reading	5.0			10.25	10.00	Gain (grams)	396.5
Minutes Per Point	5.0						

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	197.450								
1	5.0	200.860	0.32	1.59	53	53	6	303	1.5	100.8
2	10.0	204.270	0.32	1.59	54	54	6	305	4.7	100.7
3	15.0	207.690	0.32	1.59	53	53	6	307	8.4	101.4
4	20.0	210.880	0.28	1.39	54	54	6	308	12.5	100.9
5	25.0	214.070	0.28	1.39	53	53	5	310	17.7	101.2
6	30.0	217.490	0.32	1.59	54	54	5	310	25.2	101.4
7	35.0	222.160	0.60	2.98	54	54	5	310	45.6	101.4
8	40.0	227.250	0.71	3.52	54	54	4	310	53.2	101.8
9	45.0	232.460	0.75	3.72	55	55	4	312	58.3	101.3
10	50.0	237.430	0.68	3.37	55	55	4	311	62.5	101.4
11	55.0	242.340	0.66	3.27	56	56	4	310	66.1	101.4
12	60.0	247.090	0.62	3.08	55	55	4	312	69.4	101.4
Traverse 2	0.0	247.090								
1	5.0	251.480	0.53	2.63	55	55	4	314	1.5	101.4
2	10.0	256.040	0.57	2.83	56	56	4	314	4.7	101.4
3	15.0	260.720	0.60	2.98	55	55	4	315	8.4	101.8
4	20.0	265.270	0.57	2.83	55	55	4	315	12.5	101.5
5	25.0	269.820	0.57	2.83	56	56	4	314	17.7	101.2
6	30.0	273.990	0.48	2.38	55	55	4	315	25.2	101.2
7	35.0	277.410	0.32	1.59	55	55	6	313	45.6	101.4
8	40.0	280.430	0.25	1.24	54	54	6	312	53.2	101.3
9	45.0	283.270	0.22	1.09	56	56	6	312	58.3	101.1
10	50.0	285.990	0.20	0.99	55	55	6	310	62.5	101.6
11	55.0	288.560	0.18	0.89	55	55	7	309	66.1	101.1
12	60.0	291.120	0.18	0.89	54	54	7	306	69.4	100.7
Average:			0.439	2.177	54.6	54.6	3.0	310.7		101.3

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 3

Date: 14-Feb-19
Run: 1 - Particulate / Metals
Run Time: 12:04 - 14:06

Concentrations:

Particulate	1.62 mg/dscm	0.00071 gr/dscf
	0.87 mg/Acm	0.00038 gr/Acf
	1.43 mg/dscm (@ 11% O2)	0.00062 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.110 Kg/hr	0.241 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1124 dscm/min	39681 dscf/min
	18.73 dscm/sec	661 dscf/sec
	2099 Acm/min	74132 Acf/min

Velocity	13.736 m/sec	45.06 f/sec
-----------------	--------------	-------------

Temperature	153.6 oC	308.5 oF
--------------------	----------	----------

Moisture	16.2 %
-----------------	--------

Gas Analysis	9.6 % O2
	10.4 % CO2

30.045 Mol. Wt (g/gmole) Dry
28.098 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.3701 dscm	83.702 dscf
Sample Time	120.0 minutes	
Isokineticity	103.4 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 3

Date: 14-Feb-19
Run: 1 - Particulate / Metals
Run Time: 12:04 - 14:06

Control Unit (Y) 0.9986
 Nozzle Diameter (in.) 0.2923
 Pitot Factor 0.8480
 Baro. Press. (in. Hg) 29.28
 Static Press. (in. H2O) -20.00
 Stack Height (ft) 30
 Stack Diameter (in.) 70.90
 Stack Area (sq.ft.) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 5.0

Collection:
 Filter (grams) 0.00005
 Washings (grams) 0.00380
Total (grams) 0.00385

Gas Analysis (Vol. %):
 CO2 O2
 Traverse 1 9.75 10.25
 Traverse 2 11.00 9.00
10.38 9.63

Condensate Collection:
 Impinger 1 218.0
 Impinger 2 84.0
 Impinger 3 14.0
 Impinger 4 6.0
 Impinger 5 4.0
 Impinger 6 2.0
 Gel 15.0
Gain (grams) 343.0

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	957.305								
1	5.0	961.010	0.47	1.89	44	44	8	309	1.5	103.4
2	10.0	964.880	0.51	2.05	44	44	8	307	4.7	103.6
3	15.0	968.830	0.53	2.14	44	44	8	306	8.4	103.7
4	20.0	972.670	0.50	2.02	45	45	8	307	12.5	103.6
5	25.0	976.590	0.52	2.10	46	46	8	308	17.7	103.6
6	30.0	980.330	0.47	1.91	48	48	9	308	25.2	103.5
7	35.0	983.220	0.28	1.14	49	49	9	307	45.6	103.1
8	40.0	986.260	0.31	1.26	50	50	9	308	53.2	103.0
9	45.0	988.710	0.20	0.81	50	50	5	309	58.3	103.3
10	50.0	991.340	0.23	0.94	51	51	5	307	62.5	103.1
11	55.0	993.920	0.22	0.90	52	52	5	307	66.1	103.2
12	60.0	996.380	0.20	0.82	52	52	5	307	69.4	103.2
Traverse 2	0.0	996.380								
1	5.0	999.510	0.32	1.32	54	54	5	306	1.5	103.4
2	10.0	1002.540	0.30	1.23	54	54	5	307	4.7	103.5
3	15.0	1005.710	0.33	1.35	55	55	5	309	8.4	103.2
4	20.0	1008.890	0.33	1.36	56	56	5	310	12.5	103.4
5	25.0	1011.770	0.27	1.11	57	57	5	310	17.7	103.2
6	30.0	1014.810	0.30	1.24	57	57	5	309	25.2	103.3
7	35.0	1018.820	0.52	2.14	58	58	5	310	45.6	103.6
8	40.0	1022.860	0.53	2.19	58	58	7	310	53.2	103.4
9	45.0	1027.410	0.67	2.76	58	58	7	310	58.3	103.8
10	50.0	1031.580	0.56	2.32	59	59	7	309	62.5	103.6
11	55.0	1035.860	0.59	2.44	60	60	7	311	66.1	103.6
12	60.0	1040.102	0.58	2.39	60	60	7	312	69.4	103.6
Average:			0.406	1.660	52.5	52.5	6.5	308.5		103.4

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 3

Date: 15-Feb-19
Run: 2 - Particulate / Metals
Run Time: 09:15 - 11:17

Concentrations:

Particulate	0.29 mg/dscm	0.00013 gr/dscf
	0.16 mg/Acm	0.00007 gr/Acf
	0.26 mg/dscm (@ 11% O2)	0.00011 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.020 Kg/hr	0.043 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1115 dscm/min	39361 dscf/min
	18.58 dscm/sec	656 dscf/sec
	2022 Acm/min	71400 Acf/min

Velocity	13.230 m/sec	43.40 f/sec
-----------------	--------------	-------------

Temperature	151.4 oC	304.5 oF
--------------------	----------	----------

Moisture	15.1 %
-----------------	--------

Gas Analysis	9.5 % O2
	10.5 % CO2

30.060 Mol. Wt (g/gmole) Dry
28.239 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.5442 dscm	89.849 dscf
Sample Time	120.0 minutes	
Isokineticity	102.1 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 3

Date: 15-Feb-19
Run: 2 - Particulate / Metals
Run Time: 09:15 - 11:17

Control Unit (Y) 0.9986
 Nozzle Diameter (in.) 0.3060
 Pitot Factor 0.8480
 Baro. Press. (in. Hg) 29.53
 Static Press. (in. H2O) -19.00
 Stack Height (ft) 30
 Stack Diameter (in.) 70.90
 Stack Area (sq.ft.) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 5.0

Collection:
 Filter (grams) 0.00005
 Washings (grams) 0.00070
Total (grams) 0.00075

Traverse 1
 Traverse 2

Gas Analysis (Vol. %):

CO2	O2
10.50	9.50
10.50	9.50

10.50 **9.50**

Condensate Collection:

Impinger 1	164.0
Impinger 2	122.0
Impinger 3	18.0
Impinger 4	12.0
Impinger 5	5.0
Impinger 6	3.0
Gel	15.5

Gain (grams) 339.5

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	41.005								
1	5.0	45.160	0.49	2.38	46	46	5	306	1.5	102.4
2	10.0	49.480	0.53	2.59	46	46	5	304	4.7	102.3
3	15.0	54.090	0.60	2.94	47	47	5	303	8.4	102.4
4	20.0	58.350	0.51	2.50	48	48	5	303	12.5	102.3
5	25.0	62.780	0.55	2.70	49	49	12	303	17.7	102.3
6	30.0	66.840	0.46	2.26	50	50	12	304	25.2	102.3
7	35.0	70.010	0.28	1.38	51	51	12	305	45.6	102.0
8	40.0	73.070	0.26	1.28	51	51	12	305	53.2	102.1
9	45.0	75.890	0.22	1.09	52	52	12	304	58.3	102.0
10	50.0	78.780	0.23	1.14	53	53	10	302	62.5	101.9
11	55.0	81.540	0.21	1.04	53	53	10	302	66.1	101.8
12	60.0	84.300	0.21	1.04	53	53	10	302	69.4	101.8
Traverse 2	0.0	84.300								
1	5.0	87.820	0.34	1.69	55	55	9	305	1.5	102.0
2	10.0	91.190	0.31	1.54	56	56	9	306	4.7	102.1
3	15.0	94.670	0.33	1.64	57	57	9	305	8.4	102.0
4	20.0	97.820	0.27	1.34	57	57	9	307	12.5	102.1
5	25.0	100.970	0.27	1.34	57	57	9	306	17.7	102.1
6	30.0	104.070	0.26	1.30	58	58	9	305	25.2	102.1
7	35.0	107.960	0.41	2.04	58	58	9	306	45.6	102.3
8	40.0	112.170	0.48	2.39	58	58	6	305	53.2	102.3
9	45.0	116.470	0.50	2.49	59	59	6	306	58.3	102.3
10	50.0	120.860	0.52	2.60	59	59	6	305	62.5	102.3
11	55.0	125.130	0.49	2.46	60	60	6	304	66.1	102.2
12	60.0	129.311	0.47	2.36	60	60	6	304	69.4	102.2
Average:			0.383	1.897	53.9	53.9	8.5	304.5		102.1

Client: Metro Vancouver
Jobsite: WTE(Burnaby,B.C)
Source: Unit 3

Date: 15-Feb-19
Run: 3 - Particulate / Metals
Run Time: 11:39 - 13:42

Concentrations:

Particulate	0.65 mg/dscm	0.00028 gr/dscf
	0.36 mg/Acm	0.00016 gr/Acf
	0.56 mg/dscm (@ 11% O2)	0.00024 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.043 Kg/hr	0.095 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1101 dscm/min	38885 dscf/min
	18.35 dscm/sec	648 dscf/sec
	2014 Acn/min	71133 Acf/min

Velocity	13.180 m/sec	43.24 f/sec
-----------------	--------------	-------------

Temperature	151.1 oC	304.0 oF
--------------------	----------	----------

Moisture	15.9 %
-----------------	--------

Gas Analysis	9.4 % O2
	10.6 % CO2

30.075 Mol. Wt (g/gmole) Dry
28.159 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.5335 dscm	89.471 dscf
Sample Time	120.0 minutes	
Isokineticity	103.0 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE(Burnaby,B.C)
Source: Unit 3

Date: 15-Feb-19
Run: 3 - Particulate / Metals
Run Time: 11:39 - 13:42

Control Unit (Y) 0.9986
 Nozzle Diameter (in.) 0.3060
 Pitot Factor 0.8480
 Baro. Press. (in. Hg) 29.53
 Static Press. (in. H2O) -19.00
 Stack Height (ft) 30
 Stack Diameter (in.) 70.90
 Stack Area (sq.ft.) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 5.0

Collection:	
Filter (grams)	0.00005
Washings (grams)	0.00160
Total (grams) 0.00165	

Gas Analysis (Vol. %):	
CO2	O2
Traverse 1	10.50 9.50
Traverse 2	10.75 9.25
10.63 9.38	

Condensate Collection:	
Impinger 1	158.0
Impinger 2	114.0
Impinger 3	44.0
Impinger 4	20.0
Impinger 5	7.0
Impinger 6	2.0
Gel	13.5
Gain (grams) 358.5	

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	132.405								
1	5.0	135.630	0.28	1.40	59	59	4	303	1.5	102.8
2	10.0	139.070	0.32	1.60	59	59	4	305	4.7	102.8
3	15.0	142.460	0.31	1.55	59	59	4	306	8.4	102.9
4	20.0	145.740	0.29	1.45	59	59	4	306	12.5	103.0
5	25.0	148.840	0.26	1.30	59	59	4	306	17.7	102.7
6	30.0	152.060	0.28	1.40	59	59	4	306	25.2	102.8
7	35.0	156.010	0.42	2.10	59	59	4	305	45.6	103.1
8	40.0	160.400	0.52	2.60	59	59	4	305	53.2	103.1
9	45.0	165.200	0.62	3.10	60	60	4	306	58.3	103.3
10	50.0	169.930	0.60	3.01	60	60	5	304	62.5	103.3
11	55.0	174.370	0.53	2.66	60	60	5	304	66.1	103.1
12	60.0	178.770	0.52	2.61	60	60	5	304	69.4	103.1
Traverse 2	0.0	178.770								
1	5.0	182.740	0.42	2.11	61	61	4	302	1.5	103.0
2	10.0	186.750	0.43	2.16	61	61	4	305	4.7	103.1
3	15.0	190.980	0.48	2.41	61	61	4	305	8.4	103.0
4	20.0	195.080	0.45	2.26	61	61	4	304	12.5	103.0
5	25.0	199.490	0.52	2.61	61	61	4	305	17.7	103.2
6	30.0	203.940	0.53	2.65	61	61	4	306	25.2	103.2
7	35.0	207.460	0.33	1.66	62	62	5	302	45.6	102.8
8	40.0	210.460	0.24	1.21	61	61	5	302	53.2	102.8
9	45.0	213.200	0.20	1.01	61	61	5	300	58.3	102.6
10	50.0	215.870	0.19	0.96	61	61	4	301	62.5	102.7
11	55.0	218.680	0.21	1.06	61	61	4	301	66.1	102.8
12	60.0	221.420	0.20	1.01	61	61	4	302	69.4	102.8
Average:			0.381	1.912	60.2	60.2	4.3	304.0		103.0

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)
Source: Unit 1

Sample Type: HF

Parameter		Test 1	Test 2	Test 3
Test Date		13-Feb-19	13-Feb-19	13-Feb-19
Test Time		09:58 - 10:58	11:25 - 12:25	12:42 - 13:42
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	29.80	29.80	29.80
DGM Factor	(Y)	0.9446	0.9446	0.9446
Initial Reading	(m ³)	293.810	294.620	295.528
Final Reading	(m ³)	294.598	295.501	296.394
Temp. Outlet	(Avg. oF)	50.5	51.3	56.0
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm ³)	0.77	0.86	0.83
HF	(mg)	0.111	0.061	0.039
Oxygen	(Vol. %)	10.4	10.4	10.3
HF	(mg/Sm ³)	0.144	0.071	0.047
HF	(mg/Sm ³ @ 11% O2)	0.136	0.067	0.044
Moisture	(Vol. %)	14.9	14.9	16.2

Tstd. (oF) 68

Pstd. (in. Hg) 29.92

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)
Source: Unit 2

Sample Type: HF					
Parameter		Test 1	Test 2	Test 3	
Test Date		14-Feb-19	14-Feb-19	14-Feb-19	
Test Time		09:58 - 10:58	11:03 - 12:03	12:10 - 13:10	
Test Duration	(min.)	60	60	60	
Baro. Press.	(in. Hg)	29.69	29.69	29.69	
DGM Factor	(Y)	0.9446	0.9446	0.9446	
Initial Reading	(Cubic Feet)	296.415	297.168	297.992	
Final Reading	(Cubic Feet)	297.161	297.983	298.746	
Temp. Outlet	(Avg. oF)	48.4	59.3	60.0	
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50	
Gas Volume	(Sm ³)	0.72674	0.77770	0.71890	
HF	(mg)	0.011	0.023	0.009	
Oxygen	(Vol. %)	10.0	10.0	10.0	
HF	(mg/Sm³)	0.015	0.030	0.013	
HF	(mg/Sm³ @ 11% O2)	0.014	0.027	0.012	
Moisture (isokinetic)	(Vol. %)	15.6	15.6	16.7	

*Wet Basis Calculated on moisture from isokinetic tests
Tstd. (oF) 68

Pstd. (in. Hg) 29.92

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)
Source: Unit 3

Sample Type: HF

Parameter		Test 1	Test 2	Test 3
Test Date		15-Feb-19	15-Feb-19	15-Feb-19
Test Time		09:35 - 10:35	10:46 - 11:46	11:57 - 12:57
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	29.53	29.53	29.53
DGM Factor	(Y)	0.9446	0.9446	0.9446
Initial Reading	(Cubic Feet)	298.750	299.584	300.407
Final Reading	(Cubic Feet)	299.576	300.398	301.228
Temp. Outlet	(Avg. oF)	52.7	54.0	55.5
Orifice Press.	(ΔH in.H ₂ O)	0.50	0.50	0.50
Gas Volume	(Sm ³)	0.79373	0.78054	0.78486
HF	(mg)	0.017	0.009	0.017
Oxygen	(Vol. %)	9.5	9.5	9.4
HF	(mg/Sm³)	0.022	0.012	0.022
HF	(mg/Sm³ @ 11% O₂)	0.019	0.010	0.019
Moisture (isokinetic)	(Vol. %)	15.1	15.1	15.9

*Wet Basis Calculated on moisture from isokinetic tests
Tstd. (oF) 68

Pstd. (in. Hg) 29.92

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)

Parameter: N₂O

Molecular Weight: 44.00 grams/mol
Lab Detection Limit: 0.1 ppm **Reportable Detection Limit:** 0.18 mg/Sm³

Sample ID	Date	Time	N ₂ O	N ₂ O	N ₂ O
			ppm	mg/Sm ³	mg/Sm ³ @ 11% O ₂
Unit 1 Run 1	13-Feb-19	09:55-10:55	4.50	8.24	7.88
Unit 1 Run 2	13-Feb-19	10:57-11:57	0.80	1.46	1.40
Unit 1 Run 3	13-Feb-19	12:00-13:00	0.80	1.46	1.40
Average					3.56
Unit 2 Run 1	13-Feb-19	09:30-10:30	0.60	1.10	1.02
Unit 2 Run 2	13-Feb-19	10:31-11:31	3.00	5.49	5.09
Unit 2 Run 3	13-Feb-19	11:32-12:32	0.40	0.73	0.68
Average					2.26
Unit 3 Run 1	13-Feb-19	09:09-10:09	6.40	11.71	10.1
Unit 3 Run 2	13-Feb-19	10:10-11:10	5.20	9.52	8.18
Unit 3 Run 3	13-Feb-19	11:12-12:12	9.70	17.75	15.3
Average					11.2

APPENDIX - D

FIELD DATA SHEETS

15.75

4.872 H

A

CLIENT MVRD				NOZZLE MV OR DIAMETER, IN. 3.048		IMPINGER		INITIAL	FINAL	TOTAL GAIN	
SOURCE UNIT #1				PROBE AL GND Cp 8660		VOLUMES		(mL)	(mL)	(mL)	
PARAMETER / RUN No 1015 / Partic				PORT LENGTH		Imp. #1		0	142	142	
DATE Feb. 11 / 19				STATIC PRESSURE, IN. H2O -19.00		Imp. #2		100	200	100	
OPERATOR: C.L.				STACK DIAMETER 70.90"		Imp. #3		100	155	55	
CONTROL UNIT AUTS Y 1.0232				STACK HEIGHT 30'		Imp. #4		0	10	10	
BAROMETRIC PRESSURE, IN. Hg 29.80				INITIAL LEAK TEST 0.001 @ 15"		Imp. #5		100	105	5	
ASSUMED MOISTURE, Bw 6.6				FINAL LEAK TEST 0.001 @ 15"		Imp. #6		100	103	3	
						Upstream Diameters					
						Downstream Diameters					

Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites			
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %		
1	12:25	886.22	1.40	1.95	42	300	250	250	42	4				
2		889.89	1.42	2.05	43	300	250	250	42	4				
3		893.62	1.42	2.05	43	303	250	250	42	4	10.0	10.5		
4		897.35	1.42	2.05	44	305	250	250	42	4				
5		900.99	1.45	2.19	44	305	250	250	45	4				
6		904.86	1.45	2.29	46	306	250	250	45	4				
7		908.82	1.47	2.58	46	308	250	250	50	4				
8		913.01	1.53	2.44	47	308	250	250	52	6	10.0	10.0		
9		917.07	1.50	1.85	47	307	250	250	52	6				
10		920.92	1.44	1.70	46	300	250	250	52	6				
11		924.47	1.38	1.61	47	295	250	250	49	6				
12		927.83	1.33	1.75	47	308	250	250	49	6				
13	931.19	1.33	1.95	47	308	250	250	50	6					
14	14:26	934.44	1.36	1.75	47	308	250	250	49	6				
15		938.28	1.40	1.95	47	308	250	250	50	6				
16		941.69	1.35	1.70	47	310	250	250	49	6	10.5	9.5		
17		945.10	1.35	1.70	48	312	250	250	49	6				
18		948.09	1.27	1.31	48	307	250	250	48	5				
19		951.08	1.27	1.31	48	307	250	250	48	5				
20		955.13	1.49	2.39	48	306	250	250	48	5				
21		959.27	1.52	2.53	48	306	250	250	48	5				
22		963.34	1.50	2.44	49	304	250	250	48	5	10.0	10.0		
23		967.42	1.50	2.44	49	302	250	250	50	5				
24		970.84	1.32	1.70	49	295	250	250	50	5				
25		974.07	1.32	1.56	50	290					10.0	10.5		

$$\sqrt{5.75} \text{ } 4.87 \Delta H$$
[illegible]

$$\sqrt{5.75} \quad 4.87 \Delta H$$

CLIENT				NOZZLE		DIAMETER, IN.		IMPINGING		INITIAL		FINAL		TOTAL GAIN	
SOURCE				PROBE		Cp		VOLUMES		(mL)		(mL)		(mL)	
PARAMETER / RUN No				PORT LENGTH				Imp. #1							
DATE				STATIC PRESSURE, IN. H2O				Imp. #2							
OPERATOR:				STACK DIAMETER				Imp. #3							
CONTROL UNIT				STACK HEIGHT				Imp. #4							
BAROMETRIC PRESSURE, IN. Hg				INITIAL LEAK TEST				Imp. #5							
ASSUMED MOISTURE, Bw				FINAL LEAK TEST				Imp. #6							
				Upstream Diameters				Downstream Diameters							

$\sqrt{5.75}$
 -6.03
 $4.87 \Delta H$
 $4.96 -$

CLIENT MVRD					NOZZLE MV 02 DIAMETER, IN. 3018					IMPINGER		INITIAL		FINAL		TOTAL GAIN	
SOURCE Unit #2					PROBE AL CURVED Cp 8660					VOLUMES		(mL)		(mL)		(mL)	
PARAMETER / RUN No 3 Metals / Partic					PORT LENGTH					Imp. #1		0		146		146	
DATE Feb 14/19					STATIC PRESSURE, IN. H ₂ O -19.50					Imp. #2		100		232		132	
OPERATOR: CL					STACK DIAMETER 20.90					Imp. #3		100		124		24	
CONTROL UNIT ST CAE 2 $\Delta H @$ 9870					STACK HEIGHT 30'					Imp. #4		0		14		14	
BAROMETRIC PRESSURE, IN. Hg 29.28					INITIAL LEAK TEST 0.001 @ 15"					Imp. #5		100		106		6	
ASSUMED MOISTURE, Bw 16%					FINAL LEAK TEST 0.001 @ 15"					Imp. #6		100		102		2	
										Upstream Diameters							
										Downstream Diameters							
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites						
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %					
	09:35	108.100															
1		112.15	.45	2.19	410	309	250	250	45	4							
2		116.28	.47	2.20	412	309	250	250	45	4							
3		120.54	.50	2.40	415	303	250	250	46	4	10.0	10.0					
4		124.80	.50	2.40	415	303	250	250	46	4							
5		128.93	.47	2.40	413	305	250	250	48	5	10.5	10.0					
6		132.34	.47	2.50	413	304	250	250	48	5							
7		135.53	.48	2.39	414	300	250	250	48	5							
8		138.50	.45	2.24	415	308	250	250	48	5							
9		141.39	.42	1.00	415	299	250	250	46	4							
10		144.91	.34	1.26	416	300	250	250	46	4							
11		148.11	.38	1.30	417	301	250	250	46	4	10.5	10.0					
12		151.19	.26	1.20	418	304	250	250	46	4							
1		154.60	.32	1.59	418	296	250	250	45	4							
2		158.17	.35	1.71	419	299	250	250	45	4							
3		161.30	.37	1.34	419	303	250	250	46	4							
4		164.49	.38	1.39	419	303	250	250	46	4							
5		167.68	.38	1.39	419	308	250	250	46	4	10.5	10.0					
6		170.99	.30	1.44	510	308	250	250	46	4							
7		175.34	.50	2.58	510	304	250	250	48	4							
8		180.17	.64	2.17	510	307	250	250	48	4							
9		184.84	.60	2.90	512	307	250	250	46	4	10.0	10.0					
10		189.82	.48	2.30	512	303	250	250	46	4							
11		193.94	.45	2.30	512	302	250	250	47	4							
12	11:37	196.98	.42	2.08	514	300	250	250	47	4							

$\sqrt{6.03} \quad 4.96 \Delta H$

CLIENT MVRD				NOZZLE MN 02		DIAMETER, IN. 3048		IMPINGER		INITIAL		FINAL		TOTAL GAIN	
SOURCE Unit #2				PROBE AL GURD		Cp 8660		VOLUMES		(mL)		(mL)		(mL)	
PARAMETER / RUN No 3 Metals/Partic				PORT LENGTH				Imp. #1		0		152		152	
DATE Feb. 14 / 19				STATIC PRESSURE, IN. H2O		70.90 - 19.50		Imp. #2		100		229		129	
OPERATOR: CL				STACK DIAMETER		70.90		Imp. #3		100		166		66	
CONTROL UNIT ST CAFE 2 Y 9870				STACK HEIGHT		30'		Imp. #4		0		22		22	
								Imp. #5		100		108		8	
								Imp. #6		100		103		3	
BAROMETRIC PRESSURE, IN. Hg 27.28				INITIAL LEAK TEST 8.00 (e 15)				Upstream Diameters							
ASSUMED MOISTURE, Bw 16%				FINAL LEAK TEST 8.00 (e 15)				Downstream Diameters							
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites				
	11:50	197.450			Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %			
1		200.86	32	1.59	53	303	250	250	48	5					
2		204.27	32	1.59	54	305	250	250	50	5	10.5	10.0			
3		207.69	32	1.59	53	307	250	250	50	5					
4		210.88	32	1.59	53	308	250	250	50	5					
5		214.07	32	1.59	53	310	250	250	50	5					
6		217.49	32	1.59	54	310	250	250	52	5	10.0	10.0			
7		222.16	60	2.18	54	310	250	250	52	5	10.0	10.0			
8		227.25	71	3.25	54	310	250	250	52	8					
9		232.46	75	3.32	55	312	250	250	52	8					
10		237.43	68	3.27	55	311	250	250	54	10	10.5	10.0			
11		242.54	66	3.27	56	310	250	250	54	10	10.5	10.0			
12		247.09	62	3.08	55	312									
13		251.48	53	2.63	55	314	250	250	56	7					
14		256.04	57	2.83	56	314	250	250	58	7	10.0	10.0			
15		260.72	60	2.88	56	315	250	250	58	7	10.0	10.0			
16		265.27	57	2.88	56	315	250	250	60	8					
17		269.82	57	2.88	56	314	250	250	60	8					
18		273.99	48	2.51	56	315	250	250	55	8	10.5	10.0			
19		277.41	22	1.19	56	313	250	250	55	8	10.5	10.0			
20		280.45	25	1.24	56	312	250	250	54	6					
21		283.37	22	0.94	56	312	250	250	54	6					
22		285.80	18	0.84	56	310	250	250	54	5	10.0	10.0			
23		288.56	18	0.84	56	309	250	250	52	5	10.0	10.0			
24		291.12	18	0.84	56	306									

A. Lanfranco and Associates Inc.

Client COVANTA Y LMU-A(9446)
 Source UNIT 2 Cp _____
 Parameter HIF Pbar 29.69 Static _____
 Date 2/14/19 Operator M. Gears

Leak Check	Run 1	Run 2	Run 3
Initial	0.0002	0.0002	0.0002
Final	0.0002	0.0002	0.0002

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	0958	296.4152	38					
			41					
			46					
	1028	296.8314	48					
			50					
			57					
	1058	297.1608	59					
2	1103	297.1682	55					
	1133	297.6080	59					
	1203	297.9832	64					
3	1210	297.9918	59					
	1240	298.4240	64					
	1310	298.7462	65					

Client COVANTA Y LMU-A(9446)
 Source UNIT 3 Cp _____
 Parameter HIF Pbar 29.53 Static _____
 Date 2/15/19 Operator M. Gears

Leak Check	Run 1	Run 2	Run 3
Initial	0.0002	0.0002	0.0002
Final	0.0002	0.0002	0.0002

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	0935	298.7504	51					
	1005	299.0624	52					
	1035	299.5760	55					
2	1046	299.5842	52					
	1116							
	1146	300.3982	56					
3	1157	300.4070	54					
	1257	301.2279	57					

APPENDIX – E

CALIBRATION SHEETS and

TECHNICIAN CERTIFICATES

A.Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: **AU 15**
Serial #: **0028SPC-081915-1**

Date: **07-Jan-19**
Barometric Pressure: **30.01** (in. Hg)
Theoretical Critical Vacuum: **14.16** (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}((in.Hg)²(min)).
!!!!!!!

----- DRY GAS METER READINGS -----										-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.			Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		Average (deg F)
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)					Initial (deg F)	Final (deg F)	
3.50	15.00	475.500	491.040	15.540	67.0	67.0	67.0	67.0		73	0.8185	15.5	67.0	67.0	67.0
1.84	15.00	527.700	538.988	11.288	70.0	70.0	71.0	71.0		63	0.5956	17.5	77.0	79.0	78.0
1.05	15.00	541.300	550.134	8.834	72.0	72.0	72.0	72.0		55	0.4606	19.0	73.0	80.0	76.5
0.61	15.00	551.900	558.647	6.747	72.0	72.0	72.0	72.0		48	0.3560	20.0	78.0	79.0	78.5
0.29	15.00	559.400	563.934	4.534	71.0	71.0	71.0	71.0		40	0.2408	21.0	76.0	82.0	79.0

***** RESULTS *****															
--- DRY GAS METER ---				----- ORIFICE -----		-- DRY GAS METER --				----- ORIFICE -----					
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL		CALIBRATION FACTOR		CALIBRATION FACTOR		dH@		Variation		Ko	
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)		Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Value (in H2O)	Value (mm H2O)	Value (in H2O)	Variation (in H2O)	Value (in H2O)	Variation (in H2O)
15.744	445.9	16.050	454.5	15.978		1.019	-0.004	1.728	43.89	1.728	43.89	0.046	0.046	0.731	0.731
11.315	320.4	11.559	327.4	11.747		1.022	-0.002	1.740	44.19	1.740	44.19	0.058	0.058	0.728	0.728
8.813	249.6	8.952	253.5	9.072		1.016	-0.007	1.651	41.93	1.651	41.93	-0.031	-0.031	0.752	0.752
6.724	190.4	6.906	195.6	7.025		1.027	0.004	1.611	40.93	1.611	40.93	-0.070	-0.070	0.754	0.754
4.523	128.1	4.669	132.2	4.754		1.032	0.009	1.679	42.65	1.679	42.65	-0.003	-0.003	0.735	0.735
Average Y----->						1.0232		Average dH@----->		1.682	42.7	Average Ko----->		0.740	

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature	Temperature Device	Results		
Set-Point (deg F)	Reading (deg F)	Variation (deg F)	Percent of Absolute	
32	32	0	0.00%	
100	100	0	0.00%	
300	300	0	0.00%	
500	500	0	0.00%	
1000	1000	0	0.00%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: 

Date: January 7, 2019

A.Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: **CAE G10J**
Serial #: **0028-1X1310-1**

Date: **15-Jan-19**
Barometric Pressure: **29.80** (in. Hg)
Theoretical Critical Vacuum: **14.06** (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}((in.Hg)²(min)).
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.70	16.00	710.500	727.584	17.084	71.0	71.0	71.0	71.0	73	0.8185	15.0	71.0	62.0	66.5
1.90	31.00	686.300	710.357	24.057	72.0	72.0	71.0	71.0	63	0.5956	18.0	76.0	63.0	69.5
1.15	25.00	641.400	656.520	15.120	76.0	76.0	74.0	74.0	55	0.4606	19.5	68.0	75.0	71.5
0.66	64.00	656.600	686.246	29.646	74.0	74.0	72.0	72.0	48	0.3560	21.0	75.0	76.0	75.5
0.35	17.00	728.000	733.358	5.358	71.0	71.0	69.0	69.0	40	0.2408	22.0	72.0	70.0	71.0

***** RESULTS *****														
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----					
VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (cu ft)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (cu ft)	CALIBRATION FACTOR Y Value (number)	Variation (number)			CALIBRATION FACTOR dH@ Value (in H2O)	Value (mm H2O)	Variation (in H2O)			Ko (value)
17.067	483.3	17.008	481.7	17.035	0.997	-0.002			1.824	46.33	-0.006			0.710
23.905	677.0	23.911	677.2	24.085	1.000	0.002			1.777	45.15	-0.053			0.718
14.899	421.9	14.884	421.5	15.049	0.999	0.000			1.794	45.56	-0.037			0.716
29.286	829.4	29.340	830.9	29.889	1.002	0.003			1.743	44.27	-0.088			0.725
5.319	150.6	5.294	149.9	5.348	0.995	-0.003			2.014	51.17	0.184			0.679
Average Y----->					0.9986	Average dH@----->			1.830	46.5	Average Ko---->			0.710

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Results		
		Variation (degF)	Percent of Absolute	
32	32	0	0.00%	
100	100	0	0.00%	
300	300	0	0.00%	
500	500	0	0.00%	
1000	1000	0	0.00%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: 

Date: January 15, 2019

A.Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: **ST CAE2**
Serial #: **0028-072911-1**

Date: **08-Jan-19**
Barometric Pressure: **29.89** (in. Hg)
Theoretical Critical Vacuum: **14.10** (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}((in.Hg)²(min)).
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.70	15.00	651.400	667.417	16.017	68.0	68.0	70.0	70.0	73	0.8185	13.0	73.0	79.0	76.0
1.95	15.00	634.800	646.537	11.737	66.0	66.0	68.0	68.0	63	0.5956	17.1	68.0	72.0	70.0
1.15	15.00	669.700	678.825	9.125	70.0	70.0	70.0	70.0	55	0.4606	17.6	72.0	78.0	75.0
0.69	15.00	679.400	686.359	6.959	71.0	71.0	71.0	71.0	48	0.3560	18.5	78.0	72.0	75.0
0.33	15.00	686.500	691.239	4.739	70.0	70.0	71.0	71.0	40	0.2408	19.5	75.0	75.0	75.0

***** RESULTS *****														
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----					
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR			CALIBRATION FACTOR					
Vm(std)	Vm(std)		Vcr(std)	Vcr(std)	Vcr	Value	Y		Value	Value	Variation	dH@		Ko
(cu ft)	(liters)		(cu ft)	(liters)	(cu ft)	(number)	(number)		(in H2O)	(mm H2O)	(in H2O)			(value)
16.110	456.2		15.851	448.9	16.114	0.984	-0.003		1.858	47.20	0.011			0.704
11.799	334.2		11.599	328.5	11.660	0.983	-0.004		1.836	46.63	-0.012			0.710
9.103	257.8		8.928	252.8	9.059	0.981	-0.006		1.817	46.16	-0.031			0.716
6.922	196.0		6.901	195.4	7.002	0.997	0.010		1.822	46.27	-0.026			0.704
4.714	133.5		4.668	132.2	4.736	0.990	0.003		1.906	48.41	0.058			0.694
Average Y----->						0.9870	Average dH@----->		1.848	46.9	Average Ko----->		0.706	

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature	Temperature Device	Results		
Set-Point (deg F)	Reading (deg F)	Variation (degF)	Percent of Absolute	
32	32	0	0.00%	
100	100	0	0.00%	
300	300	0	0.00%	
500	500	0	0.00%	
1000	1000	0	0.00%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: 

Date: January 8, 2019

A. Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: **LMU-A**
Serial #: **Kimmon 186**

Date: **10-Jan-19**
Barometric Pressure: **30.01** (in. Hg)
Theoretical Critical Vacuum: **14.16** (in. Hg)

!!!!!!!

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (m³)	Volume Final (m³)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
0.00	16.00	288.3510	288.5002	5.269	64.0	64.0	65.0	65.0	40	0.2408	20.0	69.0	69.0	69.0
0.00	18.00	288.5100	288.6789	5.965	65.0	65.0	65.0	65.0	40	0.2408	20.0	69.0	68.0	68.5
0.00	15.00	288.6830	288.8228	4.937	65.0	65.0	66.0	66.0	40	0.2408	20.0	68.0	70.0	69.0

***** RESULTS *****											
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----		
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR			CALIBRATION FACTOR		
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)		Value (in H2O)	Value (mm H2O)	Variation (in H2O)
5.318	150.6		5.027	142.4	5.023	0.945	0.001		0.000	0.00	0.000
6.014	170.3		5.658	160.2	5.649	0.941	-0.004		0.000	0.00	0.000
4.973	140.8		4.713	133.5	4.710	0.948	0.003		0.000	0.00	0.000
Average Y----->						0.9446	Average dH@----->		0.0000	0.00	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

For Temperature Devicee, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: 

Date: January 10, 2019

A. LANFRANCO and ASSOCIATES INC.

ENVIRONMENTAL CONSULTANTS

GLASS NOZZLE DIAMETER CALIBRATION FORM

Calibrated by: Michael Goods

Date: Jan 7th 2019

Signature: 

Nozzle I.D.	d1 (inch)	d2 (inch)	d3 (inch)	difference (inch)	average dia. (inch)	average area (ft ²)
A	0.1250	0.1240	0.1245	0.0010	0.1245	0.0000845
G-165	0.1640	0.1655	0.1660	0.0020	0.1652	0.0001488
P-20	0.1855	0.1865	0.1835	0.0030	0.1852	0.0001870
J	0.1880	0.1880	0.1880	0.0000	0.1880	0.0001928
E	0.1880	0.1895	0.1882	0.0015	0.1886	0.0001939
L	0.2112	0.2120	0.2105	0.0015	0.2112	0.0002434
G-215	0.2160	0.2150	0.2130	0.0030	0.2147	0.0002513
Q	0.2190	0.2170	0.2185	0.0020	0.2182	0.0002596
G-222	0.2215	0.2220	0.2215	0.0005	0.2217	0.0002680
G-225	0.2245	0.2250	0.2240	0.0010	0.2245	0.0002749
P-18	0.2375	0.2370	0.2380	0.0010	0.2375	0.0003076
V-07	0.2447	0.2450	0.2445	0.0005	0.2447	0.0003267
G-250	0.2500	0.2505	0.2510	0.0010	0.2505	0.0003422
G-252	0.2525	0.2520	0.2530	0.0010	0.2525	0.0003477
P	0.2580	0.2570	0.2575	0.0010	0.2575	0.0003616
G-278	0.2775	0.2785	0.2790	0.0015	0.2783	0.0004225
P-2	0.2787	0.2790	0.2785	0.0005	0.2787	0.0004237
G-292	0.2922	0.2920	0.2926	0.0006	0.2923	0.0004659
MV-02	0.3050	0.3040	0.3055	0.0015	0.3048	0.0005068
MV-01	0.3060	0.3065	0.3055	0.0010	0.3060	0.0005107
G-309	0.3095	0.3095	0.3085	0.0010	0.3092	0.0005213
V-06	0.3200	0.3210	0.3210	0.0010	0.3207	0.0005608
G-330	0.3295	0.3300	0.3305	0.0010	0.3300	0.0005940
G-337	0.3380	0.3355	0.3365	0.0025	0.3367	0.0006182
P-27	0.3387	0.3385	0.3390	0.0005	0.3387	0.0006258
G-343	0.3435	0.3430	0.3435	0.0005	0.3433	0.0006429
G-349	0.3490	0.3495	0.3495	0.0005	0.3493	0.0006656
P-9	0.3648	0.3650	0.3645	0.0005	0.3648	0.0007257
G-372	0.3710	0.3730	0.3740	0.0030	0.3727	0.0007575
I	0.3785	0.3785	0.3785	0.0000	0.3785	0.0007814
P-14	0.3910	0.3935	0.3920	0.0025	0.3922	0.0008388
P-17	0.4070	0.4075	0.4065	0.0010	0.4070	0.0009035
C	0.4255	0.4225	0.4235	0.0030	0.4238	0.0009798
G-437	0.4350	0.4345	0.4355	0.0010	0.4350	0.0010321
P-29	0.4680	0.4680	0.4690	0.0010	0.4683	0.0011963
G468	0.4677	0.4670	0.4670	0.0007	0.4672	0.0011907
P-7	0.4965	0.4940	0.4930	0.0035	0.4945	0.0013337
B	0.5015	0.5030	0.5025	0.0015	0.5023	0.0013763
G-540	0.5405	0.5400	0.5405	0.0005	0.5403	0.0015924

Where:

(a) D1, D2, D3 = three different nozzle diameters; each diameter must be measured to within (0.025mm) 0.001 in.

(b) Difference = maximum difference between any two diameters; must be less than or equal to (0.1mm) 0.004 in.

(c) Average = average of D1, D2 and D3

Pitot Tube Calibration

Date: 14-Jan-19
Pbar (in.Hg): 29.69

Temp (R): 530
Dn (in.): 0.25

Pitot ID: 7A-1				
Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.350	0.510	39.3	0.8201	0.0039
0.460	0.670	45.1	0.8203	0.0038
0.530	0.770	48.4	0.8213	0.0027
0.640	0.910	53.2	0.8302	0.0062
0.700	1.000	55.6	0.8283	0.0042
Average :			0.8241	0.0042

Pitot ID:				
Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
		0.0	#DIV/0!	#DIV/0!
		0.0	#DIV/0!	#DIV/0!
		0.0	#DIV/0!	#DIV/0!
		0.0	#DIV/0!	#DIV/0!
		0.0	#DIV/0!	#DIV/0!
Average :			#DIV/0!	#DIV/0!

Pitot ID: 7B				
Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.360	0.490	39.9	0.8486	0.0082
0.480	0.640	46.0	0.8574	0.0006
0.570	0.760	50.2	0.8574	0.0006
0.640	0.850	53.2	0.8590	0.0022
0.750	0.990	57.6	0.8617	0.0049
Average :			0.8568	0.0033

Pitot ID:				
Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
		0.0	#DIV/0!	#DIV/0!
		0.0	#DIV/0!	#DIV/0!
		0.0	#DIV/0!	#DIV/0!
		0.0	#DIV/0!	#DIV/0!
		0.0	#DIV/0!	#DIV/0!
Average :			#DIV/0!	#DIV/0!

Pitot ID: AL GVRD 1				
Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.100	0.130	21.0	0.8683	0.0023
0.200	0.260	29.7	0.8683	0.0023
0.350	0.460	39.3	0.8636	0.0024
0.540	0.700	48.8	0.8695	0.0035
0.740	0.980	57.2	0.8603	0.0057
Average :			0.8660	0.0033

Pitot ID:				
Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
Average :				

Pitot ID: 7C				
Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.030	0.040	11.5	0.8574	0.0094
0.160	0.220	26.6	0.8443	0.0037
0.280	0.390	35.2	0.8388	0.0092
0.490	0.670	46.5	0.8466	0.0014
0.720	0.970	56.4	0.8529	0.0049
Average :			0.8480	0.0057

Pitot ID:				
Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
Average :				

* Average absolute deviation must not exceed 0.01.

Calibrated by: Jeremy Gibbs

Signature: _____



Date: January 14, 2019

BAROMETER CALIBRATION FORM

Device	Cal Date	Pbar Env Canada		Device (inches of Hg)		Difference
		(kPa)	(inches of Hg)	Reading	Elevation Corrected	(Env Can - Elv Corr)
LA	July 17, 2018	101.6	30.01	29.90	29.97	0.04
DS	July 17, 2018	101.6	30.01	29.91	29.98	0.03
CL	July 17, 2018	101.6	30.01	29.89	29.96	0.05
ML	July 17, 2018	101.6	30.01	29.90	29.97	0.04
MH	July 17, 2018	101.6	30.01	29.91	29.98	0.03
SH	July 17, 2018	101.6	30.01	29.91	29.98	0.03
JB	July 17, 2018	101.6	30.01	29.97	30.04	-0.03
SF	July 17, 2018	101.6	30.01	29.99	30.06	-0.05
JG	July 17, 2018	101.6	30.01	29.89	29.96	0.05
SB	July 17, 2018	101.6	30.01	29.89	29.96	0.05

Calibrated by: Daryl Sampson

Signature: 

Date: July 17, 2018

Performance Specification is

Device Corrected for Elevation must be +/- 0.1 " Hg of ENV CANADA SEA-LEVEL Pbar

Enter Environment Canada Pressure from their website for Vancouver (link below) and the reading from your barometer on the ground floor of the office.


http://www.weatheroffice.gc.ca/city/pages/bc-74_metric_e.html

A. LANFRANCO and ASSOCIATES INC.
ENVIRONMENTAL CONSULTANTS

TEMPERATURE CALIBRATION FORM

Calibrated by: Daryl Sampson
Date: January 17, 2019

Signature: _____



K-TYPE THERMOCOUPLE CALIBRATIONS

Probe/TC ID	Hg Thermometer Temp (°F)	CL23A Readout (F)		Probe/TC ID	Hg Thermometer Temp (°F)	CL23A Readout (F)
3B	212	211		TC 3-3	211	212
3C	212	212		TC 4-3	211	212
4A	212	212		TC 4-4	210	212
4B	211	212		TC 5-4	212	212
5A	212	212		TC 5-5	n/a	n/a
5B	212	211		TC 5-6	211	213
5C	211	213		TC 6-4	212	212
5D	212	213		TC 10-3	211	211
6A	212	211				
6B	212	212				
6C	212	210				
7C	211	210				
8A	211	211				
8B	211	212				
10A	212	212				
10B	212	213				
11A	211	210				
12A	212	211				
12B	210	210				

* n/a denotes not in service

A. LANFRANCO and ASSOCIATES INC.
ENVIRONMENTAL CONSULTANTS

TEMPERATURE CALIBRATION FORM

Calibrated by: Daryl Sampson

Date: 9-Jan-19

Signature:



TEMPERATURE DEVICE CALIBRATIONS

Reference Device			Temperature Settings (degrees F)													
Model CL23A Calibrator			32		100		200		300		500		800		1700	
Device	ALA #	Serial #	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation
Omega HH11A	3	300132	32	0.00%	100	0.00%	201	0.15%	301	0.13%	498	-0.21%	801	0.08%	1701	0.05%
Omega HH11A	4	200167	33	0.20%	100	0.00%	200	0.00%	300	0.00%	499	-0.10%	799	-0.08%	1698	-0.09%
Omega HH11A	6	600059	33	0.20%	100	0.00%	201	0.15%	300	0.00%	500	0.00%	798	-0.16%	1699	-0.05%
TPI 341K	7	2.0315E+10	32	0.00%	101	0.18%	200	0.00%	299	-0.13%	500	0.00%	797	-0.24%	1696	-0.19%
TPI 341K	8	2.0313E+10	32	0.00%	99	-0.18%	199	-0.15%	299	-0.13%	499	-0.10%	799	-0.08%	1696	-0.19%
Cont Cmpny	10	102008464	32	0.00%	101	0.18%	200	0.00%	300	0.00%	498	-0.21%	798	-0.16%	1698	-0.09%
Omega HH11	14	409426	32	0.00%	100	0.00%	201	0.15%	301	0.13%	499	-0.10%	800	0.00%	1698	-0.09%
TPI 341K	16	400120029	31	-0.20%	98	-0.36%	199	-0.15%	299	-0.13%	501	0.10%	800	0.00%	1701	0.05%
TPI 341K	17	2.0329E+10	30	-0.41%	98	-0.36%	198	-0.30%	298	-0.26%	497	-0.31%	797	-0.24%	1696	-0.19%
TPI 341K	18	2.0329E+10	32	0.00%	100	0.00%	200	0.00%	300	0.00%	499	-0.10%	797	-0.24%	1698	-0.09%
TPI 341K	19	2.0329E+10	30	-0.41%	98	-0.36%	198	-0.30%	298	-0.26%	497	-0.31%	797	-0.24%	1695	-0.23%
TPI 341K	20	2.0329E+10	33	0.20%	99	-0.18%	199	-0.15%	299	-0.13%	498	-0.21%	799	-0.08%	1699	-0.05%

Reference device is a NIST certified digital thermocouple calibrator

Variation expressed as a percentage of the absolute temperature must be within 1.5 %

MOUNT ROYAL UNIVERSITY

Faculty of Continuing Education and Extension

Scott Ferguson

has successfully completed

Stack Sampling

2016

May 16, 2016

Date



Dean

Faculty of Continuing Education and Extension





MOUNT ROYAL COLLEGE

Faculty of Continuing Education and Extension

Carter Lanfranco

has successfully completed

Stack Sampling

May 2009

Date

Dean
Faculty of Continuing Education and Extension

Shawn Harrington

has met the requirements of

Stack Testing for Pollutants
(CHSC 7760)

School of Process, Energy and Natural Resources
Chemical Sciences Program

Endorsed by:




Environment
Canada

Environnement
Canada



Province of
British Columbia
Ministry of
Environment,
Lands and Parks


Marsh Hemekey, Dean
School of Process, Energy and Natural Resources

JUNE 21, 2001
Dated