



**A.Lanfranco
& Associates Inc.**

Environmental Consultants

Prepared for

METRO VANCOUVER

Metrotower III 4730 Kingsway
Burnaby, BC V5H 0C6

WASTE TO ENERGY FACILITY

Appendices of Compliance Emissions Testing Report

February 2020 Survey

Table of Contents

Appendix

- A Quality Assurance / Quality Control Results
- B Laboratory Results
- C Computer Generated Results
- D Field Data Sheets
- E Calibration Sheets and Technician Certificates

APPENDIX – A

QUALITY ASSURANCE / QUALITY CONTROL RESULTS

Quality assurance / quality control (QA/QC) is divided into four categories: administration, preparation, testing, and analysis. The following sections detail results found for the above four categories.

Administration:

- All field, process, and analytical data was reviewed to ensure data integrity and accuracy.
- Duplicate proof of draft and final report, including data entry, conducted.

Preparation:

- All glassware cleaned
- Blank samples of reagents collected.

Testing:

- Stack diameter and absence of cyclonic flow confirmed
- Calibrated magnehelic used for all velocity measurements
- All trains past pre- and post- leak checks.
- Isokinetics all within $100\% \pm 10\%$.

Analysis:

- Trace Metals and Mercury analysis conducted at Element Labs, Surrey, B.C.
- Fluoride (HF) analysis conducted at ALS Environmental in Burnaby, B.C.
- Nitrous Oxide (N₂O) analysis conducted at Maxxam Analytics, Mississauga, Ont.
- Particulate analysis conducted at A. Lanfranco and Associates Inc., Surrey, BC.
- Chain of Custody protocols followed for all samples.
- Excellent blank values for all sample types. All samples blank corrected.

Sample Type	Blank Value		
	Unit 1	Unit 2	Unit 3
First Q 2020 Survey			
Filter	-0.2 mg	-0.1 mg	-0.3 mg
Front Half Washings	-0.1 mg	-0.8 mg	-1.5 mg
Mercury Front	0.00 ug	0.00 ug	0.00 ug
Mercury Back	0.03 ug	0.04 ug	0.04 ug
Trace Metals Front *	<37.0 ug	<42.4 ug	<40.3 ug
Trace Metals Back*	<28.6 ug	<20.0 ug	<20.0 ug
Fluoride	<5.0 ug	<5.0 ug	<5.0 ug

Sum of all reported elements except Hg*

APPENDIX - B

LABORATORY RESULTS

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Filter Reagent Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411877**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497065

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com

<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge Reports	PDF	COC / Test Report
Email - Multiple Reports By Agreement	PDF	COA

Notes To Clients:

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Filter Reagent Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411877**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497065

		Reference Number	1411877-1	1411877-2	1411877-3
		Sample Date	Feb 24, 2020	Feb 24, 2020	Feb 24, 2020
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Reagent Blank Unit 1 Container 1 (filter)	Reagent Blank Unit 2 Container 1 (filter)	Reagent Blank Unit 3 Container 1 (filter)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	6	<5	<5	5
Antimony	µg	<2	<2	4	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	<0.2	0.57	0.49	0.2
Cobalt	µg	<0.3	<0.3	<0.3	0.25
Copper	µg	2	3.5	2	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	<0.3	<0.3	<0.3	0.25
Nickel	µg	<0.5	<0.5	<0.5	0.5
Phosphorus	µg	40	41	43	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	3.4	4.0	2.8	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	0.7	2	2	0.5
Mercury by CVAA					
Mercury	As Tested	µg/L	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	250	250	250
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02

Approved by:



Matthew Norman, BSc, PChem
Operations Chemist

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Filter Reagent Blanks Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1411877 Control Number: Date Received: Mar 3, 2020 Date Reported: Mar 25, 2020 Report Number: 2497065
Attn: Missy Sampled By: Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 23, 2020	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2020	Element Vancouver

** Reference Method Modified*

References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.



www.Element.com

Project Information

Project ID: Metro Vancouver WTE
Project Name: Filter Reagent Blanks
Project Location:
Legal Location:
PO/AFE#:
Proj. Acct. Code:
Quote #:

Invoice To

Company: A. Lanfranco & Associates Inc.
Address: 101-9488 189 Street
Surrey BC, V4N 4W7
Attention:
Phone: 604-881-2582
Cell:
Fax:
E-mail: mark.lanfranco@alanfranco.com
Agreement ID:
Copy of Report: YES / NO

Report To

Company:
Address:
Attention:
Phone:
Cell:
Fax:
E-mail 1:
E-mail 2:
Copy of Invoice: YES / NO

Additional Reports to

1) Name:
E-mail:
2) Name:
E-mail:
Sample Custody
Sampled by:
Company:
I authorize Element to proceed with the work indicated on this form:
Signature:
Date/Time:

Report Results

Requirements

- ☐ Same Day (200%)
☐ Next Day/Two Day (100%)
☐ Three or Four Days (50%)
☒ 5 to 7 Days (Regular TAT)

When "ASAP" is requested, turn around will default to a 100% RUSH priority, with pricing and turn around time to match. Please contact the lab prior to submitting RUSH samples. If not all samples require RUSH, please indicate in the special instructions.

- ☒ Email ☐ QA/QC
☐ Online ☒ PDF
☐ Fax ☐ Excel

- ☐ HCDWORG ☐ SPIGEC
☐ AB Tier 1 ☐ BCCSR
Other (list below)

Date Required

Special Instructions/Comments (please include contact information including phone number if different from above).

* Please report µg/sample

Site I.D.	Sample Description	Depth start end in cm m	Date/Time sampled	Matrix	Sampling method	Number of Containers	ICAP	Hg	Enter tests above (✓ relevant samples below)											
1	Reagent Blank Unit 1 Container 1(filter)		24-Feb-20			1	✓	✓												
2																				
3	Reagent Blank Unit 2 Container 1 (filter)		24-Feb-20			1	✓	✓												
4																				
5	Reagent Blank Unit 3 Container 1 (filter)		24-Feb-20			1	✓	✓												
6																				
7																				
8																				
9																				
10																				
11																				
12																				
13																				
14																				
15																				

Please indicate any potentially hazardous samples

Submission of this form acknowledges acceptance of Element's Standard of terms and conditions (<https://www.element.com/terms/terms-and-conditions>)

Page ____ of ____ Control #
ED 120-005

Lot: 1411877 COC



Temp. received: 72 °C Date/Time stamp: MAR 3 '20 14:00
Delivery Method: HD
Waybill:
Received by: LC

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Reagent Blanks Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1411873 Control Number: Date Received: Mar 3, 2020 Date Reported: Mar 25, 2020 Report Number: 2497060
Attn: Missy Sampled By: Company:		

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com

Delivery	Format	Deliverables
Email - Merge Reports	PDF	COC / Test Report
Email - Multiple Reports By Agreement	PDF	COA

Notes To Clients:

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Reagent Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411873**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497060

		Reference Number	1411873-1	1411873-2	1411873-3
		Sample Date	Feb 24, 2020	Feb 24, 2020	Feb 24, 2020
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Reagent Blank Unit 1	Reagent Blank Unit 2	Reagent Blank Unit 3
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	<5	<5	<5	5
Antimony	µg	3	<2	3	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	<0.2	0.57	<0.2	0.2
Cobalt	µg	<0.3	<0.3	<0.3	0.25
Copper	µg	2	1	2	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	<0.3	<0.3	<0.3	0.25
Nickel	µg	<0.5	<0.5	<0.5	0.5
Phosphorus	µg	4	5	4	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	2.6	3.6	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2	0.8	<0.5	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	<5	<5	6	5
Antimony	µg	3	<3	<3	2.5
Arsenic	µg	3.5	1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	0.56	0.38	0.50	0.2
Cobalt	µg	<0.3	<0.3	<0.3	0.25
Copper	µg	<0.3	3.4	1	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	1	<0.3	<0.3	0.25
Nickel	µg	0.8	0.8	0.6	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	3	<2	<2	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	<0.5	<0.5	<0.5	0.5
Volume	Sample	mL	210	215	215
Volume	aliquot volume	mL	160	165	165
Mercury by CVAA					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	250	250	250

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Reagent Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411873**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497060

		Reference Number	1411873-1	1411873-2	1411873-3
		Sample Date	Feb 24, 2020	Feb 24, 2020	Feb 24, 2020
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Reagent Blank Unit 1	Reagent Blank Unit 2	Reagent Blank Unit 3
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Mercury by CVAA - Continued					
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	210	215	215
Volume	aliquot volume	mL	5.0	5.0	5.0
Volume	Final	mL	43	43	43
Mercury	Fraction 2B	µg/sample	<0.09	<0.09	<0.09
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	110	110	110
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3A	µg/sample	<0.009	<0.009	<0.009
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	250	250	250
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3B	µg/sample	<0.02	<0.02	<0.02
Mercury	As Tested	µg/L	0.09	0.13	0.08
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	200	200	200
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3C	µg/sample	0.03	0.041	0.03

Approved by:



Matthew Norman, BSc, PChem
Operations Chemist

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Reagent Blanks Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1411873 Control Number: Date Received: Mar 3, 2020 Date Reported: Mar 25, 2020 Report Number: 2497060
Attn: Missy Sampled By: Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 12, 2020	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2020	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Mar 12, 2020	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 23, 2020	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Mar 23, 2020	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2020	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2020	Element Vancouver

* Reference Method Modified

References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.



www.Element.com

Project Information

Project ID: Metro Vancouver WTE
Project Name: Reagent Blanks
Project Location:
Legal Location:
PO/AFE#:
Proj. Acct. Code:
Quote #:

Invoice To

Company: A. Lanfranco & Associates Inc.
Address: 101-9488 189 Street
Surrey BC, V4N 4W7
Attention:
Phone: 604-881-2582
Cell:
Fax:
E-mail: mark.lanfranco@alanfranco.com
Agreement ID:
Copy of Report: YES / NO

Report To

Company:
Address:
Attention:
Phone:
Cell:
Fax:
E-mail 1:
E-mail 2:
Copy of Invoice: YES / NO

Additional Reports to

1) Name:
E-mail:
2) Name:
E-mail:
Sample Custody
Sampled by:
Company:
I authorize Element to proceed with the work indicated on this form:
Signature:

Report Results

Requirements

Date/Time:

- ☐ Same Day (200%)
☐ Next Day/Two Day (100%)
☐ Three or Four Days (50%)
☒ 5 to 7 Days (Regular TAT)

When "ASAP" is requested, turn around will default to a 100% RUSH priority, with pricing and turn around time to match. Please contact the lab prior to submitting RUSH samples. If not all samples require RUSH, please indicate in the special instructions.

- ☒ Email ☐ QA/QC
☐ Online ☒ PDF
☐ Fax ☐ Excel

- ☐ HCDWORG ☐ SPIGEC
☐ AB Tier 1 ☐ BCCSR
Other (list below)

Date Required

Special Instructions/Comments (please include contact information including phone number if different from above).

*Front and Back ICAP as per EPA Method 29. *Hg analysis as per EPA Method 29. *Please report µg/sample.

	Site I.D.	Sample Description	Depth start end in cm m		Date/Time sampled	Matrix	Sampling method	Number of Containers ↓	Enter tests above (✓ relevant samples below)									
									Front ICAP	Back ICAP	Front Hg	Back Hg	5A Hg	5B Hg				
1		Reagent Blank Unit 1			24-Feb-20			5	✓	✓	✓	✓	✓	✓				
2																		
3		Reagent Blank Unit 2			24-Feb-20			5	✓	✓	✓	✓	✓	✓				
4																		
5		Reagent Blank Unit 3			24-Feb-20			5	✓	✓	✓	✓	✓	✓				
6																		
7																		
8																		
9																		
10																		
11																		
12																		
13																		
14																		
15																		

Please indicate any potentially hazardous samples

Submission of this form acknowledges acceptance of Element's Standard of terms and conditions (<https://www.element.com/terms/terms-and-conditions>)

Page ____ of ____ Control #
ED 120-005

Lot: 1411873^{COC}



Temp. received: 17.2 °C Date/Time stamp: MAR 3 '20 13:58
Delivery Method: HD
Waybill:
Received by: LC

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Field Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411865**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497049

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com

<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge Reports	PDF	COC / Test Report
Email - Multiple Reports By Agreement	PDF	COA

Notes To Clients:

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Field Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411865**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497049

		Reference Number	1411865-1	1411865-2	1411865-3
		Sample Date	Feb 25, 2020	Feb 26, 2020	Feb 27, 2020
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Field Blank Unit 1 (Beaker (MV Unit 1 Blank + 4 Bottles)	Field Blank Unit 2 (Beaker (MV Unit 2 Blank + 4 Bottles)	Field Blank Unit 3 (Beaker (MV Unit 3 Blank + 4 Bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	7	7	8	5
Antimony	µg	4	<2	<2	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	<0.2	0.35	0.29	0.2
Cobalt	µg	<0.3	<0.3	<0.3	0.25
Copper	µg	1	2.8	2	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	<0.3	0.3	0.3	0.25
Nickel	µg	<0.5	<0.5	<0.5	0.5
Phosphorus	µg	30	35	32	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	4.0	3.1	3.3	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2	2	1	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	6	5	<5	5
Antimony	µg	<2	4	<2	2.5
Arsenic	µg	2	<0.9	<0.9	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	0.57	0.40	<0.2	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	1	0.3	<0.2	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	<0.2	0.3	<0.2	0.25
Nickel	µg	0.8	1	0.9	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	<1	<1	<1	1.5
Tellurium	µg	3.7	<2	2	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	<1.0	<0.9	<0.9	1
Zinc	µg	<0.5	<0.5	<0.5	0.5
Volume	Sample	mL	300	350	340
Volume	aliquot volume	mL	250	300	290
Mercury by CVAA					
Mercury	As Tested	µg/L	<0.05	<0.05	0.05

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Field Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411865**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497049

		Reference Number	1411865-1	1411865-2	1411865-3	Nominal Detection Limit
		Sample Date	Feb 25, 2020	Feb 26, 2020	Feb 27, 2020	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Field Blank Unit 1 (Beaker (MV Unit 1 Blank + 4 Bottles)	Field Blank Unit 2 (Beaker (MV Unit 2 Blank + 4 Bottles)	Field Blank Unit 3 (Beaker (MV Unit 3 Blank + 4 Bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	
Mercury by CVAA - Continued						
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	300	350	340	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	<0.1	<0.1	<0.1	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	140	115	175	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.01	<0.009	<0.01	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	500	500	500	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.04	<0.04	<0.04	
Mercury	As Tested	µg/L	0.10	0.12	0.12	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.033	0.037	0.038	

Approved by:



Matthew Norman, BSc, PChem
Operations Chemist

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Field Blanks Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1411865 Control Number: Date Received: Mar 3, 2020 Date Reported: Mar 25, 2020 Report Number: 2497049
Attn: Missy Sampled By: Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 12, 2020	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2020	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Mar 12, 2020	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 23, 2020	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Mar 23, 2020	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2020	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2020	Element Vancouver

** Reference Method Modified*

References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.



www.Element.com

Project Information

Project ID: Metro Vancouver WTE
Project Name: Field Blanks
Project Location:
Legal Location:
PO/AFE#:
Proj. Acct. Code:
Quote #:

Invoice To
Company: A. Lanfranco & Associates Inc.
Address: 101-9488 189 Street
Surrey BC, V4N 4W7
Attention:
Phone: 604-881-2582
Cell:
Fax:
E-mail: mark.lanfranco@alanfranco.com
Agreement ID:
Copy of Report: YES / NO

Report To
Company:
Address:
Attention:
Phone:
Cell:
Fax:
E-mail 1:
E-mail 2:
Copy of Invoice: YES / NO

Additional Reports to
1) Name:
E-mail:
2) Name:
E-mail:
Sample Custody
Sampled by:
Company:
I authorize Element to proceed with the work indicated on this form:
Signature:
Date/Time:

Report Results

Requirements

- ☐ Same Day (200%)
☐ Next Day/Two Day (100%)
☐ Three or Four Days (50%)
☒ 5 to 7 Days (Regular TAT)

When "ASAP" is requested, turn around will default to a 100% RUSH priority, with pricing and turn around time to match. Please contact the lab prior to submitting RUSH samples. If not all samples require RUSH, please indicate in the special instructions.

- ☒ Email ☐ QA/QC
☐ Online ☒ PDF
☐ Fax ☐ Excel

- ☐ HCDWORG ☐ SPIGEC
☐ AB Tier 1 ☐ BCCSR
Other (list below)

Date Required

Special Instructions/Comments (please include contact information including phone number if different from above).

*Front and Back ICAP as per EPA Method 29. *Hg analysis as per EPA Method 29. *Please report µg/sample.

	Site I.D.	Sample Description	Depth start end in cm m	Date/Time sampled	Matrix	Sampling method	Number of Containers ↓	Front ICAP	Back ICAP	Front Hg	Back Hg	5A Hg	5B Hg								
1		Field Blank Unit 1 ('MV Unit 1 Blank' + 4 Bottles)		25-Feb-20			5	✓	✓	✓	✓	✓	✓								
2																					
3		Field Blank Unit 2 ('MV Unit 2 Blank' + 4 Bottles)		26-Feb-20			5	✓	✓	✓	✓	✓	✓								
4																					
5		Field Blank Unit 3 ('MV Unit 3 Blank' + 4 Bottles)		27-Feb-20			5	✓	✓	✓	✓	✓	✓								
6																					
7																					
8																					
9																					
10																					
11																					
12																					
13																					
14																					
15																					

Please indicate any potentially hazardous samples

Submission of this form acknowledges acceptance of Element's Standard of terms and conditions (<https://www.element.com/terms/terms-and-conditions>)

Page _____ of _____ Control #
ED 120-005

Lot: 1411865 COC



Temp. received: 17.2 °C Date/Time stamp: MAR 8 '20 13:58
Delivery Method: HD
Waybill:
Received by: LC

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411857**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497041

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com

<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge Reports	PDF	COC / Test Report
Email - Multiple Reports By Agreement	PDF	COA

Notes To Clients:

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411857**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497041

	Reference Number	1411857-1	1411857-2	1411857-3	
	Sample Date	Feb 24, 2020	Feb 25, 2020	Feb 25, 2020	
	Sample Time	NA	NA	NA	
	Sample Location				
	Sample Description	Unit 1 Run 1 (MV Unit 1 R-1 + 4 bottles)	Unit 1 Run 2 (MV Unit 1 R-2 + 4 bottles)	Unit 1 Run 3 (MV Unit 1 R-3 + 4 bottles)	
	Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	7	10	10	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<1	<1	1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	0.86	2.2	1.1	0.2
Cobalt	µg	<0.3	0.3	<0.3	0.25
Copper	µg	2	2	2	0.25
Lead	µg	<2	2	<2	1.5
Manganese	µg	0.8	1	0.8	0.25
Nickel	µg	<0.5	2	2	0.5
Phosphorus	µg	37	45	44	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	<2	2	2
Thallium	µg	2.6	6.4	4.3	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2.7	5.8	2	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	20	28	10	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	1	<0.9	<0.9	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	1.8	2.90	0.41	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	2	2.4	0.5	0.25
Lead	µg	<1	7.2	<1	1.5
Manganese	µg	0.3	186	<0.2	0.25
Nickel	µg	0.8	2	0.7	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	<1	2	<1	1.5
Tellurium	µg	4.1	4.2	2.7	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	8.2	6.4	<0.4	0.5
Volume	Sample	mL	775	835	795
Volume	aliquot volume	mL	725	785	745
Mercury by CVAA					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411857**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497041

		Reference Number	1411857-1	1411857-2	1411857-3	Nominal Detection Limit
		Sample Date	Feb 24, 2020	Feb 25, 2020	Feb 25, 2020	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 1 Run 1 (MV Unit 1 R-1 + 4 bottles)	Unit 1 Run 2 (MV Unit 1 R-2 + 4 bottles)	Unit 1 Run 3 (MV Unit 1 R-3 + 4 bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	
Mercury by CVAA - Continued						
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	0.52	0.26	0.25	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	775	835	795	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	3.2	1.7	1.6	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	185	190	195	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.01	<0.02	<0.02	
Mercury	As Tested	µg/L	<0.05	<0.05	0.06	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	500	500	600	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.04	<0.04	0.06	
Mercury	As Tested	µg/L	0.41	0.14	0.14	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.13	0.044	0.046	

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411857**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497041

		Reference Number	1411857-4	1411857-5	1411857-6
		Sample Date	Feb 25, 2020	Feb 26, 2020	Feb 26, 2020
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit 2 Run 1 (MV Unit 2 R-1 + 4 bottles)	Unit 2 Run 2 (MV Unit 2 R-2 + 4 bottles)	Unit 2 Run 3 (MV Unit 2 R-3 + 4 bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	8	9	8	5
Antimony	µg	<2	3	<2	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	0.93	0.97	0.81	0.2
Cobalt	µg	<0.3	<0.3	<0.3	0.25
Copper	µg	2	2	2.7	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	0.8	0.4	1	0.25
Nickel	µg	2	1	<0.5	0.5
Phosphorus	µg	31	34	36	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	3.6	3.1	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2.8	2	2.7	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	22	6	10	5
Antimony	µg	2	<2	3	2.5
Arsenic	µg	1	0.9	<0.9	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	0.68	0.56	0.63	0.2
Cobalt	µg	2	0.3	<0.2	0.25
Copper	µg	1	1	0.8	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	3.8	<0.2	0.4	0.25
Nickel	µg	1	1	0.5	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	2	<1	2	1.5
Tellurium	µg	<2	<2	3.3	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	<0.9	<0.8	<0.9	1
Zinc	µg	2	<0.4	6.4	0.5
Volume	Sample	mL	820	860	820
Volume	aliquot volume	mL	770	810	770
Mercury by CVAA					
Mercury	As Tested	µg/L	<0.05	<0.05	0.05

Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1411857 Control Number: Date Received: Mar 3, 2020 Date Reported: Mar 25, 2020 Report Number: 2497041
Attn: Missy		
Sampled By:		
Company:		

		Reference Number	1411857-4	1411857-5	1411857-6	
		Sample Date	Feb 25, 2020	Feb 26, 2020	Feb 26, 2020	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 2 Run 1 (MV Unit 2 R-1 + 4 bottles)	Unit 2 Run 2 (MV Unit 2 R-2 + 4 bottles)	Unit 2 Run 3 (MV Unit 2 R-3 + 4 bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Mercury by CVAA - Continued						
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	0.29	0.65	0.58	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	820	860	820	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	1.9	4.5	3.8	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	200	215	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	600	750	750	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.05	<0.06	<0.06	
Mercury	As Tested	µg/L	0.21	0.24	0.11	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.066	0.078	0.035	

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411857**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497041

		Reference Number	1411857-7	1411857-8	1411857-9
		Sample Date	Feb 26, 2020	Feb 27, 2020	Feb 27, 2020
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit 3 Run 1 (MV Unit 3 R-1 + 4 bottles)	Unit 3 Run 2 (MV Unit 3 R-2 + 4 bottles)	Unit 3 Run 3 (MV Unit 3 R-3 + 4 bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	6	8	8	5
Antimony	µg	<2	3	<2	2.5
Arsenic	µg	2	<1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	0.97	0.44	0.36	0.2
Cobalt	µg	<0.3	<0.3	<0.3	0.25
Copper	µg	3.3	2.7	1	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	1	0.5	0.6	0.25
Nickel	µg	2	1	0.5	0.5
Phosphorus	µg	30	39	35	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	2.6	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2	2.9	2	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	10	10	9	5
Antimony	µg	<2	4	<2	2.5
Arsenic	µg	<0.9	<0.8	2	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	1.1	0.96	0.58	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	1	0.3	<0.2	0.25
Lead	µg	2	<1	<1	1.5
Manganese	µg	57.1	24.2	0.4	0.25
Nickel	µg	1	0.7	0.7	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	<1	<1	<1	1.5
Tellurium	µg	3.0	2.4	2	2
Thallium	µg	<1	<1	2	1.5
Vanadium	µg	<0.9	<0.8	<0.9	1
Zinc	µg	1.0	<0.4	<0.4	0.5
Volume	Sample	mL	830	870	750
Volume	aliquot volume	mL	780	820	700
Mercury by CVAA					
Mercury	As Tested	µg/L	<0.05	<0.05	0.05

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1411857**
Control Number:
Date Received: Mar 3, 2020
Date Reported: Mar 25, 2020
Report Number: 2497041

		Reference Number	1411857-7	1411857-8	1411857-9	
		Sample Date	Feb 26, 2020	Feb 27, 2020	Feb 27, 2020	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 3 Run 1 (MV Unit 3 R-1 + 4 bottles)	Unit 3 Run 2 (MV Unit 3 R-2 + 4 bottles)	Unit 3 Run 3 (MV Unit 3 R-3 + 4 bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Mercury by CVAA - Continued						
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	0.33	0.37	0.35	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	830	870	750	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	2.2	2.6	2.1	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	185	190	210	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.01	<0.02	<0.02	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	600	600	750	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.05	<0.05	<0.06	
Mercury	As Tested	µg/L	0.16	0.14	0.30	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.052	0.044	0.095	

Approved by:



Matthew Norman, BSc, PChem
Operations Chemist

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1411857 Control Number: Date Received: Mar 3, 2020 Date Reported: Mar 25, 2020 Report Number: 2497041
Attn: Missy Sampled By: Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 12, 2020	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2020	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Mar 12, 2020	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Mar 23, 2020	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Mar 23, 2020	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2020	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Mar 5, 2020	Element Vancouver

** Reference Method Modified*

References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.



www.Element.com

Project Information

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg Samples
Project Location:
Legal Location:
PO/AFE#:
Proj. Acct. Code:
Quote #:

Invoice To

Company: A. Lanfranco & Associates Inc.
Address: 101-9488 189 Street
Surrey BC, V4N 4W7
Attention:
Phone: 604-881-2582
Cell:
Fax:
E-mail: mark.lanfranco@alanfranco.com
Agreement ID:
Copy of Report: YES / NO

Report To

Company:
Address:
Attention:
Phone:
Cell:
Fax:
E-mail 1:
E-mail 2:
Copy of Invoice: YES / NO

Additional Reports to

1) Name:
E-mail:
2) Name:
E-mail:
Sample Custody
Sampled by:
Company:
I authorize Element to proceed with the work indicated on this form:
Signature:
Date/Time:

Report Results

Requirements

- ☐ Same Day (200%)
☐ Next Day/Two Day (100%)
☐ Three or Four Days (50%)
☒ 5 to 7 Days (Regular TAT)

When "ASAP" is requested, turn around will default to a 100% RUSH priority, with pricing and turn around time to match. Please contact the lab prior to submitting RUSH samples. If not all samples require RUSH, please indicate in the special instructions.

- ☒ Email ☐ QA/QC
☐ Online ☒ PDF
☐ Fax ☐ Excel

- ☐ HCDWORG ☐ SPIGEC
☐ AB Tier 1 ☐ BCCSR
Other (list below)

Date Required

Special Instructions/Comments (please include contact information including phone number if different from above).

*Front and Back ICAP as per EPA Method 29. *Hg analysis as per EPA Method 29. *Please report µg/sample.

	Site I.D.	Sample Description	Depth start end in cm m	Date/Time sampled	Matrix	Sampling method	Number of Containers ↓	Front ICAP	Back ICAP	Front Hg	Back Hg	5A Hg	5B Hg								
1		Unit 1 Run 1 ('MV Unit 1 R-1' + 4 Bottles)		24-Feb-20			5	✓	✓	✓	✓	✓	✓								
2		Unit 1 Run 2 ('MV Unit 1 R-2' + 4 Bottles)		25-Feb-20			5	✓	✓	✓	✓	✓	✓								
3		Unit 1 Run 3 ('MV Unit 1 R-3' + 4 Bottles)		25-Feb-20			5	✓	✓	✓	✓	✓	✓								
4																					
5		Unit 2 Run 1 ('MV Unit 2 R-1' + 4 Bottles)		25-Feb-20			5	✓	✓	✓	✓	✓	✓								
6		Unit 2 Run 2 ('MV Unit 2 R-2' + 4 Bottles)		26-Feb-20			5	✓	✓	✓	✓	✓	✓								
7		Unit 2 Run 3 ('MV Unit 2 R-3' + 4 Bottles)		26-Feb-20			5	✓	✓	✓	✓	✓	✓								
8																					
9		Unit 3 Run 1 ('MV Unit 3 R-1' + 4 Bottles)		26-Feb-20			5	✓	✓	✓	✓	✓	✓								
10		Unit 3 Run 2 ('MV Unit 3 R-2' + 4 Bottles)		27-Feb-20			5	✓	✓	✓	✓	✓	✓								
11		Unit 3 Run 3 ('MV Unit 3 R-3' + 4 Bottles)		27-Feb-20			5	✓	✓	✓	✓	✓	✓								
12																					
13																					
14																					
15																					

Please indicate any potentially hazardous samples

Submission of this form acknowledges acceptance of Element's Standard of terms and conditions (<https://www.element.com/terms/terms-and-conditions>)

Page ____ of ____ Control #

ED 120-005

Lot: 1411857^{COC}



Temp. received: 17.2 °C
Delivery Method: AD
Waybill:
Received by: *[Signature]*
Date/Time stamp: MAR 3 '20 18:58

CERTIFICATE OF ANALYSIS

Work Order : **VA20A2564**
Client : **A. Lanfranco & Associates Inc.**
Contact : Mark Lanfranco
Address : Unit # 101 9488 - 189 St
 Surrey BC Canada V4N 4W7
Telephone : 604 881 2582
Project : Metro Vancouver WTE
PO : HF
C-O-C number : ----
Sampler : A. Lanfranco
Site : ----
Quote number : Standing Offer
No. of samples received : 3
No. of samples analysed : 3

Page : 1 of 2
Laboratory : Vancouver - Environmental
Account Manager : Brent Mack
Address : 8081 Lougheed Highway
 Burnaby BC Canada V5A 1W9
Telephone : +1 604 253 4188
Date Samples Received : 28-Feb-2020 15:50
Date Analysis Commenced : 04-Mar-2020
Issue Date : 06-Mar-2020 16:31

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Laboratory Department</i>
Cindy Tang	Team Leader - Inorganics	Inorganics - Water Quality, Burnaby, British Columbia



General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key : CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances
 LOR: Limit of Reporting (detection limit).

Unit	Description
µg/sample	micrograms per sample
L	litres

<: less than.

>: greater than.

Surrogate: An analyte that is similar in behavior to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in reports identified as "Preliminary Report" are considered authorized for use.

Analytical Results

Sub-Matrix: Impinger Solution

Client sample ID

					Unit 1 HF Blank	Unit 2 HF Blank	Unit 3 HF Blank	----	----
(Matrix: Air)					25-Feb-2020	26-Feb-2020	27-Feb-2020	----	----
Client sampling date / time					25-Feb-2020	26-Feb-2020	27-Feb-2020	----	----
Analyte	CAS Number	Method	LOR	Unit	VA20A2564-001	VA20A2564-002	VA20A2564-003	-----	-----
					Result	Result	Result	----	----
Anions and Nutrients									
fluoride	16984-48-8	E248.F	5.0	µg/sample	<5.0	<5.0	<5.0	----	----
volume, impinger	----	EP248	0.001	L	0.240	0.290	0.300	----	----

Please refer to the General Comments section for an explanation of any qualifiers detected.

CERTIFICATE OF ANALYSIS

Work Order : **VA20A2565**
Client : **A. Lanfranco & Associates Inc.**
Contact : Mark Lanfranco
Address : Unit # 101 9488 - 189 St
 Surrey BC Canada V4N 4W7
Telephone : 604 881 2582
Project : Metro Vancouver WTE
PO : HF
C-O-C number : ----
Sampler : A. Lanfranco
Site : ----
Quote number : Standing Offer
No. of samples received : 9
No. of samples analysed : 9

Page : 1 of 3
Laboratory : Vancouver - Environmental
Account Manager : Brent Mack
Address : 8081 Lougheed Highway
 Burnaby BC Canada V5A 1W9
Telephone : +1 604 253 4188
Date Samples Received : 28-Feb-2020 15:50
Date Analysis Commenced : 04-Mar-2020
Issue Date : 06-Mar-2020 16:38

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Laboratory Department</i>
Cindy Tang	Team Leader - Inorganics	Inorganics - Water Quality, Burnaby, British Columbia



General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key : CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances
LOR: Limit of Reporting (detection limit).

Unit	Description
µg/sample	micrograms per sample
L	litres

<: less than.

>: greater than.

Surrogate: An analyte that is similar in behavior to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in reports identified as "Preliminary Report" are considered authorized for use.

Qualifiers

Qualifier	Description
DLDS	Detection Limit Raised: Dilution required due to high Dissolved Solids / Electrical Conductivity.



Analytical Results

Sub-Matrix: Impinger Solution

Client sample ID

(Matrix: Air)

					Unit 1 HF Run 1	Unit 1 HF Run 2	Unit 1 HF Run 3	Unit 2 HF Run 1	Unit 2 HF Run 2
Client sampling date / time					25-Feb-2020	25-Feb-2020	25-Feb-2020	26-Feb-2020	26-Feb-2020
Analyte	CAS Number	Method	LOR	Unit	VA20A2565-001	VA20A2565-002	VA20A2565-003	VA20A2565-004	VA20A2565-005
					Result	Result	Result	Result	Result
Anions and Nutrients									
fluoride	16984-48-8	E248.F	5.0	µg/sample	<50.0 ^{DLDS}	<5.0	<25.0 ^{DLDS}	<50.0 ^{DLDS}	<50.0 ^{DLDS}
volume, impinger	----	EP248	0.001	L	0.325	0.295	0.285	0.340	0.335

Please refer to the General Comments section for an explanation of any qualifiers detected.

Analytical Results

Sub-Matrix: Impinger Solution

Client sample ID

(Matrix: Air)

					Unit 2 HF Run 3	Unit 3 HF Run 1	Unit 3 HF Run 2	Unit 3 HF Run 3	----
Client sampling date / time					26-Feb-2020	27-Feb-2020	27-Feb-2020	27-Feb-2020	----
Analyte	CAS Number	Method	LOR	Unit	VA20A2565-006	VA20A2565-007	VA20A2565-008	VA20A2565-009	-----
					Result	Result	Result	Result	----
Anions and Nutrients									
fluoride	16984-48-8	E248.F	5.0	µg/sample	<25.0 ^{DLDS}	<100 ^{DLDS}	<25.0 ^{DLDS}	<25.0 ^{DLDS}	----
volume, impinger	----	EP248	0.001	L	0.310	0.335	0.240	0.350	----

Please refer to the General Comments section for an explanation of any qualifiers detected.



Your Project #: METROVAN WTE[C013267]
Site Location: BURNABY, B.C.
Your C.O.C. #: C013267-ONTV-01-01

Attention: Customer Solutions

Bureau Veritas Laboratories
4606 Canada Way
Burnaby, BC
CANADA V5G 1K5

Report Date: 2020/03/11
Report #: R6105475
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BV LABS JOB #: C052656

Received: 2020/02/27, 08:57

Sample Matrix: Tedlar Bag
Samples Received: 9

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Nitrous Oxide (1)	9	N/A	2020/02/28	CAM SOP-00203	GC/ECD

Remarks:

Bureau Veritas Laboratories are accredited to ISO/IEC 17025 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by BV Labs are based upon recognized Provincial, Federal or US method compendia such as CCME, MELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in BV Labs profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and BV Labs in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

BV Labs liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. BV Labs has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by BV Labs, unless otherwise agreed in writing. BV Labs is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.

Results relate to samples tested. When sampling is not conducted by BV Labs, results relate to the supplied samples tested.

This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Date Analyzed is the date the analytical batch was created. Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard, where applicable.



Your Project #: METROVAN WTE[C013267]

Site Location: BURNABY, B.C.

Your C.O.C. #: C013267-ONTV-01-01

Attention: Customer Solutions

Bureau Veritas Laboratories
4606 Canada Way
Burnaby, BC
CANADA V5G 1K5

Report Date: 2020/03/11

Report #: R6105475

Version: 1 - Final

CERTIFICATE OF ANALYSIS

BV LABS JOB #: C052656

Received: 2020/02/27, 08:57

Encryption Key

Cristina Bacchus

Cristina (Maria) Bacchus
Project Manager
11 Mar 2020 11:45:04

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

Jade Browne, Project Manager Assistant - Air

Email: Jade.Browne@bvlabs.com

Phone# (905)817-5831

=====

This report has been generated and distributed using a secure automated process.

BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.



BUREAU
VERITAS

BV Labs Job #: C052656
Report Date: 2020/03/11

Bureau Veritas Laboratories
Client Project #: METROVAN WTE[C013267]
Site Location: BURNABY, B.C.

COMPRESSED GAS PARAMETERS (TEDLAR BAG)

BV Labs ID		MCQ377	MCQ377	MCQ378	MCQ379		
Sampling Date		2020/02/24	2020/02/24	2020/02/24	2020/02/24		
COC Number		C013267-ONTV-01-01	C013267-ONTV-01-01	C013267-ONTV-01-01	C013267-ONTV-01-01		
	UNITS	XL1664-UNIT1 RUN1	XL1664-UNIT1 RUN1 Lab-Dup	XL1665-UNIT1 RUN2	XL1666-UNIT1 RUN3	RDL	QC Batch

Gas

Nitrous Oxide	ppmv	15	15	18	13	0.1	6628074
---------------	------	----	----	----	----	-----	---------

RDL = Reportable Detection Limit

QC Batch = Quality Control Batch

Lab-Dup = Laboratory Initiated Duplicate

BV Labs ID		MCQ380	MCQ381	MCQ382	MCQ383		
Sampling Date		2020/02/24	2020/02/24	2020/02/24	2020/02/24		
COC Number		C013267-ONTV-01-01	C013267-ONTV-01-01	C013267-ONTV-01-01	C013267-ONTV-01-01		
	UNITS	XL1667-UNIT2 RUN1	XL1668-UNIT2 RUN2	XL1669-UNIT2 RUN3	XL1670-UNIT3 RUN1	RDL	QC Batch

Gas

Nitrous Oxide	ppmv	3.1	0.6	16	1.1	0.1	6628074
---------------	------	-----	-----	----	-----	-----	---------

RDL = Reportable Detection Limit

QC Batch = Quality Control Batch

BV Labs ID		MCQ384	MCQ385		
Sampling Date		2020/02/24	2020/02/24		
COC Number		C013267-ONTV-01-01	C013267-ONTV-01-01		
	UNITS	XL1671-UNIT3 RUN2	XL1672-UNIT3 RUN3	RDL	QC Batch

Gas

Nitrous Oxide	ppmv	13	0.6	0.1	6628074
---------------	------	----	-----	-----	---------

RDL = Reportable Detection Limit

QC Batch = Quality Control Batch



BUREAU
VERITAS

BV Labs Job #: C052656
Report Date: 2020/03/11

Bureau Veritas Laboratories
Client Project #: METROVAN WTE[C013267]
Site Location: BURNABY, B.C.

TEST SUMMARY

BV Labs ID: MCQ377
Sample ID: XL1664-UNIT1 RUN1
Matrix: Tedlar Bag

Collected: 2020/02/24
Shipped:
Received: 2020/02/27

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	6628074	N/A	2020/02/28	Anojan Sureshkumar

BV Labs ID: MCQ377 Dup
Sample ID: XL1664-UNIT1 RUN1
Matrix: Tedlar Bag

Collected: 2020/02/24
Shipped:
Received: 2020/02/27

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	6628074	N/A	2020/02/28	Anojan Sureshkumar

BV Labs ID: MCQ378
Sample ID: XL1665-UNIT1 RUN2
Matrix: Tedlar Bag

Collected: 2020/02/24
Shipped:
Received: 2020/02/27

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	6628074	N/A	2020/02/28	Anojan Sureshkumar

BV Labs ID: MCQ379
Sample ID: XL1666-UNIT1 RUN3
Matrix: Tedlar Bag

Collected: 2020/02/24
Shipped:
Received: 2020/02/27

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	6628074	N/A	2020/02/28	Anojan Sureshkumar

BV Labs ID: MCQ380
Sample ID: XL1667-UNIT2 RUN1
Matrix: Tedlar Bag

Collected: 2020/02/24
Shipped:
Received: 2020/02/27

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	6628074	N/A	2020/02/28	Anojan Sureshkumar

BV Labs ID: MCQ381
Sample ID: XL1668-UNIT2 RUN2
Matrix: Tedlar Bag

Collected: 2020/02/24
Shipped:
Received: 2020/02/27

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	6628074	N/A	2020/02/28	Anojan Sureshkumar

BV Labs ID: MCQ382
Sample ID: XL1669-UNIT2 RUN3
Matrix: Tedlar Bag

Collected: 2020/02/24
Shipped:
Received: 2020/02/27

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	6628074	N/A	2020/02/28	Anojan Sureshkumar



BUREAU
VERITAS

BV Labs Job #: C052656
Report Date: 2020/03/11

Bureau Veritas Laboratories
Client Project #: METROVAN WTE[C013267]
Site Location: BURNABY, B.C.

TEST SUMMARY

BV Labs ID: MCQ383
Sample ID: XL1670-UNIT3 RUN1
Matrix: Tedlar Bag

Collected: 2020/02/24
Shipped:
Received: 2020/02/27

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	6628074	N/A	2020/02/28	Anojan Sureshkumar

BV Labs ID: MCQ384
Sample ID: XL1671-UNIT3 RUN2
Matrix: Tedlar Bag

Collected: 2020/02/24
Shipped:
Received: 2020/02/27

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	6628074	N/A	2020/02/28	Anojan Sureshkumar

BV Labs ID: MCQ385
Sample ID: XL1672-UNIT3 RUN3
Matrix: Tedlar Bag

Collected: 2020/02/24
Shipped:
Received: 2020/02/27

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	6628074	N/A	2020/02/28	Anojan Sureshkumar



BUREAU
VERITAS

BV Labs Job #: C052656
Report Date: 2020/03/11

Bureau Veritas Laboratories
Client Project #: METROVAN WTE[C013267]
Site Location: BURNABY, B.C.

GENERAL COMMENTS

The sample was analysed 4 days after the date of sampling. The recommended holding time is 2 days.

Results relate only to the items tested.



BV Labs Job #: C052656
Report Date: 2020/03/11

QUALITY ASSURANCE REPORT

Bureau Veritas Laboratories
Client Project #: METROVAN WTE[C013267]
Site Location: BURNABY, B.C.

QC Batch	Parameter	Date	Method Blank		RPD	
			Value	UNITS	Value (%)	QC Limits
6628074	Nitrous Oxide	2020/02/28	<0.1	ppmv	NC	N/A

N/A = Not Applicable

Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference $\leq 2 \times \text{RDL}$).



BUREAU
VERITAS

BV Labs Job #: C052656
Report Date: 2020/03/11


Bureau Veritas Laboratories
Client Project #: METROVAN WTE[C013267]
Site Location: BURNABY, B.C.

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Vasan Thiagarajah, Analyst, Compressed Gases

BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports.
For Service Group specific validation please refer to the Validation Signature Page.



BV LABS INTERLAB CHAIN OF CUSTODY RECORD

Page 01 of 01

COC # C013267-ONTV-01-01

REPORT INFORMATION				ANALYSIS REQUESTED																			
Company:																							
Address:																							
Contact Name:																							
Email:																							
Phone:																							
BV Labs Project #:																							
Client Invoice To:																							
Client Report To:																							
Incl. on Report? Yes / No																							
#	SAMPLE ID	MATRIX	DATE SAMPLED (YYYY/MM/DD)	TIME SAMPLED (HH-MM)	SAMPLER INITIALS	# CONT.																	
1	XL1664-UNIT 1 RUN 1	AIR	2020/02/24			1	X																
2	XL1665-UNIT 1 RUN 2	AIR	2020/02/24			1	X																
3	XL1666-UNIT 1 RUN 1	AIR	2020/02/24			1	X																
4	XL1667-UNIT 2 RUN 1	AIR	2020/02/24			1	X																
5	XL1668-UNIT 2 RUN 2	AIR	2020/02/24			1	X																
6	XL1669-UNIT 2 RUN 3	AIR	2020/02/24			1	X																
7	XL1670-UNIT 3 RUN 1	AIR	2020/02/24			1	X																
8	XL1671-UNIT 3 RUN 2	AIR	2020/02/24			1	X																
9	XL1672-UNIT 3 RUN 3	AIR	2020/02/24			1	X																
10																							
SITE LOCATION:				REGULATORY CRITERIA				SPECIAL INSTRUCTIONS								REQUIRED EDDS				TURNAROUND TIME			
BURNABY B.C.								Please inform BV Labs immediately if you are not accredited for the requested test(s). ** Please return a copy of this form with the report **								National Excel (N001)				☐ Rush Required			
SITE #:								*DO NOT DISCARD, RETURN TO CLIENT*												2020/03/10			
PROJECT #:																Date Required							
METROVAN WTE																Please inform us if rush charges will be incurred							
PO/A/E, TASK ORDER/SERVICE ORDER, LINE ITEM:																							
COOLER ID:				COOLER ID:				COOLER ID:															
Custody Seal Present	YES	NO	Temp: (°C)	Custody Seal Present	YES	NO	Temp: (°C)	Custody Seal Present	YES	NO	Temp: (°C)												
Custody seal intact		V	N/A	Custody seal intact				Custody Seal Intact															
Cooling Media Present		V		Cooling Media Present				Cooling Media Present															
RELINQUISHED BY: (SIGN & PRINT)				DATE: (YYYY/MM/DD)				TIME: (HH-MM)				RECEIVED BY: (SIGN & PRINT)				DATE: (YYYY/MM/DD)				TIME: (HH-MM)			
J Simon King				2020/02/25				1500				Paul Gyleshaw Jdmc				2020/02/27				08:57			

APPENDIX - C

COMPUTER GENERATED RESULTS

Client: Metro Vancouver
Jobsite: WTE (Burnaby, BC)
Source: Unit 1

Date: 24-Feb-20
Run: 1 - Particulate / Metals
Run Time: 12:53 - 14:56

Concentrations:

Particulate	0.28 mg/dscm	0.00012 gr/dscf
	0.16 mg/Acm	0.00007 gr/Acf
	0.24 mg/dscm (@ 11% O2)	0.00011 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.019 Kg/hr	0.042 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1125 dscm/min	39713 dscf/min
	18.74 dscm/sec	662 dscf/sec
	1994 Acm/min	70416 Acf/min

Velocity	13.047 m/sec	42.81 f/sec
-----------------	--------------	-------------

Temperature	152.8 oC	307.0 oF
--------------------	----------	----------

Moisture	15.8 %
-----------------	--------

Gas Analysis	9.4 % O2
	11.1 % CO2

30.150 Mol. Wt (g/gmole) Dry
28.235 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.6816 dscm	94.701 dscf
Sample Time	120.0 minutes	
Isokineticity	104.1 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, BC)
Source: Unit 1

Date: 24-Feb-20
Run: 1 - Particulate / Metals
Run Time: 12:53 - 14:56

Control Unit (Y) 1.0118
Nozzle Diameter (in.) 0.3097
Pitot Factor 0.8388
Baro. Press. (in. Hg) 30.50
Static Press. (in. H2O) -19.00
Stack Height (ft) 30
Stack Diameter (in.) 70.90
Stack Area (sq.ft.) 27.417
Minutes Per Reading 5.0
Minutes Per Point 5.0

Collection:
Filter (grams) 0.00005
Washings (grams) 0.00070
Total (grams) 0.00075

Traverse 1
Traverse 2

Gas Analysis (Vol. %):
CO2 O2
Traverse 1 11.17 9.37
Traverse 2 11.00 9.47
11.08 9.42

Condensate Collection:
Impinger 1 176.0
Impinger 2 124.0
Impinger 3 42.0
Impinger 4 12.0
Impinger 5 5.0
Impinger 6 2.0
Gel 15.4
Gain (grams) 376.4

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
					Inlet (oF)	Outlet (oF)				
Traverse 1	0.0	448.000								
1	5.0	451.360	0.32	1.64	52	52	6	311	1.5	103.7
2	10.0	455.060	0.39	1.99	52	52	6	312	4.7	103.6
3	15.0	458.880	0.41	2.12	52	52	7.5	311	8.4	104.3
4	20.0	462.740	0.42	2.17	52	52	7.5	310	12.5	104.1
5	25.0	466.750	0.45	2.34	53	53	8	309	17.7	104.2
6	30.0	470.670	0.43	2.23	53	53	8	309	25.2	104.2
7	35.0	474.690	0.45	2.34	54	54	8	309	45.6	104.3
8	40.0	478.350	0.37	1.93	55	55	8	307	53.2	104.3
9	45.0	481.800	0.33	1.73	55	55	7	306	58.3	104.0
10	50.0	485.150	0.31	1.62	55	55	7	306	62.5	104.1
11	55.0	488.560	0.32	1.68	56	56	6.5	305	66.1	104.1
12	60.0	492.070	0.34	1.78	56	56	6.5	306	69.4	104.0
Traverse 2	0.0	492.070								
1	5.0	495.320	0.29	1.52	57	57	6.5	307	1.5	104.1
2	10.0	498.690	0.31	1.63	58	58	6.5	307	4.7	104.2
3	15.0	502.110	0.32	1.68	58	58	6.5	306	8.4	104.0
4	20.0	505.310	0.28	1.47	58	58	6.5	306	12.5	104.0
5	25.0	508.790	0.33	1.74	59	59	7	305	17.7	104.0
6	30.0	512.490	0.37	1.96	60	60	7	304	25.2	104.2
7	35.0	516.790	0.50	2.64	60	60	9.5	305	45.6	104.4
8	40.0	521.180	0.52	2.75	61	61	9.5	306	53.2	104.4
9	45.0	525.650	0.54	2.86	61	61	10.5	305	58.3	104.3
10	50.0	529.960	0.50	2.65	62	62	10.5	306	62.5	104.3
11	55.0	533.770	0.39	2.07	62	62	8.5	305	66.1	104.2
12	60.0	537.431	0.36	1.91	62	62	8.5	305	69.4	104.2
Average:			0.385	2.019	56.8	56.8	7.6	307.0		104.1

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 1

Date: 25-Feb-20
Run: 2 - Particulate / Metals
Run Time: 09:43 - 11:48

Concentrations:

Particulate	0.20 mg/dscm	0.00009 gr/dscf
	0.12 mg/Acm	0.00005 gr/Acf
	0.17 mg/dscm (@ 11% O2)	0.00008 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.014 Kg/hr	0.030 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1124 dscm/min	39709 dscf/min
	18.74 dscm/sec	662 dscf/sec
	1987 Acm/min	70177 Acf/min

Velocity	13.003 m/sec	42.66 f/sec
-----------------	--------------	-------------

Temperature	149.7 oC	301.5 oF
--------------------	----------	----------

Moisture	16.1 %
-----------------	--------

Gas Analysis	9.3 % O2
	11.2 % CO2

30.159 Mol. Wt (g/gmole) Dry
28.199 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.6921 dscm	95.071 dscf
Sample Time	120.0 minutes	
Isokineticity	104.6 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 1

Date: 25-Feb-20
Run: 2 - Particulate / Metals
Run Time: 09:43 - 11:48

Control Unit (Y) 1.0118
Nozzle Diameter (in.) 0.3097
Pitot Factor 0.8388
Baro. Press. (in. Hg) 30.51
Static Press. (in. H2O) -19.00
Stack Height (ft) 30
Stack Diameter (in.) 70.90
Stack Area (sq.ft.) 27.417
Minutes Per Reading 5.0
Minutes Per Point 5.0

Collection:
Filter (grams) 0.00005
Washings (grams) 0.00050
Total (grams) 0.00055

Gas Analysis (Vol. %):
CO2 O2
Traverse 1 11.17 9.33
Traverse 2 11.17 9.27
11.17 9.30

Condensate Collection:
Impinger 1 196.0
Impinger 2 132.0
Impinger 3 26.0
Impinger 4 10.0
Impinger 5 4.0
Impinger 6 2.0
Gel 18.1
Gain (grams) 388.1

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	539.900								
1	5.0	543.320	0.33	1.72	47	47	7	298	1.5	104.5
2	10.0	546.890	0.36	1.87	48	48	7	300	4.7	104.4
3	15.0	550.510	0.37	1.92	48	48	7	300	8.4	104.5
4	20.0	554.280	0.40	2.08	48	48	7	300	12.5	104.7
5	25.0	558.240	0.44	2.29	49	49	8.5	300	17.7	104.7
6	30.0	562.110	0.42	2.19	50	50	8.5	300	25.2	104.5
7	35.0	566.090	0.44	2.31	52	52	9	300	45.6	104.6
8	40.0	570.210	0.47	2.47	53	53	9	301	53.2	104.7
9	45.0	574.020	0.40	2.10	54	54	9	302	58.3	104.7
10	50.0	577.640	0.36	1.90	56	56	9	302	62.5	104.4
11	55.0	581.160	0.34	1.79	56	56	7.5	302	66.1	104.4
12	60.0	584.640	0.33	1.74	57	57	7.5	302	69.4	104.6
Traverse 2	0.0	584.640								
1	5.0	587.800	0.27	1.43	58	58	6.5	299	1.5	104.5
2	10.0	591.180	0.31	1.64	59	59	6.5	303	4.7	104.4
3	15.0	594.450	0.29	1.53	59	59	6.5	304	8.4	104.5
4	20.0	597.670	0.28	1.49	60	60	6.5	303	12.5	104.4
5	25.0	601.000	0.30	1.59	60	60	6.5	304	17.7	104.4
6	30.0	604.650	0.36	1.91	60	60	6.5	302	25.2	104.5
7	35.0	608.960	0.50	2.66	60	60	9.5	301	45.6	104.8
8	40.0	613.480	0.55	2.93	61	61	9.5	302	53.2	104.7
9	45.0	617.890	0.52	2.77	62	62	10.5	302	58.3	104.8
10	50.0	622.080	0.47	2.50	62	62	10.5	303	62.5	104.8
11	55.0	625.940	0.40	2.13	62	62	9	303	66.1	104.5
12	60.0	629.511	0.34	1.81	63	63	9	303	69.4	104.6
Average:			0.385	2.032	56.0	56.0	8.0	301.5		104.6

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 1

Date: 25-Feb-20
Run: 3 - Particulate / Metals
Run Time: 12:20 - 14:23

Concentrations:

Particulate	0.0 mg/dscm	0.0000 gr/dscf
	0.0 mg/Acm	0.0000 gr/Acf
	0.0 mg/dscm (@ 11% O2)	0.0000 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.003 Kg/hr	0.006 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1157 dscm/min	40848 dscf/min
	19.28 dscm/sec	681 dscf/sec
	2021 Acm/min	71389 Acf/min
Velocity	13.228 m/sec	43.40 f/sec
Temperature	150.9 oC	303.6 oF
Moisture	14.9 %	
Gas Analysis	9.2 % O2	
	11.3 % CO2	
	30.181 Mol. Wt (g/gmole) Dry	
	28.361 Mol. Wt (g/gmole) Wet	

Sample Parameters:

Sample Volume	2.7397 dscm	96.753 dscf
Sample Time	120.0 minutes	
Isokineticity	103.4 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 1

Date: 25-Feb-20
Run: 3 - Particulate / Metals
Run Time: 12:20 - 14:23

Control Unit (Y) 1.0118
Nozzle Diameter (in.) 0.3097
Pitot Factor 0.8388
Baro. Press. (in. Hg) 30.51
Static Press. (in. H2O) -19.00
Stack Height (ft) 30
Stack Diameter (in.) 70.90
Stack Area (sq.ft.) 27.417
Minutes Per Reading 5.0
Minutes Per Point 5.0

Collection:
 Filter (grams) 0.00005
 Washings (grams) 0.00005
Total (grams) 0.00010

Gas Analysis (Vol. %):

CO2	O2
11.83	8.83
10.83	9.53

Condensate Collection:
 Impinger 1 142.0
 Impinger 2 136.0
 Impinger 3 46.0
 Impinger 4 14.0
 Impinger 5 5.0
 Impinger 6 2.0
 Gel 16.1
Gain (grams) 361.1

11.33 9.18

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
					Inlet (oF)	Outlet (oF)				
Traverse 1	0.0	630.100								
1	5.0	633.220	0.26	1.39	63	63	7	303	1.5	103.2
2	10.0	636.570	0.30	1.60	62	62	7	303	4.7	103.5
3	15.0	639.910	0.30	1.60	62	62	7	304	8.4	103.2
4	20.0	643.140	0.28	1.49	62	62	7	304	12.5	103.3
5	25.0	646.540	0.31	1.65	62	62	7	305	17.7	103.4
6	30.0	649.990	0.32	1.70	62	62	7	304	25.2	103.3
7	35.0	654.050	0.44	2.35	63	63	9.5	303	45.6	103.5
8	40.0	658.390	0.50	2.68	63	63	9.5	300	53.2	103.7
9	45.0	663.170	0.61	3.25	63	63	12.5	303	58.3	103.7
10	50.0	667.820	0.58	3.09	63	63	12.5	305	62.5	103.6
11	55.0	672.010	0.47	2.50	64	64	10	306	66.1	103.4
12	60.0	675.940	0.41	2.19	65	65	10	306	69.4	103.6
Traverse 2	0.0	675.940								
1	5.0	679.420	0.32	1.72	66	66	8.5	302	1.5	103.2
2	10.0	683.450	0.43	2.30	66	66	8.5	304	4.7	103.4
3	15.0	687.530	0.44	2.36	66	66	9.5	304	8.4	103.5
4	20.0	691.760	0.47	2.53	67	67	9.5	303	12.5	103.6
5	25.0	695.800	0.43	2.31	67	67	10	303	17.7	103.4
6	30.0	700.030	0.47	2.53	67	67	10	303	25.2	103.6
7	35.0	704.210	0.46	2.47	67	67	10	304	45.6	103.5
8	40.0	708.210	0.42	2.26	68	68	10	303	53.2	103.4
9	45.0	712.120	0.40	2.15	68	68	9.5	303	58.3	103.5
10	50.0	715.770	0.35	1.88	68	68	9.5	303	62.5	103.2
11	55.0	719.370	0.34	1.83	68	68	9	304	66.1	103.4
12	60.0	722.862	0.32	1.72	68	68	9	304	69.4	103.3
Average:			0.401	2.148	65.0	65.0	9.1	303.6		103.4

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)
Source: Unit 1

Sample Type: HF		Test 1	Test 2	Test 3
Parameter				
Test Date		25-Feb-20	25-Feb-20	25-Feb-20
Test Time		10:45 - 11:45	12:27 - 13:27	13:38 - 14:38
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.51	30.51	30.51
DGM Factor	(Y)	0.9757	0.9757	0.9757
Initial Reading	(m ³)	381.644	382.346	383.021
Final Reading	(m ³)	382.330	383.000	383.668
Temp. Outlet	(Avg. oF)	57.0	62.0	53.0
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm ³)	0.70	0.66	0.66
HF	(mg)	0.026	0.003	0.013
Oxygen	(Vol. %)	9.3	9.3	9.2
HF	(mg/Sm³)	0.038	0.004	0.020
HF	(mg/Sm³ @ 10.032		0.003	0.017
Moisture	(Vol. %)	16.1	16.1	14.9
Tstd. (oF)		68	Pstd. (in. Hg)	29.92

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 2

Date: 25-Feb-20
Run: 1 - Particulate / Metals
Run Time: 11:50 - 13:52

Concentrations:

Particulate	0.0 mg/dscm	0.0000 gr/dscf
	0.0 mg/Acm	0.0000 gr/Acf
	0.0 mg/dscm (@ 11% O2)	0.0000 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.003 Kg/hr	0.006 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1069 dscm/min	37741 dscf/min
	17.81 dscm/sec	629 dscf/sec
	1902 Acm/min	67162 Acf/min

Velocity	12.444 m/sec	40.83 f/sec
-----------------	--------------	-------------

Temperature	152.2 oC	306.0 oF
--------------------	----------	----------

Moisture	16.1 %
-----------------	--------

Gas Analysis	9.3 % O2
	10.2 % CO2

30.000 Mol. Wt (g/gmole) Dry
28.065 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.5121 dscm	88.714 dscf
Sample Time	120.0 minutes	
Isokineticity	104.2 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 2

Date: 25-Feb-20
Run: 1 - Particulate / Metals
Run Time: 11:50 - 13:52

Control Unit (Y)	0.9905	Collection:	Gas Analysis (Vol. %):		Condensate Collection:		
Nozzle Diameter (in.)	0.3073		Filter (grams) 0.00005	CO2	O2	Impinger 1	202.0
Pitot Factor	0.8517		Washings (grams) 0.00005	10.00	9.50	Impinger 2	104.0
Baro. Press. (in. Hg)	30.52		Traverse 1	10.33	9.17	Impinger 3	30.0
Static Press. (in. H2O)	-19.50		Traverse 2			Impinger 4	8.0
Stack Height (ft)	30	Total (grams) 0.00010				Impinger 5	3.0
Stack Diameter (in.)	70.90					Impinger 6	1.0
Stack Area (sq.ft.)	27.417					Gel	14.5
Minutes Per Reading	5.0		10.17	9.33		Gain (grams)	362.5
Minutes Per Point	5.0						

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	957.862								
1	5.0	961.950	0.45	2.25	51	51	8	302	1.5	104.2
2	10.0	966.120	0.47	2.34	51	51	8	306	4.7	104.3
3	15.0	970.450	0.51	2.53	51	51	9	310	8.4	104.3
4	20.0	974.880	0.53	2.64	53	53	9	311	12.5	104.4
5	25.0	978.960	0.45	2.24	53	53	10	311	17.7	104.2
6	30.0	982.620	0.36	1.79	54	54	10	314	25.2	104.4
7	35.0	985.680	0.25	1.25	56	56	8	312	45.6	104.1
8	40.0	988.430	0.20	1.00	57	57	8	310	53.2	104.2
9	45.0	991.140	0.19	0.97	57	57	6	300	58.3	104.6
10	50.0	993.750	0.18	0.91	58	58	6	306	62.5	103.7
11	55.0	996.360	0.18	0.91	58	58	6	307	66.1	103.8
12	60.0	998.820	0.16	0.81	58	58	6	307	69.4	103.7
Traverse 2	0.0	998.820								
1	5.0	1001.680	0.21	1.08	60	60	5	298	1.5	104.3
2	10.0	1004.660	0.23	1.17	60	60	5	303	4.7	104.2
3	15.0	1007.440	0.20	1.02	61	61	5	306	8.4	104.2
4	20.0	1010.150	0.19	0.96	61	61	5	308	12.5	104.4
5	25.0	1013.060	0.22	1.12	62	62	5	308	17.7	104.0
6	30.0	1016.100	0.24	1.22	62	62	5	307	25.2	104.0
7	35.0	1020.280	0.45	2.30	63	63	6	308	45.6	104.5
8	40.0	1024.900	0.55	2.80	63	63	6	307	53.2	104.6
9	45.0	1029.950	0.65	3.34	64	64	8	302	58.3	104.7
10	50.0	1034.680	0.57	2.92	65	65	8	307	62.5	104.8
11	55.0	1039.290	0.54	2.79	65	65	10	298	66.1	104.3
12	60.0	1043.750	0.50	2.60	66	66	10	295	69.4	104.4
Average:			0.353	1.790	58.7	58.7	7.2	306.0		104.2

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 2

Date: 26-Feb-20
Run: 2 - Particulate / Metals
Run Time: 09:29 - 11:33

Concentrations:

Particulate	0.27 mg/dscm	0.00012 gr/dscf
	0.14 mg/Acm	0.00006 gr/Acf
	0.23 mg/dscm (@ 11% O2)	0.00010 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.017 Kg/hr	0.037 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1038 dscm/min	36641 dscf/min
	17.29 dscm/sec	611 dscf/sec
	1929 Acm/min	68134 Acf/min
Velocity	12.624 m/sec	41.42 f/sec
Temperature	160.3 oC	320.5 oF
Moisture	18.1 %	
Gas Analysis	9.6 % O2	
	10.9 % CO2	
	30.131 Mol. Wt (g/gmole) Dry 27.930 Mol. Wt (g/gmole) Wet	

Sample Parameters:

Sample Volume	2.4320 dscm	85.886 dscf
Sample Time	120.0 minutes	
Isokineticity	106.6 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client:	Metro Vancouver	Date:	26-Feb-20
Jobsite:	WTE (Burnaby, B.C)	Run:	2 - Particulate / Metals
Source:	Unit 2	Run Time:	09:29 - 11:33

Control Unit (Y)	0.9905	Collection:		Gas Analysis (Vol. %):		Condensate Collection:	
Nozzle Diameter (in.)	0.3097	Filter (grams)	0.00005	CO2	O2	Impinger 1	222.0
Pitot Factor	0.8388	Washings (grams)	0.00060	11.17	9.33	Impinger 2	106.0
Baro. Press. (in. Hg)	30.46			10.67	9.90	Impinger 3	42.0
Static Press. (in. H2O)	-19.00					Impinger 4	12.0
Stack Height (ft)	30					Impinger 5	4.0
Stack Diameter (in.)	70.90					Impinger 6	2.0
Stack Area (sq.ft.)	27.417					Gel	16.6
Minutes Per Reading	5.0			10.92	9.62	Gain (grams)	404.6
Minutes Per Point	5.0						

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	44.200								
1	5.0	48.390	0.48	2.37	51	51	8.5	320	1.5	106.8
2	10.0	52.730	0.51	2.53	54	54	8.5	321	4.7	106.8
3	15.0	56.600	0.40	2.00	58	58	8	321	8.4	106.6
4	20.0	60.520	0.41	2.06	58	58	8	320	12.5	106.6
5	25.0	64.330	0.38	1.92	62	62	7	320	17.7	106.7
6	30.0	67.890	0.33	1.68	64	64	7	319	25.2	106.5
7	35.0	70.810	0.22	1.12	66	66	5.5	318	45.6	106.3
8	40.0	73.540	0.19	0.97	68	68	5.5	320	53.2	106.7
9	45.0	76.600	0.24	1.23	68	68	5.5	319	58.3	106.4
10	50.0	79.460	0.21	1.08	67	67	5.5	317	62.5	106.3
11	55.0	82.500	0.24	1.22	64	64	5.5	318	66.1	106.4
12	60.0	85.450	0.23	1.16	60	60	5.5	318	69.4	106.3
Traverse 2	0.0	85.450								
1	5.0	88.880	0.31	1.56	61	61	6.5	320	1.5	106.5
2	10.0	92.260	0.30	1.51	61	61	6.5	320	4.7	106.6
3	15.0	95.530	0.28	1.41	62	62	6	321	8.4	106.6
4	20.0	98.490	0.23	1.16	62	62	6	321	12.5	106.4
5	25.0	101.520	0.24	1.21	63	63	5.5	322	17.7	106.5
6	30.0	104.960	0.31	1.57	63	63	5.5	322	25.2	106.5
7	35.0	109.800	0.61	3.09	65	65	10.5	323	45.6	106.9
8	40.0	114.740	0.63	3.20	66	66	10.5	321	53.2	107.0
9	45.0	119.680	0.63	3.21	67	67	10.5	322	58.3	106.9
10	50.0	124.460	0.59	3.00	67	67	10.5	322	62.5	106.8
11	55.0	127.990	0.32	1.63	68	68	10.5	323	66.1	106.6
12	60.0	131.634	0.34	1.73	68	68	10.5	323	69.4	106.8
Average:			0.360	1.818	63.0	63.0	7.5	320.5		106.6

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 2

Date: 26-Feb-20
Run: 3 - Particulate / Metals
Run Time: 12:05 - 14:07

Concentrations:

Particulate	0.2 mg/dscm	0.0001 gr/dscf
	0.1 mg/Acm	0.0001 gr/Acf
	0.2 mg/dscm (@ 11% O2)	0.0001 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.01 Kg/hr	0.031 lb/hr
--------------------	------------	-------------

Flue Gas Characteristics:

Flow	1102 dscm/min	38930 dscf/min
	18.37 dscm/sec	649 dscf/sec
	1983 Acm/min	70046 Acf/min

Velocity	12.979 m/sec	42.58 f/sec
-----------------	--------------	-------------

Temperature	160.4 oC	320.7 oF
--------------------	----------	----------

Moisture	15.4 %
-----------------	--------

Gas Analysis	9.7 % O2
	10.8 % CO2
	30.121 Mol. Wt (g/gmole) Dry
	28.257 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.6179 dscm	92.451 dscf
Sample Time	120.0 minutes	
Isokineticity	103.7 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 2

Date: 26-Feb-20
Run: 3 - Particulate / Metals
Run Time: 12:05 - 14:07

Control Unit (Y)	0.9905	Collection:	Gas Analysis (Vol. %):	Condensate Collection:
Nozzle Diameter (in.)	0.3097	Filter (grams) 0.00005	CO2	Impinger 1 160.0
Pitot Factor	0.8388	Washings (grams) 0.00050	O2	Impinger 2 126.0
Baro. Press. (in. Hg)	30.46		11.00 9.63	Impinger 3 44.0
Static Press. (in. H2O)	-19.00	Traverse 1	10.67 9.77	Impinger 4 8.0
Stack Height (ft)	30	Traverse 2		Impinger 5 4.0
Stack Diameter (in.)	70.90	Total (grams) 0.0006		Impinger 6 1.0
Stack Area (sq.ft.)	27.417			Gel 14.1
Minutes Per Reading	5.0		10.83 9.70	Gain (grams) 357.1
Minutes Per Point	5.0			

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	132.100								
1	5.0	135.460	0.29	1.48	67	67	6.5	319	1.5	103.6
2	10.0	138.750	0.28	1.43	66	66	6.5	319	4.7	103.5
3	15.0	141.920	0.26	1.32	66	66	6	320	8.4	103.5
4	20.0	144.970	0.24	1.23	66	66	6	318	12.5	103.5
5	25.0	147.960	0.23	1.18	67	67	5.5	319	17.7	103.5
6	30.0	151.320	0.29	1.48	67	67	5.5	320	25.2	103.7
7	35.0	156.110	0.59	3.01	67	67	10	320	45.6	104.0
8	40.0	160.990	0.61	3.12	68	68	10	319	53.2	104.0
9	45.0	165.910	0.62	3.17	68	68	10.5	319	58.3	104.0
10	50.0	170.700	0.59	3.01	67	67	10.5	319	62.5	104.0
11	55.0	174.450	0.36	1.84	68	68	9	319	66.1	103.7
12	60.0	178.090	0.34	1.74	68	68	9	319	69.4	103.6
Traverse 2	0.0	178.090								
1	5.0	182.640	0.53	2.72	67	67	10	316	1.5	103.9
2	10.0	187.120	0.52	2.64	67	67	10	324	4.7	103.8
3	15.0	191.430	0.48	2.44	67	67	9.5	323	8.4	103.8
4	20.0	195.930	0.52	2.65	68	68	9.5	323	12.5	104.0
5	25.0	200.290	0.49	2.49	68	68	9.5	324	17.7	103.8
6	30.0	204.520	0.46	2.34	68	68	9.5	324	25.2	103.9
7	35.0	207.880	0.29	1.48	68	68	7.5	322	45.6	103.6
8	40.0	211.060	0.26	1.33	68	68	7.5	321	53.2	103.5
9	45.0	214.370	0.28	1.43	69	69	7.5	322	58.3	103.7
10	50.0	217.300	0.22	1.12	69	69	7.5	322	62.5	103.5
11	55.0	220.420	0.25	1.28	69	69	6	323	66.1	103.5
12	60.0	223.280	0.21	1.07	69	69	6	323	69.4	103.4
Average:			0.384	1.958	67.6	67.6	3.0	320.7		103.7

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)
Source: Unit 2

Sample Type:		HF		
Parameter		Test 1	Test 2	Test 3
Test Date		26-Feb-20	26-Feb-20	26-Feb-20
Test Time		09:52 - 10:52	11:02 - 12:02	12:17 - 13:17
Test Duration		(min.) 60	60	60
Baro. Press.		(in. Hg) 30.46	30.46	30.46
DGM Factor		(Y) 0.9757	0.9757	0.9757
Initial Reading		(m ³) 383.684	384.372	385.062
Final Reading		(m ³) 384.364	385.055	385.673
Temp. Outlet		(Avg. oF) 58.5	67.5	65.5
Orifice Press.		(ΔH in.H2O) 0.50	0.50	0.50
Gas Volume		(Sm ³) 0.68826	0.68069	0.60974
HF		(mg) 0.026	0.026	0.013
Oxygen		(Vol. %) 9.6	9.7	9.7
HF		(mg/Sm ³) 0.038	0.039	0.022
HF		(mg/Sm ³ @ 1 0.034	0.034	0.019
Moisture (isokinetic)		(Vol. %) 18.1	18.1	15.4
*Wet Basis Calculated on moisture from isokinetic tests				
Tstd. (oF)		68	Pstd. (in. Hg)	29.92

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 3

Date: 26-Feb-20
Run: 1 - Particulate / Metals
Run Time: 10:16 - 12:23

Concentrations:

Particulate	0.25 mg/dscm	0.00011 gr/dscf
	0.14 mg/Acm	0.00006 gr/Acf
	0.22 mg/dscm (@ 11% O2)	0.00010 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.018 Kg/hr	0.040 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1196 dscm/min	42224 dscf/min
	19.93 dscm/sec	704 dscf/sec
	2112 Acm/min	74596 Acf/min

Velocity	13.822 m/sec	45.35 f/sec
-----------------	--------------	-------------

Temperature	153.9 oC	309.0 oF
--------------------	----------	----------

Moisture	15.2 %
-----------------	--------

Gas Analysis	9.7 % O2
	10.1 % CO2

30.000 Mol. Wt (g/gmole) Dry
28.180 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.5939 dscm	91.604 dscf
Sample Time	115.0 minutes	
Isokineticity	100.7 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 3

Date: 26-Feb-20
Run: 1 - Particulate / Metals
Run Time: 10:16 - 12:23

Control Unit (Y) 0.9982
 Nozzle Diameter (in.) 0.3073
 Pitot Factor 0.8517
 Baro. Press. (in. Hg) 30.48
 Static Press. (in. H2O) -19.00
 Stack Height (ft) 30
 Stack Diameter (in.) 70.90
 Stack Area (sq.ft.) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 5.0

Collection:
 Filter (grams) 0.00005
 Washings (grams) 0.00060
Total (grams) 0.00065

Traverse 1
 Traverse 2

Gas Analysis (Vol. %):
 CO2 O2
 10.17 9.67
 10.00 9.67
10.08 9.67

Condensate Collection:
 Impinger 1 182.0
 Impinger 2 108.0
 Impinger 3 26.0
 Impinger 4 10.0
 Impinger 5 4.0
 Impinger 6 2.0
 Gel 16.0
Gain (grams) 348.0

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1										
1	0.0	121.903								
2	5.0	126.500	0.58	3.05	50	50	8	303	1.5	103.4
3	10.0	131.200	0.61	3.18	50	50	8	310	4.7	103.6
4	15.0	135.820	0.59	3.06	50	50	8	312	8.4	103.6
5	20.0	140.400	0.58	3.01	51	51	8	313	12.5	103.5
6	25.0	144.900	0.56	2.91	51	51	6	314	17.7	103.5
7	30.0	149.330	0.54	2.81	52	52	6	314	25.2	103.5
8	35.0	152.700	0.31	1.62	53	53	6	312	45.6	103.3
9	40.0	155.900	0.28	1.47	53	53	6	310	53.2	103.1
10	45.0	159.060	0.27	1.42	55	55	5	311	58.3	103.3
11	50.0	162.280	0.28	1.47	56	56	5	311	62.5	103.2
12	55.0	165.650	0.30	1.60	57	57	5	300	66.1	103.4
12	60.0	169.120	0.32	1.71	58	58	5	301	69.4	103.0
Traverse 2										
1	0.0	169.120								
2	5.0	172.800	0.36	1.92	59	59	6	306	1.5	103.2
3	10.0	176.580	0.38	2.01	59	59	6	311	4.7	103.5
4	15.0	180.360	0.38	2.01	61	61	6	313	8.4	103.2
5	20.0	184.080	0.37	1.95	61	61	6	317	12.5	103.2
6	25.0	187.380	0.29	1.53	61	61	7	315	17.7	103.2
7	30.0	190.620	0.28	1.48	61	61	7	315	25.2	103.1
8	35.0	194.400	0.38	2.01	61	61	8	314	45.6	103.3
9	40.0	198.780	0.51	2.71	61	61	8	312	53.2	103.4
10	45.0	203.250	0.52	2.81	62	62	8	299	58.3	103.4
11	50.0	207.800	0.54	2.92	62	62	8	298	62.5	103.2
11	55.0	209.600	0.48	2.60	62	62	8	297	66.1	43.3
Average:										
			0.422	2.229	56.8	56.8	6.7	309.0		100.7

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 3

Date: 27-Feb-20
Run: 2 - Particulate / Metals
Run Time: 09:40 - 11:42

Concentrations:

Particulate	0.94 mg/dscm	0.00041 gr/dscf
	0.52 mg/Acm	0.00023 gr/Acf
	0.93 mg/dscm (@ 11% O2)	0.00041 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.064 Kg/hr	0.142 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1145 dscm/min	40422 dscf/min
	19.08 dscm/sec	674 dscf/sec
	2061 Acm/min	72778 Acf/min

Velocity	13.485 m/sec	44.24 f/sec
-----------------	--------------	-------------

Temperature	158.3 oC	316.9 oF
--------------------	----------	----------

Moisture	15.9 %
-----------------	--------

Gas Analysis	10.9 % O2
	9.6 % CO2

29.970 Mol. Wt (g/gmole) Dry
28.068 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.7270 dscm	96.305 dscf
Sample Time	120.0 minutes	
Isokineticity	104.1 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 3

Date: 27-Feb-20
Run: 2 - Particulate / Metals
Run Time: 09:40 - 11:42

Control Unit (Y) 0.9982
Nozzle Diameter (in.) 0.3097
Pitot Factor 0.8388
Baro. Press. (in. Hg) 30.40
Static Press. (in. H2O) -18.00
Stack Height (ft) 30
Stack Diameter (in.) 70.90
Stack Area (sq.ft.) 27.417
Minutes Per Reading 5.0
Minutes Per Point 5.0

Collection:
 Filter (grams) 0.00005
 Washings (grams) 0.00250
Total (grams) 0.00255

Gas Analysis (Vol. %):
 CO2 O2
 Traverse 1 9.50 11.00
 Traverse 2 9.67 10.83
9.58 10.92

Condensate Collection:
 Impinger 1 176.0
 Impinger 2 124.0
 Impinger 3 48.0
 Impinger 4 14.0
 Impinger 5 5.0
 Impinger 6 2.0
 Gel 17.5
Gain (grams) 386.5

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)Outlet (oF)		Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	209.800								
1	5.0	214.320	0.56	2.94	52	52	10	314	1.5	104.2
2	10.0	218.710	0.53	2.78	51	51	10	315	4.7	104.2
3	15.0	223.190	0.55	2.89	52	52	10	315	8.4	104.2
4	20.0	227.880	0.60	3.15	53	53	10	316	12.5	104.4
5	25.0	232.610	0.61	3.20	54	54	12	318	17.7	104.4
6	30.0	237.360	0.61	3.22	56	56	12	317	25.2	104.3
7	35.0	240.960	0.35	1.85	57	57	9	317	45.6	103.8
8	40.0	243.940	0.24	1.27	57	57	9	319	53.2	103.8
9	45.0	246.800	0.22	1.16	57	57	6	317	58.3	103.9
10	50.0	249.730	0.23	1.22	58	58	6	316	62.5	103.8
11	55.0	252.780	0.25	1.32	58	58	6	318	66.1	103.8
12	60.0	255.580	0.21	1.11	58	58	6	318	69.4	103.9
Traverse 2	0.0	255.580								
1	5.0	259.360	0.38	2.02	61	61	7	319	1.5	104.0
2	10.0	263.040	0.36	1.91	61	61	7	319	4.7	104.0
3	15.0	266.460	0.31	1.65	62	62	6.5	320	8.4	104.0
4	20.0	269.700	0.28	1.49	61	61	6.5	319	12.5	103.7
5	25.0	273.010	0.29	1.54	62	62	6.5	319	17.7	103.9
6	30.0	276.330	0.29	1.55	63	63	6.5	318	25.2	104.0
7	35.0	280.550	0.47	2.51	63	63	10	317	45.6	104.0
8	40.0	285.170	0.56	3.00	63	63	10	315	53.2	104.3
9	45.0	289.660	0.53	2.84	63	63	10.5	315	58.3	104.2
10	50.0	294.240	0.55	2.95	63	63	10.5	314	62.5	104.3
11	55.0	298.610	0.50	2.68	64	64	10	316	66.1	104.2
12	60.0	302.622	0.42	2.26	64	64	10	315	69.4	104.2
Average:			0.413	2.188	58.9	58.9	8.6	316.9		104.1

Client:	Metro Vancouver	Date:	27-Feb-20
Jobsite:	WTE(Burnaby,B.C)	Run:	3 - Particulate / Metals
Source:	Unit 3	Run Time:	12:10 - 14:11

Concentrations:

Particulate	0.24 mg/dscm	0.00010 gr/dscf
	0.13 mg/Acm	0.00006 gr/Acf
	0.20 mg/dscm (@ 11% O2)	0.00009 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.016 Kg/hr	0.036 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1139 dscm/min	40222 dscf/min
	18.98 dscm/sec	670 dscf/sec
	2049 Acn/min	72372 Acf/min

Velocity	13.410 m/sec	43.99 f/sec
-----------------	--------------	-------------

Temperature	158.5 oC	317.3 oF
--------------------	----------	----------

Moisture	15.8 %
-----------------	--------

Gas Analysis	9.3 % O2
	11.2 % CO2

	30.160 Mol. Wt (g/gmole) Dry
	28.240 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.7179 dscm	95.982 dscf
Sample Time	120.0 minutes	
Isokineticity	104.3 %	

* Standard Conditions:	Metric: 20 deg C, 101.325 kPa
	Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE(Burnaby,B.C)
Source: Unit 3

Date: 27-Feb-20
Run: 3 - Particulate / Metals
Run Time: 12:10 - 14:11

Control Unit (Y) 0.9982
 Nozzle Diameter (in.) 0.3097
 Pitot Factor 0.8388
 Baro. Press. (in. Hg) 30.40
 Static Press. (in. H2O) -18.00
 Stack Height (ft) 30
 Stack Diameter (in.) 70.90
 Stack Area (sq.ft.) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 5.0

Collection:
 Filter (grams) 0.00005
 Washings (grams) 0.00060
Total (grams) 0.00065

Gas Analysis (Vol. %):	
CO2	O2
Traverse 1 11.00	9.50
Traverse 2 11.33	9.17
11.17	9.33

Condensate Collection:
 Impinger 1 184.0
 Impinger 2 128.0
 Impinger 3 34.0
 Impinger 4 10.0
 Impinger 5 4.0
 Impinger 6 3.0
 Gel 19.5
Gain (grams) 382.5

Traverse / Point	Time (min.)	Dry Gas Meter		Orifice ^H (in. H2O)	Dry Gas Temperature			Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
		Pitot ^P (in. H2O)			Inlet (oF)	Outlet (oF)					
Traverse 1	0.0	303.100									
1	5.0	306.870	0.37	2.00	63	63	7	310	1.5	104.3	
2	10.0	310.470	0.34	1.82	64	64	7	316	4.7	104.1	
3	15.0	313.910	0.31	1.66	64	64	6	317	8.4	104.2	
4	20.0	317.230	0.29	1.55	63	63	6	317	12.5	104.1	
5	25.0	320.430	0.27	1.44	63	63	5.5	317	17.7	104.0	
6	30.0	323.800	0.30	1.60	63	63	5.5	318	25.2	104.0	
7	35.0	328.200	0.51	2.72	63	63	9	318	45.6	104.4	
8	40.0	332.820	0.56	3.00	64	64	9	317	53.2	104.4	
9	45.0	337.690	0.62	3.33	64	64	9.5	316	58.3	104.6	
10	50.0	342.520	0.61	3.27	65	65	9.5	318	62.5	104.5	
11	55.0	346.890	0.50	2.68	65	65	9	318	66.1	104.3	
12	60.0	351.080	0.46	2.47	65	65	9	318	69.4	104.2	
Traverse 2	0.0	351.080									
1	5.0	355.220	0.45	2.41	65	65	8.5	320	1.5	104.3	
2	10.0	359.630	0.51	2.73	65	65	8.5	320	4.7	104.4	
3	15.0	364.290	0.57	3.05	65	65	9	319	8.4	104.4	
4	20.0	369.080	0.60	3.21	65	65	9	319	12.5	104.6	
5	25.0	373.790	0.58	3.11	66	66	9.5	320	17.7	104.4	
6	30.0	378.210	0.51	2.74	66	66	9.5	319	25.2	104.4	
7	35.0	381.940	0.36	1.94	67	67	7	317	45.6	104.3	
8	40.0	385.050	0.25	1.35	67	67	7	316	53.2	104.1	
9	45.0	387.900	0.21	1.13	67	67	5.5	317	58.3	104.1	
10	50.0	390.880	0.23	1.24	67	67	5.5	315	62.5	103.9	
11	55.0	393.920	0.24	1.29	67	67	5.5	317	66.1	103.9	
12	60.0	396.701	0.20	1.08	67	67	5.5	316	69.4	104.0	
Average:			0.410	2.201	65.0	65.0	7.6	317.3		104.3	

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)
Source: Unit 3

Sample Type: HF		Test 1	Test 2	Test 3
Parameter				
Test Date		27-Feb-20	27-Feb-20	27-Feb-20
Test Time		10:05 - 11:05	11:17 - 12:17	12:31 - 13:31
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.40	30.40	30.40
DGM Factor	(Y)	0.9757	0.9757	0.9757
Initial Reading	(m ³)	385.685	386.402	387.145
Final Reading	(m ³)	386.394	387.142	387.854
Temp. Outlet	(Avg. oF)	61.0	68.5	69.0
Orifice Press.	(ΔH in.H ₂ O)	0.50	0.50	0.50
Gas Volume	(Sm ³)	0.71298	0.73320	0.70219
HF	(mg)	0.051	0.013	0.013
Oxygen	(Vol. %)	10.9	10.9	9.3
HF	(mg/Sm ³)	0.072	0.018	0.018
HF	(mg/Sm ³ @ 1	0.072	0.017	0.016
Moisture (isokinetic)	(Vol. %)	15.9	15.9	15.8
*Wet Basis Calculated on moisture from isokinetic tests				
Tstd. (oF)	68		Pstd. (in. Hg)	29.92

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)

Parameter: N₂O

Molecular Weight: 44.00 grams/mol
Lab Detection Limit: 0.1 ppm
Oxygen Correction: 11 %
Reportable Detection Limit: 0.18 mg/Sm³

Sample ID	Date	Time	N ₂ O ppm	N ₂ O mg/Sm ³	O ₂ % Vol	N ₂ O mg/Sm ³ @ 11% O ₂
Unit 1 Run 1	24-Feb-20	10:15 - 11:15	15.0	27.4	9.70	24.3
Unit 1 Run 2	24-Feb-20	11:20 - 12:20	18.0	32.9	9.70	29.1
Unit 1 Run 3	24-Feb-20	12:50 - 13:50	13.0	23.8	9.70	21.0
Average						24.8
Unit 2 Run 1	24-Feb-20	10:00 - 11:00	3.1	5.7	9.60	5.0
Unit 2 Run 2	24-Feb-20	11:01 - 12:01	0.6	1.1	9.60	1.0
Unit 2 Run 3	24-Feb-20	12:02 - 13:02	16.0	29.3	9.60	25.6
Average						10.5
Unit 3 Run 1	24-Feb-20	12:30 - 13:30	1.1	2.0	9.60	1.8
Unit 3 Run 2	24-Feb-20	13:31 - 14:31	13.0	23.8	9.60	20.8
Unit 3 Run 3	24-Feb-20	14:32 - 15:32	0.6	1.1	9.60	1.0
Average						7.9

APPENDIX - D

FIELD DATA SHEETS

[illegible]

[illegible]

CA

CLIENT MV WTE					NOZZLE 6-310		DIAMETER, IN. 0.3097		IMPINGER		INITIAL		FINAL		TOTAL GAIN	
SOURCE WTE #1					PROBE 7C		Cp 0.8388		VOLUMES		(mL)		(mL)		(mL)	
PARAMETER / RUN No MCMS/Hg/Static RUN#3					PORT LENGTH				Imp. #1		100		142		142	
DATE FEB. 25, 2020					STATIC PRESSURE, IN. H ₂ O -19.0				Imp. #2		100		236		136	
OPERATOR: SE					STACK DIAMETER 70.90				Imp. #3		0		146		46	
CONTROL UNIT CAE AL 1					STACK HEIGHT 30				Imp. #4		100		14		14	
BAROMETRIC PRESSURE, IN. Hg 30.51					INITIAL LEAK TEST 0.002 @ 15" Hg				Imp. #5		100		105		5	
ASSUMED MOISTURE, Bw 14.5%					FINAL LEAK TEST 0.002 @ 15" Hg				Imp. #6		0m		102		2	
					Upstream Diameters											
					Downstream Diameters											
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites					
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %				
1	12:20	630.100														
2	5	633.22	0.26	1.39	63	303	254	261	54	7	11.5	9.1				
3	10	636.57	0.30	1.60	62	303										
4	15	639.91	0.30	1.60	62	304										
5	20	643.14	0.28	1.49	62	304	263	257	53	7						
6	25	646.54	0.31	1.65	62	305										
7	30	649.99	0.32	1.70	62	304				7	11.5	9.4				
8	35	654.05	0.44	2.35	63	303	252	253	57	9.5						
9	40	658.39	0.50	2.68	63	300										
10	45	663.17	0.61	3.25	63	303										
11	50	667.82	0.58	3.09	63	305	255	256	61	12.5	12.5	9.0				
12	55	672.01	0.47	2.50	64	306										
	60	675.94	0.41	2.19	65	306				10.0						
1	5	679.42	0.32	1.72	66	302	259	258	56	8.8	11	9.4				
2	10	683.45	0.43	2.30	66	304										
3	15	687.53	0.44	2.30	66	304										
4	20	691.76	0.47	2.53	67	303	259	256	53	9.5						
5	25	695.80	0.43	2.31	67	303										
6	30	700.03	0.47	2.53	67	303				10	11	9.5				
7	35	704.21	0.46	2.47	67	304	258	257	63	10						
8	40	708.21	0.42	2.26	68	303										
9	45	712.12	0.40	2.15	68	303										
10	50	715.77	0.35	1.88	68	303	258	255	52	9.5	10.5	9.7				
11	55	719.37	0.34	1.83	68	304										
12	60	722.86	0.32	1.72	68	304				9						
WAB	14:23															

CA

PLANT <u>M.V. W.T.E.</u>		PROBE TIP DIAMETER, IN. <u>G-3072 / 0.3073</u>		IMPINGER		INITIAL	FINAL	TOTAL GAIN
RUN No <u>1 - Potable / Ractonate</u>		PROBE LENGTH, FT / Cp <u>ALGURO / 0.8517</u>		VOLUMES		(mL)	(mL)	(mL)
LOCATION <u>Unit #2</u>		FILTER NUMBER		Imp. # 1		0	202	202
DATE <u>Feb. 25, 2020</u>		STATIC PRESSURE, IN. H ₂ O <u>-19.5"</u>		Imp. # 2		100	204	104
OPERATOR: <u>Daryl Sampson + CNL</u>		STACK DIAMETER <u>70.9"</u>		Imp. # 3		100	130	30
CONTROL UNIT / Y <u>CAE GDS / 0.9905</u>		STACK HEIGHT <u>30.0'</u>		Imp. # 4		0	8	8
BAROMETRIC PRESSURE, IN. Hg <u>30.52</u>		INITIAL LEAK TEST <u>0.006 @ 15"</u>		#5		100	103	3
ASSUMED MOISTURE, Bw <u>15%</u>		FINAL LEAK TEST <u>0.005 @ 15"</u>		#6		100	101	1
				Upstream Diameters		Gel. 200g		
				Downstream Diameters				

5 Point Min	Clock Time	Dry Gas Meter Ft ³	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp. Outlet °F	Temperature °F				Pump Vac. IN. Hg Gauge	Fyrites	
						Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %
1	11:50	957.862										
2		961.95	0.45	2.25	51	302	256	239	54	8		
3		966.12	0.47	2.34	51	306						
4		970.45	0.51	2.53	51	310	256	244	55	9	10.0	9.5
5		974.88	0.53	2.64	53	311						
6		978.96	0.45	2.24	53	311	256	257	58	10		
7		982.62	0.36	1.79	54	314						
8		985.68	0.25	1.25	56	312	256	256	59	8	10.0	9.5
9		988.43	0.20	1.00	57	310						
10		991.14	0.19	0.97	57	300	256	257	60	6		
11		993.75	0.18	0.91	58	306						
12		996.36	0.18	0.91	58	307	256	257	57	6		
		998.82	0.16	0.81	58	307						
1		1001.68	0.21	1.08	60	298	256	246	56	5	10.0	9.5
2		1004.66	0.23	1.17	60	303						
3		1007.44	0.20	1.02	61	306	256	256	56	5	10.0	9.5
4		1010.15	0.19	0.96	61	308						
5		1013.06	0.22	1.12	62	308	256	256	55	5		
6		1016.10	0.24	1.22	62	307						
7		1020.78	0.45	2.30	63	306	256	256	54	6	10.5	9.0
8		1024.70	0.55	2.80	63	307						
9		1029.75	0.65	3.34	64	302	256	256	55	8		
10		1034.68	0.57	2.92	65	307						
11		1039.29	0.54	2.79	65	298	256	255	57	10	10.5	9.0
12	13:52	1043.75	0.50	2.60	66	295						

[illegible]

[illegible]

CLIENT MV WLE				NOZZLE G-310		DIAMETER, IN. 0.3097		IMPINGER		INITIAL		FINAL		TOTAL GAIN		
SOURCE UNIT #3				PROBE 7C		Cp 0.8388		VOLUMES		(mL)		(mL)		(mL)		
PARAMETER / RUN No Run #2 MCHMS/Hg/Partic.				PORT LENGTH				Imp. #1		100		176		176		
DATE FEB 27, 2020				STATIC PRESSURE, IN. H2O -18				Imp. #2		100		224		124		
OPERATOR JS				STACK DIAMETER 70.90"				Imp. #3		0		148		48		
CONTROL UNIT CGK				STACK HEIGHT 30'				Imp. #4		100		14		14		
				Y 0.9982				Imp. #5		100		105		5		
				ΔH@ 1.867				Imp. #6		100		102		2		
BAROMETRIC PRESSURE, IN. Hg 30.40				INITIAL LEAK TEST 0.003 @ 15" Hg				Upstream Diameters								
ASSUMED MOISTURE, Bw 145%				FINAL LEAK TEST 0.003 @ 15" Hg				Downstream Diameters								
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites					
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %				
	0940	209.800														
1	5	214.32	0.56	2.94	52	314	261	254	52	10	9	11.5				
2	10	218.71	0.52	2.78	51	315										
3	15	223.19	0.55	2.89	52	315										
4	20	227.88	0.60	3.15	53	316	262	254	56	10						
5	25	232.61	0.61	3.20	54	318			59	12	10	10.5				
6	30	237.36	0.61	3.22	56	317										
7	35	240.96	0.35	1.85	57	317	283	280	61	9						
8	40	243.94	0.24	1.27	57	319										
9	45	246.80	0.22	1.16	57	317			58	6	9.5	11				
10	50	249.73	0.23	1.22	58	316	250	250	58	6						
11	55	252.78	0.25	1.32	58	318			56	6						
12	60	255.58	0.21	1.11	58	318										
13																
14	5	259.36	0.38	2.02	61	319	250	250	53	7	9.5	10				
15	10	263.04	0.36	1.91	61	319										
16	15	266.46	0.31	1.65	62	320			53	6.5						
17	20	269.70	0.25	1.49	61	319	252	250								
18	25	273.01	0.29	1.54	62	319			52	6.5	10	10.5				
19	30	276.33	0.29	1.55	63	318										
20	35	280.55	0.47	2.51	63	317	252	249	53	10						
21	40	285.17	0.86</													

CLIENT MU WLE					NOZZLE G-310		DIAMETER, IN. 0.3097		IMPINGER		INITIAL		FINAL		TOTAL GAIN		
SOURCE UN143					PROBE 7C		Cp 0.8388		VOLUMES		(mL)		(mL)		(mL)		
PARAMETER / RUN No RUN#3 PWTNS/PARTIC/Hg					PORT LENGTH				Imp. #1		100		184		184		
DATE FEB 27, 2020					STATIC PRESSURE, IN. H2O ~18.				Imp. #2		100		228		128		
OPERATOR CF					STACK DIAMETER 70.90"				Imp. #3		0		134		34		
CONTROL UNIT G64B					STACK HEIGHT 30'				Imp. #4		100		10		10		
									Imp. #5		100		104		4		
BAROMETRIC PRESSURE, IN. Hg 30.40					INITIAL LEAK TEST 0.002 @ 15" Hg				Imp. #6		600		103		3		
ASSUMED MOISTURE, Bw 14.5%					FINAL LEAK TEST 0.002 @ 15" Hg				Upstream Diameters								
									Downstream Diameters								
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites						
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %					
1		303.100															
2	10	306.87	0.37	2.00	63	310	248	253	56	7	11	9.5					
3		310.47	0.34	1.82	64	316											
4	20	313.91	0.31	1.66	64	317											
5		317.23	0.29	1.55	63	317	262	254	55	6							
6	30	320.43	0.27	1.44	63	317											
7		323.80	0.30	1.60	63	317			58	5.5	11	9.5					
8	40	328.20	0.51	2.72	63	318	249	252	59	9							
9		332.82	0.56	3.00	64	317											
10	50	337.69	0.62	3.33	64	316			62	9.5	11	9.5					
11		342.52	0.61	3.27	65	318	252	249	62								
12	60	346.89	0.50	2.68	65	318			61	9							
		351.08	0.46	2.47	65	318											
1		355.22	0.45	2.41	65	320	255	246	56	8.5	11	9.5					
2	10	359.63	0.51	2.73	65	320											
3		364.29	0.57	3.05	65	319			54	9							
4	20	369.08	0.60	3.21	65	319	251	250									
5		373.79	0.58	3.11	66	320			53	9.5	11.5	9					
6	30	378.21	0.61	3.27	66	319											
7		381.94	0.36	1.94	67	317	252	250	56	7							
8	40	385.05	0.25	1.35	67	316											
9		387.90	0.21	1.13	67	317			57	5.5	11.5	9					

A. Lanfranco and Associates Inc.

Client MV Covanta Y LMA (.9757)
 Source Unit #1 Cp _____
 Parameter MF Pbar 30.51 Static _____
 Date Feb-25-2020 Operator MF

Leak Check	Run 1	Run 2	Run 3
Initial	0.0002	0.0002	0.0002
Final	0.0002	0.0002	0.0002

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	1045	381.6438	50		200			
			52					
			55					
			58					
			60					
			62					
	1145	382.3300	62		265			
2	1227	382.3460	56		200			
	1227	383.0000	68		245			
3	1338	383.0208	54		200			
	1438	383.6684	52		230			

Client MV Covanta Y LMA (.9757)
 Source Unit #2 Cp _____
 Parameter MF Pbar 30.46 Static _____
 Date Feb-26-2020 Operator MF

Leak Check	Run 1	Run 2	Run 3
Initial	0.0002	0.0002	0.0002
Final	0.0002	0.0002	0.0002

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	0952	383.6840	49		200			
	1052	384.3636	68		285			
2	1102	384.3716	64		200			
	1202	385.0554	71		284			
3	1217	385.0624	64		200			
	1317	385.6726	67		260			

A. Lanfranco and Associates Inc.

Client MV Cuentera Y LMD-A (9757)
 Source Unit #3 Cp 1.488
 Parameter H-F Pbar 30.40 Static
 Date Feb-27-2020 Operator MB

Client Y
 Source Cp
 Parameter Pbar Static
 Date Operator

Leak Check	Run 1	Run 2	Run 3
Initial	0.0002	0.0002	0.0002
Final	0.0002	0.0002	0.0002

Leak Check	Run 1	Run 2	Run 3
Initial			
Final			

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	1005	385.6852	51		200			
2	1105	386.3940	71		290			
3	1217	386.4024	66		200			
3	1231	387.1418	71		215			
3	1331	387.1452	66		200			
3		387.8540	72		288			

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1								
2								
3								

APPENDIX – E

CALIBRATION SHEETS and

TECHNICIAN CERTIFICATES

A.Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: CAE AL1
Serial #: 0028-070611-1

Date: 06-Jan-20
Barometric Pressure: 29.94 (in. Hg)
Theoretical Critical Vacuum: 14.12 (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}((in.Hg)²(min)).
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.65	21.00	927.900	950.011	22.111	71.0	71.0	74.0	74.0	73	0.8185	17.5	78.0	83.0	80.5
1.85	17.00	898.900	911.682	12.782	62.0	62.0	66.0	66.0	63	0.5956	20.5	70.0	75.0	72.5
1.10	19.00	960.300	971.646	11.346	74.0	74.0	76.0	76.0	55	0.4606	22.0	80.0	80.0	80.0
0.69	19.00	950.800	959.398	8.598	73.0	73.0	75.0	75.0	48	0.3560	23.5	80.0	80.0	80.0
0.35	17.00	972.100	977.388	5.288	75.0	75.0	76.0	76.0	40	0.2408	25.0	70.0	77.0	73.5

***** RESULTS *****														
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----					
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y			CALIBRATION FACTOR dH@					
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)		Value (in H2O)	Value (mm H2O)	Variation (in H2O)			Ko (value)
22.127	626.6		22.136	626.9	22.654	1.000	-0.011		1.833	46.57	0.005			0.715
12.942	366.5		13.137	372.0	13.245	1.015	0.003		1.757	44.63	-0.072			0.721
11.231	318.1		11.275	319.3	11.529	1.004	-0.008		1.735	44.07	-0.094			0.734
8.518	241.2		8.715	246.8	8.910	1.023	0.011		1.825	46.36	-0.004			0.703
5.220	147.8		5.306	150.3	5.360	1.017	0.005		1.994	50.64	0.165			0.677
Average Y----->						1.0118	Average dH@----->		1.829	46.5	Average Ko---->		0.710	

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Results		
		Variation (degF)	Percent of Absolute	
32	32	0	0.00%	
100	100	0	0.00%	
300	300	0	0.00%	
500	500	0	0.00%	
1000	1000	0	0.00%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: 

Date: January 6, 2020

A.Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: **CAE G10J**
Serial #: **0028-1X1310-1**

Date: **10-Jan-20**
Barometric Pressure: **29.99** (in. Hg)
Theoretical Critical Vacuum: **14.15** (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}((in.Hg)²(min)).
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.60	15.00	874.100	890.242	16.142	72.0	72.0	73.0	73.0	73	0.8185	16.0	74.0	78.0	76.0
1.85	15.00	860.800	872.526	11.726	73.0	73.0	73.0	73.0	63	0.5956	19.0	71.0	73.0	72.0
1.10	15.00	899.200	908.287	9.087	71.0	71.0	71.0	71.0	55	0.4606	20.0	76.0	78.0	77.0
0.65	15.00	890.700	897.640	6.940	71.0	71.0	71.0	71.0	48	0.3560	21.5	74.0	77.0	75.5
0.34	16.00	911.100	916.145	5.045	58.0	58.0	58.0	58.0	40	0.2408	23.0	50.0	51.0	50.5

***** RESULTS *****														
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----					
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR			CALIBRATION FACTOR					
Vm(std)	Vm(std)		Vcr(std)	Vcr(std)	Vcr	Value	Variation	Y	Value	Value	Variation	dH@		Ko
(cu ft)	(liters)		(cu ft)	(liters)	(cu ft)	(number)	(number)		(in H2O)	(mm H2O)	(in H2O)			(value)
16.178	458.2		15.904	450.4	16.114	0.983	-0.007		1.790	45.47	0.016			0.721
11.691	331.1		11.616	329.0	11.682	0.994	0.003		1.723	43.76	-0.052			0.728
9.078	257.1		8.941	253.2	9.076	0.985	-0.006		1.736	44.08	-0.039			0.733
6.925	196.1		6.921	196.0	7.005	0.999	0.009		1.712	43.48	-0.063			0.727
5.157	146.0		5.114	144.8	4.935	0.992	0.001		1.913	48.58	0.138			0.694
Average Y----->						0.9905	Average dH@----->		1.775	45.1	Average Ko----->		0.721	

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature	Temperature Device	Results		
Set-Point (deg F)	Reading (deg F)	Variation (deg F)	Percent of Absolute	
32	32	0	0.00%	
100	100	0	0.00%	
300	300	0	0.00%	
500	500	0	0.00%	
1000	1000	0	0.00%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: 

Date: January 10, 2020

A.Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: FE 18
Serial #: 0028-020118-1

Date: 07-Jan-20
Barometric Pressure: 29.66 (in. Hg)
Theoretical Critical Vacuum: 13.99 (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}((in.Hg)*(min)).
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.65	22.00	586.500	609.839	23.339	63.0	63.0	66.0	66.0	73	0.8185	15.0	65.0	72.0	68.5
1.90	22.00	610.800	627.778	16.978	66.0	66.0	68.0	68.0	63	0.5956	17.2	72.0	74.0	73.0
1.20	23.00	461.100	474.910	13.810	73.0	73.0	73.0	73.0	55	0.4606	19.5	70.0	73.0	71.5
0.68	18.00	641.000	649.247	8.247	69.0	69.0	70.0	70.0	48	0.3560	19.9	75.0	75.0	75.0
0.34	27.00	649.900	658.342	8.442	70.0	70.0	70.0	70.0	40	0.2408	21.2	75.0	76.0	75.5

***** RESULTS *****									
--- DRY GAS METER ---		----- ORIFICE -----		-- DRY GAS METER --		----- ORIFICE -----			
VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (cu ft)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (cu ft)	CALIBRATION FACTOR Y		CALIBRATION FACTOR dH@		
					Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Ko (value)
23.492	665.3	23.232	657.9	23.467	0.989	-0.009	1.837	46.67	0.712
16.935	479.6	16.834	476.7	17.149	0.994	-0.004	1.813	46.05	0.715
13.596	385.1	13.629	386.0	13.845	1.002	0.004	1.888	47.95	0.695
8.163	231.2	8.217	232.7	8.402	1.007	0.008	1.814	46.08	0.707
8.341	236.2	8.333	236.0	8.529	0.999	0.001	1.983	50.36	0.682
Average Y----->					0.9982		Average dH@----->		0.702

TEMPERATURE CALIBRATION			
Calibration Standard ----->		Omega Model CL23A S/N:T-218768	
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Results	
		Variation (deg F)	Percent of Absolute
32	32	0	0.00%
100	100	0	0.00%
300	300	0	0.00%
500	500	0	0.00%
1000	1000	0	0.00%

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: 

Date: January 7, 2020

A. Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: **LMU-A**
Serial #: **Kimmon 186**

Date: **10-Jan-20**
Barometric Pressure: **29.55** (in. Hg)
Theoretical Critical Vacuum: **13.94** (in. Hg)

!!!!!!!

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}/(in.Hg)*(min)).
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (m³)	Volume Final (m³)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
0.00	22.00	377.0640	377.2633	7.038	66.0	66.0	62.0	62.0	40	0.2408	20.0	61.0	62.0	61.5
0.00	15.00	377.2670	377.4029	4.799	62.0	62.0	63.0	63.0	40	0.2408	20.0	62.0	64.0	63.0
0.00	15.00	377.4060	377.5421	4.806	63.0	63.0	64.0	64.0	48	0.2408	20.0	64.0	66.0	65.0

***** RESULTS *****											
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----		
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR			CALIBRATION FACTOR		
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)		Value (in H2O)	Value (mm H2O)	Variation (in H2O)
7.001	198.3		6.855	194.1	6.858	0.979	0.003		0.000	0.00	0.000
4.788	135.6		4.667	132.2	4.683	0.975	-0.001		0.000	0.00	0.000
4.786	135.5		4.658	131.9	4.692	0.973	-0.002		0.000	0.00	0.000
Average Y----->						0.9757		Average dH@----->	0.0000	0.00	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

For Temperature Devicee, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: 

Date: January 10, 2020

A. LANFRANCO and ASSOCIATES INC.**ENVIRONMENTAL CONSULTANTS****GLASS NOZZLE DIAMETER CALIBRATION FORM**

Calibrated by: Scott Ferguson
Date: February 10, 2020

Signature: _____

Nozzle I.D.	d1 (inch)	d2 (inch)	d3 (inch)	difference (inch)	average dia. (inch)	average area (ft ²)
A	0.1250	0.1240	0.1245	0.0010	0.1245	0.0000845
G-165	0.1640	0.1655	0.1660	0.0020	0.1652	0.0001488
G-178	0.1780	0.1780	0.1790	0.0010	0.1783	0.0001735
J	0.1880	0.1880	0.1880	0.0000	0.1880	0.0001928
E	0.1880	0.1895	0.1882	0.0015	0.1886	0.0001939
L	0.2112	0.2120	0.2105	0.0015	0.2112	0.0002434
G-215	0.2140	0.2150	0.2155	0.0015	0.2148	0.0002517
Q	0.2190	0.2170	0.2185	0.0020	0.2182	0.0002596
G-218	0.2180	0.2175	0.2190	0.0015	0.2182	0.0002596
G-223	0.2220	0.2230	0.2225	0.0010	0.2225	0.0002700
G-225	0.2245	0.2250	0.2240	0.0010	0.2245	0.0002749
G-2251	0.2230	0.2260	0.2245	0.0030	0.2245	0.0002749
P-18	0.2375	0.2370	0.2380	0.0010	0.2375	0.0003076
G-247	0.2450	0.2470	0.2470	0.0020	0.2463	0.0003310
G-253	0.2525	0.2520	0.2525	0.0005	0.2523	0.0003473
G-257	0.2570	0.2570	0.2570	0.0000	0.2570	0.0003602
P	0.2580	0.2570	0.2575	0.0010	0.2575	0.0003616
G-275	0.2750	0.2740	0.2750	0.0010	0.2747	0.0004115
G-278	0.2780	0.2770	0.2780	0.0010	0.2777	0.0004205
P-2	0.2787	0.2790	0.2785	0.0005	0.2787	0.0004237
G-287	0.2870	0.2880	0.2860	0.0020	0.2870	0.0004493
G-292	0.2922	0.2920	0.2926	0.0006	0.2923	0.0004659
G-304	0.3040	0.3050	0.3040	0.0010	0.3043	0.0005052
MV-02	0.3050	0.3040	0.3055	0.0015	0.3048	0.0005068
MV-01	0.3050	0.3045	0.3055	0.0010	0.3050	0.0005074
G-3071	0.3075	0.3070	0.3070	0.0005	0.3072	0.0005146
G-3072	0.3070	0.3070	0.3080	0.0010	0.3073	0.0005152
G-309	0.3090	0.3090	0.3085	0.0005	0.3088	0.0005202
G-310	0.3090	0.3105	0.3095	0.0015	0.3097	0.0005230
G-316	0.3160	0.3160	0.3170	0.0010	0.3163	0.0005458
V-06	0.3200	0.3210	0.3210	0.0010	0.3207	0.0005608
G-337	0.3380	0.3365	0.3380	0.0015	0.3375	0.0006213
P-27	0.3387	0.3385	0.3390	0.0005	0.3387	0.0006258
G-343	0.3435	0.3430	0.3435	0.0005	0.3433	0.0006429
I	0.3785	0.3785	0.3785	0.0000	0.3785	0.0007814
P-14	0.3910	0.3935	0.3920	0.0025	0.3922	0.0008388
P-17	0.4070	0.4075	0.4065	0.0010	0.4070	0.0009035
C	0.4255	0.4225	0.4235	0.0030	0.4238	0.0009798
#21	0.4335	0.4325	0.4330	0.0010	0.4330	0.0010226
G-437	0.4350	0.4345	0.4355	0.0010	0.4350	0.0010321
G-468	0.4677	0.4670	0.4670	0.0007	0.4672	0.0011907
P-29	0.4680	0.4680	0.4690	0.0010	0.4683	0.0011963
P-7	0.4965	0.4940	0.4930	0.0035	0.4945	0.0013337
B	0.5015	0.5030	0.5025	0.0015	0.5023	0.0013763
G-540	0.5405	0.5400	0.5405	0.0005	0.5403	0.0015924

Where:

- (a) D1, D2, D3 = three different nozzle diameters; each diameter must be measured to within (0.025mm) 0.001 in.
- (b) Difference = maximum difference between any two diameters; must be less than or equal to (0.1mm) 0.004 in.
- (c) Average = average of D1, D2 and D3

Pitot Tube Calibration

Date: 10-Jan-20
Pbar (in.Hg): 29.69

Temp (R): 530
Dn (in.): 0.25

Pitot ID: **7A-1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.045	0.060	14.1	0.8574	0.0024
0.115	0.155	22.5	0.8527	0.0022
0.300	0.400	36.4	0.8574	0.0024
0.520	0.700	47.9	0.8533	0.0017
0.610	0.820	51.9	0.8539	0.0011
Average :			0.8549	0.0020

Pitot ID: **ST 8A**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.065	0.090	16.9	0.8413	0.0008
0.100	0.140	21.0	0.8367	0.0054
0.220	0.300	31.2	0.8478	0.0057
0.450	0.620	44.6	0.8434	0.0013
0.650	0.900	53.6	0.8413	0.0008
Average :			0.8421	0.0028

Pitot ID: **7B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.080	0.110	18.8	0.8443	0.0000
0.100	0.140	21.0	0.8367	0.0075
0.220	0.300	31.2	0.8478	0.0035
0.400	0.550	42.0	0.8443	0.0000
0.690	0.940	55.2	0.8482	0.0039
Average :			0.8442	0.0030

Pitot ID: **ST 8B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.030	0.040	11.5	0.8574	0.0034
0.105	0.140	21.5	0.8574	0.0034
0.220	0.300	31.2	0.8478	0.0061
0.520	0.700	47.9	0.8533	0.0007
0.610	0.820	51.9	0.8539	0.0001
Average :			0.8539	0.0027

Pitot ID: **AL GVRD 1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.045	0.060	14.1	0.8574	0.0057
0.090	0.120	19.9	0.8574	0.0057
0.280	0.380	35.2	0.8498	0.0019
0.550	0.750	49.3	0.8478	0.0039
0.650	0.890	53.6	0.8461	0.0056
Average :			0.8517	0.0046

Pitot ID: **ST 8C**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.090	0.130	19.9	0.8237	0.0012
0.110	0.160	22.0	0.8209	0.0041
0.200	0.290	29.7	0.8222	0.0028
0.350	0.500	39.3	0.8283	0.0033
0.590	0.840	51.0	0.8297	0.0048
Average :			0.8249	0.0032

Pitot ID: **7C**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.050	0.070	14.9	0.8367	0.0021
0.080	0.110	18.8	0.8443	0.0055
0.190	0.270	29.0	0.8305	0.0083
0.540	0.740	48.8	0.8457	0.0069
0.650	0.910	53.6	0.8367	0.0021
Average :			0.8388	0.0050

Pitot ID:

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
Average :				

* Average absolute deviation must not exceed 0.01.

Calibrated by: Michael Goods

Signature: 

Date: January 10, 2020

BAROMETER CALIBRATION FORM

Device	Cal Date	Pbar Env Canada		Device (inches of Hg)		Difference (Env Can - Elv Corr)
		(kPa)	(inches of Hg)	Reading	Elevation Corrected	
LA	January 16, 2020	100.3	29.62	29.55	29.62	0.00
DS	January 22, 2020	101.6	30.01	29.87	29.94	0.07
CL	January 16, 2020	100.3	29.62	29.56	29.63	-0.01
ML	January 6, 2020	101.8	30.07	29.96	30.03	0.03
SB	January 16, 2020	100.3	29.62	29.54	29.61	0.01
SH	January 16, 2020	100.3	29.62	29.46	29.53	0.09
JB	January 16, 2020	100.3	29.62	29.51	29.58	0.04
SF	January 6, 2020	101.8	30.07	29.96	30.03	0.03
JG	January 16, 2020	100.3	29.62	29.52	29.59	0.03

Calibrated by: Scott Ferguson

Signature:



Date: January 16th, 2020

Performance Specification is

Device Corrected for Elevation must be +/- 0.1 " Hg of ENV CANADA SEA-LEVEL Pbar

Enter Environment Canada Pressure from their website for Vancouver (link below)
and the reading from your barometer on the ground floor of the office.

http://www.weatheroffice.gc.ca/city/pages/bc-74_metric_e.html

TEMPERATURE CALIBRATION FORM

Signature:

Paula

TEMPERATURE DEVICE CALIBRATIONS

Reference Device Model CL23A Calibrator			Temperature Settings (degrees F)													
			32		100		200		300		500		800		1700	
Device	ALA #	Serial #	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation
Omega HH11A	3	300132	33	0.20%	101	0.18%	200	0.00%	300	0.00%	499	-0.10%	800	0.00%	1700	0.00%
Omega HH11A	4	200167	33	0.20%	101	0.18%	200	0.00%	301	0.13%	500	0.00%	801	0.08%	1699	-0.05%
Omega HH11A	6	600059	32	0.00%	100	0.00%	199	-0.15%	299	-0.13%	501	0.10%	799	-0.08%	1699	-0.05%
TPI 341K	7	2.0315E+10	29.8	-0.45%	97.4	-0.46%	197.2	-0.42%	297	-0.39%	496.4	-0.38%	795.8	-0.33%	1693	-0.32%
TPI 341K	8	2.0313E+10	31	-0.20%	98	-0.36%	200	0.00%	300	0.00%	500	0.00%	800	0.00%	1697	-0.14%
Cont Cmpny	10	102008464	31.3	-0.14%	98.8	-0.21%	198.9	-0.17%	298.9	-0.14%	498.6	-0.15%	796.3	-0.29%	1693.8	-0.29%
Omega HH11	14	409426	33.2	0.24%	100.2	0.04%	202	0.30%	302	0.26%	500	0.00%	799	-0.08%	1699	-0.05%
TPI 341K	16	400120029	32	0.00%	99	-0.18%	200	0.00%	301	0.13%	500	0.00%	800	0.00%	1700	0.00%
TPI 341K	18	2.0329E+10	32	0.00%	101	0.18%	200	0.00%	300	0.00%	501	0.10%	799	-0.08%	1699	-0.05%
TPI 341K	20	2.0329E+10	30.4	-0.33%	98.2	-0.32%	198.2	-0.27%	298	-0.26%	497.1	-0.30%	796.8	-0.25%	1695	-0.23%
Reference device is a NIST certified digital thermocouple calibrator																
Variation expressed as a percentage of the absolute temperature must be within 1.5 %																

Calibration Certificate

Date: 27-Jan-20
Calibrated by: Louis Agassiz
Authorizing Signature: 

Insrtument Calibrated: Testo 1 (330-2LL)
Serial #: 03101345
Customer: ALA

Ambient Conditions: Temperature: 9 °C Barometric Pressure: 101.8 kPa Relative Humidity: 94%

A. Lanfranco and Associates Inc. certifies that the described instrument has been inspected and tested following calibration procedures in the Environment Canada Report EPS 1/PG/7 (Revised 2005). Below are the observed readings after calibrations are complete. Calibration checks should be completed at least every 6 months.

O ₂ Gas	Initial Evaluation				After Calibration				Certified Value (vol %)
	Instrument Reading (vol %)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (vol %)	% Calibration Error	Pass/Fail	Notes	
Zero	0.1	0.10	Pass		0	0.00	Pass		0
O ₂	11.3	0.33	Pass	Recal on Amb	11.0	0.03	Pass		10.97
Ambient	21.0	0.04	Pass		21.0	0.01	Pass		20.96

Performance Specification: +/- 1% O₂ (absolute diff)

CO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	1878	0.2%	Pass	Recal w 2 Gas	1880	0.1%	Pass		1881
2 Gas	440	1.8%	Pass		448	0.0%	Pass		448
3 Gas	240	4.4%	Pass		249	0.8%	Pass		251

Performance Specification: +/- 5% of Certified Gas Value

NO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	6	2.0%	Pass		0	0.0%	Pass		0
1 Gas	91	0.6%	Pass		91	0.6%	Pass		91
2 Gas	470	1.3%	Pass	Recal w 2 Gas	464	0.0%	Pass		464
3 Gas	47.5	4.6%	Pass		45.4	0.0%	Pass		45.4
4Gas	255	1.6%	Pass		252	0.4%	Pass		251

Performance Specification: +/- 5% of Certified Gas Value

NIST Traceable Calibration Gases:

Cylinder	Cylinder ID Number	Certification Date	Expiration Date	Cylinder Pressure (PSI)	O ₂ (Vol. %)	CO (ppm)	NO (ppm)
Zero Gas (N ₂)	894130	27-Jun-2019	26-May-2024	380	0	0	0
1 Gas	CC700648	5-Feb-2018	5-Feb-2026	200	-	1881	90.5
2 Gas	CC222743	13-Jan-2017	13-Jan-2025	500	-	448	464
3 Gas	CC119937	1-Feb-2018	1-Feb-2021	280	-	251	45.4
4 Gas	CC200180	13-Dec-2013	13-Dec-2021	710	-	-	251
O ₂ /CO ₂	CC28009	5-Dec-2018	5-Dec-2026	1200	10.97	-	-

Note: National Institute of Standards and Technology traceable certificates are available upon request.

Calibration Certificate

Date: 27-Jan-20
Calibrated by: Louis Agassiz
Authorizing Signature: 

Insrtument Calibrated: Testo 2 (330-2LX)
Serial #: 03282252
Customer: ALA

Ambient Conditions: Temperature: 9 °C Barometric Pressure: 101.8 kPa Relative Humidity: 94%

A. Lanfranco and Associates Inc. certifies that the described instrument has been inspected and tested following calibration procedures in the Environment Canada Report EPS 1/PG/7 (Revised 2005). Below are the observed readings after calibrations are complete. Calibration checks should be completed at least every 6 months.

O ₂ Gas	Initial Evaluation				After Calibration				Certified Value (vol %)
	Instrument Reading (vol %)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (vol %)	% Calibration Error	Pass/Fail	Notes	
Zero	0.1	0.10	Pass	Rezero	0	0.00	Pass		0
O ₂	10.9	0.07	Pass		11.0	0.03	Pass		10.97
Ambient	20.7	0.26	Pass		21.0	0.04	Pass		20.96

Performance Specification: +/- 1% O₂ (absolute diff)

CO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	0	0.0%	Pass	Recal w 2 Gas	0	0.0%	Pass		0
1 Gas	1810	3.8%	Pass		1880	0.1%	Pass		1881
2 Gas	435	2.9%	Pass		448	0.0%	Pass		448
3 Gas	246	2.0%	Pass		250	0.4%	Pass		251

Performance Specification: +/- 5% of Certified Gas Value

NO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	1	0.3%	Pass	Recal w 2 Gas	0	0.0%	Pass		0
1 Gas	88	2.8%	Pass		91	0.6%	Pass		91
2 Gas	450	3.0%	Pass		464	0.0%	Pass		464
3 Gas	43.5	4.2%	Pass		45	0.9%	Pass		45.4
4Gas	247	1.6%	Pass		251	0.0%	Pass		251

Performance Specification: +/- 5% of Certified Gas Value

NIST Traceable Calibration Gases:

Cylinder	Cylinder ID Number	Certification Date	Expiration Date	Cylinder Pressure (PSI)	O ₂ (Vol. %)	CO (ppm)	NO (ppm)
Zero Gas (N ₂)	894130	27-Jun-2019	26-May-2024	380	0	0	0
1 Gas	CC700648	5-Feb-2018	5-Feb-2026	200	-	1881	90.5
2 Gas	CC222743	13-Jan-2017	13-Jan-2025	500	-	448	464
3 Gas	CC119937	1-Feb-2018	1-Feb-2021	280	-	251	45.4
4 Gas	CC200180	13-Dec-2013	13-Dec-2021	710	-	-	251
O ₂ /CO ₂	CC28009	5-Dec-2018	5-Dec-2026	1200	10.97	-	-

Note: National Institute of Standards and Technology traceable certificates are available upon request.

Shawn Harrington

has met the requirements of

Stack Testing for Pollutants
(CHSC 7760)

School of Process, Energy and Natural Resources
Chemical Sciences Program

Endorsed by:




Environment
Canada

Environnement
Canada



Province of
British Columbia
Ministry of
Environment,
Lands and Parks


Marsh Hemekey, Dean
School of Process, Energy and Natural Resources

JUNE 21, 2001
Dated



MOUNT ROYAL COLLEGE

Faculty of Continuing Education and Extension

Daryl Sampson

has successfully completed

The program of studies and is awarded the certificate in

STACK SAMPLING

May 2005

Date

Donna Spaulding

Dean

Faculty of Continuing Education and Extension

MOUNT ROYAL UNIVERSITY

Faculty of Continuing Education and Extension

Michael Eugene Goods

has successfully completed

Stack Sampling

35 Hours / 2019

May 22, 2019

Date

BM
Dean

Faculty of Continuing Education and Extension



MOUNT ROYAL UNIVERSITY

Faculty of Continuing Education and Extension

Scott Ferguson

has successfully completed

Stack Sampling

2016

May 16, 2016

Date



Dean

Faculty of Continuing Education and Extension

