



**A. Lanfranco  
& Associates Inc.**

Environmental Consultants

Prepared for  
**METRO VANCOUVER**

**Metrotower III 4730 Kingsway  
Burnaby, BC V5H 0C6**

**WASTE TO ENERGY FACILITY**  
**Appendices of Compliance Emissions Testing Report**  
**May 2021 Survey**

# Table of Contents

## **Appendix**

- A      Quality Assurance / Quality Control Results
- B      Laboratory Results
- C      Computer Generated Results
- D      Field Data Sheets
- E      Calibration Sheets and Technician Certificates

## **APPENDIX – A**

### **QUALITY ASSURANCE / QUALITY CONTROL RESULTS**

Quality assurance / quality control (QA/QC) is divided into four categories: administration, preparation, testing, and analysis. The following sections detail results found for the above four categories.

#### **Administration:**

- All field, process, and analytical data was reviewed to ensure data integrity and accuracy.
- Duplicate proof of draft and final report, including data entry, conducted.

#### **Preparation:**

- All glassware cleaned
- Blank samples of reagents collected.

#### **Testing:**

- Stack diameter and absence of cyclonic flow confirmed
- Calibrated magnehelic used for all velocity measurements
- All trains past pre- and post- leak checks.
- Isokinetics all within  $100\% \pm 10\%$ .

Analysis:

- Trace Metals and Mercury analysis conducted at Element Labs, Surrey, B.C.
- Fluoride (HF) analysis conducted at ALS Environmental in Burnaby, B.C.
- Nitrous Oxide (N<sub>2</sub>O) analysis conducted with portable analyzer by A. Lanfranco and Associates.
- Particulate analysis conducted at A. Lanfranco and Associates Inc., Surrey, BC.
- Chain of Custody protocols followed for all samples.
- Excellent blank values for all sample types. All samples blank corrected.

Sample Type	Blank Value		
Second Q 2021	Unit 1	Unit 2	Unit 3
Filter	-0.2 mg	-0.2 mg	-0.3 mg
Front Half Washings	0.9 mg	0.5 mg	0.6 mg
Mercury Front	<0.02 ug	<0.02 ug	<0.02 ug
Mercury Back	<0.09 ug	<0.10 ug	<0.10 ug
Trace Metals Front *	<32.5 ug	<34.0 ug	<35.3 ug
Trace Metals Back*	<25.3 ug	<7.6 ug	<28.7 ug
Fluoride	<5.0 ug	<5.0 ug	<5.0 ug

Sum of all reported elements except Hg\*

**APPENDIX - B**

**LABORATORY RESULTS**

---

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Reagent Blank Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1491345</b> Control Number: Date Received: May 10, 2021 Date Reported: Jun 8, 2021 Report Number: 2621757
Attn: Missy Sampled By: Company:		

---

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com

Delivery	Format	Deliverables
Email - Merge Reports	PDF	COC / Test Report
Email - Multiple Reports By Agreement	PDF	COA
Email - Single Report	PDF	COR

---

**Notes To Clients:**

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Reagent Blank  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1491345**  
Control Number:  
Date Received: May 10, 2021  
Date Reported: Jun 8, 2021  
Report Number: 2621757

		Reference Number	1491345-1	1491345-2	1491345-3
		Sample Date	May 04, 2021	May 04, 2021	May 04, 2021
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Reagent Blank Unit 1 / 22.6°C	Reagent Blank Unit 2 / 22.6°C	Reagent Blank Unit 3 / 22.6°C
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	<5	<5	<5	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	<0.2	0.43	0.2	0.2
Cobalt	µg	0.4	<0.3	0.6	0.25
Copper	µg	<0.3	1	<0.3	0.25
Lead	µg	3.1	2	3.0	1.5
Manganese	µg	<0.3	<0.3	0.3	0.25
Nickel	µg	<0.5	<0.5	1	0.5
Phosphorus	µg	<2	<2	<2	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2	0.9	3.3	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	<5	<5	<5	5
Antimony	µg	5	<3	<3	2.5
Arsenic	µg	<1	2	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	0.41	0.84	0.73	0.2
Cobalt	µg	<0.3	<0.3	<0.3	0.25
Copper	µg	<0.3	1	1	0.25
Lead	µg	2	<2	<2	1.5
Manganese	µg	<0.3	<0.3	<0.3	0.25
Nickel	µg	<0.5	<0.5	<0.5	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	4.1	<2	<2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<2	2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	<0.5	<0.5	<0.5	0.5
Volume	Sample	mL	210	210	210
Volume	aliquot volume	mL	160	160	160
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Reagent Blank  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1491345**  
Control Number:  
Date Received: May 10, 2021  
Date Reported: Jun 8, 2021  
Report Number: 2621757

		Reference Number	1491345-1	1491345-2	1491345-3
		Sample Date	May 04, 2021	May 04, 2021	May 04, 2021
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Reagent Blank Unit 1 / 22.6°C	Reagent Blank Unit 2 / 22.6°C	Reagent Blank Unit 3 / 22.6°C
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Mercury by CVAA - Continued</b>					
Volume	Sample	mL	250	250	250
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	210	210	210
Volume	aliquot volume	mL	5.0	5.0	5.0
Volume	Final	mL	40	45	45
Mercury	Fraction 2B	µg/sample	<0.08	<0.09	<0.09
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	100	100	100
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3A	µg/sample	<0.008	<0.008	<0.008
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	200	200	200
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3B	µg/sample	<0.02	<0.02	<0.02
Mercury	As Tested	µg/L	0.07	0.11	0.06
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	200	200	200
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3C	µg/sample	0.02	0.035	0.02

Approved by:



Max Hewitt  
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.



## Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Reagent Blank Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1491345</b> Control Number: Date Received: May 10, 2021 Date Reported: Jun 8, 2021 Report Number: 2621757
Attn: Missy Sampled By: Company:		

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	May 28, 2021	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	May 28, 2021	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	May 21, 2021	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	May 31, 2021	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	May 31, 2021	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 28, 2021	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 21, 2021	Element Vancouver

\* Reference Method Modified

## References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Please indicate any potentially hazardous samples <u>Submission of this form acknowledges acceptance of Element's Standard of terms and conditions (<a href="https://www.element.com/terms/terms-and-conditions">https://www.element.com/terms/terms-and-conditions</a>)</u>		Lot: 1491345 <sup>COC</sup> 	Temp. received: 22.6 °C	Date/Time stamp: MAY 10 2021 15:55pm
Page ____ of ____ ED 120-005	Control #		Delivery Method: _____	Waybill: _____ Received by: _____

---

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Field Blank Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1491346</b> Control Number: Date Received: May 10, 2021 Date Reported: Jun 8, 2021 Report Number: 2621758
Attn: Missy Sampled By: Company:		

---

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com

Delivery	Format	Deliverables
Email - Merge Reports	PDF	COC / Test Report
Email - Multiple Reports By Agreement	PDF	COA
Email - Single Report	PDF	COR

---

**Notes To Clients:**

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Field Blank  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1491346**  
Control Number:  
Date Received: May 10, 2021  
Date Reported: Jun 8, 2021  
Report Number: 2621758

	Reference Number	1491346-1	1491346-2	1491346-3	
	Sample Date	May 04, 2021	May 07, 2021	May 05, 2021	
	Sample Time	NA	NA	NA	
	Sample Location				
	Sample Description	Field Blank Unit 1 (Unit 1 Blank' + 4 Bottles) / 22.6°C	Field Blank Unit 2 (Unit 1 Blank' + 4 Bottles) / 22.6°C	Field Blank Unit 3 (Unit 1 Blank' + 4 Bottles) / 22.6°C	
	Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	9	7	10	5
Antimony	µg	3	6	<2	2.5
Arsenic	µg	<1	1	<1	1
Cadmium	µg	0.3	<0.3	<0.3	0.25
Chromium	µg	<0.2	0.40	0.33	0.2
Cobalt	µg	<0.3	<0.3	0.3	0.25
Copper	µg	<0.3	<0.3	<0.3	0.25
Lead	µg	3.2	5.6	<2	1.5
Manganese	µg	<0.3	<0.3	0.4	0.25
Nickel	µg	0.7	<0.5	0.9	0.5
Phosphorus	µg	20	20	25	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2	2	3.3	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	<5	<5	6	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<0.9	<0.9	2.4	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	0.28	0.59	0.32	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	<0.2	2	<0.2	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	0.6	<0.2	0.5	0.25
Nickel	µg	<0.5	<0.5	<0.5	0.5
Phosphorus	µg	25	7	20	2.5
Selenium	µg	<1	2	<1	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<1	3.9	1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	<0.5	<0.5	<0.5	0.5
Volume	Sample	mL	355	355	
Volume	aliquot volume	mL	305	305	
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	0.05

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Field Blank  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1491346**  
Control Number:  
Date Received: May 10, 2021  
Date Reported: Jun 8, 2021  
Report Number: 2621758

		Reference Number	1491346-1	1491346-2	1491346-3
		Sample Date	May 04, 2021	May 07, 2021	May 05, 2021
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Field Blank Unit 1 (Unit 1 Blank' + 4 Bottles) / 22.6°C	Field Blank Unit 2 (Unit 1 Blank' + 4 Bottles) / 22.6°C	Field Blank Unit 3 (Unit 1 Blank' + 4 Bottles) / 22.6°C
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Mercury by CVAA - Continued</b>					
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	250	250	250
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	355	355	355
Volume	aliquot volume	mL	5.0	5.0	5.0
Volume	Final	mL	50	50	50
Mercury	Fraction 2B	µg/sample	<0.2	<0.2	<0.2
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	155	155	155
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3A	µg/sample	<0.01	<0.01	<0.01
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	500	500	600
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3B	µg/sample	<0.04	<0.04	<0.05
Mercury	As Tested	µg/L	<0.05	0.08	<0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	200	200	200
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3C	µg/sample	<0.02	0.03	<0.02

Approved by:



Max Hewitt  
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

## Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Field Blank Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1491346</b> Control Number: Date Received: May 10, 2021 Date Reported: Jun 8, 2021 Report Number: 2621758
Attn: Missy Sampled By: Company:		

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	May 28, 2021	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	May 28, 2021	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	May 21, 2021	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	May 31, 2021	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	May 31, 2021	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 28, 2021	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 21, 2021	Element Vancouver

\* Reference Method Modified

## References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.





---

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1491431</b> Control Number: Date Received: May 10, 2021 Date Reported: Jun 8, 2021 Report Number: 2621859
Attn: Missy Sampled By: Company:		

---

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com

Delivery	Format	Deliverables
Email - Merge Reports	PDF	COC / Test Report
Email - Multiple Reports By Agreement	PDF	COA
Email - Single Report	PDF	COR

---

**Notes To Clients:**



## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Metals and Hg Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1491431**  
Control Number:  
Date Received: May 10, 2021  
Date Reported: Jun 8, 2021  
Report Number: 2621859

	Reference Number	1491431-1	1491431-2	1491431-3	
	Sample Date	May 04, 2021	May 04, 2021	May 04, 2021	
	Sample Time	NA	NA	NA	
	Sample Location				
	Sample Description	Unit 1 Run 1 (Unit 1 R-1 + 4 bottles) / 22.6C	Unit 1 Run 2 (Unit 1 R-2 + 4 bottles) / 22.6C	Unit 1 Run 3 ('MV Unit 1 R-3' + 4 bottles) / 22.6C	
	Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	20	20	26	5
Antimony	µg	<2	4	<2	2.5
Arsenic	µg	1	<1	<1	1
Cadmium	µg	<0.3	<0.3	0.3	0.25
Chromium	µg	3.30	5.80	1.4	0.2
Cobalt	µg	0.3	0.9	0.4	0.25
Copper	µg	0.6	1	<0.3	0.25
Lead	µg	4.1	7.2	7.2	1.5
Manganese	µg	1	3.6	0.9	0.25
Nickel	µg	2	15	2	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	4.7	<2	<2	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	8.8	20	23	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	27	34	20	5
Antimony	µg	<2	4	<2	2.5
Arsenic	µg	<0.9	<0.9	<0.9	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	22.5	2.75	1.7	0.2
Cobalt	µg	0.4	<0.2	<0.2	0.25
Copper	µg	3.0	7.7	1	0.25
Lead	µg	2.5	<1	<1	1.5
Manganese	µg	4.3	1	1	0.25
Nickel	µg	17	2	1.0	0.5
Phosphorus	µg	24	20	20	2.5
Selenium	µg	<1	2.6	<1	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	21.4	6.0	0.9	0.5
Volume	Sample	mL	760	770	
Volume	aliquot volume	mL	710	720	
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	0.05	0.06	0.09

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Metals and Hg Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1491431**  
Control Number:  
Date Received: May 10, 2021  
Date Reported: Jun 8, 2021  
Report Number: 2621859

		Reference Number	1491431-1	1491431-2	1491431-3	Nominal Detection Limit
		Sample Date	May 04, 2021	May 04, 2021	May 04, 2021	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 1 Run 1 (Unit 1 R-1 + 4 bottles) / 22.6C	Unit 1 Run 2 (Unit 1 R-2 + 4 bottles) / 22.6C	Unit 1 Run 3 (Unit 1 R-3' + 4 bottles) / 22.6C	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results		
<b>Mercury by CVAA - Continued</b>						
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	0.02	0.03	0.04	
Mercury	As Tested	µg/L	0.51	0.49	0.35	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	760	760	770	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	3.1	3.0	2.1	
Mercury	As Tested	µg/L	0.43	0.75	0.12	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	155	150	155	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	0.11	0.18	0.029	
Mercury	As Tested	µg/L	<0.05	0.15	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	600	600	500	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.05	0.14	<0.04	
Mercury	As Tested	µg/L	0.20	0.53	0.09	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.063	0.17	0.03	

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1491431</b> Control Number: Date Received: May 10, 2021 Date Reported: Jun 8, 2021 Report Number: 2621859
Attn: Missy Sampled By: Company:		

		Reference Number	1491431-4	1491431-5	1491431-6
		Sample Date	May 07, 2021	May 07, 2021	May 07, 2021
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit 2 Run 1 ('MV Unit 2 R-1' + 4 bottles) / 22.6C	Unit 2 Run 2 ('MV Unit 2 R-2' + 4 bottles) / 22.6C	Unit 2 Run 3 ('MV Unit 2 R-3' + 4 bottles) / 22.6C
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	26	10	10	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	1.3	5.14	1.3	0.2
Cobalt	µg	0.4	<0.3	<0.3	0.25
Copper	µg	<0.3	0.5	<0.3	0.25
Lead	µg	10	5.8	5.3	1.5
Manganese	µg	0.8	2	0.9	0.25
Nickel	µg	1	8.0	<0.5	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	2.9	<2	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	7.8	5.1	4.0	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	<4	34	<4	5
Antimony	µg	3	<2	<2	2.5
Arsenic	µg	<0.9	<0.9	<0.9	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	1.1	0.87	0.46	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	1	0.6	0.8	0.25
Lead	µg	2	<1	<1	1.5
Manganese	µg	0.9	1.0	0.6	0.25
Nickel	µg	1	0.8	2	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	2.8	<1	2.3	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	<0.4	0.5	<0.4	0.5
Volume	Sample	mL	710	760	850
Volume	aliquot volume	mL	660	710	800
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	0.05

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1491431</b> Control Number: Date Received: May 10, 2021 Date Reported: Jun 8, 2021 Report Number: 2621859
Attn: Missy Sampled By: Company:		

		Reference Number	1491431-4	1491431-5	1491431-6	Nominal Detection Limit
		Sample Date	May 07, 2021	May 07, 2021	May 07, 2021	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 2 Run 1 ('MV Unit 2 R-1' + 4 bottles) / 22.6C	Unit 2 Run 2 ('MV Unit 2 R-2' + 4 bottles) / 22.6C	Unit 2 Run 3 ('MV Unit 2 R-3' + 4 bottles) / 22.6C	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results		
<b>Mercury by CVAA - Continued</b>						
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	0.50	0.38	0.35	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	710	760	850	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	2.8	2.3	2.4	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	160	155	155	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.01	<0.01	<0.01	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	500	600	600	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.04	<0.05	<0.05	
Mercury	As Tested	µg/L	0.06	0.13	0.12	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.02	0.040	0.039	

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1491431</b> Control Number: Date Received: May 10, 2021 Date Reported: Jun 8, 2021 Report Number: 2621859
Attn: Missy		
Sampled By:		
Company:		

		Reference Number	1491431-7	1491431-8	1491431-9
		Sample Date	May 05, 2021	May 05, 2021	May 05, 2021
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit 3 Run 1 (Unit 3 R-1' + 4 bottles) / 22.6C	Unit 3 Run 2 (Unit 3 R-2' + 4 bottles) / 22.6C	Unit 3 Run 3 (MV Unit 3 R-3' + 4 bottles) / 22.6C
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	9	10	10	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<1	2.7	<1	1
Cadmium	µg	<0.3	<0.3	0.3	0.25
Chromium	µg	2.57	0.78	1.1	0.2
Cobalt	µg	0.3	<0.3	0.4	0.25
Copper	µg	<0.3	<0.3	0.4	0.25
Lead	µg	3.2	<2	4.5	1.5
Manganese	µg	2	0.7	1	0.25
Nickel	µg	8.4	<0.5	3.5	0.5
Phosphorus	µg	20	20	33	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	9.5	8.7	11	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	10	6	8	5
Antimony	µg	<2	3	2	2.5
Arsenic	µg	<0.9	<0.9	<0.9	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	0.32	0.85	0.28	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	6.1	1	1	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	1.0	17	0.9	0.25
Nickel	µg	0.5	6.9	1	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	<1	<1	2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	0.9	0.9	1.0	0.5
Volume	Sample	mL	850	760	
Volume	aliquot volume	mL	800	710	
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	0.05

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1491431</b> Control Number: Date Received: May 10, 2021 Date Reported: Jun 8, 2021 Report Number: 2621859
Attn: Missy Sampled By: Company:		

		Reference Number	1491431-7	1491431-8	1491431-9	Nominal Detection Limit
		Sample Date	May 05, 2021	May 05, 2021	May 05, 2021	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 3 Run 1 (Unit 3 R-1' + 4 bottles) / 22.6C	Unit 3 Run 2 (Unit 3 R-2' + 4 bottles) / 22.6C	Unit 3 Run 3 (MV Unit 3 R-3' + 4 bottles) / 22.6C	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results		
<b>Mercury by CVAA - Continued</b>						
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	0.02	
Mercury	As Tested	µg/L	0.12	0.13	0.15	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	850	850	760	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	0.82	0.86	0.93	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	160	160	160	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.01	<0.01	<0.01	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	500	500	600	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.04	<0.04	<0.05	
Mercury	As Tested	µg/L	0.07	0.10	0.11	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.02	0.032	0.034	

Approved by:



Max Hewitt  
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

## Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1491431</b> Control Number: Date Received: May 10, 2021 Date Reported: Jun 8, 2021 Report Number: 2621859
Attn: Missy Sampled By: Company:		

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	May 28, 2021	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	May 28, 2021	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	May 21, 2021	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	May 31, 2021	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	May 31, 2021	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 28, 2021	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 21, 2021	Element Vancouver

\* Reference Method Modified

## References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.





www.Element.com

### Project Information

Project ID: Metro Vancouver WTE  
Project Name: Metals and Hg Samples  
Project Location: \_\_\_\_\_  
Legal Location: \_\_\_\_\_  
PO/AFE#: \_\_\_\_\_  
Proj. Acct. Code: \_\_\_\_\_  
Quote #: \_\_\_\_\_

### Invoice To

Company: A. Lanfranco & Associates Inc.  
Address: 101-9488 189 Street  
Surrey BC, V4N 4W7  
Attention: \_\_\_\_\_  
Phone: 604-881-2582  
Cell: \_\_\_\_\_  
Fax: \_\_\_\_\_  
E-mail: [mark.lanfranco@alanfranco.com](mailto:mark.lanfranco@alanfranco.com)  
Agreement ID: \_\_\_\_\_  
Copy of Report: YES / NO

### Report To

Company: \_\_\_\_\_  
Address: \_\_\_\_\_  
Attention: \_\_\_\_\_  
Phone: \_\_\_\_\_  
Cell: \_\_\_\_\_  
Fax: \_\_\_\_\_  
E-mail 1: \_\_\_\_\_  
E-mail 2: \_\_\_\_\_  
Copy of Invoice: YES / NO

### Additional Reports to

1) Name: \_\_\_\_\_  
E-mail: \_\_\_\_\_  
2) Name: \_\_\_\_\_  
E-mail: \_\_\_\_\_  
**Sample Custody**  
Sampled by: \_\_\_\_\_  
Company: \_\_\_\_\_  
I authorize Element to proceed with the work indicated on this form:  
Signature: \_\_\_\_\_  
Date/Time: \_\_\_\_\_

### Report Results

### Requirements

- ☐ Same Day (200%)  
☐ Next Day/Two Day (100%)  
☐ Three or Four Days (50%)  
☒ 5 to 7 Days (Regular TAT)

When "ASAP" is requested, turn around will default to a 100% RUSH priority, with pricing and turn around time to match. Please contact the lab prior to submitting RUSH samples. If not all samples require RUSH, please indicate in the special instructions.

- ☒ Email ☐ QA/QC  
☐ Online ☒ PDF  
☐ Fax ☐ Excel

- ☐ HCDWORG ☐ SPIGEC  
☐ AB Tier 1 ☐ BCCSR  
Other (list below)

Date Required \_\_\_\_\_

Special Instructions/Comments (please include contact information including phone number if different from above).

\*Front and Back ICAP as per EPA Method 29. \*Hg analysis as per EPA Method 29. \*Please report µg/sample.

	Site I.D.	Sample Description	Depth start end in cm m		Date/Time sampled	Matrix	Sampling method	Number of Containers ↓	Enter tests above (✓ relevant samples below)									
									Front ICAP	Back ICAP	Front Hg	Back Hg	5A Hg	5B Hg				
1		Unit 1 Run 1 (Unit 1 R-1' + 4 Bottles)			4-May-21			5	✓	✓	✓	✓	✓	✓				
2		Unit 1 Run 2 (Unit 1 R-2' + 4 Bottles)			4-May-21			5	✓	✓	✓	✓	✓	✓				
3		Unit 1 Run 3 ('MV Unit 1 R-3' + 4 Bottles)			4-May-21			5	✓	✓	✓	✓	✓	✓				
4																		
5		Unit 2 Run 1 ('MV Unit 2 R-1' + 4 Bottles)			7-May-21			5	✓	✓	✓	✓	✓	✓				
6		Unit 2 Run 2 ('MV Unit 2 R-2' + 4 Bottles)			7-May-21			5	✓	✓	✓	✓	✓	✓				
7		Unit 2 Run 3 ('MV Unit 2 R-3' + 4 Bottles)			7-May-21			5	✓	✓	✓	✓	✓	✓				
8																		
9		Unit 3 Run 1 (Unit 3 R-1' + 4 Bottles)			5-May-21			5	✓	✓	✓	✓	✓	✓				
10		Unit 3 Run 2 (Unit 3 R-2' + 4 Bottles)			5-May-21			5	✓	✓	✓	✓	✓	✓				
11		Unit 3 Run 3 ('MV Unit 3 R-3' + 4 Bottles)			5-May-21			5	✓	✓	✓	✓	✓	✓				
12																		
13																		
14																		
15																		

Please indicate any potentially hazardous samples

Submission of this form acknowledges acceptance of Element's Standard of terms and conditions (<https://www.element.com/terms/terms-and-conditions>)

Page \_\_\_\_\_ of \_\_\_\_\_ Control #  
ED 120-005

Lot: 1491431 COC



Temp. received: 22.6 °C  
Delivery Method: \_\_\_\_\_  
Waybill: \_\_\_\_\_  
Received by: \_\_\_\_\_  
Date/Time stamp: MAY 11 2021 @ 1:55 PM



## CERTIFICATE OF ANALYSIS

**Work Order** : **VA21A8849**  
**Client** : **A. Lanfranco & Associates Inc.**  
**Contact** : Mark Lanfranco  
**Address** : Unit # 101 9488 - 189 St  
                   Surrey BC Canada V4N 4W7  
**Telephone** : 604 881 2582  
**Project** : Metro Vancouver WTE  
**PO** : HF  
**C-O-C number** : ----  
**Sampler** : AL  
**Site** : ----  
**Quote number** : Standing Offer  
**No. of samples received** : 3  
**No. of samples analysed** : 3

**Page** : 1 of 2  
**Laboratory** : Vancouver - Environmental  
**Account Manager** : Brent Mack  
**Address** : 8081 Lougheed Highway  
                   Burnaby BC Canada V5A 1W9  
**Telephone** : 778-370-3279  
**Date Samples Received** : 10-May-2021 10:55  
**Date Analysis Commenced** : 11-May-2021  
**Issue Date** : 17-May-2021 13:53

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

### Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Laboratory Department</i>
Cindy Tang	Team Leader - Inorganics	Inorganics, Burnaby, British Columbia



## General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key : CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances  
 LOR: Limit of Reporting (detection limit).

Unit	Description
µg/sample	micrograms per sample
mL	millilitre

<: less than.

>: greater than.

Surrogate: An analyte that is similar in behavior to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

## Analytical Results

Sub-Matrix: Air

(Matrix: Air)

					Client sample ID	Unit 1 HF Blank	Unit 2 HF Blank	Unit 3 HF Blank	----	----
					Client sampling date / time	04-May-2021	07-May-2021	05-May-2021	----	----
Analyte	CAS Number	Method	LOR	Unit		VA21A8849-001	VA21A8849-002	VA21A8849-003	-----	-----
						Result	Result	Result	----	----
<b>Field Tests</b>										
volume, impinger	----	EP248	0.1	mL		360	355	355	----	----
<b>Anions and Nutrients</b>										
fluoride	16984-48-8	E248.F	5.0	µg/sample		<5.0	<5.0	<5.0	----	----

Please refer to the General Comments section for an explanation of any qualifiers detected.

## QUALITY CONTROL INTERPRETIVE REPORT

Work Order	: <b>VA21A8849</b>	Page	: 1 of 4
Client	: <b>A. Lanfranco &amp; Associates Inc.</b>	Laboratory	: Vancouver - Environmental
Contact	: Mark Lanfranco	Account Manager	: Brent Mack
Address	: Unit # 101 9488 - 189 St Surrey BC Canada V4N 4W7	Address	: 8081 Lougheed Highway Burnaby, British Columbia Canada V5A 1W9
Telephone	: 604 881 2582	Telephone	: 778-370-3279
Project	: Metro Vancouver WTE	Date Samples Received	: 10-May-2021 10:55
PO	: HF	Issue Date	: 17-May-2021 13:55
C-O-C number	: ----		
Sampler	: AL		
Site	: ----		
Quote number	: Standing Offer		
No. of samples received	: 3		
No. of samples analysed	: 3		

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

### Key

**Anonymous:** Refers to samples which are not part of this work order, but which formed part of the QC process lot.

**CAS Number:** Chemical Abstracts Services number is a unique identifier assigned to discrete substances.

**DQO:** Data Quality Objective.

**LOR:** Limit of Reporting (detection limit).

**RPD:** Relative Percent Difference.

## Summary of Outliers

### Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

### Outliers: Reference Material (RM) Samples

- No Reference Material (RM) Sample outliers occur.

### Outliers : Analysis Holding Time Compliance (Breaches)

- No Analysis Holding Time Outliers exist.

### Outliers : Frequency of Quality Control Samples

- No Quality Control Sample Frequency Outliers occur.



## Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and /or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Matrix: **Air**

Evaluation: ✖ = Holding time exceedance ; ✔ = Within Holding Time

Analyte Group Container / Client Sample ID(s)	Method	Sampling Date	Extraction / Preparation				Analysis			
			Preparation Date	Holding Times		Eval	Analysis Date	Holding Times		Eval
				Rec	Actual			Rec	Actual	
Anions and Nutrients : Fluoride by IC (Impinger, mg/sample)										
HDPE Unit 2 HF Blank	E248.F	07-May-2021	11-May-2021	----	5 days	✓	11-May-2021	28 days	1 days	✓
Anions and Nutrients : Fluoride by IC (Impinger, mg/sample)										
HDPE Unit 3 HF Blank	E248.F	05-May-2021	11-May-2021	----	7 days	✓	11-May-2021	28 days	1 days	✓
Anions and Nutrients : Fluoride by IC (Impinger, mg/sample)										
HDPE Unit 1 HF Blank	E248.F	04-May-2021	11-May-2021	----	8 days	✓	11-May-2021	28 days	1 days	✓

### Legend & Qualifier Definitions

Rec. HT: ALS recommended hold time (see units).



## Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Matrix: **Air**

Evaluation: ✖ = QC frequency outside specification; ✔ = QC frequency within specification.

Quality Control Sample Type	Method	QC Lot #	Count		Frequency (%)		
			QC	Regular	Actual	Expected	Evaluation
Analytical Methods							
Laboratory Duplicates (DUP)							
Fluoride by IC (Impinger, mg/sample)	E248.F	195452	1	12	8.3	5.0	✓
Laboratory Control Samples (LCS)							
Fluoride by IC (Impinger, mg/sample)	E248.F	195452	1	12	8.3	5.0	✓
Method Blanks (MB)							
Fluoride by IC (Impinger, mg/sample)	E248.F	195452	1	12	8.3	5.0	✓
Matrix Spikes (MS)							
Fluoride by IC (Impinger, mg/sample)	E248.F	195452	1	12	8.3	5.0	✓



## Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by "mod").

<i>Analytical Methods</i>	<i>Method / Lab</i>	<i>Matrix</i>	<i>Method Reference</i>	<i>Method Descriptions</i>
Fluoride by IC (Impinger, mg/sample)	E248.F  Vancouver - Environmental	Air	EPA 300.1 (mod)	Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection. Reported sample volumes are for the bottle/sub-sample submitted for the listed analyses.
<i>Preparation Methods</i>	<i>Method / Lab</i>	<i>Matrix</i>	<i>Method Reference</i>	<i>Method Descriptions</i>
Preparation of Anions for IC (Impinger)	EP248  Vancouver - Environmental	Air	EPA 300.1 (mod)	Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection. Reported sample volumes are for the bottle/sub-sample submitted for the listed analyses.



## QUALITY CONTROL REPORT

Work Order : **VA21A8849**

Page : 1 of 3

Client : A. Lanfranco & Associates Inc.  
Contact : Mark Lanfranco  
Address : Unit # 101 9488 - 189 St  
Surrey BC Canada V4N 4W7  
Telephone : 604 881 2582  
Project : Metro Vancouver WTE  
PO : HF  
C-O-C number : ----  
Sampler : AL  
Site : ----  
Quote number : Standing Offer  
No. of samples received : 3  
No. of samples analysed : 3

Laboratory : Vancouver - Environmental  
Account Manager : Brent Mack  
Address : 8081 Lougheed Highway  
Burnaby, British Columbia Canada V5A 1W9  
Telephone : 778-370-3279  
Date Samples Received : 10-May-2021 10:55  
Date Analysis Commenced : 11-May-2021  
Issue Date : 17-May-2021 13:53

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

- Laboratory Duplicate (DUP) Report; Relative Percentage Difference (RPD) and Acceptance Limits
- Matrix Spike (MS) Report; Recovery and Acceptance Limits
- Reference Material (RM) Report; Recovery and Acceptance Limits
- Method Blank (MB) Report; Recovery and Acceptance Limits
- Laboratory Control Sample (LCS) Report; Recovery and Acceptance Limits

### Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories	Position	Laboratory Department
Cindy Tang	Team Leader - Inorganics	Inorganics, Burnaby, British Columbia



General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

- Key :
- Anonymous = Refers to samples which are not part of this work order, but which formed part of the QC process lot.
  - CAS Number = Chemical Abstracts Services number is a unique identifier assigned to discrete substances.
  - DQO = Data Quality Objective.
  - LOR = Limit of Reporting (detection limit).
  - RPD = Relative Percentage Difference
  - # = Indicates a QC result that did not meet the ALS DQO.

Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test specific).

Sub-Matrix: Air					Laboratory Duplicate (DUP) Report						
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier
Anions and Nutrients (QC Lot: 195452)											
VA21A8849-001	Unit 1 HF Blank	fluoride	16984-48-8	E248.F	5.0	mg/sample	<5.0	<0.0050	0	Diff <2x LOR	----
		volume, impinger	----	EP248	0.1	mL	µg/sample 360	360		Diff <2x LOR	----

Method Blank (MB) Report

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: Air						
Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
Anions and Nutrients (QC Lot: 195452)						
fluoride	16984-48-8	E248.F	0.005	mg/sample	<0.0050	----
volume, impinger	----	EP248	0.1	mL	500	----





Laboratory Control Sample (LCS) Report

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: Air

					Laboratory Control Sample (LCS) Report				
					Spike	Recovery (%)	Recovery Limits (%)		
Analyte	CAS Number	Method	LOR	Unit	Concentration	LCS	Low	High	Qualifier
Anions and Nutrients (QCLot: 195452)									
fluoride	16984-48-8	E248.F	0.005	mg/sample	0.5 mg/sample	104	90.0	110	----

Matrix Spike (MS) Report

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DQO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for the associated sample (or similar samples) may be subject to bias. ND – Recovery not determined, background level >= 1x spike level.

Sub-Matrix: Air

					Matrix Spike (MS) Report				
					Spike		Recovery (%)	Recovery Limits (%)	
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	Concentration	Target	MS	Low	High
Anions and Nutrients (QCLot: 195452)									
VA21A8849-002	Unit 2 HF Blank	fluoride	16984-48-8	E248.F	0.382 mg/sample	0.5 mg/sample	76.4	75.0	125

- No Matrix Spike (MS) Results are required to be reported.



## CERTIFICATE OF ANALYSIS

**Work Order** : **VA21A8850**  
**Client** : **A. Lanfranco & Associates Inc.**  
**Contact** : Mark Lanfranco  
**Address** : Unit # 101 9488 - 189 St  
                   Surrey BC Canada V4N 4W7  
**Telephone** : 604 881 2582  
**Project** : Metro Vancouver WTE  
**PO** : HF  
**C-O-C number** : ----  
**Sampler** : AL  
**Site** : ----  
**Quote number** : Standing Offer  
**No. of samples received** : 9  
**No. of samples analysed** : 9

**Page** : 1 of 3  
**Laboratory** : Vancouver - Environmental  
**Account Manager** : Brent Mack  
**Address** : 8081 Lougheed Highway  
                   Burnaby BC Canada V5A 1W9  
**Telephone** : 778-370-3279  
**Date Samples Received** : 10-May-2021 10:55  
**Date Analysis Commenced** : 11-May-2021  
**Issue Date** : 17-May-2021 13:55

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

### Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Laboratory Department</i>
Cindy Tang	Team Leader - Inorganics	Inorganics, Burnaby, British Columbia



## General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key : CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances  
LOR: Limit of Reporting (detection limit).

<i>Unit</i>	<i>Description</i>
µg/sample	micrograms per sample
mL	millilitre

<: less than.

>: greater than.

Surrogate: An analyte that is similar in behavior to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

## Qualifiers

<i>Qualifier</i>	<i>Description</i>
DLDS	Detection Limit Raised: Dilution required due to high Dissolved Solids / Electrical Conductivity.



## Analytical Results

Sub-Matrix: Air					Client sample ID	Unit 1 HF Run 1	Unit 1 HF Run 2	Unit 1 HF Run 3	Unit 2 HF Run 1	Unit 2 HF Run 2
(Matrix: Air)										
					Client sampling date / time	04-May-2021	04-May-2021	04-May-2021	07-May-2021	07-May-2021
Analyte	CAS Number	Method	LOR	Unit		VA21A8850-001	VA21A8850-002	VA21A8850-003	VA21A8850-004	VA21A8850-005
						Result	Result	Result	Result	Result
<b>Field Tests</b>										
volume, impinger	----	EP248	0.1	mL		455	475	430	400	400
<b>Anions and Nutrients</b>										
fluoride	16984-48-8	E248.F	5.0	µg/sample		<5.0	<5.0	<21.5 <sup>DLDS</sup>	<20.0 <sup>DLDS</sup>	<20.0 <sup>DLDS</sup>

Please refer to the General Comments section for an explanation of any qualifiers detected.

## Analytical Results

Sub-Matrix: Air					Client sample ID	Unit 2 HF Run 3	Unit 3 HF Run 1	Unit 3 HF Run 2	Unit 3 HF Run 3	----
(Matrix: Air)										
					Client sampling date / time	07-May-2021	05-May-2021	05-May-2021	05-May-2021	----
Analyte	CAS Number	Method	LOR	Unit		VA21A8850-006	VA21A8850-007	VA21A8850-008	VA21A8850-009	-----
						Result	Result	Result	Result	----
<b>Field Tests</b>										
volume, impinger	----	EP248	0.1	mL		425	450	420	440	----
<b>Anions and Nutrients</b>										
fluoride	16984-48-8	E248.F	5.0	µg/sample		<21.2 <sup>DLDS</sup>	<22.5 <sup>DLDS</sup>	<21.0 <sup>DLDS</sup>	<22.0 <sup>DLDS</sup>	----

Please refer to the General Comments section for an explanation of any qualifiers detected.

## QUALITY CONTROL INTERPRETIVE REPORT

Work Order	: <b>VA21A8850</b>	Page	: 1 of 5
Client	: <b>A. Lanfranco &amp; Associates Inc.</b>	Laboratory	: Vancouver - Environmental
Contact	: Mark Lanfranco	Account Manager	: Brent Mack
Address	: Unit # 101 9488 - 189 St Surrey BC Canada V4N 4W7	Address	: 8081 Lougheed Highway Burnaby, British Columbia Canada V5A 1W9
Telephone	: 604 881 2582	Telephone	: 778-370-3279
Project	: Metro Vancouver WTE	Date Samples Received	: 10-May-2021 10:55
PO	: HF	Issue Date	: 17-May-2021 13:53
C-O-C number	: ----		
Sampler	: AL		
Site	: ----		
Quote number	: Standing Offer		
No. of samples received	: 9		
No. of samples analysed	: 9		

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

### Key

**Anonymous:** Refers to samples which are not part of this work order, but which formed part of the QC process lot.

**CAS Number:** Chemical Abstracts Services number is a unique identifier assigned to discrete substances.

**DQO:** Data Quality Objective.

**LOR:** Limit of Reporting (detection limit).

**RPD:** Relative Percent Difference.

## Summary of Outliers

### Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

### Outliers: Reference Material (RM) Samples

- No Reference Material (RM) Sample outliers occur.

### Outliers : Analysis Holding Time Compliance (Breaches)

- No Analysis Holding Time Outliers exist.

### Outliers : Frequency of Quality Control Samples

- No Quality Control Sample Frequency Outliers occur.



## Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and /or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Matrix: Air

Evaluation: \* = Holding time exceedance ; ✓ = Within Holding Time

Analyte Group Container / Client Sample ID(s)	Method	Sampling Date	Extraction / Preparation				Analysis			
			Preparation Date	Holding Times		Eval	Analysis Date	Holding Times		Eval
				Rec	Actual			Rec	Actual	
Anions and Nutrients : Fluoride by IC (Impinger, mg/sample)										
HDPE Unit 2 HF Run 1	E248.F	07-May-2021	11-May-2021	----	5 days	✓	11-May-2021	28 days	1 days	✓
Anions and Nutrients : Fluoride by IC (Impinger, mg/sample)										
HDPE Unit 2 HF Run 2	E248.F	07-May-2021	11-May-2021	----	5 days	✓	11-May-2021	28 days	1 days	✓
Anions and Nutrients : Fluoride by IC (Impinger, mg/sample)										
HDPE Unit 2 HF Run 3	E248.F	07-May-2021	11-May-2021	----	5 days	✓	11-May-2021	28 days	1 days	✓
Anions and Nutrients : Fluoride by IC (Impinger, mg/sample)										
HDPE Unit 3 HF Run 1	E248.F	05-May-2021	11-May-2021	----	7 days	✓	11-May-2021	28 days	1 days	✓
Anions and Nutrients : Fluoride by IC (Impinger, mg/sample)										
HDPE Unit 3 HF Run 2	E248.F	05-May-2021	11-May-2021	----	7 days	✓	11-May-2021	28 days	1 days	✓
Anions and Nutrients : Fluoride by IC (Impinger, mg/sample)										
HDPE Unit 3 HF Run 3	E248.F	05-May-2021	11-May-2021	----	7 days	✓	11-May-2021	28 days	1 days	✓
Anions and Nutrients : Fluoride by IC (Impinger, mg/sample)										
HDPE Unit 1 HF Run 1	E248.F	04-May-2021	11-May-2021	----	8 days	✓	11-May-2021	28 days	1 days	✓



Matrix: **Air** Evaluation: ✖ = Holding time exceedance ; ✔ = Within Holding Time

Analyte Group	Method	Sampling Date	Extraction / Preparation				Analysis			
Container / Client Sample ID(s)			Preparation Date	Holding Times		Eval	Analysis Date	Holding Times		Eval
				Rec	Actual			Rec	Actual	
Anions and Nutrients : Fluoride by IC (Impinger, mg/sample)										
HDPE Unit 1 HF Run 2	E248.F	04-May-2021	11-May-2021	----	8 days	✓	11-May-2021	28 days	1 days	✓
Anions and Nutrients : Fluoride by IC (Impinger, mg/sample)										
HDPE Unit 1 HF Run 3	E248.F	04-May-2021	11-May-2021	----	8 days	✓	11-May-2021	28 days	1 days	✓

Legend & Qualifier Definitions

Rec. HT: ALS recommended hold time (see units).





## Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Matrix: **Air**

Evaluation: ✖ = QC frequency outside specification; ✔ = QC frequency within specification.

Quality Control Sample Type	Method	QC Lot #	Count		Frequency (%)		
			QC	Regular	Actual	Expected	Evaluation
Analytical Methods							
Laboratory Duplicates (DUP)							
Fluoride by IC (Impinger, mg/sample)	E248.F	195452	1	12	8.3	5.0	✓
Laboratory Control Samples (LCS)							
Fluoride by IC (Impinger, mg/sample)	E248.F	195452	1	12	8.3	5.0	✓
Method Blanks (MB)							
Fluoride by IC (Impinger, mg/sample)	E248.F	195452	1	12	8.3	5.0	✓
Matrix Spikes (MS)							
Fluoride by IC (Impinger, mg/sample)	E248.F	195452	1	12	8.3	5.0	✓



## Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by "mod").

Analytical Methods	Method / Lab	Matrix	Method Reference	Method Descriptions
Fluoride by IC (Impinger, mg/sample)	E248.F  Vancouver - Environmental	Air	EPA 300.1 (mod)	Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection. Reported sample volumes are for the bottle/sub-sample submitted for the listed analyses.

Preparation Methods	Method / Lab	Matrix	Method Reference	Method Descriptions
Preparation of Anions for IC (Impinger)	EP248  Vancouver - Environmental	Air	EPA 300.1 (mod)	Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection. Reported sample volumes are for the bottle/sub-sample submitted for the listed analyses.



## QUALITY CONTROL REPORT

Work Order : **VA21A8850**

Page : 1 of 3

Client : A. Lanfranco & Associates Inc.  
Contact : Mark Lanfranco  
Address : Unit # 101 9488 - 189 St  
Surrey BC Canada V4N 4W7  
Telephone : 604 881 2582  
Project : Metro Vancouver WTE  
PO : HF  
C-O-C number : ----  
Sampler : AL  
Site : ----  
Quote number : Standing Offer  
No. of samples received : 9  
No. of samples analysed : 9

Laboratory : Vancouver - Environmental  
Account Manager : Brent Mack  
Address : 8081 Lougheed Highway  
Burnaby, British Columbia Canada V5A 1W9  
Telephone : 778-370-3279  
Date Samples Received : 10-May-2021 10:55  
Date Analysis Commenced : 11-May-2021  
Issue Date : 17-May-2021 13:53

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

- Laboratory Duplicate (DUP) Report; Relative Percentage Difference (RPD) and Acceptance Limits
- Matrix Spike (MS) Report; Recovery and Acceptance Limits
- Reference Material (RM) Report; Recovery and Acceptance Limits
- Method Blank (MB) Report; Recovery and Acceptance Limits
- Laboratory Control Sample (LCS) Report; Recovery and Acceptance Limits

### Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories	Position	Laboratory Department
Cindy Tang	Team Leader - Inorganics	Inorganics, Burnaby, British Columbia



General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

- Key :
- Anonymous = Refers to samples which are not part of this work order, but which formed part of the QC process lot.
  - CAS Number = Chemical Abstracts Services number is a unique identifier assigned to discrete substances.
  - DQO = Data Quality Objective.
  - LOR = Limit of Reporting (detection limit).
  - RPD = Relative Percentage Difference
  - # = Indicates a QC result that did not meet the ALS DQO.

Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test specific).

Sub-Matrix: Air					Laboratory Duplicate (DUP) Report						
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier
Anions and Nutrients (QC Lot: 195452)											
VA21A8849-001	Anonymous	fluoride	16984-48-8	E248.F	5.0	mg/sample	<5.0	<0.0050	0	Diff <2x LOR	----
		volume, impinger	----	EP248	0.1	mL	µg/sample 360	360		Diff <2x LOR	----

Method Blank (MB) Report

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: Air						
Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
Anions and Nutrients (QC Lot: 195452)						
fluoride	16984-48-8	E248.F	0.005	mg/sample	<0.0050	----
volume, impinger	----	EP248	0.1	mL	500	----



Laboratory Control Sample (LCS) Report

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: Air

					Laboratory Control Sample (LCS) Report				
					Spike	Recovery (%)	Recovery Limits (%)		
Analyte	CAS Number	Method	LOR	Unit	Concentration	LCS	Low	High	Qualifier
Anions and Nutrients (QCLot: 195452)									
fluoride	16984-48-8	E248.F	0.005	mg/sample	0.5 mg/sample	104	90.0	110	----

Matrix Spike (MS) Report

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DQO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for the associated sample (or similar samples) may be subject to bias. ND – Recovery not determined, background level >= 1x spike level.

Sub-Matrix: Air

					Matrix Spike (MS) Report				
					Spike		Recovery (%)	Recovery Limits (%)	
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	Concentration	Target	MS	Low	High
Anions and Nutrients (QCLot: 195452)									
VA21A8849-002	Anonymous	fluoride	16984-48-8	E248.F	0.382 mg/sample	0.5 mg/sample	76.4	75.0	125

- No Matrix Spike (MS) Results are required to be reported.



**APPENDIX - C**

**COMPUTER GENERATED RESULTS**

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, BC)  
**Source:** Unit 1

**Date:** 3-May-21  
**Run:** 1 - Particulate / Metals  
**Run Time:** 10:58 - 13:00

---

**Concentrations:**

<b>Particulate</b>	0.63 mg/dscm	0.00028 gr/dscf
	0.36 mg/Acm	0.00016 gr/Acf
	0.57 mg/dscm (@ 11% O2)	0.00025 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.048 Kg/hr	0.105 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1254 dscm/min	44279 dscf/min
	20.90 dscm/sec	738 dscf/sec
	2193 Acm/min	77444 Acf/min

<b>Velocity</b>	14.349 m/sec	47.08 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	155.3 oC	311.6 oF
--------------------	----------	----------

<b>Moisture</b>	12.9 %
-----------------	--------

<b>Gas Analysis</b>	10.0 % O2
	10.0 % CO2

30.000 Mol. Wt (g/gmole) Dry  
28.452 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.9240 dscm	103.261 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	102.3 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg



**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, BC)  
**Source:** Unit 1

**Date:** 3-May-21  
**Run:** 1 - Particulate / Metals  
**Run Time:** 10:58 - 13:00

Control Unit (Y) 1.0006  
Nozzle Diameter (in.) 0.3090  
Pitot Factor 0.8494  
Baro. Press. (in. Hg) 30.14  
Static Press. (in. H2O) -19.50  
Stack Height (ft) 30  
Stack Diameter (in.) 70.90  
Stack Area (sq.ft.) 27.417  
Minutes Per Reading 5.0  
Minutes Per Point 5.0

**Collection:**  
Filter (grams) 0.00005  
Washings (grams) 0.00180  
**Total (grams) 0.00185**

**Gas Analysis (Vol. %):**  
CO2 O2  
10.00 10.00  
10.00 10.00  
**10.00 10.00**

**Condensate Collection:**  
Impinger 1 140.0  
Impinger 2 116.0  
Impinger 3 42.0  
Impinger 4 8.0  
Impinger 5 4.0  
Impinger 6 2.0  
Gel 12.9  
**Gain (grams) 324.9**

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	673.700								
1	5.0	677.320	0.32	1.96	68	68	6	309	1.5	102.7
2	10.0	681.360	0.40	2.45	69	69	6	310	4.7	102.5
3	15.0	685.400	0.40	2.45	69	69	7	313	8.4	102.7
4	20.0	689.550	0.42	2.57	69	69	7	314	12.5	103.0
5	25.0	693.590	0.40	2.45	70	70	8	315	17.7	102.6
6	30.0	697.640	0.40	2.45	70	70	8	316	25.2	102.9
7	35.0	702.720	0.63	3.86	71	71	12	314	45.6	102.9
8	40.0	707.700	0.61	3.73	71	71	12	313	53.2	102.4
9	45.0	712.220	0.50	3.06	71	71	10	310	58.3	102.3
10	50.0	716.370	0.42	2.57	72	72	10	307	62.5	102.0
11	55.0	720.310	0.38	2.33	73	73	8	305	66.1	101.4
12	60.0	724.140	0.36	2.20	73	73	8	300	69.4	100.9
Traverse 2	0.0	724.140								
1	5.0	728.180	0.40	2.45	74	74	8	309	1.5	101.4
2	10.0	732.470	0.45	2.75	75	75	8	310	4.7	101.5
3	15.0	737.080	0.52	3.18	75	75	8	314	8.4	101.8
4	20.0	741.460	0.47	2.88	76	76	8	315	12.5	101.6
5	25.0	746.070	0.42	3.18	76	76	8	315	17.7	113.2
6	30.0	750.500	0.48	2.94	77	77	8	315	25.2	101.5
7	35.0	755.110	0.52	3.18	77	77	9	313	45.6	101.4
8	40.0	759.630	0.50	3.06	78	78	9	313	53.2	101.2
9	45.0	764.240	0.52	3.18	78	78	10	312	58.3	101.1
10	50.0	768.430	0.43	2.63	77	77	10	312	62.5	101.1
11	55.0	772.470	0.40	2.45	77	77	10	312	66.1	101.1
12	60.0	776.520	0.40	2.45	78	78	10	312	69.4	101.1
Average:			0.448	2.767	73.5	73.5	8.7	311.6		102.3

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 1

**Date:** 4-May-21  
**Run:** 2 - Particulate / Metals  
**Run Time:** 08:53 - 10:55

---

**Concentrations:**

<b>Particulate</b>	0.46 mg/dscm	0.00020 gr/dscf
	0.26 mg/Acm	0.00011 gr/Acf
	0.43 mg/dscm (@ 11% O2)	0.00019 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.035 Kg/hr	0.076 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1253 dscm/min	44248 dscf/min
	20.88 dscm/sec	737 dscf/sec
	2191 Acm/min	77358 Acf/min

<b>Velocity</b>	14.334 m/sec	47.03 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	150.4 oC	302.7 oF
--------------------	----------	----------

<b>Moisture</b>	14.0 %
-----------------	--------

<b>Gas Analysis</b>	10.3 % O2
	9.8 % CO2

29.970 Mol. Wt (g/gmole) Dry  
28.293 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.9371 dscm	103.722 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	102.9 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

<b>Client:</b>	Metro Vancouver	<b>Date:</b>	4-May-21
<b>Jobsite:</b>	WTE (Burnaby, B.C)	<b>Run:</b>	2 - Particulate / Metals
<b>Source:</b>	Unit 1	<b>Run Time:</b>	08:53 - 10:55

<b>Control Unit (Y)</b>	1.0006	<b>Collection:</b>	<b>Gas Analysis (Vol. %):</b>	<b>Condensate Collection:</b>
<b>Nozzle Diameter (in.)</b>	0.3090	Filter (grams) 0.00005	CO2 O2	Impinger 1 192.0
<b>Pitot Factor</b>	0.8494	Washings (grams) 0.00130	9.50 10.50	Impinger 2 102.0
<b>Baro. Press. (in. Hg)</b>	30.15		10.00 10.00	Impinger 3 34.0
<b>Static Press. (in. H2O)</b>	-19.00	<b>Total (grams) 0.00135</b>		Impinger 4 10.0
<b>Stack Height (ft)</b>	30			Impinger 5 5.0
<b>Stack Diameter (in.)</b>	70.90			Impinger 6 2.0
<b>Stack Area (sq.ft.)</b>	27.417			Gel 14.1
<b>Minutes Per Reading</b>	5.0		<b>9.75 10.25</b>	<b>Gain (grams) 359.1</b>
<b>Minutes Per Point</b>	5.0			

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	776.950								
1	5.0	780.150	0.25	1.53	62	62	4	296	1.5	103.8
2	10.0	783.530	0.28	1.71	63	63	4	300	4.7	103.8
3	15.0	787.140	0.32	1.96	63	63	4	294	8.4	103.3
4	20.0	790.750	0.32	1.96	64	64	4	295	12.5	103.2
5	25.0	794.370	0.32	1.96	64	64	4	293	17.7	103.3
6	30.0	798.200	0.36	2.20	65	65	4	298	25.2	103.3
7	35.0	803.470	0.68	4.16	66	66	8	299	45.6	103.8
8	40.0	808.820	0.70	4.28	68	68	8	303	53.2	103.7
9	45.0	814.240	0.72	4.41	70	70	10	304	58.3	103.3
10	50.0	819.590	0.70	4.28	71	71	10	308	62.5	103.5
11	55.0	824.200	0.52	3.18	71	71	6	309	66.1	103.3
12	60.0	828.240	0.40	2.45	72	72	6	303	69.4	102.4
Traverse 2	0.0	828.240								
1	5.0	831.860	0.32	1.96	72	72	6	302	1.5	102.4
2	10.0	835.900	0.40	2.45	73	73	6	301	4.7	102.1
3	15.0	839.840	0.38	2.33	73	73	6	302	8.4	102.2
4	20.0	843.880	0.40	2.45	73	73	6	302	12.5	102.1
5	25.0	848.490	0.52	3.18	74	74	6	302	17.7	102.2
6	30.0	853.100	0.52	3.18	74	74	6	308	25.2	102.6
7	35.0	857.140	0.40	2.45	74	74	6	308	45.6	102.3
8	40.0	861.290	0.42	2.57	74	74	6	307	53.2	102.6
9	45.0	865.820	0.50	3.06	74	74	7	307	58.3	102.7
10	50.0	870.430	0.52	3.18	74	74	7	308	62.5	102.6
11	55.0	875.170	0.55	3.37	75	75	7	308	66.1	102.4
12	60.0	879.550	0.47	2.88	76	76	7	307	69.4	102.0
<b>Average:</b>			0.457	2.798	70.2	70.2	6.2	302.7		102.9

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 1

**Date:** 4-May-21  
**Run:** 3 - Particulate / Metals  
**Run Time:** 11:18 - 13:10

---

**Concentrations:**

<b>Particulate</b>	1.2 mg/dscm	0.0005 gr/dscf
	0.7 mg/Acm	0.0003 gr/Acf
	1.1 mg/dscm (@ 11% O2)	0.0005 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.092 Kg/hr	0.202 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1261 dscm/min	44515 dscf/min
	21.01 dscm/sec	742 dscf/sec
	2225 Acm/min	78578 Acf/min

<b>Velocity</b>	14.560 m/sec	47.77 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	151.5 oC	304.7 oF
--------------------	----------	----------

<b>Moisture</b>	14.6 %
-----------------	--------

<b>Gas Analysis</b>	10.1 % O2
	9.9 % CO2

29.990 Mol. Wt (g/gmole) Dry  
28.239 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.7268 dscm	96.296 dscf
<b>Sample Time</b>	110.0 minutes	
<b>Isokineticity</b>	103.6 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

<b>Client:</b>	Metro Vancouver	<b>Date:</b>	4-May-21
<b>Jobsite:</b>	WTE (Burnaby, B.C)	<b>Run:</b>	3 - Particulate / Metals
<b>Source:</b>	Unit 1	<b>Run Time:</b>	11:18 - 13:10

Control Unit (Y)	1.0006	Collection:	Gas Analysis (Vol. %):		Condensate Collection:	
Nozzle Diameter (in.)	0.3090	Filter (grams) 0.00020	CO2	O2	Impinger 1	186.0
Pitot Factor	0.8494	Washings (grams) 0.00310	9.83	10.20	Impinger 2	98.0
Baro. Press. (in. Hg)	30.15		10.00	10.00	Impinger 3	30.0
Static Press. (in. H20)	-19.00	Total (grams) 0.00330			Impinger 4	12.0
Stack Height (ft)	30				Impinger 5	6.0
Stack Diameter (in.)	70.90				Impinger 6	3.0
Stack Area (sq.ft.)	27.417				Gel	14.9
Minutes Per Reading	5.0		9.92	10.10	Gain (grams)	349.9
Minutes Per Point	5.0					

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	880.050								
1	5.0	883.940	0.37	2.26	72	72	5	293	1.5	102.4
2	10.0	887.980	0.40	2.45	73	73	5	298	4.7	102.5
3	15.0	892.020	0.40	2.45	72	72	5	303	8.4	103.0
4	20.0	896.070	0.40	2.45	73	73	5	302	12.5	103.0
5	25.0	900.840	0.42	2.57	73	73	6	302	17.7	118.4
6	30.0	904.880	0.40	2.45	74	74	6	302	25.2	102.6
7	35.0	909.020	0.42	2.57	73	73	6	303	45.6	102.8
8	40.0	913.450	0.48	2.94	72	72	6	303	53.2	103.2
9	45.0	917.970	0.50	3.06	73	73	6	304	58.3	103.1
10	50.0	922.580	0.52	3.18	73	73	6	305	62.5	103.2
11	55.0	927.100	0.50	3.06	73	73	6	305	66.1	103.2
12	60.0	931.490	0.47	2.88	74	74	6	306	69.4	103.2
Traverse 2	0.0	931.490								
1	5.0	935.530	0.40	2.45	74	74	6	303	1.5	102.6
2	10.0	939.670	0.42	2.57	75	75	6	304	4.7	102.5
3	15.0	943.720	0.40	2.45	75	75	6	306	8.4	102.9
4	20.0	947.860	0.42	2.57	76	76	6	308	12.5	102.6
5	25.0	952.000	0.42	2.57	75	75	6	308	17.7	102.8
6	30.0	956.040	0.40	2.45	76	76	6	309	25.2	102.6
7	35.0	961.070	0.62	3.79	76	76	8	310	45.6	103.0
8	40.0	966.190	0.64	3.92	77	77	8	311	53.2	103.1
9	45.0	971.140	0.60	3.67	76	76	7	310	58.3	103.1
10	50.0	976.010	0.58	3.55	77	77	7	309	62.5	102.8
Average:			0.463	2.832	74.2	74.2	6.1	304.7		103.6

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 2

**Date:** 7-May-21  
**Run:** 1 - Particulate / Metals  
**Run Time:** 09:30 - 11:32

---

**Concentrations:**

<b>Particulate</b>	0.1 mg/dscm	0.0000 gr/dscf
	0.0 mg/Acm	0.0000 gr/Acf
	0.0 mg/dscm (@ 11% O2)	0.0000 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.004 Kg/hr	0.009 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1225 dscm/min	43260 dscf/min
	20.42 dscm/sec	721 dscf/sec
	2107 Acm/min	74398 Acf/min

<b>Velocity</b>	13.785 m/sec	45.23 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	153.3 oC	307.9 oF
--------------------	----------	----------

<b>Moisture</b>	12.0 %
-----------------	--------

<b>Gas Analysis</b>	9.6 % O2
	9.9 % CO2

29.965 Mol. Wt (g/gmole) Dry  
28.533 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.7036 dscm	95.477 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	97.9 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 2

**Date:** 7-May-21  
**Run:** 1 - Particulate / Metals  
**Run Time:** 09:30 - 11:32

Control Unit (Y)	1.0101	Collection:		Gas Analysis (Vol. %):		Condensate Collection:	
Nozzle Diameter (in.)	0.3073	Filter (grams)	0.00005	CO2	O2	Impinger 1	162.0
Pitot Factor	0.8490	Washings (grams)	0.00010	Traverse 1	9.50	Impinger 2	58.0
Baro. Press. (in. Hg)	30.07			Traverse 2	10.25	Impinger 3	28.0
Static Press. (in. H2O)	-18.00	<b>Total (grams) 0.00015</b>				Impinger 4	8.0
Stack Height (ft)	30					Impinger 5	4.0
Stack Diameter (in.)	70.90					Impinger 6	2.0
Stack Area (sq.ft.)	27.417					Gel	13.8
Minutes Per Reading	5.0				<b>9.88</b>	<b>Gain (grams)</b>	<b>275.8</b>
Minutes Per Point	5.0				<b>9.63</b>		

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	168.600								
1	5.0	172.890	0.50	2.52	67	67	8.5	301	1.5	98.0
2	10.0	177.270	0.52	2.62	68	68	8.5	305	4.7	98.2
3	15.0	181.470	0.48	2.41	68	68	8	306	8.4	98.0
4	20.0	185.890	0.53	2.66	69	69	8	308	12.5	98.2
5	25.0	190.270	0.52	2.61	70	70	8.5	309	17.7	98.1
6	30.0	194.610	0.51	2.56	70	70	8.5	310	25.2	98.2
7	35.0	198.160	0.34	1.71	71	71	6	308	45.6	97.8
8	40.0	201.550	0.31	1.56	72	72	6	309	53.2	97.7
9	45.0	205.010	0.32	1.62	73	73	6	309	58.3	97.8
10	50.0	207.950	0.23	1.17	73	73	6	302	62.5	97.6
11	55.0	211.080	0.26	1.32	74	74	5	306	66.1	97.9
12	60.0	214.080	0.24	1.22	74	74	5	307	69.4	97.7
Traverse 2	0.0	214.080								
1	5.0	217.450	0.30	1.53	74	74	7	303	1.5	98.0
2	10.0	220.860	0.31	1.57	74	74	7	310	4.7	98.0
3	15.0	224.150	0.29	1.47	74	74	6.5	310	8.4	97.7
4	20.0	227.270	0.26	1.32	74	74	6.5	309	12.5	97.7
5	25.0	230.670	0.31	1.56	73	73	6.5	310	17.7	97.9
6	30.0	234.280	0.35	1.77	73	73	6.5	310	25.2	97.3
7	35.0	238.800	0.55	2.77	73	73	9.5	311	45.6	98.0
8	40.0	243.710	0.65	3.27	72	72	9.5	311	53.2	98.2
9	45.0	248.270	0.56	2.82	72	72	11	310	58.3	98.1
10	50.0	253.120	0.63	3.18	73	73	11	310	62.5	98.3
11	55.0	257.970	0.63	3.19	73	73	11	308	66.1	98.2
12	60.0	262.860	0.64	3.24	73	73	11	307	69.4	98.2
Average:			0.427	2.153	72.0	72.0	7.8	307.9		97.9

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 2

**Date:** 7-May-21  
**Run:** 2 - Particulate / Metals  
**Run Time:** 11:51:13:53

---

**Concentrations:**

<b>Particulate</b>	0.43 mg/dscm	0.00019 gr/dscf
	0.24 mg/Acm	0.00011 gr/Acf
	0.37 mg/dscm (@ 11% O2)	0.00016 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.029 Kg/hr	0.065 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1132 dscm/min	39990 dscf/min
	18.87 dscm/sec	666 dscf/sec
	2008 Acn/min	70910 Acf/min

<b>Velocity</b>	13.139 m/sec	43.11 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	155.9 oC	312.6 oF
--------------------	----------	----------

<b>Moisture</b>	14.1 %
-----------------	--------

<b>Gas Analysis</b>	9.3 % O2
	10.3 % CO2

30.010 Mol. Wt (g/gmole) Dry  
28.318 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.4349 dscm	85.987 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	99.9 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg



<b>Client:</b>	Metro Vancouver	<b>Date:</b>	7-May-21
<b>Jobsite:</b>	WTE (Burnaby, B.C)	<b>Run:</b>	2 - Particulate / Metals
<b>Source:</b>	Unit 2	<b>Run Time:</b>	11:51:13:53

<b>Control Unit (Y)</b>	1.0101	<b>Collection:</b>		<b>Gas Analysis (Vol. %):</b>		<b>Condensate Collection:</b>	
<b>Nozzle Diameter (in.)</b>	0.3073	Filter (grams)	0.00005	CO2	O2	Impinger 1	196.0
<b>Pitot Factor</b>	0.8490	Washings (grams)	0.00100	10.25	9.50	Impinger 2	74.0
<b>Baro. Press. (in. Hg)</b>	30.07			10.25	9.00	Impinger 3	8.0
<b>Static Press. (in. H2O)</b>	-18.00	<b>Total (grams)</b>	<b>0.00105</b>			Impinger 4	4.0
<b>Stack Height (ft)</b>	30.1					Impinger 5	2.0
<b>Stack Diameter (in.)</b>	70.90					Impinger 6	1.0
<b>Stack Area (sq.ft.)</b>	27.417					Gel	14.7
<b>Minutes Per Reading</b>	5.0			<b>10.25</b>	<b>9.25</b>	<b>Gain (grams)</b>	<b>299.7</b>
<b>Minutes Per Point</b>	5.0						

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	263.300								
1	5.0	266.610	0.30	1.50	67	67	6	310	1.5	100.0
2	10.0	269.850	0.29	1.44	67	67	6	314	4.7	99.8
3	15.0	272.980	0.27	1.34	67	67	5.5	313	8.4	99.8
4	20.0	275.990	0.25	1.24	67	67	5.5	313	12.5	99.7
5	25.0	279.240	0.29	1.44	68	68	6	313	17.7	99.8
6	30.0	282.650	0.32	1.59	68	68	6	313	25.2	99.7
7	35.0	287.210	0.57	2.84	68	68	10	313	45.6	100.2
8	40.0	291.930	0.61	3.04	69	69	10	314	53.2	100.2
9	45.0	296.820	0.65	3.25	71	71	11	314	58.3	100.3
10	50.0	301.560	0.61	3.05	71	71	11	313	62.5	100.2
11	55.0	306.300	0.61	3.06	71	71	10.5	312	66.1	100.1
12	60.0	310.930	0.58	2.92	71	71	10.5	310	69.4	100.2
Traverse 2	0.0	310.930								
1	5.0	314.970	0.44	2.21	72	72	7.5	311	1.5	100.0
2	10.0	318.960	0.43	2.15	72	72	7.5	314	4.7	100.1
3	15.0	323.090	0.46	2.31	73	73	8	313	8.4	100.0
4	20.0	327.090	0.43	2.17	74	74	8	313	12.5	99.9
5	25.0	331.000	0.41	2.07	74	74	7	312	17.7	100.0
6	30.0	334.810	0.39	1.96	74	74	7	314	25.2	100.0
7	35.0	338.040	0.28	1.41	74	74	6.5	314	45.6	99.9
8	40.0	341.090	0.25	1.24	74	74	6.5	313	53.2	99.7
9	45.0	343.890	0.21	1.06	74	74	6	314	58.3	99.9
10	50.0	346.750	0.22	1.11	74	74	6	312	62.5	99.6
11	55.0	349.490	0.20	1.01	74	74	6	310	66.1	99.9
12	60.0	352.150	0.19	0.96	74	74	6	311	69.4	99.6
Average:			0.386	1.932	71.2	71.2	7.5	312.6		99.9

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 2

**Date:** 7-May-21  
**Run:** 3 - Particulate / Metals  
**Run Time:** 14:12 - 16:14

---

**Concentrations:**

<b>Particulate</b>	0.3 mg/dscm	0.0001 gr/dscf
	0.2 mg/Acm	0.0001 gr/Acf
	0.3 mg/dscm (@ 11% O2)	0.0001 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.02 Kg/hr	0.050 lb/hr
--------------------	------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1153 dscm/min	40726 dscf/min
	19.22 dscm/sec	679 dscf/sec
	2027 Acm/min	71591 Acf/min

<b>Velocity</b>	13.265 m/sec	43.52 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	153.4 oC	308.1 oF
--------------------	----------	----------

<b>Moisture</b>	13.8 %
-----------------	--------

<b>Gas Analysis</b>	8.6 % O2
	10.8 % CO2

30.065 Mol. Wt (g/gmole) Dry  
28.394 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.5967 dscm	91.702 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	99.8 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

<b>Client:</b>	Metro Vancouver	<b>Date:</b>	7-May-21
<b>Jobsite:</b>	WTE (Burnaby, B.C)	<b>Run:</b>	3 - Particulate / Metals
<b>Source:</b>	Unit 2	<b>Run Time:</b>	14:12 - 16:14

Control Unit (Y)	1.0101	Collection:		Gas Analysis (Vol. %):		Condensate Collection:			
Nozzle Diameter (in.)	0.3073		Filter (grams)	0.00005	CO2	O2	Impinger 1	182.0	
Pitot Factor	0.8490		Washings (grams)	0.00080	Traverse 1	11.00	8.50	Impinger 2	78.0
Baro. Press. (in. Hg)	30.07				Traverse 2	10.50	8.75	Impinger 3	26.0
Static Press. (in. H2O)	-18.00		Total (grams) 0.0008					Impinger 4	8.0
Stack Height (ft)	30						Impinger 5	3.0	
Stack Diameter (in.)	70.90						Impinger 6	2.0	
Stack Area (sq.ft.)	27.417						Gel	14.2	
Minutes Per Reading	5.0				10.75	8.63	Gain (grams)	313.2	
Minutes Per Point	5.0								

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	355.100								
1	5.0	359.420	0.50	2.54	71	71	8.5	303	1.5	100.0
2	10.0	363.640	0.48	2.42	71	71	8.5	307	4.7	99.9
3	15.0	368.060	0.53	2.66	71	71	10	312	8.4	99.9
4	20.0	372.350	0.50	2.50	71	71	10	314	12.5	100.0
5	25.0	376.680	0.51	2.55	71	71	10	314	17.7	99.9
6	30.0	380.930	0.49	2.45	71	71	10	314	25.2	100.0
7	35.0	384.570	0.36	1.80	71	71	7.5	314	45.6	99.8
8	40.0	387.540	0.24	1.20	71	71	7.5	313	53.2	99.5
9	45.0	390.450	0.23	1.15	71	71	5.5	313	58.3	99.6
10	50.0	393.300	0.22	1.11	71	71	5.5	309	62.5	99.5
11	55.0	396.280	0.24	1.21	71	71	6	309	66.1	99.6
12	60.0	399.070	0.21	1.06	71	71	6	308	69.4	99.6
Traverse 2	0.0	399.070								
1	5.0	402.410	0.30	1.52	72	72	7	307	1.5	99.6
2	10.0	405.700	0.29	1.47	72	72	7	307	4.7	99.8
3	15.0	408.940	0.28	1.42	73	73	6.5	307	8.4	99.8
4	20.0	412.060	0.26	1.32	73	73	6.5	308	12.5	99.8
5	25.0	415.360	0.29	1.47	74	74	7	307	17.7	99.7
6	30.0	418.830	0.32	1.63	75	75	7	307	25.2	99.6
7	35.0	423.350	0.54	2.75	76	76	9.5	307	45.6	100.0
8	40.0	427.960	0.56	2.86	77	77	9.5	307	53.2	100.0
9	45.0	432.540	0.55	2.82	78	78	10	306	58.3	100.0
10	50.0	437.100	0.54	2.78	79	79	10	302	62.5	100.0
11	55.0	441.540	0.51	2.64	79	79	9.5	300	66.1	100.0
12	60.0	445.902	0.49	2.54	80	80	9.5	300	69.4	100.0
Average:			0.393	1.995	73.3	73.3	3.0	308.1		99.8

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 3

**Date:** 5-May-21  
**Run:** 1 - Particulate / Metals  
**Run Time:** 08:48 - 10:50

---

**Concentrations:**

<b>Particulate</b>	0.13 mg/dscm	0.00006 gr/dscf
	0.07 mg/Acm	0.00003 gr/Acf
	0.12 mg/dscm (@ 11% O2)	0.00005 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.009 Kg/hr	0.019 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1160 dscm/min	40949 dscf/min
	19.33 dscm/sec	682 dscf/sec
	2051 Acm/min	72445 Acf/min

<b>Velocity</b>	13.423 m/sec	44.04 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	151.7 oC	305.0 oF
--------------------	----------	----------

<b>Moisture</b>	14.6 %
-----------------	--------

<b>Gas Analysis</b>	10.4 % O2
	9.7 % CO2

29.960 Mol. Wt (g/gmole) Dry  
28.212 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.7679 dscm	97.747 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	104.7 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 3

**Date:** 5-May-21  
**Run:** 1 - Particulate / Metals  
**Run Time:** 08:48 - 10:50

Control Unit (Y) 0.9925  
 Nozzle Diameter (in.) 0.3090  
 Pitot Factor 0.8494  
 Baro. Press. (in. Hg) 30.10  
 Static Press. (in. H2O) -19.00  
 Stack Height (ft) 30  
 Stack Diameter (in.) 70.90  
 Stack Area (sq.ft.) 27.417  
 Minutes Per Reading 5.0  
 Minutes Per Point 5.0

**Collection:**  
 Filter (grams) 0.00005  
 Washings (grams) 0.00030  
**Total (grams) 0.00035**

**Gas Analysis (Vol. %):**  
 CO2 O2  
 Traverse 1 9.50 10.50  
 Traverse 2 9.83 10.20  
**9.67 10.35**

**Condensate Collection:**  
 Impinger 1 168.0  
 Impinger 2 116.0  
 Impinger 3 42.0  
 Impinger 4 10.0  
 Impinger 5 5.0  
 Impinger 6 2.0  
 Gel 12.5  
**Gain (grams) 355.5**

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	464.588								
1	5.0	469.140	0.50	2.70	55	55	8	309	1.5	106.7
2	10.0	473.790	0.52	2.80	56	56	8	310	4.7	106.8
3	15.0	478.430	0.52	2.80	56	56	8	310	8.4	106.6
4	20.0	482.880	0.48	2.59	56	56	8	308	12.5	106.2
5	25.0	487.210	0.45	2.43	57	57	8	307	17.7	106.4
6	30.0	491.390	0.42	2.26	58	58	8	307	25.2	106.1
7	35.0	495.040	0.32	1.72	59	59	8	304	45.6	105.6
8	40.0	498.570	0.30	1.62	60	60	8	303	53.2	105.1
9	45.0	501.980	0.28	1.51	61	61	8	303	58.3	104.9
10	50.0	505.390	0.28	1.51	62	62	8	304	62.5	104.8
11	55.0	508.670	0.26	1.40	62	62	8	303	66.1	104.5
12	60.0	511.950	0.26	1.40	63	63	8	302	69.4	104.2
Traverse 2	0.0	511.950								
1	5.0	515.660	0.33	1.78	63	63	8	303	1.5	104.8
2	10.0	519.470	0.35	1.89	64	64	8	304	4.7	104.4
3	15.0	523.440	0.38	2.05	64	64	8	304	8.4	104.4
4	20.0	527.080	0.32	1.72	65	65	8	304	12.5	104.1
5	25.0	530.720	0.32	1.72	66	66	8	305	17.7	103.9
6	30.0	534.530	0.35	1.89	67	67	8	305	25.2	103.9
7	35.0	539.080	0.50	2.70	68	68	8	305	45.6	103.8
8	40.0	543.540	0.48	2.59	68	68	8	304	53.2	103.7
9	45.0	548.000	0.48	2.59	69	69	8	304	58.3	103.5
10	50.0	552.550	0.50	2.70	70	70	8	305	62.5	103.4
11	55.0	556.870	0.45	2.43	70	70	8	304	66.1	103.3
12	60.0	561.040	0.42	2.26	71	71	8	303	69.4	102.9
<b>Average:</b>			0.395	2.128	62.9	62.9	8.0	305.0		104.7

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 3

**Date:** 5-May-21  
**Run:** 2 - Particulate / Metals  
**Run Time:** 11:05 - 13:07

---

**Concentrations:**

<b>Particulate</b>	0.32 mg/dscm	0.00014 gr/dscf
	0.18 mg/Acm	0.00008 gr/Acf
	0.29 mg/dscm (@ 11% O2)	0.00013 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.023 Kg/hr	0.051 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1207 dscm/min	42632 dscf/min
	20.12 dscm/sec	711 dscf/sec
	2143 Acm/min	75662 Acf/min

<b>Velocity</b>	14.019 m/sec	45.99 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	150.4 oC	302.7 oF
--------------------	----------	----------

<b>Moisture</b>	15.1 %
-----------------	--------

<b>Gas Analysis</b>	10.1 % O2
	9.9 % CO2

29.990 Mol. Wt (g/gmole) Dry  
28.174 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.8310 dscm	99.976 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	102.9 %	

**\* Standard Conditions:**      Metric:    20 deg C, 101.325 kPa  
   Imperial: 68 deg F, 29.92 in.Hg

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 3

**Date:** 5-May-21  
**Run:** 2 - Particulate / Metals  
**Run Time:** 11:05 - 13:07

Control Unit (Y) 0.9925  
 Nozzle Diameter (in.) 0.3090  
 Pitot Factor 0.8494  
 Baro. Press. (in. Hg) 30.10  
 Static Press. (in. H2O) -19.00  
 Stack Height (ft) 30  
 Stack Diameter (in.) 70.90  
 Stack Area (sq.ft.) 27.417  
 Minutes Per Reading 5.0  
 Minutes Per Point 5.0

**Collection:**  
 Filter (grams) 0.00000  
 Washings (grams) 0.00090  
**Total (grams) 0.00090**

**Gas Analysis (Vol. %):**  
 CO2 O2  
 Traverse 1 10.00 10.00  
 Traverse 2 9.83 10.17  
**9.92 10.09**

**Condensate Collection:**  
 Impinger 1 252.0  
 Impinger 2 86.0  
 Impinger 3 18.0  
 Impinger 4 6.0  
 Impinger 5 2.0  
 Impinger 6 1.0  
 Gel 14.2  
**Gain (grams) 379.2**

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	561.950								
1	5.0	565.760	0.35	1.89	68	68	4	294	1.5	103.5
2	10.0	569.670	0.37	1.99	69	69	4	296	4.7	103.3
3	15.0	573.480	0.35	1.89	69	69	4	303	8.4	103.9
4	20.0	577.290	0.35	1.89	70	70	4	302	12.5	103.6
5	25.0	580.920	0.32	1.72	70	70	4	303	17.7	103.3
6	30.0	584.560	0.32	1.72	71	71	4	304	25.2	103.5
7	35.0	589.020	0.48	2.59	71	71	4	304	45.6	103.7
8	40.0	593.570	0.50	2.70	72	72	4	306	53.2	103.6
9	45.0	598.210	0.52	2.80	72	72	6	307	58.3	103.7
10	50.0	602.990	0.55	2.96	73	73	6	304	62.5	103.6
11	55.0	607.890	0.58	3.13	74	74	6	302	66.1	103.1
12	60.0	612.780	0.58	3.13	75	75	6	301	69.4	102.6
Traverse 2	0.0	612.780								
1	5.0	617.560	0.55	2.96	75	75	6	302	1.5	103.0
2	10.0	622.200	0.52	2.80	76	76	6	302	4.7	102.6
3	15.0	626.980	0.55	2.96	76	76	6	303	8.4	102.9
4	20.0	631.620	0.52	2.80	77	77	6	304	12.5	102.6
5	25.0	636.170	0.50	2.70	77	77	6	303	17.7	102.5
6	30.0	640.630	0.48	2.59	78	78	6	302	25.2	102.2
7	35.0	644.710	0.40	2.16	78	78	6	302	45.6	102.3
8	40.0	648.630	0.37	1.99	79	79	6	302	53.2	102.0
9	45.0	652.270	0.32	1.72	79	79	6	304	58.3	101.9
10	50.0	655.800	0.30	1.62	80	80	5	305	62.5	101.9
11	55.0	659.330	0.30	1.62	79	79	5	304	66.1	102.1
12	60.0	662.740	0.28	1.51	80	80	5	305	69.4	101.9
<b>Average:</b>			0.432	2.327	74.5	74.5	5.2	302.7		102.9

**Client:** Metro Vancouver  
**Jobsite:** WTE(Burnaby,B.C)  
**Source:** Unit 3

**Date:** 5-May-21  
**Run:** 3 - Particulate / Metals  
**Run Time:** 13:32-15:35

---

**Concentrations:**

<b>Particulate</b>	0.28 mg/dscm	0.00012 gr/dscf
	0.16 mg/Acm	0.00007 gr/Acf
	0.23 mg/dscm (@ 11% O2)	0.00010 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.019 Kg/hr	0.043 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1137 dscm/min	40139 dscf/min
	18.94 dscm/sec	669 dscf/sec
	2041 Acn/min	72083 Acf/min

<b>Velocity</b>	13.356 m/sec	43.82 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	153.9 oC	309.1 oF
--------------------	----------	----------

<b>Moisture</b>	15.0 %
-----------------	--------

<b>Gas Analysis</b>	8.8 % O2
	10.0 % CO2

29.950 Mol. Wt (g/gmole) Dry  
28.159 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.6495 dscm	93.566 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	100.9 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg



**Client:** Metro Vancouver  
**Jobsite:** WTE(Burnaby,B.C)  
**Source:** Unit 3

**Date:** 5-May-21  
**Run:** 3 - Particulate / Metals  
**Run Time:** 13:32-15:35

Control Unit (Y)	0.9925	Collection:	Gas Analysis (Vol. %):	Condensate Collection:
Nozzle Diameter (in.)	0.3110	Filter (grams) 0.00005	CO2 O2	Impinger 1 230.0
Pitot Factor	0.8494	Washings (grams) 0.00070	Traverse 1 10.00 9.00	Impinger 2 84.0
Baro. Press. (in. Hg)	29.95		Traverse 2 10.00 8.50	Impinger 3 14.0
Static Press. (in. H2O)	-19.00		10.00 8.50	Impinger 4 5.0
Stack Height (ft)	30	<b>Total (grams) 0.00075</b>	10.00 9.00	Impinger 5 2.0
Stack Diameter (in.)	70.90			Impinger 6 1.0
Stack Area (sq.ft.)	27.417			Gel 14.6
Minutes Per Reading	5.0		<b>10.00 8.75</b>	<b>Gain (grams) 350.6</b>
Minutes Per Point	5.0			

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	664.300								
1	5.0	668.760	0.48	2.56	77	77	9	308	1.5	101.1
2	10.0	673.310	0.50	2.67	77	77	9	308	4.7	101.0
3	15.0	677.860	0.50	2.66	77	77	10	309	8.4	101.1
4	20.0	682.470	0.51	2.72	78	78	10	308	12.5	101.2
5	25.0	686.980	0.49	2.26	78	78	10	308	17.7	100.9
6	30.0	691.400	0.47	2.51	78	78	10	308	25.2	101.0
7	35.0	695.160	0.34	1.81	78	78	7	309	45.6	100.9
8	40.0	698.970	0.35	1.86	78	78	7	310	53.2	100.9
9	45.0	702.670	0.33	1.76	78	78	7	310	58.3	100.9
10	50.0	705.690	0.22	1.17	78	78	7	309	62.5	100.6
11	55.0	708.570	0.20	1.07	78	78	6	310	66.1	100.7
12	60.0	711.380	0.19	1.01	78	78	6	309	69.4	100.7
Traverse 2	0.0	711.380								
1	5.0	714.990	0.31	1.65	78	78	7.5	310	1.5	101.5
2	10.0	718.440	0.29	1.54	78	78	7.5	310	4.7	100.3
3	15.0	721.850	0.28	1.49	78	78	7	310	8.4	100.8
4	20.0	725.140	0.26	1.39	79	79	7	309	12.5	100.7
5	25.0	728.500	0.27	1.44	79	79	7	309	17.7	100.9
6	30.0	731.790	0.26	1.39	79	79	7	309	25.2	100.7
7	35.0	736.360	0.50	2.67	79	79	13	309	45.6	101.2
8	40.0	741.060	0.53	2.83	79	79	13	309	53.2	101.1
9	45.0	745.850	0.55	2.94	79	79	14	309	58.3	101.2
10	50.0	750.640	0.55	2.94	79	79	14	310	62.5	101.2
11	55.0	755.250	0.51	2.72	79	79	13	310	66.1	101.1
12	60.0	759.822	0.50	2.68	79	79	13	308	69.4	101.2
Average:			0.391	2.073	78.3	78.3	9.2	309.1		100.9

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)  
**Source:** Unit 1

**Sample Type:** HF

Parameter		Test 1	Test 2	Test 3
Test Date		4-May-21	4-May-21	4-May-21
Test Time		09:35 - 10:35	10:44 - 11:44	11:55 - 12:55
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.17	30.17	30.17
DGM Factor	(Y)	1.0347	1.0347	1.0347
Initial Reading	(m <sup>3</sup> )	145.1820	145.7757	146.3620
Final Reading	(m <sup>3</sup> )	145.7668	146.3557	146.9416
Temp. Outlet	(Avg. oF)	68.1	76.3	77.0
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm <sup>3</sup> )	0.61	0.60	0.60
HF	(mg)	0.003	0.003	0.011
Oxygen	(Vol. %)	10.3	10.3	10.1
HF	(mg/Sm <sup>3</sup> )	0.004	0.004	0.019
HF	(mg/Sm <sup>3</sup> @ 11% O2)	0.004	0.004	0.017
Moisture	(Vol. %)	14.0	14.0	14.6

Tstd. (oF) 68

Pstd. (in. Hg) 29.92

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)  
**Source:** Unit 2

Sample Type: HF		Test 1	Test 2	Test 3
Parameter				
Test Date		7-May-21	7-May-21	7-May-21
Test Time		09:45 - 10:45	10:58 - 11:58	12:10 - 13:10
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.07	30.07	30.07
DGM Factor	(Y)	1.0347	1.0347	1.0347
Initial Reading	(m <sup>3</sup> )	148.6532	149.2540	149.8653
Final Reading	(m <sup>3</sup> )	149.2472	149.8570	150.4634
Temp. Outlet	(Avg. oF)	64.0	72.5	70.5
Orifice Press.	(ΔH in.H <sub>2</sub> O)	0.50	0.50	0.50
Gas Volume	(Sm <sup>3</sup> )	0.62317	0.62251	0.61978
HF	(mg)	0.011	0.011	0.011
Oxygen	(Vol. %)	9.3	8.6	8.6
HF	(mg/Sm <sup>3</sup> )	0.017	0.017	0.018
HF	(mg/Sm <sup>3</sup> @ 11% O <sub>2</sub> )	0.014	0.014	0.015
Moisture (isokinetic)	(Vol. %)	14.1	14.1	13.8
Tstd. (oF)		68	Pstd. (in. Hg)	29.92

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)  
**Source:** Unit 3

**Sample Type:** HF

Parameter		Test 1	Test 2	Test 3
Test Date		5-May-21	5-May-21	5-May-21
Test Time		09:08 - 10:08	10:22 - 11:22	11:42 - 12:42
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.10	30.10	30.10
DGM Factor	(Y)	1.0347	1.0347	1.0347
Initial Reading	(m <sup>3</sup> )	146.9500	147.5322	148.0640
Final Reading	(m <sup>3</sup> )	147.5253	148.0563	148.6458
Temp. Outlet	(Avg. oF)	67.3	77.5	77.0
Orifice Press.	(ΔH in.H <sub>2</sub> O)	0.50	0.50	0.50
Gas Volume	(Sm <sup>3</sup> )	0.600	0.537	0.596
HF	(mg)	0.012	0.011	0.011
Oxygen	(Vol. %)	10.1	10.1	8.8
<b>HF</b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>0.019</b>	<b>0.020</b>	<b>0.019</b>
<b>HF</b>	<b>(mg/Sm<sup>3</sup> @ 11% O<sub>2</sub>)</b>	<b>0.018</b>	<b>0.018</b>	<b>0.015</b>
<b>Moisture (isokinetic)</b>	<b>(Vol. %)</b>	<b>15.1</b>	<b>15.1</b>	<b>15.0</b>
Tstd. (oF)		68	Pstd. (in. Hg)	29.92

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)

**Parameter:** N<sub>2</sub>O

**Molecular Weight:** 44.00 grams/mol  
**Lab Detection Limit:** 0.1 ppm  
**Reportable Detection Limit:** 0.18 mg/Sm<sup>3</sup>

Sample ID	Date	Time (hh:mm - hh:mm)	N <sub>2</sub> O (ppm)	N <sub>2</sub> O (mg/Sm <sup>3</sup> )	N <sub>2</sub> O (mg/Sm <sup>3</sup> @ 11% O <sub>2</sub> )
<b>Unit #1</b>					
Run 1	4-May-21	09:35 - 10:35	5.66	10.36	10.26
Run 2	4-May-21	10:44 - 11:44	5.00	9.15	8.84
Run 3	4-May-21	11:55 - 12:55	5.00	9.15	8.97
<b>Average</b>					<b>9.35</b>
<b>Unit #2</b>					
Run 1	7-May-21	09:45 - 10:45	5.00	9.15	9.41
Run 2	7-May-21	10:58 - 11:58	5.00	9.15	9.79
Run 3	7-May-21	12:10 - 13:10	5.83	10.67	12.25
<b>Average</b>					<b>10.48</b>
<b>Unit #3</b>					
Run 1	5-May-21	09:08 - 10:08	5.00	9.15	8.75
Run 2	5-May-21	10:22 - 11:22	5.00	9.15	8.98
Run 3	5-May-21	11:34 - 12:34	5.00	9.15	10.35
<b>Average</b>					<b>9.36</b>

**APPENDIX - D**

**FIELD DATA SHEETS**

V639

6.12AH

CLIENT <b>MVRD</b>				NOZZLE <b>G309</b>		DIAMETER, IN. <b>3.090</b>		IMPINGER		INITIAL	FINAL	TOTAL GAIN
SOURCE <b>Unit #1</b>				PROBE <b>TC</b>		Cp <b>1.8494</b>		VOLUMES	(mL)	(mL)	(mL)	
PARAMETER / RUN No <b>1 Metals/Partic</b>				PORT LENGTH				Imp. #1	0	140	140	
DATE <b>May. 3/21</b>				STATIC PRESSURE, IN. H2O <b>-19.50</b>				Imp. #2	100	216	116	
OPERATOR: <b>C. L.</b>				STACK DIAMETER <b>31.0"</b>				Imp. #3	100	142	142	
CONTROL UNIT <b>3014</b> Y <b>1.0006</b>				STACK HEIGHT <b>200'</b>				Imp. #4	0	8	8	
								Imp. #5	100	104	4	
								Imp. #6	100	102	2	
BAROMETRIC PRESSURE, IN. Hg <b>30.14</b>				INITIAL LEAK TEST <b>0.002 @ 15"</b>				Upstream Diameters				
ASSUMED MOISTURE, Bw <b>15%</b>				FINAL LEAK TEST <b>0.002 @ 15"</b>				Downstream Diameters <b>14.8</b>				

5min Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites			
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %		
1	10:58	673.700												
2		677.32	32	1.96	68	309	250	250	65	6				
3		681.36	40	2.45	69	310	250	250	65	7	10.0	10.0		
4		685.40	40	2.45	69	313	250	250	66	7				
5		689.50	42	2.57	69	314	250	250	66	8				
6		693.59	40	2.45	70	315	250	250	64	8				
7		697.64	40	2.45	70	316	250	250	66	12	10.0	10.0		
8		702.72	63	3.86	71	314	250	250	66	12				
9		707.70	61	3.73	71	313	250	250	68	10				
10		712.82	50	3.06	71	310	250	250	68	10				
11		716.87	42	2.57	72	307	250	250	66	8	10.0	10.0		
12		720.91	38	2.33	73	305	250	250	66	8				
13		724.14	36	2.20	73	300								
14														
15		728.18	40	2.45	74	309	250	250	62	8				
16		732.47	45	2.75	75	310	250	250	62	8				
17		737.08	52	3.18	75	314	250	250	60	8				
18		741.46	47	2.88	76	315	250	250	58	8	10.0	10.0		
19		746.07	52	3.18	76	315	250	250	58	8				
20		750.50	48	2.94	77	315	250	250	58	8				
21		755.11	52	3.18	77	313	250	250	56	9				
22		759.63	50	3.06	78	313	250	250	55	10				
23		764.24	52	3.18	78	312	250	250	55	10				
24		768.43	43	2.63	77	312	250	250	54	10	10.0	10.0		
25		772.47	40	2.45	77	312	250	250	54	10				
26	13:00	776.52	40	2.45	78	312								





$\sqrt{6.39} \quad 6.12 \Delta H$ 

CLIENT <b>MURD</b>					NOZZLE <b>G309</b>		DIAMETER, IN. <b>3.90</b>			IMPINGER	INITIAL	FINAL	TOTAL GAIN
SOURCE <b>Unit #1</b>					PROBE <b>TC</b>		Cp <b>.8494</b>			VOLUMES	(mL)	(mL)	(mL)
PARAMETER / RUN No <b>3 metals/partic</b>					PORT LENGTH					Imp. #1	0	186	186
DATE <b>May. 4/21</b>					STATIC PRESSURE, IN. H2O <b>-19.00</b>					Imp. #2	100	198	298
OPERATOR: <b>C.L.</b>					STACK DIAMETER <b>131.0"</b>					Imp. #3	100	130	230
CONTROL UNIT <b>5014</b>					STACK HEIGHT <b>300'</b>					Imp. #4	0	12	12
<b>Y 1.0006</b>										Imp. #5	100	106	6
<b>ΔH@</b>										Imp. #6	100	103	3
BAROMETRIC PRESSURE, IN. Hg <b>30.15</b>					INITIAL LEAK TEST <b>0.002 @ 15"</b>					Upstream Diameters			
ASSUMED MOISTURE, Bw <b>15%</b>					FINAL LEAK TEST <b>0.002 @ 15"</b>					Downstream Diameters			
Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites		
	<b>11:18</b>	<b>880.050</b>			Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %	
1		883.94	.37	2.26	72	293	250	250	62	5			
2		887.98	.40	2.45	73	298							
3		892.02	.40	2.45	73	303	250	250	62	5	10.0	10.0	
4		896.07	.40	2.45	73	302							
5		900.84	.42	2.57	73	302	250	250	64	6			
6		904.88	.40	2.45	74	302							
7		909.02	.42	2.57	73	303	250	250	64	6	9.5	10.5	
8		913.45	.48	2.94	72	303							
9		917.97	.50	3.06	73	304	250	250	65	6			
10		922.58	.52	3.18	73	305							
11		927.10	.50	3.06	73	305	250	250	66	6	10.0	10.0	
12		931.49	.47	2.88	74	306							
13		935.53	.46	2.45	74	303	250	250	64	6			
14		939.67	.42	2.57	75	304							
15		943.72	.40	2.45	75	304	250	250	62	6			
16		947.87	.43	2.57	76	306							
17		952.00	.42	2.57	75	308	250	250	60	6	10.0	10.0	
18		956.04	.40	2.45	76	309							
19		961.07	.62	3.79	76	310	250	250	58	8			
20		966.10	.64	3.62	77	311							
21		971.14	.60	3.67	76	310	250	250	56	7	10.0	10.0	
22	<b>13:10</b>	976.01	.58	3.55	77	309							
23		End of test					250	250	54	7			

\* from  
trapped \*

[illegible]

[illegible]

CLIENT <u>MV LME</u>				NOZZLE <u>G-3072</u> DIAMETER, IN. <u>0.3073</u>		IMPINGER		INITIAL		FINAL		TOTAL GAIN		
SOURCE <u>WPH#2</u>				PROBE <u>1st Guard</u> Cp <u>0.8490</u>		VOLUMES		(mL)		(mL)		(mL)		
PARAMETER / RUN No <u>M17ME/1700000+Hg Run#3</u>				PORT LENGTH		Imp. #1		<u>100</u>		<u>182</u>		<u>182</u>		
DATE <u>MM 7 2001</u>				STATIC PRESSURE, IN. H2O <u>-18.0</u>		Imp. #2		<u>100</u>		<u>178</u>		<u>278</u>		
OPERATOR <u>RF</u>				STACK DIAMETER		Imp. #3		<u>100</u>		<u>126</u>		<u>226</u>		
CONTROL UNIT <u>309</u> Y <u>1.0101</u>				STACK HEIGHT		Imp. #4		<u>100</u>		<u>103</u>		<u>203</u>		
BAROMETRIC PRESSURE, IN. Hg <u>30.07</u>				INITIAL LEAK TEST <u>0.002 @ 15" Hg</u>		Imp. #5		<u>100</u>		<u>107</u>		<u>207</u>		
ASSUMED MOISTURE, Bw <u>14%</u>				FINAL LEAK TEST <u>0.002 @ 15" Hg</u>		Imp. #6		<u>100</u>		<u>107</u>		<u>207</u>		
						Upstream Diameters								
						Downstream Diameters								
Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites			
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %		
1		355.100	.50											
2		359.412	.50	2.54	71	303	254	250	58	8.5	11	8.5		
3	10	363.64	.48	2.42	71	307								
4		368.06	.53	2.66	71	312				10				
5	20	372.35	.50	2.50	71	314	250	245	58					
6		376.68	.51	2.55	71	314				10				
7	30	380.93	.49	2.45	71	314								
8		384.57	.36	1.80	71	314	251	250	57	7.5				
9	40	387.54	.24	1.20	71	313					11	8.5		
10		390.45	.23	1.15	71	313				5.5				
11	50	393.30	.22	1.11	71	309	250	245	56					
12		396.28	.24	1.21	71	309				6				
13	60	399.07	.21	1.06	71	308								
14														
15		402.41	.30	1.52	72	307	250	252	58	7	10.5	8.5		
16	10	405.70	.29	1.47	72	307								
17		408.94	.28	1.42	73	307				6.5				
18	20	412.06	.26	1.32	73	308	251	252	56					
19		415.36	.29	1.47	74	307				7				
20	30	418.83	.32	1.63	75	307								
21		423.35	.54	2.78	76	307	251	246	56	9.5				
22	40	427.96	.56	2.86	77	307					10.5	9		
23		432.54	.55	2.82	78	306				10				
24	50	437.10	.54	2.78	79	302	252	248	58					
25		441.54	.51	2.64	79	300				9.5				



V6.44 5.39 ΔH

A

CLIENT <b>MVRD</b>				NOZZLE <b>G309</b>		DIAMETER, IN. <b>3090</b>		IMPINGER		INITIAL	FINAL	TOTAL GAIN
SOURCE <b>Unit #3</b>				PROBE <b>7C</b>		Cp <b>8194</b>		VOLUMES	(mL)	(mL)	(mL)	
PARAMETER / RUN No <b>2 Metals / Partic</b>				PORT LENGTH				Imp. #1	0	252	252	
DATE <b>May 5/21</b>				STATIC PRESSURE, IN. H2O <b>-19.00</b>				Imp. #2	100	186	86	
OPERATOR: <b>C.L.</b>				STACK DIAMETER <b>131.0"</b>				Imp. #3	100	118	18	
CONTROL UNIT <b>ALI</b> Y <b>.9925</b>				STACK HEIGHT <b>300'</b>				Imp. #4	0	6	6	
ΔH@								Imp. #5	100	102	2	
BAROMETRIC PRESSURE, IN. Hg <b>30.10</b>				INITIAL LEAK TEST <b>0.002 @ 15"</b>				Imp. #6	100	101	1	
ASSUMED MOISTURE, Bw <b>15%</b>				FINAL LEAK TEST <b>0.002 @ 15"</b>				Upstream Diameters				
								Downstream Diameters				

Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites			
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %		
	11:05	561.950												
1		565.76	35	1.88	68	294	250	250	66	4				
2		569.67	35	1.88	69	296	250	250	66	4				
3		573.48	35	1.88	69	296	250	250	66	4				
4		577.39	35	1.88	70	300	250	250	68	4	10.0	10.0		
5		580.92	35	1.88	70	303	250	250	66	4				
6		584.56	35	1.88	71	304	250	250	66	4				
7		588.02	48	2.39	71	304	250	250	60	4				
8		593.57	55	2.70	72	306	250	250	54	6	10.0	10.0		
9		598.21	55	2.80	72	307	250	250	54	6	10.0	10.0		
10		602.99	55	2.96	73	304	250	250	52	6				
11		607.89	58	3.13	74	302	250	250	52	6				
12		612.78	58	3.13	75	301	250	250	53	6				
1		617.56	55	2.96	75	302	250	250	52	6				
2		622.20	52	2.80	76	302	250	250	52	6				
3		626.98	52	2.96	76	303	250	250	52	6	10.0	10.0		
4		631.62	52	2.80	77	304	250	250	52	6				
5		636.17	50	2.70	77	303	250	250	52	6				
6		640.63	48	2.59	78	302	250	250	50	6				
7		644.71	46	2.46	78	302	250	250	52	6	10.0	10.0		
8		648.63	37	1.72	79	304	250	250	52	6	10.0	10.0		
9		652.87	32	1.62	79	304	250	250	52	5				
10		657.80	30	1.62	80	305	250	250	52	5				
11		659.33	30	1.62	79	304	250	250	54	5	9.5	10.5		
12	13:07	662.74	28	1.51	80	305			54	5				





A. Lanfranco and Associates Inc.

Client MV WTE Y LMV-B 1.0347  
 Source Unit #3 Cp  
 Parameter HIF Pbar 30.17 Static -19  
 Date MAY 4, 2021 Operator Connor Laan

Leak Check	Run 1	Run 2	Run 3
Initial	0.0001	0.0001	0.0001
Final	0.0001	0.0001	0.0001

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H <sub>2</sub> O		
			DGM Outlet	Stack		R1	R2	R3
1	0935	145.1820	57.3					
	0945	145.2870						
	1005	145.4910	69.0					
	1035	145.7668	78.0					
2	1044	145.7757	73.5					
	11:44	146.3557	79					
3	11:55	146.3620	74					
	12:55	146.9416	80					

Client MV WTE Y LMV B 1.0347  
 Source Unit #3 Cp  
 Parameter HIF Pbar 30.1 Static -19  
 Date May 5/2021 Operator Connor Laan

Leak Check	Run 1	Run 2	Run 3
Initial	0.0001	0.0001	0.0001
Final	0.0001	0.0001	0.0001

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H <sub>2</sub> O		
			DGM Outlet	Stack		R1	R2	R3
1	0908	146.9500	57					
	0928	147.1290						
	1008	147.5253	77.5					
2	1022	147.5322	73					
	1122	148.0563	82					
3	1134	148.0640	75					
	1234	148.6458	79					



A. Lanfranco and Associates Inc.

Client MV W/TIE Y LMV-B 1.0347  
 Source Unit 2 Cp \_\_\_\_\_  
 Parameter HF Pbar 30.07 Static \_\_\_\_\_  
 Date May 7/21 Operator Conner Laan

Client \_\_\_\_\_ Y \_\_\_\_\_  
 Source \_\_\_\_\_ Cp \_\_\_\_\_  
 Parameter \_\_\_\_\_ Pbar \_\_\_\_\_ Static \_\_\_\_\_  
 Date \_\_\_\_\_ Operator \_\_\_\_\_

Leak Check	Run 1	Run 2	Run 3
Initial	0.0001	0.0001	0.0001
Final	0.0001	0.0001	0.0001

Leak Check	Run 1	Run 2	Run 3
Initial			
Final			

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H₂O		
			DGM Outlet	Stack		R1	R2	R3
1	09:45	148.6532	58					
	10:45	149.2472	70					
2	10:58	149.2540	69					
	11:58	149.8570	76					
3	12:10	149.8653	69					
	13:10	150.4634	77					

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H₂O		
			DGM Outlet	Stack		R1	R2	R3
1								
2								
3								

**A. Lanfranco & Associates Inc.**

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Parameter:** N<sub>2</sub>O

**Operator:** Connor Luan

**Unit #1**

**Barometric Pressure:** 30.17

Sample ID	Date	Time (hh:mm - hh:mm)	N <sub>2</sub> O (ppm)					
Run 1	May 4/21	09:35-10:35	0.0	0	0	4	0	0
Run 2	May 4/21	10:44-11:44	0	0	0	0	0	0
Run 3	May 4/21	11:55-12:55	0	0	0	0	0	0

**Unit #2**

**Barometric Pressure:** 30.07

Sample ID	Date	Time (hh:mm - hh:mm)	N <sub>2</sub> O (ppm)					
Run 1	May 7/21	9:45-10:45	0	0	0	0	0	0
Run 2	May 7/21	10:58-11:58	0	0	0	0	0	0
Run 3	May 7/21	12:10-13:10	0	0	0	0	0	5

**Unit #3**

**Barometric Pressure:** 30.10

Sample ID	Date	Time (hh:mm - hh:mm)	N <sub>2</sub> O (ppm)					
Run 1	May 5/21	9:08-10:08	0	0	0	0	0	0
Run 2	May 5/21	10:22-11:22	0	0	0	0	0	0
Run 3	May 5/21	11:34-12:34	0	0	0	0	0	0

**APPENDIX – E**

**CALIBRATION SHEETS and**

**TECHNICIAN CERTIFICATES**

# A.Lanfranco & Associates inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

Model #: CAE AL1  
Serial #: 0028-070611-1

Date: 04-Jan-21  
Barometric Pressure: 29.38 (in. Hg)  
Theoretical Critical Vacuum: 13.86 (in. Hg)

!!!!!!!  
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>((in.Hg)<sup>2</sup>(min)).  
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.60	16.00	161.300	178.620	17.320	73.0	73.0	77.0	77.0	73	0.8185	17.0	83.0	80.0	81.5
1.85	19.00	145.000	159.782	14.782	71.0	71.0	73.0	73.0	63	0.5956	20.0	74.0	74.0	74.0
1.10	19.00	132.300	143.732	11.432	67.0	67.0	70.0	70.0	55	0.4606	22.0	73.0	78.0	75.5
0.64	24.00	119.200	130.140	10.940	64.0	64.0	67.0	67.0	48	0.3560	23.5	67.0	72.0	69.5
0.33	31.00	179.300	189.153	9.853	77.0	77.0	76.0	76.0	40	0.2408	25.0	80.0	74.0	77.0

***** RESULTS *****														
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----					
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y			CALIBRATION FACTOR dH@					
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)		Value (in H2O)	Value (mm H2O)	Variation (in H2O)			Ko (value)
16.929	479.4		16.535	468.3	17.276	0.977	-0.016		1.838	46.67	0.033			0.717
14.467	409.7		14.388	407.5	14.825	0.995	0.002		1.769	44.92	-0.036			0.719
11.241	318.4		11.111	314.7	11.480	0.988	-0.004		1.775	45.08	-0.030			0.723
10.807	306.0		10.909	308.9	11.145	1.009	0.017		1.719	43.67	-0.086			0.720
9.526	269.8		9.464	268.0	9.806	0.994	0.001		1.925	48.88	0.120			0.692
Average Y----->						0.9925	Average dH@----->		1.805	45.8	Average Ko---->		0.714	

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Results		
		Variation (degF)	Percent of Absolute	
32	32	0	0.00%	
100	100	0	0.00%	
300	300	0	0.00%	
500	500	0	0.00%	
1000	1000	0	0.00%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.  
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 dm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.  
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: \_\_\_\_\_

Date: January 4, 2021

# A.Lanfranco & Associates inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

Model #: **JU 14**  
Serial #: **0028-030615-1**

Date: **05-Jan-21**  
Barometric Pressure: **29.88** (in. Hg)  
Theoretical Critical Vacuum: **14.09** (in. Hg)

!!!!!!!  
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>((in.Hg)<sup>2</sup>(min)).  
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
4.15	32.00	987.300	1021.299	33.999	70.0	70.0	74.0	74.0	73	0.8185	16.0	69.0	78.0	73.5
2.15	21.00	21.600	37.757	16.157	75.0	75.0	76.0	76.0	63	0.5956	17.0	80.0	80.0	80.0
1.30	21.00	38.600	51.239	12.639	76.0	76.0	77.0	77.0	55	0.4606	18.5	82.0	82.0	82.0
0.76	21.00	51.600	61.225	9.625	76.0	76.0	76.0	76.0	48	0.3560	19.5	84.0	84.0	84.0
0.36	15.00	61.500	66.239	4.739	76.0	76.0	78.0	78.0	40	0.2408	21.0	84.0	82.0	83.0

***** RESULTS *****														
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----					
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y			CALIBRATION FACTOR dH@					
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)		Value (in H2O)	Value (mm H2O)	Variation (in H2O)			Ko (value)
34.029	963.7		33.883	959.6	34.296	0.996	-0.005		2.064	52.42	0.012			0.669
15.987	452.8		16.083	455.5	16.477	1.006	0.005		2.030	51.57	-0.021			0.669
12.457	352.8		12.414	351.6	12.766	0.997	-0.004		2.057	52.24	0.005			0.672
9.483	268.5		9.577	271.2	9.885	1.010	0.009		2.022	51.36	-0.030			0.669
4.656	131.8		4.632	131.2	4.771	0.995	-0.006		2.086	52.97	0.034			0.669
Average Y----->						1.0006	Average dH@----->		2.052	52.1	Average Ko---->		0.670	

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Results		
		Variation (degF)	Percent of Absolute	
32	32	0	0.00%	
100	100	0	0.00%	
300	300	0	0.00%	
500	500	0	0.00%	
1000	1000	0	0.00%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.  
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 dm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.  
For Temperature Devices, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: 

Date: January 5, 2021

# A.Lanfranco & Associates inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

Model #: CAE JO99  
Serial #: 0028-022210-1

Date: 06-Jan-21  
Barometric Pressure: 30.18 (in. Hg)  
Theoretical Critical Vacuum: 14.24 (in. Hg)

!!!!!!!  
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>((in.Hg)<sup>2</sup>(min)).  
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.60	45.00	402.300	448.616	46.316	58.0	58.0	67.0	67.0	73	0.8185	16.5	75.0	81.0	78.0
1.90	19.00	450.400	464.811	14.411	67.0	67.0	70.0	70.0	63	0.5956	19.5	81.0	80.0	80.5
1.15	15.00	392.400	401.338	8.938	71.0	71.0	72.0	72.0	55	0.4606	21.5	71.0	75.0	73.0
0.66	16.00	465.100	472.274	7.174	70.0	70.0	71.0	71.0	48	0.3560	23.5	80.0	81.0	80.5
0.33	22.00	472.500	479.319	6.819	71.0	71.0	72.0	72.0	40	0.2408	24.5	78.0	85.0	81.5

***** RESULTS *****														
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----					
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR			CALIBRATION FACTOR					
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)	Y	Value (in H2O)	Value (mm H2O)	Variation (in H2O)	dH@		Ko (value)
47.605	1348.2		47.925	1357.2	48.431	1.0067	-0.003		1.820	46.22	0.008			0.712
14.584	413.0		14.690	416.0	14.914	1.0073	-0.003		1.802	45.76	-0.011			0.716
8.978	254.3		9.032	255.8	9.042	1.0060	-0.004		1.788	45.41	-0.024			0.721
7.211	204.2		7.394	209.4	7.507	1.0254	0.015		1.745	44.33	-0.067			0.716
6.836	193.6		6.871	194.6	6.988	1.0051	-0.005		1.907	48.44	0.095			0.699
Average Y----->						1.0101	Average dH@----->		1.812	46.0	Average Ko----->		0.713	

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Results		
		Variation (degF)	Percent of Absolute	
32	32	0	0.00%	
100	100	0	0.00%	
300	300	0	0.00%	
500	500	0	0.00%	
1000	1000	0	0.00%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.  
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 dm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.  
For Temperature Devices, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Scott Ferguson

Signature: 

Date: January 6, 2021

# A. Lanfranco & Associates inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

Model #: **LMU-B**  
Serial #: **Wizit 6276**

Date: **07-Jan-21**  
Barometric Pressure: **30.17** (in. Hg)  
Theoretical Critical Vacuum: **14.23** (in. Hg)

!!!!!!!

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)\*(min)).

!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (m³)	Volume Final (m³)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
0.00	20.00	125.0520	125.3036	8.885	59.0	59.0	64.0	64.0	48	0.3560	20.0	57.0	63.0	60.0
0.00	23.00	125.3050	125.5968	10.305	64.0	64.0	69.0	69.0	48	0.3560	20.0	63.0	67.0	65.0
0.00	23.00	125.6000	125.8940	10.383	69.0	69.0	70.0	70.0	48	0.3560	20.0	67.0	69.0	68.0

***** RESULTS *****											
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----		
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR			CALIBRATION FACTOR		
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Y Variation (number)		Value (in H2O)	dH@ Value (mm H2O)	Variation (in H2O)
9.067	256.8		9.420	266.8	9.204	1.039	0.004		0.000	0.00	0.000
10.416	295.0		10.781	305.3	10.636	1.035	0.000		0.000	0.00	0.000
10.435	295.5		10.751	304.5	10.666	1.030	-0.005		0.000	0.00	0.000
Average Y----->						1.0347		Average dH@----->	0.0000	0.00	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.

For Temperature Devicee, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Justin Ching

Signature: \_\_\_\_\_



Date: January 7, 2021

## Pitot Tube Calibration

Date: 01-Jan-21  
Pbar (in.Hg): 29.69

Temp (R): 530  
Dn (in.): 0.25

Pitot ID: **7A-1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.050	0.070	14.9	0.8367	0.0148
0.150	0.200	25.7	0.8574	0.0058
0.250	0.340	33.2	0.8489	0.0026
0.450	0.600	44.6	0.8574	0.0058
0.600	0.800	51.5	0.8574	0.0058
Average :			0.8515	0.0070

Pitot ID: **ST 8A**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.060	0.085	16.3	0.8318	0.0069
0.115	0.160	22.5	0.8393	0.0006
0.360	0.490	39.9	0.8486	0.0099
0.590	0.820	51.0	0.8398	0.0011
0.660	0.930	54.0	0.8340	0.0047
Average :			0.8387	0.0046

Pitot ID: **7A**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.050	0.070	14.9	0.8367	0.0056
0.190	0.260	29.0	0.8463	0.0040
0.240	0.330	32.6	0.8443	0.0020
0.500	0.690	47.0	0.8427	0.0005
0.650	0.900	53.6	0.8413	0.0009
Average :			0.8423	0.0026

Pitot ID: **ST 8B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.030	0.040	11.5	0.8574	0.0067
0.150	0.200	25.7	0.8574	0.0067
0.240	0.340	32.6	0.8318	0.0189
0.460	0.610	45.1	0.8597	0.0090
0.630	0.860	52.8	0.8473	0.0034
Average :			0.8507	0.0089

Pitot ID: **AL GVRD 1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.060	0.085	16.3	0.8318	0.0172
0.140	0.190	24.9	0.8498	0.0008
0.230	0.310	31.9	0.8527	0.0038
0.410	0.550	42.6	0.8548	0.0058
0.680	0.910	54.8	0.8558	0.0068
Average :			0.8490	0.0069

Pitot ID: **ST 8C**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.070	0.100	17.6	0.8283	0.0051
0.250	0.350	33.2	0.8367	0.0033
0.300	0.420	36.4	0.8367	0.0033
0.450	0.650	44.6	0.8237	0.0096
0.650	0.900	53.6	0.8413	0.0080
Average :			0.8334	0.0059

Pitot ID: **7C**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.045	0.060	14.1	0.8574	0.0079
0.120	0.160	23.0	0.8574	0.0079
0.250	0.340	33.2	0.8489	0.0005
0.490	0.680	46.5	0.8404	0.0090
0.660	0.910	54.0	0.8431	0.0063
Average :			0.8494	0.0063

Pitot ID:

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
Average :				

\* Average absolute deviation must not exceed 0.01.

Calibrated by: Michael Goods

Signature: 

Date: January 1, 2021



ENVIRONMENTAL CONSULTANTS

GLASS NOZZLE DIAMETER CALIBRATION FORM

Signature:

(c) Average = average of D1, D2 and D3

## TEMPERATURE CALIBRATION FORM

Signature:

Peri Ag...

## TEMPERATURE DEVICE CALIBRATIONS

Reference Device			Temperature Settings (degrees F)													
Model CL23A Calibrator			32		100		200		300		500		800		1700	
Device	ALA #	Serial #	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation
Omega HH11A	3	300132	32.3	0.06%	99.3	-0.13%	200	0.00%	301	0.13%	498	-0.21%	798	-0.16%	1698	-0.09%
Omega HH11A	4	200167		-6.51%		-17.87%		-30.32%		-39.49%		-52.10%		-63.51%		-78.72%
Omega HH11A	6	600059	33.1	0.22%	100	0.00%	202	0.30%	302	0.26%	499	-0.10%	798	-0.16%	1697	-0.14%
TPI 341K	7	2.0315E+10	30.5	-0.31%	98.3	-0.30%	198.1	-0.29%	298	-0.26%	497	-0.31%	796.4	-0.29%	1693	-0.32%
TPI 341K	8	2.0313E+10	32.1	0.02%	99.3	-0.13%	200.5	0.08%	299.9	-0.01%	499.3	-0.07%	798.7	-0.10%	1696	-0.19%
Cont Cmpny	10	102008464	30.2	-0.37%	97.5	-0.45%	197.8	-0.33%	297.7	-0.30%	497.7	-0.24%	795.9	-0.33%	1693.8	-0.29%
Omega HH11	14	409426		-6.51%		-17.87%		-30.32%		-39.49%		-52.10%		-63.51%		-78.72%
TPI 341K	16	400120029	30.7	-0.26%	99	-0.18%	199.4	-0.09%	299.2	-0.11%	499.6	-0.04%	800.2	0.02%	1703	0.14%
TPI 341K	18	2.0329E+10	31	-0.20%	98.9	-0.20%	198.9	-0.17%	298.7	-0.17%	498.5	-0.16%	798.4	-0.13%	1698	-0.09%
TPI 341K	20	2.0329E+10	30	-0.41%	98.2	-0.32%	198.1	-0.29%	297.7	-0.30%	497.2	-0.29%	797.1	-0.23%	1696	-0.19%
TPI 341K	22	2.0329E+10	30.5	-0.31%	98.6	-0.25%	198.5	-0.23%	298.3	-0.22%	497.7	-0.24%	797.4	-0.21%	1696	-0.19%
Reference device is a NIST certified digital thermocouple calibrator																
Variation expressed as a percentage of the absolute temperature must be within 1.5 %																

# BAROMETER CALIBRATION FORM

Device	Cal Date	Pbar Env Canada		Device (inches of Hg)		Difference
		(kPa)	(inches of Hg)	Reading	Elevation Corrected	(Env Can - Elv Corr)
LA	6-Jan-21	101.8	30.07	29.94	30.01	0.05
DS	6-Jan-21	101.8	30.07	29.94	30.01	0.05
CL	6-Jan-21	101.8	30.07	29.94	30.01	0.05
ML	6-Jan-21	101.8	30.07	29.91	29.98	0.08
SB	6-Jan-21	101.8	30.07	29.93	30.00	0.06
SH	6-Jan-21	101.8	30.07	29.95	30.02	0.04
MG	6-Jan-21	101.8	30.07	29.94	30.01	0.05
SF	6-Jan-21	101.8	30.07	29.91	29.98	0.08
JG	6-Jan-21	101.8	30.07	29.89	29.96	0.10
JC	6-Jan-21	101.8	30.07	29.93	30.00	0.06
CNL	6-Jan-21	101.8	30.07	30.08	30.15	-0.09

Calibrated by: Jeremy Gibbs

Signature: 

Date: 06-Jan-21

## Performance Specification is

**Device Corrected for Elevation must be +/- 0.1 " Hg of ENV CANADA SEA-LEVEL Pbar**

Enter Environment Canada Pressure from their website for Vancouver (link below)  
and the reading from your barometer on the ground floor of the office.

[https://weather.gc.ca/city/pages/bc-74\\_metric\\_e.html](https://weather.gc.ca/city/pages/bc-74_metric_e.html)

# Calibration Certificate

**Date:** 19-Jan-21  
**Calibrated by:** Scott Ferguson  
**Authorizing Signature:** 

**Instrument Calibrated:** Testo 1 (330-2LL)  
**Serial #:** 03101345  
**Customer:** ALA

**Ambient Conditions:** Temperature: 9 °C Barometric Pressure: 102.3 kPa Relative Humidity: 90%

A. Lanfranco and Associates Inc. certifies that the described instrument has been inspected and tested following calibration procedures in the Environment Canada Report EPS 1/PG/7 (Revised 2005). Below are the observed readings after calibrations are complete. Calibration checks should be completed at least every 6 months.

<b>O<sub>2</sub></b>	<b>Initial Evaluation</b>				<b>After Calibration</b>				<b>Certified Value</b>
<b>Gas</b>	<b>Instrument Reading (vol %)</b>	<b>% Calibration Error</b>	<b>Pass/Fail</b>	<b>Notes</b>	<b>Instrument Reading (vol %)</b>	<b>% Calibration Error</b>	<b>Pass/Fail</b>	<b>Notes</b>	<b>(vol %)</b>
Zero	0.3	0.30	Pass		0	0.00	Pass		0
O <sub>2</sub>	10.9	0.07	Pass	Recal on Amb	11.0	0.03	Pass		10.97
Ambient	21.1	0.15	Pass		21.0	0.00	Pass		20.95

Performance Specification: +/- 1% O<sub>2</sub> (absolute diff)

<b>CO</b>	<b>Initial Evaluation</b>				<b>After Calibration</b>				<b>Certified Value</b>
<b>Gas</b>	<b>Instrument Reading (ppm)</b>	<b>% Calibration Error</b>	<b>Pass/Fail</b>	<b>Notes</b>	<b>Instrument Reading (ppm)</b>	<b>% Calibration Error</b>	<b>Pass/Fail</b>	<b>Notes</b>	<b>(ppm)</b>
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	279	11.2%	Fail	Recal w 2 Gas	251	0.0%	Pass		251
2 Gas	1990	3.6%	Pass		1918	0.1%	Pass		1920

Performance Specification: +/- 5% of Certified Gas Value

<b>NO</b>	<b>Initial Evaluation</b>				<b>After Calibration</b>				<b>Certified Value</b>
<b>Gas</b>	<b>Instrument Reading (ppm)</b>	<b>% Calibration Error</b>	<b>Pass/Fail</b>	<b>Notes</b>	<b>Instrument Reading (ppm)</b>	<b>% Calibration Error</b>	<b>Pass/Fail</b>	<b>Notes</b>	<b>(ppm)</b>
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	45	1.3%	Pass		46	0.9%	Pass		46
2 Gas	102	0.9%	Pass	Recal w 2 Gas	103	0.1%	Pass		102.9

Performance Specification: +/- 5% of Certified Gas Value

## NIST Traceable Calibration Gases:

<b>Cylinder</b>	<b>Cylinder ID Number</b>	<b>Certification Date</b>	<b>Expiration Date</b>	<b>Cylinder Pressure (PSI)</b>	<b>O<sub>2</sub> (Vol. %)</b>	<b>CO (ppm)</b>	<b>NO (ppm)</b>
Zero Gas (N <sub>2</sub> )	340943	21/Jan/2020	24/Aug/2021	500	0	0	0
1 Gas	CC14093	5/Aug/2019	6/Aug/2027	900	-	251	45.6
2 Gas	CC711737	24/Feb/2020	25/Feb/2028	800	-	1920	102.9
O <sub>2</sub> /CO <sub>2</sub>	CC168470	27/Jul/2020	28/Jul/2028	1500	10.97	-	-

Note: National Institute of Standards and Technology traceable certificates are available upon request.

# Calibration Certificate

**Date:** 18-Jan-21  
**Calibrated by:** Scott Ferguson  
**Authorizing Signature:** 

**Instrument Calibrated:** Testo 2 (330-2LX)  
**Serial #:** 03282252  
**Customer:** ALA

**Ambient Conditions:** Temperature: 8 °C Barometric Pressure: 101.8 kPa Relative Humidity: 92%

A. Lanfranco and Associates Inc. certifies that the described instrument has been inspected and tested following calibration procedures in the Environment Canada Report EPS 1/PG/7 (Revised 2005). Below are the observed readings after calibrations are complete. Calibration checks should be completed at least every 6 months.

<b>O<sub>2</sub></b>	<b>Initial Evaluation</b>				<b>After Calibration</b>				<b>Certified Value</b>
<b>Gas</b>	<b>Instrument Reading (vol %)</b>	<b>% Calibration Error</b>	<b>Pass/Fail</b>	<b>Notes</b>	<b>Instrument Reading (vol %)</b>	<b>% Calibration Error</b>	<b>Pass/Fail</b>	<b>Notes</b>	<b>(vol %)</b>
Zero	0.1	0.10	Pass		0	0.00	Pass		0
O <sub>2</sub>	11.0	0.16	Pass		10.9	0.01	Pass		10.84
Ambient	21.1	0.14	Pass	Recal	21.0	0.04	Pass		20.96

Performance Specification: +/- 1% O<sub>2</sub> (absolute diff)

<b>CO</b>	<b>Initial Evaluation</b>				<b>After Calibration</b>				<b>Certified Value</b>
<b>Gas</b>	<b>Instrument Reading (ppm)</b>	<b>% Calibration Error</b>	<b>Pass/Fail</b>	<b>Notes</b>	<b>Instrument Reading (ppm)</b>	<b>% Calibration Error</b>	<b>Pass/Fail</b>	<b>Notes</b>	<b>(ppm)</b>
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	1932	0.6%	Pass		1921	0.1%	Pass		1920
2 Gas	259	3.1%	Pass	Recal	251	0.1%	Pass		251

Performance Specification: +/- 5% of Certified Gas Value

<b>NO</b>	<b>Initial Evaluation</b>				<b>After Calibration</b>				<b>Certified Value</b>
<b>Gas</b>	<b>Instrument Reading (ppm)</b>	<b>% Calibration Error</b>	<b>Pass/Fail</b>	<b>Notes</b>	<b>Instrument Reading (ppm)</b>	<b>% Calibration Error</b>	<b>Pass/Fail</b>	<b>Notes</b>	<b>(ppm)</b>
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	102	0.9%	Pass	Recal	103	0.1%	Pass		103
2 Gas	46	0.9%	Pass		46	0.9%	Pass		45.61

Performance Specification: +/- 5% of Certified Gas Value

## NIST Traceable Calibration Gases:

<b>Cylinder</b>	<b>Cylinder ID Number</b>	<b>Certification Date</b>	<b>Expiration Date</b>	<b>Cylinder Pressure (PSI)</b>	<b>O<sub>2</sub> (Vol. %)</b>	<b>CO (ppm)</b>	<b>NO (ppm)</b>
Zero Gas (N <sub>2</sub> )	340943	21/Jan/2020	21/Aug/2024	500	0	0	0
1 Gas	CC711737	24/Feb/2020	25/Feb/2028	800	-	1920	102.9
2 Gas	CC140943	5/Aug/2019	6/Aug/2027	900	-	251.3	45.61
O <sub>2</sub> /CO <sub>2</sub>	CC168470	27/Jul/2020	28/Jul/2028	1500	10.84	-	-

Note: National Institute of Standards and Technology traceable certificates are available upon request.

Calibration Certificate

Date:  
Calibrated by:  
Authorizing Signature:

10-May-21

Scott Ferguson

Daryl Sampson

Insrtument Calibrated:  
Serial #:  
Customer:

Viasensor G200  
IN12898  
ALA

Ambient Conditions:  
A. Lanfranco and Associates Inc. certifies that the described instrument has been inspected and tested following calibration procedures in the Environment Canada Report EPS 1/PG/7 (Revised 2005). Below are the observed readings after calibrations are complete. Calibration checks should be completed at least every 6 months.

Temperature:17 °C

Barometric Pressure: 100.9 kPa

Relative Humidity: 62%

N <sub>2</sub> O Gas	Initial Calibration		Final Calibration		Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Instrument Reading (ppm)	% Calibration Error	
Zero	5.0	5.0	0	0.00	0
1 Gas	90.5	1.8	92.0	0.22	92.20
2 Gas	39.2	4.6	41.0	0.24	41.1

Performance Specification: +/- 5% of Certified Gas Value

NIST Traceable Calibration Gases:

Cylinder	Cylinder ID Number	Certification Date	Expiration Date	Cylinder Pressure (PSI)	N <sub>2</sub> O (ppm)
Zero Gas (N <sub>2</sub> )	340943	21/Jan/2020	21/Aug/2024	500	0
1 Gas	FF58284	31/Oct/2020	30/Oct/2023	1900	92.2
2 Gas	FF62315	31/Oct/2020	30/Oct/2023	1900	41.1

Note: National Institute of Standards and Technology traceable certificates are available upon request.



# **MOUNT ROYAL COLLEGE**

**Faculty of Continuing Education and Extension**

**Carter Lanfranco**

has successfully completed

**Stack Sampling**

**May 2009**

Date

Dean  
Faculty of Continuing Education and Extension

# MOUNT ROYAL UNIVERSITY

Faculty of Continuing Education and Extension

**Scott Ferguson**

has successfully completed

**Stack Sampling**

2016

May 16, 2016

*Date*



*Dean*

*Faculty of Continuing Education and Extension*





## Conflict of Interest Disclosure Statement

A qualified professional<sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

## Declaration

I Carter Lanfranco, as a member of Air and Waste Management Association  
declare

### **Select one of the following:**

☒ Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.

☐ Real or perceived conflict of interest

Description and nature of conflict(s):

---

---

---

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

---

---

---

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

X

Print name: Carter Lanfranco

Witnessed by:

X

Print name: Mark Lanfranco

Date: Dec. 16, 2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.



## Conflict of Interest Disclosure Statement

A qualified professional<sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

### Declaration

I Shawn Harrington as a member of Air and Waste Management Association  
declare

#### **Select one of the following:**

- ☒ Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas

, erring on the side of caution.



☐ Real or perceived conflict of interest

Description and nature of conflict(s):

---

---

---

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

---

---

---

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

x Shawn Harrington

Print name: Shawn Harrington

Date: Dec. 16, 2020

Witnessed by:

x Mark Lanfranco

Print name: Mark Lanfranco

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.



## A. LANFRANCO and ASSOCIATES INC.


ENVIRONMENTAL CONSULTANTS

### Confidentiality and Impartiality Agreement

**Confidentiality** is legally enforceable in our client contracts for all projects and ensures that our firm, its personnel, and any outsourced bodies treat all information obtained or created during our scope of work as confidential. Our firm does not disclose information that is not public regarding a client or responsible party to a third party without express consent of that party. Our firm informs the client and responsible party before placing any information in the public domain and will use equipment and facilities to ensure the secure handling of confidential information.

**Impartiality** Our firm's policies and procedures regarding conflict of interest (COI) and safeguarding impartiality reflects the commitment to act impartially in all activities. Our firm understands that the principles of COI and impartiality are essential to providing independent services. Our team is required to personally declare any potential threat to impartiality or potential COI. Should a potential COI or threat to impartiality be identified, our team will work to determine mitigation measures, if applicable.

This agreement is made by and between

  
\_\_\_\_\_  
Scott Ferguson  
AND  
(1<sup>st</sup> Party)

A. Lanfranco and Associates Inc.  
\_\_\_\_\_  
(2<sup>nd</sup> Party)

As of NOV. 24, 2020

### Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional Scott Ferguson  
Title Environmental Technician
2. Are you a registered member of a professional association in B.C.? ☒ Yes ☐ No  
Name of Association: ASTTBC Registration # 29114
3. Brief description of professional services:  
Environmental consulting, specializing in air and atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

### Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature:

x 

Print Name: Scott Ferguson

Witnessed by:

x 

Print Name: Michael Goods

Date signed: 11/23/2020

<sup>1</sup> *Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who*

- a) *is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and*
- b) *through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.*



### Declaration of Competency


The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.


1. Name of Qualified Professional Shawn Harrington  
Title Senior Environmental Technician /Project manager
2. Are you a registered member of a professional association in B.C.? ☐ Yes ☒ No  
Name of Association: \_\_\_\_\_ Registration # \_\_\_\_\_
3. Brief description of professional services:  
Environmental consulting ,specializing in air and atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

### Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature:   
Print Name: Shawn Harrington

Witnessed by:   
Print Name: Mark Lanfranco

Date signed: November 26, 2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.



### Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional Carter Lanfanco  
Title Chief operations officer / anet
2. Are you a registered member of a professional association in B.C.? ☐ Yes ☒ No  
Name of Association: \_\_\_\_\_ Registration # \_\_\_\_\_
3. Brief description of professional services:  
\_\_\_\_\_  
\_\_\_\_\_

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

### Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature: [Signature]  
X [Signature]  
Print Name: Carter Lanfanco

Witnessed by: [Signature]  
X [Signature]  
Print Name: Shawn Harrington

Date signed: Dec. 7/2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.