



**A.Lanfranco
& Associates Inc.**

Environmental Consultants

Prepared for

METRO VANCOUVER

Metrotower III

4515 Central Boulevard

Burnaby, BC V5H 0C6

WASTE-TO-ENERGY FACILITY

Appendices of Emissions Testing Report

July 2023 Survey

Third Quarter 2023

Table of Contents

Appendix

- A Quality Assurance / Quality Control Results
- B Laboratory Results
- C Computer Generated Results
- D Field Data Sheets
- E Calibration Sheets and Technician Certificates

APPENDIX – A

QUALITY ASSURANCE / QUALITY CONTROL RESULTS

Quality assurance / quality control (QA/QC) is divided into four categories: administration, preparation, testing, and analysis. The following sections detail results found for the above four categories.

Administration:

- All field, process, and analytical data was reviewed to ensure data integrity and accuracy.
- Duplicate proof of draft and final report, including data entry, conducted.

Preparation:

- All glassware cleaned
- Blank samples of reagents collected.

Testing:

- Stack diameter and absence of cyclonic flow confirmed
- Calibrated magnehelic used for all velocity measurements
- All trains past pre- and post- leak checks.
- Isokinetics all within $100\% \pm 10\%$.

Analysis:

- Trace Metals and Mercury analysis conducted at Element Labs, Surrey, B.C.
- Fluoride (HF) analysis conducted at ALS Environmental in Burnaby, B.C.
- Nitrous Oxide (N₂O) analysis conducted with portable analyzer by A. Lanfranco and Associates.
- Particulate analysis conducted at A. Lanfranco and Associates Inc., Surrey, BC.
- Chain of Custody protocols followed for all samples.
- Acceptable blank values for all sample types. All samples blank corrected.

Sample Type	Blank Value		
	Unit 1	Unit 2	Unit 3
Third Quarter 2023			
Filter	-0.2 mg	-0.3 mg	-0.3 mg
Front Half Washings	0.3 mg	0.4 mg	0.8 mg
Mercury Front	<0.02 ug	<0.02 ug	<0.02 ug
Mercury Back	<0.179 ug	<0.17 ug	<0.17 ug
Trace Metals Front *	<20.7 ug	<16.6 ug	<17.5 ug
Trace Metals Back*	<50.6 ug	<32.8 ug	<36.6 ug
Hexavalent Chromium	N/A	N/A	<0.42 ug
Ammonia	24.0 ug	30.8 ug	74.4 ug
Fluoride	<9 ug	<9 ug	<9 ug

Sum of all reported elements except Hg*

APPENDIX - B

LABORATORY RESULTS

Appendix B - Particulate Analysis

Client: Metro Vancouver
Source: Units 1, 2, and 3

Sample Date: July 17-19, 2023
Location: WTE (Burnaby, B.C)

A. Lanfranco & Associates Standard Operating Procedure:

SOP 1.2.1 Gravimetric determination of total particulate matter

Filter Collection:

Test #	Initial (grams)	Final (grams)	Net Difference (grams)	Blank Adjusted (grams)
Unit 1 Blank	0.4721	0.4719	-0.0002	
Unit 1 Run 1	0.4644	0.4657	0.0013	0.0015
Unit 1 Run 2	0.4707	0.4709	0.0002	0.0004
Unit 1 Run 3	0.4696	0.4721	0.0025	0.0027
Unit 2 Blank	0.4701	0.4698	-0.0003	
Unit 2 Run 1	0.4720	0.4725	0.0005	0.0008
Unit 2 Run 2	0.4707	0.4705	-0.0002	0.0001
Unit 2 Run 3	0.4723	0.4720	-0.0003	ND
Unit 3 Blank	0.4682	0.4679	-0.0003	
Unit 3 Run 1	0.4690	0.4688	-0.0002	0.0001
Unit 3 Run 2	0.4649	0.4645	-0.0004	ND
Unit 3 Run 3	0.4675	0.4673	-0.0002	0.0001

Front Half Washings:

Test #	Initial (grams)	Final (grams)	Net Difference (grams)	Blank Adjusted (grams)
Unit 1 Blank	121.3312	121.3315	0.0003	
Unit 1 Run 1	102.5385	102.5407	0.0022	0.0019
Unit 1 Run 2	119.7614	119.7624	0.0010	0.0007
Unit 1 Run 3	97.5815	97.5843	0.0028	0.0025
Unit 2 Blank	114.3624	114.3628	0.0004	
Unit 2 Run 1	119.9498	119.9512	0.0014	0.0010
Unit 2 Run 2	92.7510	92.7530	0.0020	0.0016
Unit 2 Run 3	117.7445	117.7457	0.0012	0.0008
Unit 3 Blank	121.7993	121.8001	0.0008	
Unit 3 Run 1	87.9211	87.9225	0.0014	0.0006
Unit 3 Run 2	95.9996	96.0003	0.0007	ND
Unit 3 Run 3	123.7626	123.7635	0.0009	0.0001

Task	Unit	Personnel	Date	Quality Control	Y/N
Filter Recovery:	Unit 1	S.Harrington	17+19-July-23	Adequate PW volume:	Y
	Unit 2	S.Harrington	18-Jul-23	No sample leakage:	Y
	Unit 3	S.Harrington	19-20-July-23	Filter not compromised:	Y
PW Initial Analysis:	Unit 1	J. Ching	24-Jul-23		
	Unit 2	J. Ching	24-Jul-23		
	Unit 3	J. Ching	24-Jul-23		
PW, FilterFinal Analysis:	Unit 1	J. Ching	26-Jul-23		
	Unit 2	J. Ching	26-Jul-23		
	Unit 3	J. Ching	26-Jul-23		
Data entered to computer:	All	C. Lanfranco	21-Aug-23		

Comments:

No problems encountered in sample analysis.

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Filter Reagent Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668174**
Control Number:
Date Received: Jul 26, 2023
Date Reported: Aug 17, 2023
Report Number: 2898281

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

Notes To Clients:

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Filter Reagent Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668174**
Control Number:
Date Received: Jul 26, 2023
Date Reported: Aug 17, 2023
Report Number: 2898281

		Reference Number	1668174-1	1668174-2	1668174-3
		Sample Date	Jul 17, 2023	Jul 17, 2023	Jul 17, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Reagent Blank Unit 1 Container 1 (filter)	Reagent Blank Unit 2 Container 1 (filter)	Reagent Blank Unit 3 Container 1 (filter)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	<5	<5	<5	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<1	2	2	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	0.2	<0.2	0.63	0.2
Cobalt	µg	<0.3	0.8	<0.3	0.25
Copper	µg	<0.3	<0.3	<0.3	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	<0.3	<0.3	<0.3	0.25
Nickel	µg	0.5	0.6	<0.5	0.5
Phosphorus	µg	20	10	20	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<2	5.3	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	1	1.0	2	0.5
Mercury by CVAA					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	250	250	250
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02

Approved by:



Max Hewitt
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Filter Reagent Blanks Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1668174 Control Number: Date Received: Jul 26, 2023 Date Reported: Aug 17, 2023 Report Number: 2898281
Attn: Missy Sampled By: Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Aug 16, 2023	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Jul 31, 2023	Element Vancouver

** Reference Method Modified*

References

EMC	Emission Measurement Center of EPA
-----	------------------------------------

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Reagent Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668178**
Control Number:
Date Received: Jul 26, 2023
Date Reported: Aug 17, 2023
Report Number: 2898285

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

Notes To Clients:

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Reagent Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668178**
Control Number:
Date Received: Jul 26, 2023
Date Reported: Aug 17, 2023
Report Number: 2898285

Reference Number	1668178-1	1668178-2	1668178-3
Sample Date	Jul 17, 2023	Jul 17, 2023	Jul 17, 2023
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Reagent Blank Unit 1	Reagent Blank Unit 2	Reagent Blank Unit 3

		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A						
Aluminum		µg	<5	<5	<5	5
Antimony		µg	4	<2	6	2.5
Arsenic		µg	<1	1	<1	1
Cadmium		µg	<0.3	<0.3	<0.3	0.25
Chromium		µg	0.97	0.79	<0.2	0.2
Cobalt		µg	<0.3	0.6	<0.3	0.25
Copper		µg	0.9	<0.3	<0.3	0.25
Lead		µg	<2	<2	<2	1.5
Manganese		µg	<0.3	<0.3	<0.3	0.25
Nickel		µg	<0.5	<0.5	<0.5	0.5
Phosphorus		µg	<2	5	<2	2.5
Selenium		µg	<2	<2	<2	1.5
Tellurium		µg	<2	3.8	<2	2
Thallium		µg	3.3	3.0	<2	1.5
Vanadium		µg	<1	<1	<1	1
Zinc		µg	2	1.0	1	0.5
Back Half Metals Fraction 2A						
Aluminum		µg	6	<5	<5	5
Antimony		µg	<3	<3	3	2.5
Arsenic		µg	1	2	<1	1
Cadmium		µg	<0.3	<0.3	<0.3	0.25
Chromium		µg	<0.2	<0.2	0.50	0.2
Cobalt		µg	<0.3	<0.3	<0.3	0.25
Copper		µg	<0.3	<0.3	<0.3	0.25
Lead		µg	<2	<2	<2	1.5
Manganese		µg	0.3	0.4	0.3	0.25
Nickel		µg	<0.5	<0.5	1.0	0.5
Phosphorus		µg	26	32	41	2.5
Selenium		µg	3.2	12	7.1	1.5
Tellurium		µg	<2	<2	<2	2
Thallium		µg	<2	<2	<2	1.5
Vanadium		µg	1	<1	1	1
Zinc		µg	5.7	4.8	4.6	0.5
Volume	Sample	mL	213	215	212	
Volume	aliquot volume	mL	163	165	162	
Mercury by CVAA						
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	250	250	250	

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Reagent Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668178**
Control Number:
Date Received: Jul 26, 2023
Date Reported: Aug 17, 2023
Report Number: 2898285

		Reference Number	1668178-1	1668178-2	1668178-3
		Sample Date	Jul 17, 2023	Jul 17, 2023	Jul 17, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Reagent Blank Unit 1	Reagent Blank Unit 2	Reagent Blank Unit 3
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Mercury by CVAA - Continued					
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02
Mercury	As Tested	µg/L	<0.05	<0.05	0.07
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	213	215	212
Volume	aliquot volume	mL	5.0	5.0	5.0
Volume	Final	mL	45	45	45
Mercury	Fraction 2B	µg/sample	<0.10	<0.10	0.1
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	99	98	99
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3A	µg/sample	<0.008	<0.008	<0.008
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	500	500	500
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3B	µg/sample	<0.04	<0.04	<0.04
Mercury	As Tested	µg/L	<0.05	<0.05	0.10
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	200	200	200
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3C	µg/sample	<0.02	<0.02	0.03

Approved by:



Max Hewitt
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Reagent Blanks Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1668178 Control Number: Date Received: Jul 26, 2023 Date Reported: Aug 17, 2023 Report Number: 2898285
Attn: Missy Sampled By: Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Aug 16, 2023	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Aug 15, 2023	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Aug 16, 2023	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Aug 15, 2023	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Aug 16, 2023	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Aug 1, 2023	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Jul 31, 2023	Element Vancouver

* Reference Method Modified

References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Field Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668182**
Control Number:
Date Received: Jul 27, 2023
Date Reported: Aug 17, 2023
Report Number: 2898292

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

Notes To Clients:

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Field Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668182**
Control Number:
Date Received: Jul 27, 2023
Date Reported: Aug 17, 2023
Report Number: 2898292

		Reference Number	1668182-1	1668182-2	1668182-3
		Sample Date	Jul 19, 2023	Jul 18, 2023	Jul 20, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Field Blank Unit 1 (MV Unit 1 BLK + 4 Bottles)	Field Blank Unit 2 (MV Unit 2 BLK + 4 Bottles)	Field Blank Unit 3 (MV Unit 3 BLK + 4 Bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	<5	9	<5	5
Antimony	µg	5	<2	4	2.5
Arsenic	µg	<1	2	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	0.72	<0.2	0.39	0.2
Cobalt	µg	<0.3	<0.3	<0.3	0.25
Copper	µg	1	<0.3	<0.3	0.25
Lead	µg	3.3	<2	2	1.5
Manganese	µg	<0.3	<0.3	<0.3	0.25
Nickel	µg	0.7	0.6	<0.5	0.5
Phosphorus	µg	6	3	5	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	2	<2	4.1	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2	2	2	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	<5	<5	<5	5
Antimony	µg	6	<2	2	2.5
Arsenic	µg	3.1	<0.9	<0.9	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	<0.2	<0.2	<0.2	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	<0.2	<0.2	<0.2	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	<0.2	0.7	<0.2	0.25
Nickel	µg	<0.5	<0.5	0.6	0.5
Phosphorus	µg	31	25	20	2.5
Selenium	µg	6.7	<1	4.9	1.5
Tellurium	µg	<2	<2	3.3	2
Thallium	µg	<1	2	<1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	3.8	5.1	5.8	0.5
Volume	Sample	mL	345	372	362
Volume	aliquot volume	mL	295	322	312
Mercury by CVAA					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Field Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668182**
Control Number:
Date Received: Jul 27, 2023
Date Reported: Aug 17, 2023
Report Number: 2898292

		Reference Number	1668182-1	1668182-2	1668182-3	Nominal Detection Limit
		Sample Date	Jul 19, 2023	Jul 18, 2023	Jul 20, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Field Blank Unit 1 (MV Unit 1 BLK + 4 Bottles)	Field Blank Unit 2 (MV Unit 2 BLK + 4 Bottles)	Field Blank Unit 3 (MV Unit 3 BLK + 4 Bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results		
Mercury by CVAA - Continued						
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	345	372	362	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	0.1	<0.1	<0.1	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	108	140	165	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.009	<0.01	<0.01	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	500	500	500	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.04	<0.04	<0.04	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	<0.02	<0.02	<0.02	

Approved by:



Max Hewitt
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Field Blanks Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1668182 Control Number: Date Received: Jul 27, 2023 Date Reported: Aug 17, 2023 Report Number: 2898292
Attn: Missy Sampled By: Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Aug 16, 2023	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Aug 15, 2023	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Aug 16, 2023	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Aug 15, 2023	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Aug 16, 2023	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Aug 1, 2023	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Jul 31, 2023	Element Vancouver

* Reference Method Modified

References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668162**
Control Number:
Date Received: Jul 26, 2023
Date Reported: Aug 17, 2023
Report Number: 2898261

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

Notes To Clients:

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668162**
Control Number:
Date Received: Jul 26, 2023
Date Reported: Aug 17, 2023
Report Number: 2898261

	Reference Number	1668162-1	1668162-2	1668162-3	
	Sample Date	Jul 17, 2023	Jul 19, 2023	Jul 19, 2023	
	Sample Time	NA	NA	NA	
	Sample Location				
	Sample Description	Unit 1 Run 1 (MV Unit 1 Run 1 + 4 Bottles)	Unit 1 Run 2 (MV Unit 1 Run 2 + 4 Bottles)	Unit 1 Run 3 (MV Unit 1 Run 3 + 4 Bottles)	
	Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	37	10	10	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<1	<1	2	1
Cadmium	µg	0.4	<0.3	<0.3	0.25
Chromium	µg	3.39	2.66	23.3	0.2
Cobalt	µg	<0.3	0.7	<0.3	0.25
Copper	µg	2	1	<0.3	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	2	2	2	0.25
Nickel	µg	3.8	4.5	13	0.5
Phosphorus	µg	8	10	10	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<2	3.5	8.2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	17	4.2	7.5	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	20	10	10	5
Antimony	µg	4	3	<2	2.5
Arsenic	µg	<0.9	2.1	1	1
Cadmium	µg	0.3	0.4	<0.2	0.25
Chromium	µg	1.6	1.9	0.74	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	<0.2	0.5	<0.2	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	12	1	0.4	0.25
Nickel	µg	2	1	1	0.5
Phosphorus	µg	33	20	28	2.5
Selenium	µg	6.9	<1	18	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	<0.9	1	<0.9	1
Zinc	µg	7.3	5.0	4.0	0.5
Volume	Sample	mL	800	850	
Volume	aliquot volume	mL	750	835	
Mercury by CVAA					
Mercury	As Tested	µg/L	<0.05	<0.05	0.05

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668162**
Control Number:
Date Received: Jul 26, 2023
Date Reported: Aug 17, 2023
Report Number: 2898261

		Reference Number	1668162-1	1668162-2	1668162-3	Nominal Detection Limit
		Sample Date	Jul 17, 2023	Jul 19, 2023	Jul 19, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 1 Run 1 (MV Unit 1 Run 1 + 4 Bottles)	Unit 1 Run 2 (MV Unit 1 Run 2 + 4 Bottles)	Unit 1 Run 3 (MV Unit 1 Run 3 + 4 Bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results		
Mercury by CVAA - Continued						
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	800	885	850	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	<0.3	<0.4	<0.3	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	150	154	144	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.01	<0.01	<0.01	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	500	1000	500	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.04	<0.08	<0.04	
Mercury	As Tested	µg/L	0.52	0.07	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.17	0.02	<0.02	

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668162**
Control Number:
Date Received: Jul 26, 2023
Date Reported: Aug 17, 2023
Report Number: 2898261

		Reference Number	1668162-4	1668162-5	1668162-6
		Sample Date	Jul 18, 2023	Jul 18, 2023	Jul 18, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit 2 Run 1 (MV Unit 2 Run 1 + 4 Bottles)	Unit 2 Run 2 (Unit - 2 Run 2 + 4 Bottles)	Unit 2 Run 3 (Unit - 2 Run 3 + 4 Bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A					
Aluminum	µg	8	8	9	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<1	1	3.7	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	17.7	2.4	1.7	0.2
Cobalt	µg	0.3	<0.3	0.3	0.25
Copper	µg	<0.3	<0.3	<0.3	0.25
Lead	µg	2.9	2	<2	1.5
Manganese	µg	1	1	0.3	0.25
Nickel	µg	2	4.0	2.7	0.5
Phosphorus	µg	10	5	10	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	5.4	<2	2
Thallium	µg	<2	4.0	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	5.6	4.4	3.4	0.5
Back Half Metals Fraction 2A					
Aluminum	µg	26	10	20	5
Antimony	µg	<2	6	2	2.5
Arsenic	µg	<0.8	1	2	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	1.1	<0.2	3.52	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	1	<0.2	1	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	0.9	2	2	0.25
Nickel	µg	2	1	2.3	0.5
Phosphorus	µg	23	20	29	2.5
Selenium	µg	<1	6.9	6.3	1.5
Tellurium	µg	<2	<2	2.2	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	1	1	<0.8	1
Zinc	µg	7.1	8.4	8.2	0.5
Volume	Sample	mL	855	830	885
Volume	aliquot volume	mL	805	780	835
Mercury by CVAA					
Mercury	As Tested	µg/L	<0.05	<0.05	0.05

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668162**
Control Number:
Date Received: Jul 26, 2023
Date Reported: Aug 17, 2023
Report Number: 2898261

		Reference Number	1668162-4	1668162-5	1668162-6	
		Sample Date	Jul 18, 2023	Jul 18, 2023	Jul 18, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 2 Run 1 (MV Unit 2 Run 1 + 4 Bottles)	Unit 2 Run 2 (Unit - 2 Run 2 + 4 Bottles)	Unit 2 Run 3 (Unit - 2 Run 3 + 4 Bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Mercury by CVAA - Continued						
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	855	830	885	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	<0.3	<0.3	<0.4	
Mercury	As Tested	µg/L	0.20	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	160	144	169	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	0.052	<0.01	<0.01	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	1000	500	1000	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.08	<0.04	<0.08	
Mercury	As Tested	µg/L	0.30	0.09	0.25	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.094	0.03	0.080	

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668162**
Control Number:
Date Received: Jul 26, 2023
Date Reported: Aug 17, 2023
Report Number: 2898261

		Reference Number	1668162-7	1668162-8	1668162-9	
		Sample Date	Jul 19, 2023	Jul 20, 2023	Jul 20, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 3 Run 1 (MV Unit 3 Run 1 + 4 Bottles	Unit 3 Run 2 (MV Unit 3 Run 2 + 4 Bottles)	Unit 3 Run 3 (MV Unit 3 Run 3 + 4 Bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Front Half Metals Fraction 1A						
Aluminum		µg	10	5	7	5
Antimony		µg	<2	<2	<2	2.5
Arsenic		µg	<1	<1	<1	1
Cadmium		µg	<0.3	<0.3	0.4	0.25
Chromium		µg	1.9	1.2	2.83	0.2
Cobalt		µg	0.4	<0.3	<0.3	0.25
Copper		µg	2	<0.3	<0.3	0.25
Lead		µg	<2	<2	<2	1.5
Manganese		µg	1	0.7	0.9	0.25
Nickel		µg	8.0	3.4	3.8	0.5
Phosphorus		µg	10	10	20	2.5
Selenium		µg	<2	<2	<2	1.5
Tellurium		µg	5.4	<2	<2	2
Thallium		µg	2	13	5.8	1.5
Vanadium		µg	<1	<1	<1	1
Zinc		µg	15	11	14	0.5
Back Half Metals Fraction 2A						
Aluminum		µg	10	7	9	5
Antimony		µg	<2	4	<2	2.5
Arsenic		µg	0.9	1	<0.8	1
Cadmium		µg	0.3	<0.2	<0.2	0.25
Chromium		µg	0.97	1.2	0.68	0.2
Cobalt		µg	<0.2	<0.2	<0.2	0.25
Copper		µg	<0.2	2.5	<0.2	0.25
Lead		µg	<1	<1	1	1.5
Manganese		µg	0.8	0.8	0.5	0.25
Nickel		µg	1	1	1.0	0.5
Phosphorus		µg	20	20	20	2.5
Selenium		µg	2	8.0	11	1.5
Tellurium		µg	<2	2.7	<2	2
Thallium		µg	<1	<1	<1	1.5
Vanadium		µg	<0.9	<0.9	<0.8	1
Zinc		µg	6.7	5.3	4.6	0.5
Volume	Sample	mL	835	800	855	
Volume	aliquot volume	mL	785	750	805	
Mercury by CVAA						
Mercury	As Tested	µg/L	0.05	<0.05	<0.05	0.05

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: Metals and Hg Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1668162**
Control Number:
Date Received: Jul 26, 2023
Date Reported: Aug 17, 2023
Report Number: 2898261

		Reference Number	1668162-7	1668162-8	1668162-9	Nominal Detection Limit
		Sample Date	Jul 19, 2023	Jul 20, 2023	Jul 20, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 3 Run 1 (MV Unit 3 Run 1 + 4 Bottles	Unit 3 Run 2 (MV Unit 3 Run 2 + 4 Bottles)	Unit 3 Run 3 (MV Unit 3 Run 3 + 4 Bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results		
Mercury by CVAA - Continued						
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	835	800	855	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	<0.3	<0.3	<0.3	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	161	160	152	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.01	<0.01	<0.01	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	500	1000	1000	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.04	<0.08	<0.08	
Mercury	As Tested	µg/L	0.15	0.06	0.16	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.049	0.02	0.053	

Approved by:



Max Hewitt
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1668162 Control Number: Date Received: Jul 26, 2023 Date Reported: Aug 17, 2023 Report Number: 2898261
Attn: Missy Sampled By: Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Aug 16, 2023	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Aug 15, 2023	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Aug 16, 2023	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Aug 15, 2023	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Aug 16, 2023	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Aug 1, 2023	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Jul 31, 2023	Element Vancouver

* Reference Method Modified

References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

CERTIFICATE OF ANALYSIS

Work Order : **VA23B7585**
Client : **A. Lanfranco & Associates Inc.**
Contact : Mark Lanfranco
Address : Unit # 101 9488 - 189 St
Surrey BC Canada V4N 4W7
Telephone : 604 881 2582
Project : MV WTW UNIT 3
PO : ----
C-O-C number : ----
Sampler : A. Lanfranco
Site : ----
Quote number : Standing Offer
No. of samples received : 4
No. of samples analysed : 4

Page : 1 of 2
Laboratory : ALS Environmental - Vancouver
Account Manager : Brent Mack
Address : 8081 Lougheed Highway
Burnaby BC Canada V5A 1W9
Telephone : 778-370-3279
Date Samples Received : 31-Jul-2023 15:35
Date Analysis Commenced : 02-Aug-2023
Issue Date : 22-Aug-2023 16:54

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Laboratory Department</i>
Jon Fisher	Production Manager, Environmental	Metals, Waterloo, Ontario



General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key : CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances
LOR: Limit of Reporting (detection limit).

Unit	Description
µg	micrograms
mL	millilitres

<: less than.
>: greater than.

Surrogate: An analyte that is similar in behavior to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical Results

Sub-Matrix: Impinger (Matrix: Air)					Client sample ID	MV WTE Unit 3 - Cr+6 Blank	MV WTE Unit 3 - Cr+6 Run 1	MV WTE Unit 3 - Cr+6 Run 2	MV WTE Unit 3 - Cr+6 Run 3	----
Client sampling date / time						25-Jul-2023 00:00	25-Jul-2023 00:00	26-Jul-2023 00:00	26-Jul-2023 00:00	----
Analyte	CAS Number	Method/Lab	LOR	Unit	VA23B7585-001	VA23B7585-002	VA23B7585-003	VA23B7585-004	-----	
					Result	Result	Result	Result	----	
Sample Preparation										
Volume, impinger	----	EP532C/WT	0.1	mL	415	890	850	883	----	
Speciated Metals										
Chromium, hexavalent [Cr VI]	18540-29-9	E532C/WT	0.20	µg	<0.42	<0.89	<0.85	<0.88	----	

Please refer to the General Comments section for an explanation of any result qualifiers detected.

Please refer to the Accreditation section for an explanation of analyte accreditations.

QUALITY CONTROL INTERPRETIVE REPORT

Work Order	: VA23B7585	Page	: 1 of 5
Client	: A. Lanfranco & Associates Inc.	Laboratory	: ALS Environmental - Vancouver
Contact	: Mark Lanfranco	Account Manager	: Brent Mack
Address	: Unit # 101 9488 - 189 St Surrey BC Canada V4N 4W7	Address	: 8081 Lougheed Highway Burnaby, British Columbia Canada V5A 1W9
Telephone	: 604 881 2582	Telephone	: 778-370-3279
Project	: MV WTW UNIT 3	Date Samples Received	: 31-Jul-2023 15:35
PO	: ----	Issue Date	: 22-Aug-2023 16:59
C-O-C number	: ----		
Sampler	: A. Lanfranco		
Site	: ----		
Quote number	: Standing Offer		
No. of samples received	: 4		
No. of samples analysed	: 4		

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO: Data Quality Objective.

LOR: Limit of Reporting (detection limit).

RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "----" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

- No Reference Material (RM) Sample outliers occur.

Outliers : Analysis Holding Time Compliance (Breaches)

- No Analysis Holding Time Outliers exist.

Outliers : Frequency of Quality Control Samples

- No Quality Control Sample Frequency Outliers occur.



Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and /or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Matrix: Air

Evaluation: ✖ = Holding time exceedance ; ✔ = Within Holding Time

Analyte Group Container / Client Sample ID(s)	Method	Sampling Date	Extraction / Preparation				Analysis			
			Preparation Date	Holding Times		Eval	Analysis Date	Holding Times		Eval
				Rec	Actual			Rec	Actual	
Speciated Metals : Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)										
HDPE MV WTE Unit 3 - Cr+6 Run 2	E532C	26-Jul-2023	02-Aug-2023	14 days	7 days	✓	02-Aug-2023	14 days	7 days	✓
Speciated Metals : Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)										
HDPE MV WTE Unit 3 - Cr+6 Run 3	E532C	26-Jul-2023	02-Aug-2023	14 days	7 days	✓	02-Aug-2023	14 days	7 days	✓
Speciated Metals : Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)										
HDPE MV WTE Unit 3 - Cr+6 Blank	E532C	25-Jul-2023	02-Aug-2023	14 days	8 days	✓	02-Aug-2023	14 days	8 days	✓
Speciated Metals : Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)										
HDPE MV WTE Unit 3 - Cr+6 Run 1	E532C	25-Jul-2023	02-Aug-2023	14 days	8 days	✓	02-Aug-2023	14 days	8 days	✓

Legend & Qualifier Definitions

Rec. HT: ALS recommended hold time (see units).



Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Matrix: **Air**

Evaluation: ✖ = QC frequency outside specification; ✔ = QC frequency within specification.

Quality Control Sample Type			Count		Frequency (%)		
Analytical Methods	Method	QC Lot #	QC	Regular	Actual	Expected	Evaluation
Laboratory Duplicates (DUP)							
Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)	E532C	1067553	1	4	25.0	5.0	✓
Laboratory Control Samples (LCS)							
Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)	E532C	1067553	1	4	25.0	5.0	✓
Method Blanks (MB)							
Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)	E532C	1067553	1	4	25.0	5.0	✓
Matrix Spikes (MS)							
Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)	E532C	1067553	1	4	25.0	5.0	✓



Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by "mod").

<i>Analytical Methods</i>	<i>Method / Lab</i>	<i>Matrix</i>	<i>Method Reference</i>	<i>Method Descriptions</i>
Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)	E532C ALS Environmental - Waterloo	Air	EPA 7199 / EPA 306	Impinger samples are analyzed by ion chromatography with UV/Vis detector using diphenylcarbazide in a sulphuric acid solution.
<i>Preparation Methods</i>	<i>Method / Lab</i>	<i>Matrix</i>	<i>Method Reference</i>	<i>Method Descriptions</i>
Preparation of Hexavalent Chromium (Impinger)	EP532C ALS Environmental - Waterloo	Air	APHA 3500-Cr C (Ion Chromatography)	pH of a homogenized impinger sample is adjusted to pH 9 by NaOH for Ion Chromatography analysis.

QUALITY CONTROL REPORT

Work Order	: VA23B7585	Page	: 1 of 3
Client	: A. Lanfranco & Associates Inc.	Laboratory	: ALS Environmental - Vancouver
Contact	: Mark Lanfranco	Account Manager	: Brent Mack
Address	: Unit # 101 9488 - 189 St Surrey BC Canada V4N 4W7	Address	: 8081 Lougheed Highway Burnaby, British Columbia Canada V5A 1W9
Telephone	:	Telephone	: 778-370-3279
Project	: MV WTW UNIT 3	Date Samples Received	: 31-Jul-2023 15:35
PO	: ----	Date Analysis Commenced	: 02-Aug-2023
C-O-C number	: ----	Issue Date	: 22-Aug-2023 16:57
Sampler	: A. Lanfranco 604 881 2582		
Site	: ----		
Quote number	: Standing Offer		
No. of samples received	: 4		
No. of samples analysed	: 4		

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

- Laboratory Duplicate (DUP) Report; Relative Percent Difference (RPD) and Data Quality Objectives
- Matrix Spike (MS) Report; Recovery and Data Quality Objectives
- Method Blank (MB) Report; Recovery and Data Quality Objectives
- Laboratory Control Sample (LCS) Report; Recovery and Data Quality Objectives

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories	Position	Laboratory Department
Jon Fisher	Production Manager, Environmental	Waterloo Metals, Waterloo, Ontario



General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

- Key :
- Anonymous = Refers to samples which are not part of this work order, but which formed part of the QC process lot.
 - CAS Number = Chemical Abstracts Service number is a unique identifier assigned to discrete substances.
 - DQO = Data Quality Objective.
 - LOR = Limit of Reporting (detection limit).
 - RPD = Relative Percent Difference
 - # = Indicates a QC result that did not meet the ALS DQO.

Workorder Comments

Holding times are displayed as "----" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test-specific).

Sub-Matrix: Air					Laboratory Duplicate (DUP) Report						
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier
Sample Preparation (QC Lot: 1067553)											
VA23B7585-002	MV WTE Unit 3 - Cr+6 Run 1	Volume, impinger	----	EP532C	0.1	mL	890	890		Diff <2x LOR	----
Speciated Metals (QC Lot: 1067553)											
VA23B7585-002	MV WTE Unit 3 - Cr+6 Run 1	Chromium, hexavalent [Cr VI]	18540-29-9	E532C	0.89	µg	<0.89	<0.89	0	Diff <2x LOR	----



Method Blank (MB) Report

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: Air

Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
Sample Preparation (QCLot: 1067553)						
Volume, impinger	----	EP532C	0.1	mL	200	----
Speciated Metals (QCLot: 1067553)						
Chromium, hexavalent [Cr VI]	18540-29-9	E532C	0.2	µg	<0.20	----

Laboratory Control Sample (LCS) Report

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: Air

					Laboratory Control Sample (LCS) Report				
					Spike	Recovery (%)	Recovery Limits (%)		
Analyte	CAS Number	Method	LOR	Unit	Concentration	LCS	Low	High	Qualifier
Speciated Metals (QCLot: 1067553)									
Chromium, hexavalent [Cr VI]	18540-29-9	E532C	0.2	µg	10 µg	90.7	90.0	110	----

Matrix Spike (MS) Report

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DQO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for the associated sample (or similar samples) may be subject to bias. ND – Recovery not determined, background level >= 1x spike level.

Sub-Matrix: Air

					Matrix Spike (MS) Report				
					Spike		Recovery (%)	Recovery Limits (%)	
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	Concentration	Target	MS	Low	High
Sample Preparation (QCLot: 1067553)									
VA23B7585-002	MV WTE Unit 3 - Cr+6 Run 1	Volume, impinger	----	EP532C		mL		0	0
Speciated Metals (QCLot: 1067553)									
VA23B7585-002	MV WTE Unit 3 - Cr+6 Run 1	Chromium, hexavalent [Cr VI]	18540-29-9	E532C	33.5 µg	35.6 µg	94.2	75.0	125

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: HF Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667016**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 26, 2023
Report Number: 2896535

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential.
If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited.
If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: HF Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667016**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 26, 2023
Report Number: 2896535

		Reference Number	1667016-1	1667016-2	1667016-3	
		Sample Date	Jul 19, 2023	Jul 18, 2023	Jul 20, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit #1 HF Blank / 23.6 °C	Unit #2 HF Blank / 23.6 °C	Unit #3 HF Blank / 23.6 °C	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Air Quality						
Volume	Sample	mL	293	295	298	
Dilution Factor	fluoride		1.00000000	1.00000000	1.00000000	
Fluoride	As Tested	mg/L	<0.03	<0.03	<0.03	0.03
Fluoride	Water Soluble	µg/sample	<9	<9	<9	

Approved by:



Max Hewitt
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: HF Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667016**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 26, 2023
Report Number: 2896535

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Anions by IEC in air (VAN)	EMC	* Determination of Hydrogen Halide & Halogen Emissions from Stationary Sources (Isokinetic), 26A	Jul 24, 2023	Element Vancouver

** Reference Method Modified*

References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: HF Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667017**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 26, 2023
Report Number: 2896537

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential.
If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited.
If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: HF Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667017**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 26, 2023
Report Number: 2896537

		Reference Number	1667017-1	1667017-2	1667017-3	
		Sample Date	Jul 19, 2023	Jul 19, 2023	Jul 19, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit #1 HF Run 1 / 24.1 °C	Unit #1 HF Run 2 / 24.1 °C	Unit #1 HF Run 3 / 24.1 °C	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Air Quality						
Volume	Sample	mL	510	406	359	
Dilution Factor	fluoride		10.00	10.00	10.00	
Fluoride	As Tested	mg/L	<0.3	<0.3	<0.3	0.03
Fluoride	Water Soluble	µg/sample	<200	<100	<100	

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: HF Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667017**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 26, 2023
Report Number: 2896537

Reference Number	1667017-4	1667017-5	1667017-6
Sample Date	Jul 18, 2023	Jul 18, 2023	Jul 18, 2023
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit #2 HF Run 1 / 24.1 °C	Unit #2 HF Run 2 / 24.1 °C	Unit #2 HF Run 3 / 24.1 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Air Quality					
Volume	Sample	mL	267	338	315
Dilution Factor	fluoride	10.00	10.00	10.00	
Fluoride	As Tested	mg/L	<0.3	<0.3	<0.3
Fluoride	Water Soluble	µg/sample	<80	<100	<90

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: HF Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667017**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 26, 2023
Report Number: 2896537

Reference Number	1667017-7	1667017-8	1667017-9
Sample Date	Jul 20, 2023	Jul 20, 2023	Jul 20, 2023
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit #3 HF Run 1 / 24.1 °C	Unit #3 HF Run 2 / 24.1 °C	Unit #3 HF Run 3 / 24.1 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Air Quality					
Volume	Sample	mL	447	414	332
Dilution Factor	fluoride		10.00	10.00	10.00
Fluoride	As Tested	mg/L	<0.3	<0.3	<0.3
Fluoride	Water Soluble	µg/sample	<100	<100	<100

Approved by:



Max Hewitt
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: HF Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667017**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 26, 2023
Report Number: 2896537

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Anions by IEC in air (VAN)	EMC	* Determination of Hydrogen Halide & Halogen Emissions from Stationary Sources (Isokinetic), 26A	Jul 25, 2023	Element Vancouver

** Reference Method Modified*

References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: NH3 Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667009**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 27, 2023
Report Number: 2896529

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

Notes To Clients:

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: NH3 Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667009**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 27, 2023
Report Number: 2896529

		Reference Number	1667009-1	1667009-2	1667009-3	
		Sample Date	Jul 19, 2023	Jul 18, 2023	Jul 20, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit #1 NH3 Blk / 23.7 °C	Unit #2 NH3 Blk / 23.7 °C	Unit #3 NH3 Blk / 23.7 °C	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Air Quality						
Ammonium - N	As Tested	µg/L	81	105	253	25
Dilution Factor	As Tested		1.00	1.00	1.00	
Sample Volume	Sample volume	mL	293	293	294	
Ammonium - N		µg/sample	24	30.8	74.4	

Approved by:



Abhishek Suryawanshi
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: NH3 Blanks
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667009**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 27, 2023
Report Number: 2896529

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Ammonium in Impingers (VAN)	APHA	* Automated Phenate Method, 4500-NH3 G	Jul 27, 2023	Element Edmonton - Roper Road

** Reference Method Modified*

References

APHA Standard Methods for the Examination of Water and Wastewater

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: NH3 Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667012**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 27, 2023
Report Number: 2896533

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

Notes To Clients:

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: NH3 Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667012**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 27, 2023
Report Number: 2896533

		Reference Number	1667012-1	1667012-2	1667012-3
		Sample Date	Jul 19, 2023	Jul 19, 2023	Jul 19, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit 1 NH3 Run 1 / 23.4 °C	Unit 1 NH3 Run 2 / 23.4 °C	Unit 1 NH3 Run 3 / 23.4 °C
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Air Quality					
Ammonium - N	As Tested	µg/L	1940	2840	3440
Dilution Factor	As Tested		1.00	1.00	1.00
Sample Volume	Sample volume	mL	340	380	363
Ammonium - N		µg/sample	658	1080	1250

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: NH3 Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667012**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 27, 2023
Report Number: 2896533

Reference Number	1667012-4	1667012-5	1667012-6
Sample Date	Jul 18, 2023	Jul 18, 2023	Jul 18, 2023
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit 2 NH3 Run 1 / 23.4 °C	Unit 2 NH3 Run 2 / 23.4 °C	Unit 2 NH3 Run 3 / 23.4 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Air Quality					
Ammonium - N	As Tested	µg/L	4010	3990	3540
Dilution Factor	As Tested		1.00	1.00	1.00
Sample Volume	Sample volume	mL	355	468	448
Ammonium - N		µg/sample	1420	1870	1590

Analytical Report

Bill To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Missy
Sampled By:
Company:

Project ID: Metro Vancouver WTE
Project Name: NH3 Samples
Project Location:
LSD:
P.O.:
Proj. Acct. code:

Lot ID: **1667012**
Control Number:
Date Received: Jul 21, 2023
Date Reported: Jul 27, 2023
Report Number: 2896533

Reference Number	1667012-7	1667012-8	1667012-9
Sample Date	Jul 20, 2023	Jul 20, 2023	Jul 20, 2023
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit 3 NH3 Run 1 / 23.4 °C	Unit 3 NH3 Run 2 / 23.4 °C	Unit 3 NH3 Run 3 / 23.4 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Air Quality					
Ammonium - N	As Tested	µg/L	9160	3680	3410
Dilution Factor	As Tested		1.00	1.00	1.00
Sample Volume	Sample volume	mL	385	375	384
Ammonium - N		µg/sample	3530	1380	1310

Approved by:



Abhishek Suryawanshi
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Terms and Conditions: <https://www.element.com/terms/terms-and-conditions>

Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: NH3 Samples Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1667012 Control Number: Date Received: Jul 21, 2023 Date Reported: Jul 27, 2023 Report Number: 2896533
Attn: Missy Sampled By: Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Ammonium in Impingers (VAN)	APHA	* Automated Phenate Method, 4500-NH3 G	Jul 27, 2023	Element Edmonton - Roper Road
* Reference Method Modified				

References

APHA	Standard Methods for the Examination of Water and Wastewater
------	--

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY REPORT

August 9, 2023

Mark Lanfranco
A. Lanfranco and Associates Inc.
9488 189 St., Unit 101
Surrey, BC V4N 4W7

RE: Metro Vancouver W.T.E.

Dear Mark:

Enclosed are the results of the samples submitted to our laboratory on July 26, 2023. For your reference, these analyses have been assigned our service request number P2303500.

All analyses were performed according to our laboratory's NELAP and DoD-ELAP-approved quality assurance program. The test results meet requirements of the current NELAP and DoD-ELAP standards, where applicable, and except as noted in the laboratory case narrative provided. For a specific list of NELAP and DoD-ELAP-accredited analytes, refer to the certifications section at www.alsglobal.com. Results are intended to be considered in their entirety and apply only to the samples analyzed and reported herein.

If you have any questions, please call me at (805) 526-7161.

ALS | Environmental


By Sue Anderson at 3:21 pm, Aug 09, 2023

Sue Anderson
Project Manager



Client: A. Lanfranco and Associates Inc.
Project: Metro Vancouver W.T.E.

Service Request No: P2303500

CASE NARRATIVE

The samples were received intact under chain of custody on July 26, 2023 and were stored in accordance with the analytical method requirements. Please refer to the sample acceptance check form for additional information. The results reported herein are applicable only to the condition of the samples at the time of sample receipt.

C3 through C6 Hydrocarbons, Methane, Ethene and Ethane Analysis

The samples were analyzed per modified EPA Method TO-3 for C3 through >C6 hydrocarbons and methane, ethene and ethane using a gas chromatograph equipped with a flame ionization detector (FID). This procedure is described in laboratory SOP VOA-TO3C1C6. This method is included on the laboratory's DoD-ELAP scope of accreditation, however it is not part of the NELAP or AIHA-LAP, LLC accreditation.

The results of analyses are given in the attached laboratory report. All results are intended to be considered in their entirety, and ALS Environmental (ALS) is not responsible for utilization of less than the complete report.

Use of ALS Environmental (ALS)'s Name. Client shall not use ALS's name or trademark in any marketing or reporting materials, press releases or in any other manner ("Materials") whatsoever and shall not attribute to ALS any test result, tolerance or specification derived from ALS's data ("Attribution") without ALS's prior written consent, which may be withheld by ALS for any reason in its sole discretion. To request ALS's consent, Client shall provide copies of the proposed Materials or Attribution and describe in writing Client's proposed use of such Materials or Attribution. If ALS has not provided written approval of the Materials or Attribution within ten (10) days of receipt from Client, Client's request to use ALS's name or trademark in any Materials or Attribution shall be deemed denied. ALS may, in its discretion, reasonably charge Client for its time in reviewing Materials or Attribution requests. Client acknowledges and agrees that the unauthorized use of ALS's name or trademark may cause ALS to incur irreparable harm for which the recovery of money damages will be inadequate. Accordingly, Client acknowledges and agrees that a violation shall justify preliminary injunctive relief. For questions contact the laboratory.



CERTIFICATIONS, ACCREDITATIONS, AND REGISTRATIONS

Agency	Web Site	Number
Alaska DEC	https://dec.alaska.gov/spar/csp/lab-approval/list-of-approved-labs	17-019
Arizona DHS	http://www.azdhs.gov/preparedness/state-laboratory/lab-licensure-certification/index.php#laboratory-licensure-home	AZ0694
Florida DOH (NELAP)	http://www.floridahealth.gov/licensing-and-regulation/environmental-laboratories/index.html	E871020
Louisiana DEQ (NELAP)	https://internet.deq.louisiana.gov/portal/divisions/lalap/accredited-laboratories	05071
Maine DHHS	http://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtm	2022028
Minnesota DOH (NELAP)	http://www.health.state.mn.us/accreditation	006-999-456
New Jersey DEP (NELAP)	https://dep.nj.gov/dsr/oqa/certified-laboratories/	CA009
New York DOH (NELAP)	http://www.wadsworth.org/labcert/elap/elap.html	11221
Oklahoma DEQ (NELAP)	labaccreditation.deq.ok.gov/labaccreditation/	2207
Oregon PHD (NELAP)	http://www.oregon.gov/oha/ph/LaboratoryServices/EnvironmentalLaboratoryAccreditation/Pages/index.aspx	4068-011
Pennsylvania DEP	http://www.dep.pa.gov/Business/OtherPrograms/Labs/Pages/Laboratory-Accreditation-Program.aspx	68-03307 (Registration)
PJLA (DoD ELAP)	http://www.pjlabs.com/search-accredited-labs	65818 (Testing)
Texas CEQ (NELAP)	http://www.tceq.texas.gov/agency/qa/env_lab_accreditation.html	T104704413-23-14
Utah DOH (NELAP)	https://uphl.utah.gov/certifications/environmental-laboratory-certification/	CA016272023-15
Washington DOE	http://www.ecy.wa.gov/programs/eap/labs/lab-accreditation.html	C946

Analyses were performed according to our laboratory's NELAP and DoD-ELAP approved quality assurance program. A complete listing of specific NELAP and DoD-ELAP certified analytes can be found in the certifications section at www.alsglobal.com, or at the accreditation body's website.

Each of the certifications listed above have an explicit Scope of Accreditation that applies to specific matrices/methods/analytes; therefore, please contact the laboratory for information corresponding to a particular certification.

ALS ENVIRONMENTAL

DETAIL SUMMARY REPORT

Client: A. Lanfranco and Associates Inc.
Project ID: Metro Vancouver W.T.E.

Service Request: P2303500

Date Received: 7/26/2023
Time Received: 09:32

Client Sample ID	Lab Code	Matrix	Date Collected	Time Collected	Container ID	Pi1 (psig)	Pfl (psig)	TO-3 Modified - C1C6+ Can	
								TO-3 Modified - C1C6+ Can	TO-3 Modified - MEEPP Can
Unit#1 Run1	P2303500-001	Air	7/19/2023	10:35	SC00787	-3.70	3.95	X	X
Unit#1 Run2	P2303500-002	Air	7/19/2023	11:51	SC02241	-3.24	4.00	X	X
Unit#1 Run3	P2303500-003	Air	7/19/2023	13:08	SC02186	-4.69	4.00	X	X
Unit#2 Run1	P2303500-004	Air	7/18/2023	11:42	SC01024	-5.90	3.61	X	X
Unit#2 Run2	P2303500-005	Air	7/18/2023	13:28	SC02242	-3.74	3.93	X	X
Unit#2 Run3	P2303500-006	Air	7/18/2023	14:44	SC01996	-3.53	3.69	X	X
Unit#3 Run1	P2303500-007	Air	7/20/2023	11:10	SC00640	-4.62	3.85	X	X
Unit#3 Run2	P2303500-008	Air	7/20/2023	12:35	SC00861	-4.87	4.10	X	X
Unit#3 Run3	P2303500-009	Air	7/20/2023	13:45	SC00265	-4.07	3.99	X	X



Air - Chain of Custody Record & Analytical Service Request

Page _____ of _____

2655 Park Center Drive, Suite A
Simi Valley, California 93065
Phone (805) 526-7161
Fax (805) 526-7270

Requested Turnaround Time in Business Days (Surcharges) please circle
1 Day (100%) 2 Day (75%) 3 Day (50%) 4 Day (35%) 5 Day (25%) 10 Day-Standard

ALS Project No. 2503500

Company Name & Address (Reporting Information) <u>A. Lanfranco & Associates Inc. V4N 4W7</u> <u>#101-9488 189 Street Surrey BC, Canada</u>				Project Name <u>Metco Vancouver W.T.E.</u>				ALS Contact:		Analysis Method <u>TO-3</u> (List on File)	Comments e.g. Actual Preservative or specific instructions
Project Manager <u>Mark Lanfranco</u>				Project Number							
Phone <u>604-881-2582</u> Fax				P.O. # / Billing Information <u>Bill to Account</u>							
Email Address for Result Reporting <u>Mark.Lanfranco@alfranco.com</u>				Sampler (Print & Sign) <u>Sean Vesby</u>							
Client Sample ID	Laboratory ID Number	Date Collected	Time Collected	Canister ID (Bar code # - AC, SC, etc.)	Flow Controller ID (Bar code # - FC #)	Canister Start Pressure "Hg	Canister End Pressure "Hg/psig	Sample Volume			
<u>Unit #1 Run 1</u>	<u>1</u>	<u>07-19-23</u>	<u>9:35-10:35</u>	<u>SC00787</u>	<u>OA00154</u>	<u>-30.0</u>	<u>-8.0</u>	<u>6L</u>			
<u>Unit #1 Run 2</u>	<u>2</u>	<u>07-19-23</u>	<u>10:51-11:51</u>	<u>SC02241</u>	<u>OA02255</u>	<u>-29.5</u>	<u>-6.5</u>	<u>6L</u>			
<u>Unit #1 Run 3</u>	<u>3</u>	<u>07-19-23</u>	<u>12:08-13:08</u>	<u>SC02186</u>	<u>OA01544</u>	<u>-34.0</u>	<u>-12.0</u>	<u>6L</u>			
<u>Unit #2 Run 1</u>	<u>4</u>	<u>07-18-23</u>	<u>10:42-11:42</u>	<u>SC01024</u>	<u>OA00091</u>	<u>-32.5</u>	<u>-12.5</u>	<u>6L</u>			
<u>Unit #2 Run 2</u>	<u>5</u>	<u>07-18-23</u>	<u>12:28-13:28</u>	<u>SC02242</u>	<u>OA00217</u>	<u>-32.0</u>	<u>-9.0</u>	<u>6L</u>			
<u>Unit #2 Run 3</u>	<u>6</u>	<u>07-18-23</u>	<u>13:44-14:44</u>	<u>SC01996</u>	<u>OA01178</u>	<u>-30.0</u>	<u>-6.5</u>	<u>6L</u>			
<u>Unit #3 Run 1</u>	<u>7</u>	<u>07-20-23</u>	<u>10:10-11:10</u>	<u>SC00640</u>	<u>OA00250</u>	<u>-30.0</u>	<u>-10.0</u>	<u>6L</u>			
<u>Unit #3 Run 2</u>	<u>8</u>	<u>07-20-23</u>	<u>11:35-12:35</u>	<u>SC00861</u>	<u>OA01809</u>	<u>-29.0</u>	<u>-9.0</u>	<u>6L</u>			
<u>Unit #3 Run 3</u>	<u>9</u>	<u>07-20-23</u>	<u>12:45-13:45</u>	<u>SC00265</u>	<u>OA01000</u>	<u>-29.0</u>	<u>-7.0</u>	<u>6L</u>			
Report Tier Levels - please select										Project Requirements (MRLs, QAPP)	
Tier I - Results (Default if not specified) _____		Tier III (Results + QC & Calibration Summaries) _____		EDD required Yes / No		Chain of Custody Seal: (Circle)					
Tier II (Results + QC Summaries) _____		Tier IV (Data Validation Package) 10% Surcharge _____		Type: _____ Units: _____		INTACT BROKEN ABSENT					
Relinquished by: (Signature)			Date:	Time:	Received by: (Signature)			Date:	Time:	Cooler / Blank Temperature °C	
Relinquished by: (Signature) <u>[Signature]</u>			Date:	Time:	Received by: (Signature) <u>[Signature]</u>			Date:	Time:		

ALS Environmental Sample Acceptance Check Form

Client: A. Lanfranco and Associates Inc. Work order: P2303500
 Project: Metro Vancouver W.T.E
 Sample(s) received on: 7/26/2023 - 7/27/2023 Date opened: 7/26/23 by: ADAVID

Note: This form is used for all samples received by ALS. The use of this form for custody seals is strictly meant to indicate presence/absence and not as an indication of compliance or nonconformity. Thermal preservation and pH will only be evaluated either at the request of the client and/or as required by the method/SOP.

	Yes	No	N/A
1 Were sample containers properly marked with client sample ID?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2 Did sample containers arrive in good condition?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3 Were chain-of-custody papers used and filled out?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4 Did sample container labels and/or tags agree with custody papers?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5 Was sample volume received adequate for analysis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6 Are samples within specified holding times?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7 Was proper temperature (thermal preservation) of cooler at receipt adhered to?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8 Were custody seals on outside of cooler/Box/Container?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Location of seal(s)? _____ Sealing Lid?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Were signature and date included?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Were seals intact?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
9 Do containers have appropriate preservation , according to method/SOP or Client specified information?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Is there a client indication that the submitted samples are pH preserved?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Were VOA vials checked for presence/absence of air bubbles?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Does the client/method/SOP require that the analyst check the sample pH and <u>if necessary</u> alter it?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
10 Tubes: Are the tubes capped and intact?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
11 Badges: Are the badges properly capped and intact?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Are dual bed badges separated and individually capped and intact?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Lab Sample ID	Container Description	Required pH *	Received pH	Adjusted pH	VOA Headspace (Presence/Absence)	Receipt / Preservation Comments
P2303500-001.01	6.0 L Source Can					
P2303500-002.01	6.0 L Source Can					
P2303500-003.01	6.0 L Source Can					
P2303500-004.01	6.0 L Source Can					
P2303500-005.01	6.0 L Source Can					
P2303500-006.01	6.0 L Source Can					
P2303500-007.01	6.0 L Source Can					
P2303500-008.01	6.0 L Source Can					
P2303500-009.01	6.0 L Source Can					

Explain any discrepancies: (include lab sample ID numbers): _____

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#1 Run1

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-001

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC00787

Date Collected: 7/19/23

Date Received: 7/26/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -3.70

Final Pressure (psig): 3.95

Container Dilution Factor: 1.70

Compound	Result ppmV	MRL ppmV	Data Qualifier
C ₃ as Propane	ND	0.85	
C ₄ as n-Butane	ND	0.85	
C ₅ as n-Pentane	ND	0.85	
C ₆ as n-Hexane	ND	0.85	
C ₆ + as n-Hexane	ND	1.7	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#1 Run2

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-002

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC02241

Date Collected: 7/19/23

Date Received: 7/26/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -3.24

Final Pressure (psig): 4.00

Container Dilution Factor: 1.63

Compound	Result ppmV	MRL ppmV	Data Qualifier
C ₃ as Propane	ND	0.82	
C ₄ as n-Butane	ND	0.82	
C ₅ as n-Pentane	ND	0.82	
C ₆ as n-Hexane	ND	0.82	
C ₆ + as n-Hexane	1.7	1.6	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#1 Run3

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-003

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC02186

Date Collected: 7/19/23

Date Received: 7/26/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -4.69 **Final Pressure (psig):** 4.00

Container Dilution Factor: 1.87

Compound	Result ppmV	MRL ppmV	Data Qualifier
C ₃ as Propane	ND	0.94	
C ₄ as n-Butane	ND	0.94	
C ₅ as n-Pentane	ND	0.94	
C ₆ as n-Hexane	ND	0.94	
C ₆ + as n-Hexane	ND	1.9	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#2 Run1

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-004

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC01024

Date Collected: 7/18/23

Date Received: 7/26/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -5.90

Final Pressure (psig): 3.61

Container Dilution Factor: 2.08

Compound	Result ppmV	MRL ppmV	Data Qualifier
C ₃ as Propane	ND	1.0	
C ₄ as n-Butane	ND	1.0	
C ₅ as n-Pentane	ND	1.0	
C ₆ as n-Hexane	ND	1.0	
C ₆ + as n-Hexane	2.7	2.1	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#2 Run2

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-005

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC02242

Date Collected: 7/18/23

Date Received: 7/26/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -3.74

Final Pressure (psig): 3.93

Container Dilution Factor: 1.70

Compound	Result ppmV	MRL ppmV	Data Qualifier
C ₃ as Propane	ND	0.85	
C ₄ as n-Butane	ND	0.85	
C ₅ as n-Pentane	ND	0.85	
C ₆ as n-Hexane	ND	0.85	
C ₆ + as n-Hexane	ND	1.7	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#2 Run3

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-006

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC01996

Date Collected: 7/18/23

Date Received: 7/27/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -3.53 Final Pressure (psig): 3.69

Container Dilution Factor: 1.65

Compound	Result ppmV	MRL ppmV	Data Qualifier
C ₃ as Propane	ND	0.83	
C ₄ as n-Butane	ND	0.83	
C ₅ as n-Pentane	ND	0.83	
C ₆ as n-Hexane	ND	0.83	
C ₆ + as n-Hexane	ND	1.7	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#3 Run1

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-007

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Kylan Malloy

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC00640

Date Collected: 7/20/23

Date Received: 7/27/23

Date Analyzed: 8/4/23

Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -4.62 **Final Pressure (psig):** 3.85

Container Dilution Factor: 1.84

Compound	Result ppmV	MRL ppmV	Data Qualifier
C ₃ as Propane	ND	0.92	
C ₄ as n-Butane	ND	0.92	
C ₅ as n-Pentane	ND	0.92	
C ₆ as n-Hexane	ND	0.92	
C ₆ + as n-Hexane	ND	1.8	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#3 Run2

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-008

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Kylan Malloy

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC00861

Date Collected: 7/20/23

Date Received: 7/27/23

Date Analyzed: 8/4/23

Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -4.87 **Final Pressure (psig):** 4.10

Container Dilution Factor: 1.91

Compound	Result ppmV	MRL ppmV	Data Qualifier
C ₃ as Propane	ND	0.96	
C ₄ as n-Butane	ND	0.96	
C ₅ as n-Pentane	ND	0.96	
C ₆ as n-Hexane	ND	0.96	
C ₆ + as n-Hexane	ND	1.9	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#3 Run3

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-009

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Kylan Malloy

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC00265

Date Collected: 7/20/23

Date Received: 7/27/23

Date Analyzed: 8/4/23

Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -4.07 **Final Pressure (psig):** 3.99

Container Dilution Factor: 1.76

Compound	Result ppmV	MRL ppmV	Data Qualifier
C ₃ as Propane	ND	0.88	
C ₄ as n-Butane	ND	0.88	
C ₅ as n-Pentane	ND	0.88	
C ₆ as n-Hexane	ND	0.88	
C ₆ + as n-Hexane	ND	1.8	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Method Blank

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P230802-MB

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Date Collected: NA

Date Received: NA

Date Analyzed: 8/02/23

Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
C ₃ as Propane	ND	0.50	
C ₄ as n-Butane	ND	0.50	
C ₅ as n-Pentane	ND	0.50	
C ₆ as n-Hexane	ND	0.50	
C ₆ + as n-Hexane	ND	1.0	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Method Blank

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P230804-MB

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Date Collected: NA

Date Received: NA

Date Analyzed: 8/04/23

Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
C ₃ as Propane	ND	0.50	
C ₄ as n-Butane	ND	0.50	
C ₅ as n-Pentane	ND	0.50	
C ₆ as n-Hexane	ND	0.50	
C ₆ + as n-Hexane	ND	1.0	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

LABORATORY CONTROL SAMPLE / DUPLICATE LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Duplicate Lab Control Sample

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P230802-DLCS

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Date Collected: NA

Date Received: NA

Date Analyzed: 8/02/23

Volume(s) Analyzed: NA ml(s)

Compound	Spike Amount	Result		% Recovery		ALS	RPD	RPD	Data
	LCS / DLCS ppmV	LCS ppmV	DLCS ppmV	LCS	DLCS	Acceptance Limits			
Propane	1,000	1,080	1,070	108	107	92-120	0.9	6	
n-Butane	1,000	1,090	1,080	109	108	91-121	0.9	6	
n-Pentane	1,000	1,070	1,060	107	106	89-118	0.9	6	
n-Hexane	1,000	1,130	1,120	113	112	92-125	0.9	6	

ALS ENVIRONMENTAL

LABORATORY CONTROL SAMPLE / DUPLICATE LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Duplicate Lab Control Sample

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P230804-DLCS

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Date Collected: NA

Date Received: NA

Date Analyzed: 8/04/23

Volume(s) Analyzed: NA ml(s)

Compound	Spike Amount	Result		% Recovery		ALS	RPD	RPD	Data
	LCS / DLCS ppmV	LCS ppmV	DLCS ppmV	LCS	DLCS	Acceptance Limits			
Propane	1,000	1,140	1,100	114	110	92-120	4	6	
n-Butane	1,000	1,140	1,110	114	111	91-121	3	6	
n-Pentane	1,000	1,120	1,090	112	109	89-118	3	6	
n-Hexane	1,000	1,190	1,150	119	115	92-125	3	6	

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#1 Run1

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-001

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC00787

Date Collected: 7/19/23

Date Received: 7/26/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -3.70 Final Pressure (psig): 3.95

Container Dilution Factor: 1.70

CAS #	Compound	Result mg/m ³	MRL mg/m ³	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	3.0	2.2	4.5	3.4	
74-85-1	Ethene	ND	1.2	ND	1.0	
74-84-0	Ethane	ND	1.3	ND	1.0	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#1 Run2

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-002

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC02241

Date Collected: 7/19/23

Date Received: 7/26/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -3.24 **Final Pressure (psig):** 4.00

Container Dilution Factor: 1.63

CAS #	Compound	Result mg/m ³	MRL mg/m ³	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.1	ND	3.3	
74-85-1	Ethene	ND	1.1	ND	0.98	
74-84-0	Ethane	ND	1.2	ND	0.98	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#1 Run3

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-003

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC02186

Date Collected: 7/19/23

Date Received: 7/26/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -4.69 **Final Pressure (psig):** 4.00

Container Dilution Factor: 1.87

CAS #	Compound	Result mg/m ³	MRL mg/m ³	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.5	ND	3.7	
74-85-1	Ethene	ND	1.3	ND	1.1	
74-84-0	Ethane	ND	1.4	ND	1.1	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#2 Run1

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-004

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC01024

Date Collected: 7/18/23

Date Received: 7/26/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -5.90 **Final Pressure (psig):** 3.61

Container Dilution Factor: 2.08

CAS #	Compound	Result mg/m ³	MRL mg/m ³	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	3.5	2.7	5.4	4.2	
74-85-1	Ethene	ND	1.4	ND	1.2	
74-84-0	Ethane	ND	1.5	ND	1.2	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#2 Run2

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-005

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC02242

Date Collected: 7/18/23

Date Received: 7/26/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -3.74 **Final Pressure (psig):** 3.93

Container Dilution Factor: 1.70

CAS #	Compound	Result mg/m ³	MRL mg/m ³	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.2	ND	3.4	
74-85-1	Ethene	ND	1.2	ND	1.0	
74-84-0	Ethane	ND	1.3	ND	1.0	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#2 Run3

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-006

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC01996

Date Collected: 7/18/23

Date Received: 7/27/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -3.53 **Final Pressure (psig):** 3.69

Container Dilution Factor: 1.65

CAS #	Compound	Result mg/m ³	MRL mg/m ³	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.2	ND	3.3	
74-85-1	Ethene	ND	1.1	ND	0.99	
74-84-0	Ethane	ND	1.2	ND	0.99	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#3 Run1

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-007

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC00640

Date Collected: 7/20/23

Date Received: 7/27/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -4.62 **Final Pressure (psig):** 3.85

Container Dilution Factor: 1.84

CAS #	Compound	Result mg/m ³	MRL mg/m ³	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.4	ND	3.7	
74-85-1	Ethene	ND	1.3	ND	1.1	
74-84-0	Ethane	ND	1.4	ND	1.1	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#3 Run2

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-008

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC00861

Date Collected: 7/20/23

Date Received: 7/27/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -4.87 **Final Pressure (psig):** 4.10

Container Dilution Factor: 1.91

CAS #	Compound	Result mg/m ³	MRL mg/m ³	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.5	ND	3.8	
74-85-1	Ethene	ND	1.3	ND	1.1	
74-84-0	Ethane	ND	1.4	ND	1.1	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Unit#3 Run3

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P2303500-009

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC00265

Date Collected: 7/20/23

Date Received: 7/27/23

Date Analyzed: 8/2/23

Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -4.07 **Final Pressure (psig):** 3.99

Container Dilution Factor: 1.76

CAS #	Compound	Result mg/m ³	MRL mg/m ³	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.3	ND	3.5	
74-85-1	Ethene	ND	1.2	ND	1.1	
74-84-0	Ethane	ND	1.3	ND	1.1	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Method Blank

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P230802-MB

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Date Collected: NA

Date Received: NA

Date Analyzed: 8/02/23

Volume(s) Analyzed: 0.50 ml(s)

CAS #	Compound	Result mg/m ³	MRL mg/m ³	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	1.3	ND	2.0	
74-85-1	Ethene	ND	0.69	ND	0.60	
74-84-0	Ethane	ND	0.74	ND	0.60	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

DUPLICATE LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Duplicate Lab Control Sample

Client Project ID: Metro Vancouver W.T.E.

ALS Project ID: P2303500

ALS Sample ID: P230802-DLCS

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Date Collected: NA

Date Received: NA

Date Analyzed: 8/02/23

Volume(s) Analyzed: NA ml(s)

CAS #	Compound	Spike Amount	Result		% Recovery		ALS	RPD	RPD	Data
		LCS / DLCS ppmV	LCS ppmV	DLCS ppmV	LCS	DLCS	Acceptance Limits			
74-82-8	Methane	7.60	7.82	8.00	103	105	70-130	2	15	
74-85-1	Ethene	7.53	7.82	7.84	104	104	70-130	0	15	
74-84-0	Ethane	7.49	7.94	8.23	106	110	70-130	4	15	

APPENDIX - C

COMPUTER GENERATED RESULTS

Client: Metro Vancouver
Jobsite: WTE (Burnaby, BC)
Source: Unit 1

Date: 17-Jul-23
Run: 1 - Particulate / Metals
Run Time: 11:15 - 13:16

Concentrations:

Particulate	1.21 mg/dscm	0.00053 gr/dscf
	0.69 mg/Acm	0.00030 gr/Acf
	1.08 mg/dscm (@ 11% O2)	0.00047 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.087 Kg/hr	0.192 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1197 dscm/min	42272 dscf/min
	19.95 dscm/sec	705 dscf/sec
	2103 Acm/min	74277 Acf/min

Velocity	13.763 m/sec	45.15 f/sec
-----------------	--------------	-------------

Temperature	145.0 oC	293.0 oF
--------------------	----------	----------

Moisture	14.9 %
-----------------	--------

Gas Analysis	9.8 % O2
	10.0 % CO2

29.993 Mol. Wt (g/gmole) Dry
28.204 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.8051 dscm	99.061 dscf
Sample Time	120.0 minutes	
Isokineticity	103.3 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client:	Metro Vancouver	Date:	17-Jul-23
Jobsite:	WTE (Burnaby, BC)	Run:	1 - Particulate / Metals
Source:	Unit 1	Run Time:	11:10 - 13:15

Control Unit (Y)	0.9852	Collection:	Gas Analysis (Vol. %):	Condensate Collection:
Nozzle Diameter (in.)	0.3083	Filter (grams) 0.00150	CO2 O2	Impinger 1 216.0
Pitot Factor	0.8489	Washings (grams) 0.00190	10.00 9.90	Impinger 2 95.0
Baro. Press. (in. Hg)	29.98	Traverse 1	10.00 9.73	Impinger 3 26.0
Static Press. (in. H2O)	-19.50	Traverse 2		Impinger 4 10.0
Stack Height (ft)	30			Impinger 5 5.0
Stack Diameter (in.)	70.90			Impinger 6 3.0
Stack Area (sq.ft.)	27.417			Gel 14.0
Minutes Per Reading	5.0			
Minutes Per Point	5.0			

Total (grams) 0.00340	10.00 9.82	Gain (grams) 369.0
------------------------------	-------------------	---------------------------

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1										
1	5.0	272.565	0.34	1.91	85	85	4	289	1.5	103.1
2	10.0	280.420	0.35	1.97	85	85	4	287	4.7	103.2
3	15.0	284.700	0.40	2.28	90	90	4	285	8.4	103.3
4	20.0	289.050	0.41	2.34	91	91	4	284	12.5	103.4
5	25.0	293.940	0.52	2.96	93	93	4	289	17.7	103.4
6	30.0	298.880	0.53	3.02	94	94	4	290	25.2	103.3
7	35.0	304.050	0.58	3.30	94	94	6	291	45.6	103.5
8	40.0	308.860	0.50	2.84	97	97	6	295	53.2	103.3
9	45.0	313.580	0.48	2.73	97	97	6	296	58.3	103.5
10	50.0	318.490	0.52	2.96	98	98	6	296	62.5	103.4
11	55.0	323.050	0.45	2.56	97	97	6	296	66.1	103.3
12	60.0	327.460	0.42	2.39	98	98	6	297	69.4	103.2
Traverse 2										
1	5.0	327.460								
2	10.0	332.020	0.45	2.55	98	98	6	300	1.5	103.4
3	15.0	336.690	0.47	2.97	99	99	6	300	4.7	103.5
4	20.0	341.160	0.43	2.45	100	100	6	299	8.4	103.2
5	25.0	345.490	0.40	2.28	101	101	6	298	12.5	103.3
6	30.0	349.760	0.39	2.22	100	100	6	297	17.7	103.3
7	35.0	354.040	0.39	2.23	101	101	6	296	25.2	103.3
8	40.0	358.280	0.38	2.18	101	101	7	294	45.6	103.5
9	45.0	362.440	0.37	2.12	99	99	7	292	53.2	103.1
10	50.0	366.430	0.34	1.95	99	99	5	292	58.3	103.2
11	55.0	370.250	0.31	1.78	99	99	5	291	62.5	103.3
12	60.0	373.950	0.29	1.67	99	99	4	290	66.1	103.4
		377.700	0.30	1.73	99	99	4	288	69.4	102.9
Average:										
			0.418	2.391	96.4	96.4	4.0	293.0		103.3

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 1

Date: 19-Jul-23
Run: 2 - Particulate / Metals
Run Time: 08:57 - 11:01

Concentrations:

Particulate	0.39 mg/dscm	0.00017 gr/dscf
	0.22 mg/Acm	0.00009 gr/Acf
	0.34 mg/dscm (@ 11% O2)	0.00015 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.028 Kg/hr	0.061 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1173 dscm/min	41416 dscf/min
	19.55 dscm/sec	690 dscf/sec
	2121 Acm/min	74899 Acf/min

Velocity	13.878 m/sec	45.53 f/sec
-----------------	--------------	-------------

Temperature	146.3 oC	295.4 oF
--------------------	----------	----------

Moisture	17.2 %
-----------------	--------

Gas Analysis	9.6 % O2
	10.0 % CO2

29.989 Mol. Wt (g/gmole) Dry
27.925 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.8038 dscm	99.015 dscf
Sample Time	120.0 minutes	
Isokineticity	105.4 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
 Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 1

Date: 19-Jul-23
Run: 2 - Particulate / Metals
Run Time: 08:57 - 11:01

Control Unit (Y)	0.9852	Collection:	Gas Analysis (Vol. %):	Condensate Collection:
Nozzle Diameter (in.)	0.3083	Filter (grams) 0.00040	CO2 O2	Impinger 1 268.0
Pitot Factor	0.8489	Washings (grams) 0.00070	10.10 9.50	Impinger 2 120.0
Baro. Press. (in. Hg)	30.03		9.95 9.75	Impinger 3 18.0
Static Press. (in. H2O)	-19.50	Total (grams) 0.00110		Impinger 4 6.0
Stack Height (ft)	30			Impinger 5 4.0
Stack Diameter (in.)	70.90			Impinger 6 2.0
Stack Area (sq.ft.)	27.417			Gel 19.5
Minutes Per Reading	5.0		10.03 9.63	Gain (grams) 437.5
Minutes Per Point	5.0			

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	380.854								
1	5.0	384.570	0.31	1.74	85	85	5	288	1.5	105.3
2	10.0	388.170	0.29	1.63	87	87	5	289	4.7	105.1
3	15.0	391.980	0.32	1.82	90	90	5	287	8.4	105.2
4	20.0	395.910	0.34	1.93	90	90	5	287	12.5	105.3
5	25.0	399.670	0.31	1.77	92	92	5	287	17.7	105.1
6	30.0	403.310	0.29	1.65	93	93	5	288	25.2	105.1
7	35.0	407.850	0.45	2.57	93	93	5	288	45.6	105.4
8	40.0	412.500	0.47	2.68	94	94	5	288	53.2	105.5
9	45.0	417.110	0.46	2.63	96	96	6	290	58.3	105.5
10	50.0	421.910	0.50	2.86	96	96	6	290	62.5	105.4
11	55.0	426.530	0.46	2.63	97	97	8	290	66.1	105.5
12	60.0	430.940	0.42	2.47	97	97	8	289	69.4	105.3
Traverse 2	0.0	430.940								
1	5.0	435.410	0.44	2.48	95	95	4	300	1.5	105.4
2	10.0	440.010	0.47	2.64	93	93	4	300	4.7	105.4
3	15.0	444.730	0.49	2.76	95	95	6	300	8.4	105.5
4	20.0	449.250	0.45	2.53	95	95	6	300	12.5	105.4
5	25.0	453.880	0.47	2.65	97	97	7	302	17.7	105.4
6	30.0	458.470	0.46	2.60	98	98	7	302	25.2	105.5
7	35.0	463.370	0.52	2.94	101	101	7	304	45.6	105.5
8	40.0	468.030	0.47	2.67	102	102	7	304	53.2	105.3
9	45.0	472.530	0.44	2.49	100	100	7	304	58.3	105.5
10	50.0	476.820	0.40	2.26	100	100	7	304	62.5	105.4
11	55.0	481.160	0.41	2.32	100	100	8	304	66.1	105.3
12	60.0	485.550	0.42	2.37	100	100	8	304	69.4	105.3
Average:			0.419	2.379	95.3	95.3	6.1	295.4		105.4

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 1

Date: 19-Jul-23
Run: 3 - Particulate / Metals
Run Time: 11:30 - 13:32

Concentrations:

Particulate	1.9 mg/dscm	0.0008 gr/dscf
	1.0 mg/Acm	0.0004 gr/Acf
	1.7 mg/dscm (@ 11% O2)	0.0007 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.131 Kg/hr	0.288 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1159 dscm/min	40941 dscf/min
	19.32 dscm/sec	682 dscf/sec
	2130 Acm/min	75234 Acf/min

Velocity	13.940 m/sec	45.73 f/sec
-----------------	--------------	-------------

Temperature	153.6 oC	308.5 oF
--------------------	----------	----------

Moisture	17.1 %
-----------------	--------

Gas Analysis	10.1 % O2
	10.2 % CO2

30.030 Mol. Wt (g/gmole) Dry
27.971 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.7694 dscm	97.801 dscf
Sample Time	120.0 minutes	
Isokineticity	105.3 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 1

Date: 19-Jul-23
Run: 3 - Particulate / Metals
Run Time: 11:30 - 13:32

Control Unit (Y) 0.9852
 Nozzle Diameter (in.) 0.3083
 Pitot Factor 0.8489
 Baro. Press. (in. Hg) 30.03
 Static Press. (in. H2O) -19.50
 Stack Height (ft) 30
 Stack Diameter (in.) 70.90
 Stack Area (sq.ft.) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 5.0

Collection:
 Filter (grams) 0.00270
 Washings (grams) 0.00250
Total (grams) 0.00520

Traverse 1
 Traverse 2

Gas Analysis (Vol. %):
 CO2 O2
 9.5 10.43
 10.17 9.70
10.17 10.07

Condensate Collection:
 Impinger 1 270.0
 Impinger 2 100.0
 Impinger 3 28.0
 Impinger 4 8.0
 Impinger 5 4.0
 Impinger 6 2.0
 Gel 17.0
Gain (grams) 429.0

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	487.457								
1	5.0	491.880	0.44	2.46	88	88	7	295	1.5	105.2
2	10.0	496.420	0.46	2.56	94	94	7	308	4.7	105.4
3	15.0	501.180	0.50	2.80	98	98	9	308	8.4	105.3
4	20.0	505.650	0.44	2.47	98	98	9	307	12.5	105.3
5	25.0	510.270	0.47	2.63	98	98	10	308	17.7	105.4
6	30.0	514.850	0.46	2.58	100	100	10	309	25.2	105.3
7	35.0	519.650	0.51	2.85	98	98	10	310	45.6	105.3
8	40.0	524.260	0.47	2.63	98	98	10	310	53.2	105.3
9	45.0	528.720	0.44	2.96	98	98	10	310	58.3	105.4
10	50.0	532.980	0.40	2.24	98	98	10	309	62.5	105.3
11	55.0	537.290	0.41	2.29	98	98	9	309	66.1	105.3
12	60.0	541.550	0.40	2.24	98	98	9	308	69.4	105.2
Traverse 2	0.0	541.550								
1	5.0	545.340	0.32	1.78	96	96	7	310	1.5	105.1
2	10.0	549.010	0.30	1.67	96	96	7	310	4.7	105.1
3	15.0	552.760	0.31	1.73	98	98	7	310	8.4	105.2
4	20.0	556.670	0.34	1.89	97	97	7	311	12.5	105.1
5	25.0	560.350	0.30	1.67	97	97	7	311	17.7	105.2
6	30.0	563.900	0.28	1.56	97	97	7	311	25.2	105.0
7	35.0	568.370	0.44	1.47	98	98	10	308	45.6	105.1
8	40.0	573.040	0.48	2.69	98	98	10	308	53.2	105.4
9	45.0	577.730	0.48	2.69	99	99	10	308	58.3	105.7
10	50.0	582.440	0.49	2.75	99	99	10	309	62.5	105.1
11	55.0	586.960	0.45	2.52	99	99	11	309	66.1	105.2
12	60.0	591.283	0.41	2.30	99	99	11	308	69.4	105.3
Average:			0.417	2.310	97.4	97.4	8.9	308.5		105.3

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)
Source: Unit 1

Sample Type: HF

Parameter		Test 1	Test 2	Test 3
Test Date		19-Jul-23	19-Jul-23	19-Jul-23
Test Time		09:35-10:35	10:51-11:51	12:08-13:08
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.07	30.07	30.07
DGM Factor	(Y)	1.0276	1.0276	1.0276
Initial Reading	(m ³)	112.797	113.653	114.269
Final Reading	(m ³)	113.652	114.265	114.883
Temp. Outlet	(Avg. oF)	90.7	107.1	101.5
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm ³)	0.85	0.59	0.60
HF	(mg)	0.105	0.053	0.053
Oxygen	(Vol. %)	9.8	9.6	10.1
HF	(mg/Sm³)	0.124	0.089	0.088
HF	(mg/Sm³ @ 11% O2)	0.111	0.078	0.081
Moisture	(Vol. %)	17.2	17.2	17.1

Tstd. (oF)

68

Pstd. (in. Hg)

29.92

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)
Source: Unit 1

Sample Type: NH₃

Parameter		Test 1	Test 2	Test 3
Test Date		19-Jul-23	19-Jul-23	19-Jul-23
Test Time		09:35-10:35	10:51-11:51	12:08-13:08
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.07	30.07	30.07
DGM Factor	(Y)	1.0365	1.0365	1.0365
Initial Reading	(m ³)	260.516	261.002	261.487
Final Reading	(m ³)	260.999	261.482	261.974
Temp. Outlet	(Avg. oF)	91.0	102.8	100.8
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm ³)	0.48	0.47	0.48
NH ₃	(mg)	0.8	1.3	1.5
Oxygen	(Vol. %)	9.8	9.6	10.1
NH₃	(mg/Sm³)	1.6	2.7	3.1
NH₃	(mg/Sm³ @ 11% O2)	1.4	2.4	2.8
Moisture	(Vol. %)	17.2	17.2	17.1

Tstd. (oF)

68

Pstd. (in. Hg)

29.92

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 2

Date: 18-Jul-23
Run: 1 - Particulate / Metals
Run Time: 09:50 - 11:52

Concentrations:

Particulate	0.7 mg/dscm	0.0003 gr/dscf
	0.4 mg/Acm	0.0002 gr/Acf
	0.6 mg/dscm (@ 11% O2)	0.0003 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.045 Kg/hr	0.100 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1147 dscm/min	40491 dscf/min
	19.11 dscm/sec	675 dscf/sec
	2076 Acm/min	73308 Acf/min

Velocity	13.583 m/sec	44.56 f/sec
-----------------	--------------	-------------

Temperature	149.9 oC	301.9 oF
--------------------	----------	----------

Moisture	16.9 %
-----------------	--------

Gas Analysis	10.1 % O2 9.9 % CO2
---------------------	------------------------

29.988 Mol. Wt (g/gmole) Dry
27.964 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.7418 dscm	96.825 dscf
Sample Time	120.0 minutes	
Isokineticity	105.4 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client:	Metro Vancouver	Date:	18-Jul-23
Jobsite:	WTE (Burnaby, B.C)	Run:	1 - Particulate / Metals
Source:	Unit 2	Run Time:	09:50 - 11:52

Control Unit (Y)	1.0284	Collection:	Gas Analysis (Vol. %):		Condensate Collection:		
Nozzle Diameter (in.)	0.3083		CO2	O2	Impinger 1	266.0	
Pitot Factor	0.8489	Filter (grams) 0.00080			Impinger 2	96.0	
Baro. Press. (in. Hg)	30.13	Washings (grams) 0.00100	Traverse 1	9.83	10.03	Impinger 3	22.0
Static Press. (in. H2O)	-19.50	Total (grams) 0.00180	Traverse 2	10.00	10.07	Impinger 4	8.0
Stack Height (ft)	30.16					Impinger 5	4.0
Stack Diameter (in.)	70.90				Impinger 6	2.0	
Stack Area (sq.ft.)	27.417				Gel	20.0	
Minutes Per Reading	5.0			9.92	10.05	Gain (grams)	418.0
Minutes Per Point	5.0						

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	578.552								
1	5.0	582.660	0.44	2.38	72	72	5	300	1.5	105.3
2	10.0	586.820	0.45	2.43	73	73	5	302	4.7	105.4
3	15.0	591.020	0.46	2.49	73	73	5	302	8.4	105.3
4	20.0	595.320	0.48	2.60	74	74	5	302	12.5	105.3
5	25.0	599.520	0.46	2.49	74	74	6	303	17.7	105.1
6	30.0	603.350	0.38	2.06	75	75	6	302	25.2	105.1
7	35.0	607.040	0.35	1.90	77	77	6	303	45.6	105.1
8	40.0	610.580	0.32	1.74	77	77	6	303	53.2	105.4
9	45.0	614.010	0.30	1.64	77	77	7	299	58.3	105.2
10	50.0	617.280	0.27	1.48	80	80	7	302	62.5	105.3
11	55.0	620.450	0.25	1.38	84	84	6	302	66.1	105.3
12	60.0	623.580	0.24	1.39	88	88	6	299	69.4	105.1
Traverse 2	0.0	623.580								
1	5.0	627.080	0.31	1.70	81	81	5	301	1.5	105.0
2	10.0	630.750	0.34	1.86	81	81	5	303	4.7	105.3
3	15.0	634.200	0.30	1.64	82	82	5	305	8.4	105.3
4	20.0	637.600	0.29	1.60	84	84	5	304	12.5	105.0
5	25.0	640.890	0.27	1.49	85	85	6	303	17.7	105.1
6	30.0	644.340	0.28	1.63	85	85	6	304	25.2	108.3
7	35.0	648.990	0.54	2.98	85	85	7	302	45.6	105.3
8	40.0	653.980	0.62	3.43	86	86	7	302	53.2	105.4
9	45.0	658.890	0.60	3.32	86	86	8	302	58.3	105.4
10	50.0	663.860	0.61	3.39	87	87	8	301	62.5	105.5
11	55.0	668.940	0.64	3.55	87	87	8	302	66.1	105.4
12	60.0	673.800	0.58	3.24	87	87	8	297	69.4	105.5
Average:			0.408	2.242	80.8	80.8	6.2	301.9		105.4

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 2

Date: 18-Jul-23
Run: 2 - Particulate / Metals
Run Time: 12:28 - 14:29

Concentrations:

Particulate	0.66 mg/dscm	0.00029 gr/dscf
	0.36 mg/Acm	0.00016 gr/Acf
	0.53 mg/dscm (@ 11% O2)	0.00023 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.044 Kg/hr	0.097 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1110 dscm/min	39200 dscf/min
	18.50 dscm/sec	653 dscf/sec
	2039 Acm/min	72024 Acf/min

Velocity	13.345 m/sec	43.78 f/sec
-----------------	--------------	-------------

Temperature	150.6 oC	303.1 oF
--------------------	----------	----------

Moisture	18.0 %
-----------------	--------

Gas Analysis	8.6 % O2
	11.2 % CO2

30.131 Mol. Wt (g/gmole) Dry
27.951 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.5676 dscm	90.674 dscf
Sample Time	120.0 minutes	
Isokineticity	106.6 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client:	Metro Vancouver	Date:	18-Jul-23
Jobsite:	WTE (Burnaby, B.C)	Run:	2 - Particulate / Metals
Source:	Unit 2	Run Time:	12:28 - 14:29

Control Unit (Y)	1.0284	Collection:	Gas Analysis (Vol. %):	Condensate Collection:
Nozzle Diameter (in.)	0.3083	Filter (grams) 0.00010	CO2 O2	Impinger 1 278.0
Pitot Factor	0.8489	Washings (grams) 0.00160	11.00 8.73	Impinger 2 104.0
Baro. Press. (in. Hg)	30.13	Traverse 1	11.33 8.50	Impinger 3 14.0
Static Press. (in. H2O)	-19.50	Traverse 2		Impinger 4 5.0
Stack Height (ft)	30.16	Total (grams) 0.00170		Impinger 5 3.0
Stack Diameter (in.)	70.90			Impinger 6 2.0
Stack Area (sq.ft.)	27.417			Gel 16.1
Minutes Per Reading	5.0		11.17 8.62	Gain (grams) 422.1
Minutes Per Point	5.0			

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	675.890								
1	5.0	679.230	0.28	1.54	83	83	4	302	1.5	106.4
2	10.0	682.690	0.30	1.65	84	84	4	304	4.7	106.5
3	15.0	685.980	0.27	1.49	85	85	4	305	8.4	106.6
4	20.0	689.220	0.26	1.43	87	87	4	306	12.5	106.6
5	25.0	692.640	0.29	1.61	88	88	4	305	17.7	106.3
6	30.0	696.200	0.32	1.75	83	83	4	306	25.2	106.4
7	35.0	701.160	0.62	3.40	83	83	5	305	45.6	106.9
8	40.0	706.050	0.60	3.50	84	84	5	305	53.2	107.0
9	45.0	710.980	0.61	3.35	84	84	5	305	58.3	106.9
10	50.0	715.860	0.60	3.30	84	84	5	304	62.5	106.6
11	55.0	720.700	0.59	3.24	84	84	6	305	66.1	106.7
12	60.0	725.400	0.56	3.08	84	84	6	304	69.4	106.2
Traverse 2	0.0	725.400								
1	5.0	729.450	0.41	2.26	85	85	7	304	1.5	106.6
2	10.0	733.600	0.43	2.37	85	85	7	304	4.7	106.7
3	15.0	737.750	0.43	2.37	85	85	8	303	8.4	106.6
4	20.0	742.020	0.45	2.49	86	86	8	302	12.5	107.0
5	25.0	746.180	0.43	2.38	86	86	8	303	17.7	106.7
6	30.0	749.990	0.36	1.99	86	86	8	302	25.2	106.6
7	35.0	753.580	0.32	1.77	86	86	6	302	45.6	106.5
8	40.0	757.010	0.29	1.61	87	87	6	302	53.2	106.6
9	45.0	760.380	0.28	1.56	87	87	6	300	58.3	106.5
10	50.0	763.650	0.26	1.45	88	88	6	299	62.5	106.9
11	55.0	766.780	0.24	1.34	88	88	6	300	66.1	106.6
12	60.0	769.900	0.24	1.34	87	87	6	297	69.4	106.2
Average:			0.393	2.178	85.4	85.4	5.8	303.1		106.6

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 2

Date: 18-Jul-23
Run: 3 - Particulate / Metals
Run Time: 14:50 - 15:52

Concentrations:

Particulate	0.3 mg/dscm	0.0001 gr/dscf
	0.2 mg/Acm	0.0001 gr/Acf
	0.3 mg/dscm (@ 11% O2)	0.0001 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.02 Kg/hr	0.047 lb/hr
--------------------	------------	-------------

Flue Gas Characteristics:

Flow	1156 dscm/min	40839 dscf/min
	19.27 dscm/sec	681 dscf/sec
	2095 Acm/min	73968 Acf/min

Velocity	13.706 m/sec	44.97 f/sec
-----------------	--------------	-------------

Temperature	149.1 oC	300.3 oF
--------------------	----------	----------

Moisture	17.1 %
-----------------	--------

Gas Analysis	9.8 % O2
	10.2 % CO2

30.016 Mol. Wt (g/gmole) Dry
27.963 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.7711 dscm	97.863 dscf
Sample Time	120.0 minutes	
Isokineticity	105.6 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client:	Metro Vancouver	Date:	18-Jul-23
Jobsite:	WTE (Burnaby, B.C)	Run:	3 - Particulate / Metals
Source:	Unit 2	Run Time:	14:50 - 15:52

Control Unit (Y)	1.0284	Collection:		Gas Analysis (Vol. %):		Condensate Collection:			
Nozzle Diameter (in.)	0.3083		Filter (grams)	0.00005	CO2	O2	Impinger 1	240.0	
Pitot Factor	0.8489		Washings (grams)	0.00080	Traverse 1	10.33	9.80	Impinger 2	132.0
Baro. Press. (in. Hg)	30.13				Traverse 2	10.00	9.70	Impinger 3	28.0
Static Press. (in. H2O)	-19.50	Total (grams) 0.0008					Impinger 4	8.0	
Stack Height (ft)	30						Impinger 5	5.0	
Stack Diameter (in.)	70.90						Impinger 6	1.0	
Stack Area (sq.ft.)	27.417						Gel	14.7	
Minutes Per Reading	5.0				10.17	9.75	Gain (grams)	428.7	
Minutes Per Point	5.0								

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	770.233								
1	5.0	774.630	0.48	2.66	87	87	5.5	303	1.5	105.5
2	10.0	779.120	0.50	2.77	87	87	5.5	304	4.7	105.6
3	15.0	783.690	0.52	2.87	86	86	5.5	305	8.4	105.7
4	20.0	788.300	0.53	2.92	86	86	5.5	306	12.5	105.7
5	25.0	792.730	0.49	2.71	87	87	5.5	305	17.7	105.3
6	30.0	796.830	0.42	2.31	86	86	5.5	306	25.2	105.5
7	35.0	800.250	0.29	1.60	87	87	5.5	306	45.6	105.5
8	40.0	803.620	0.28	1.55	87	87	5.5	305	53.2	105.7
9	45.0	807.090	0.30	1.66	87	87	5.5	306	58.3	105.2
10	50.0	810.520	0.29	1.61	88	88	5.5	302	62.5	105.3
11	55.0	813.780	0.26	1.45	88	88	4.5	300	66.1	105.5
12	60.0	816.980	0.25	1.40	89	89	4.5	299	69.4	105.4
Traverse 2	0.0	816.980								
1	5.0	820.250	0.26	1.45	88	88	6	299	1.5	105.8
2	10.0	823.380	0.24	1.34	88	88	6	299	4.7	105.4
3	15.0	826.760	0.28	1.56	88	88	6	298	8.4	105.3
4	20.0	830.260	0.30	1.68	88	88	6	298	12.5	105.4
5	25.0	833.940	0.33	1.85	89	89	6.5	297	17.7	105.5
6	30.0	837.730	0.35	1.96	89	89	6.5	298	25.2	105.6
7	35.0	842.820	0.63	3.54	89	89	6.5	296	45.6	105.9
8	40.0	847.880	0.62	3.49	89	89	6.5	294	53.2	106.0
9	45.0	853.050	0.65	3.65	89	89	6.5	295	58.3	105.9
10	50.0	858.050	0.61	3.42	89	89	6	296	62.5	105.7
11	55.0	862.950	0.58	3.26	90	90	6	296	66.1	106.0
12	60.0	867.750	0.56	3.16	90	90	6	294	69.4	105.5
Average:			0.418	2.328	88.0	88.0	3.0	300.3		105.6

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)
Source: Unit 2

Sample Type: HF				
Parameter		Test 1	Test 2	Test 3
Test Date		18-Jul-23	18-Jul-23	18-Jul-23
Test Time		10:42-11:42	12:28 - 13:28	13:44-14:44
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.13	30.13	30.13
DGM Factor	(Y)	1.0365	1.0365	1.0365
Initial Reading	(m ³)	259.124	259.619	260.056
Final Reading	(m ³)	259.613	260.052	260.512
Temp. Outlet	(Avg. oF)	85.2	89.1	93.8
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm ³)	0.49550	0.43481	0.45373
HF	(mg)	0.042	0.053	0.047
Oxygen	(Vol. %)	10.1	8.6	9.8
HF	(mg/Sm³)	0.085	0.121	0.104
HF	(mg/Sm³ @ 11% O2)	0.078	0.098	0.093
Moisture (isokinetic)	(Vol. %)	16.9	18.0	17.1

*Wet Basis Calculated on moisture from isokinetic tests
Tstd. (oF) 68

Pstd. (in. Hg) 29.92

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)
Source: Unit 2

Sample Type: NH ₃				
Parameter		Test 1	Test 2	Test 3
Test Date		18-Jul-23	18-Jul-23	18-Jul-23
Test Time		10:42-11:42	12:28 - 13:28	13:44-14:44
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.13	30.13	30.13
DGM Factor	(Y)	1.0276	1.0276	1.0276
Initial Reading	(m ³)	110.960	111.599	112.186
Final Reading	(m ³)	111.594	112.183	112.793
Temp. Outlet	(Avg. oF)	89.5	91.4	97.5
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm ³)	0.63135	0.57918	0.59521
NH ₃	(mg)	1.7	2.2	1.9
Oxygen	(Vol. %)	10.1	8.6	9.8
NH₃	(mg/Sm³)	2.7	3.9	3.2
NH₃	(mg/Sm³ @ 11% O2)	2.4	3.1	2.8
Moisture (isokinetic)	(Vol. %)	16.9	18.0	17.1

*Wet Basis Calculated on moisture from isokinetic tests
Tstd. (oF) 68

Pstd. (in. Hg) 29.92

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 3

Date: 19-Jul-23
Run: 1 - Particulate / Metals
Run Time: 10:20 - 12:23

Concentrations:

Particulate	0.26 mg/dscm	0.00011 gr/dscf
	0.15 mg/Acm	0.00006 gr/Acf
	0.23 mg/dscm (@ 11% O2)	0.00010 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.018 Kg/hr	0.040 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1153 dscm/min	40731 dscf/min
	19.22 dscm/sec	679 dscf/sec
	2068 Acm/min	73034 Acf/min

Velocity	13.532 m/sec	44.40 f/sec
-----------------	--------------	-------------

Temperature	154.4 oC	310.0 oF
--------------------	----------	----------

Moisture	15.1 %
-----------------	--------

Gas Analysis	9.5 % O2
	10.7 % CO2

30.086 Mol. Wt (g/gmole) Dry
28.263 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.6656 dscm	94.137 dscf
Sample Time	120.0 minutes	
Isokineticity	103.5 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 3

Date: 19-Jul-23
Run: 1 - Particulate / Metals
Run Time: 10:20 - 12:23

Control Unit (Y) 0.9927
 Nozzle Diameter (in.) 0.3058
 Pitot Factor 0.8469
 Baro. Press. (in. Hg) 30.06
 Static Press. (in. H2O) -19.00
 Stack Height (ft) 30
 Stack Diameter (in.) 70.90
 Stack Area (sq.ft.) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 5.0

Collection:
 Filter (grams) 0.00010
 Washings (grams) 0.00060
Total (grams) 0.00070

Gas Analysis (Vol. %):
 CO2 O2
 Traverse 1 11.33 9.33
 Traverse 2 10.00 9.67
10.67 9.50

Condensate Collection:
 Impinger 1 216.0
 Impinger 2 94.0
 Impinger 3 22.0
 Impinger 4 6.0
 Impinger 5 3.0
 Impinger 6 1.0
 Gel 13.5
Gain (grams) 355.5

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	724.241								
1	5.0	728.940	0.54	2.80	79	79	5	302	1.5	103.9
2	10.0	733.720	0.56	2.90	80	80	5	308	4.7	104.0
3	15.0	738.330	0.52	2.69	81	81	6	305	8.4	103.7
4	20.0	742.880	0.51	2.63	81	81	6	310	12.5	103.6
5	25.0	747.380	0.50	2.57	81	81	7	312	17.7	103.6
6	30.0	751.660	0.44	2.26	82	82	7	312	25.2	104.8
7	35.0	755.300	0.33	1.72	83	83	5	302	45.6	101.9
8	40.0	758.690	0.28	1.46	83	83	5	305	53.2	103.2
9	45.0	761.830	0.24	1.24	83	83	5	309	58.3	103.5
10	50.0	765.030	0.25	1.29	84	84	5	312	62.5	103.3
11	55.0	768.120	0.23	1.19	86	86	5	314	66.1	103.8
12	60.0	771.160	0.22	1.16	87	87	5	303	69.4	103.4
Traverse 2	0.0	771.160								
1	5.0	774.680	0.30	1.56	86	86	6	310	1.5	103.3
2	10.0	778.260	0.31	1.61	87	87	6	311	4.7	103.3
3	15.0	781.900	0.32	1.66	88	88	5	313	8.4	103.3
4	20.0	785.180	0.26	1.35	88	88	5	313	12.5	103.2
5	25.0	788.540	0.27	1.41	89	89	5	312	17.7	103.5
6	30.0	792.140	0.31	1.61	89	89	5	313	25.2	103.6
7	35.0	796.480	0.45	2.55	90	90	7	312	45.6	103.6
8	40.0	801.480	0.60	3.13	91	91	7	315	53.2	103.6
9	45.0	806.560	0.62	3.23	91	91	8	316	58.3	103.6
10	50.0	811.490	0.58	3.03	92	92	8	315	62.5	103.6
11	55.0	816.480	0.59	3.10	92	92	8	310	66.1	103.7
12	60.0	821.350	0.56	2.96	92	92	8	305	69.4	103.5
Average:			0.408	2.130	86.0	86.0	6.0	310.0		103.5

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 3

Date: 20-Jul-23
Run: 2 - Particulate / Metals
Run Time: 09:17 - 11:18

Concentrations:

Particulate	0.04 mg/dscm	0.00002 gr/dscf
	0.02 mg/Acm	0.00001 gr/Acf
	0.03 mg/dscm (@ 11% O2)	0.00001 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.003 Kg/hr	0.006 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1162 dscm/min	41046 dscf/min
	19.37 dscm/sec	684 dscf/sec
	2050 Acm/min	72410 Acf/min

Velocity	13.417 m/sec	44.02 f/sec
-----------------	--------------	-------------

Temperature	152.8 oC	307.1 oF
--------------------	----------	----------

Moisture	14.1 %
-----------------	--------

Gas Analysis	9.9 % O2
	10.1 % CO2

30.010 Mol. Wt (g/gmole) Dry
28.312 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.6584 dscm	93.882 dscf
Sample Time	120.0 minutes	
Isokineticity	102.4 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Date: 20-Jul-23
Run: 2 - Particulate / Metals
Run Time: 09:17 - 11:18

Condensate Collection:	
Impinger 1	210.0
Impinger 2	96.0
Impinger 3	4.0
Impinger 4	3.0
Impinger 5	2.0
Impinger 6	1.0
Gel	12.5
Gain (grams)	328.5

A. Lanfranco and Associates Inc. (604-881-2582)

Client: Metro Vancouver
Jobsite: WTE(Burnaby,B.C)
Source: Unit 3

Date: 20-Jul-23
Run: 3 - Particulate / Metals
Run Time: 11:45 - 13:46

Concentrations:

Particulate	0.08 mg/dscm	0.00003 gr/dscf
	0.04 mg/Acm	0.00002 gr/Acf
	0.07 mg/dscm (@ 11% O2)	0.00003 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.005 Kg/hr	0.011 lb/hr
--------------------	-------------	-------------

Flue Gas Characteristics:

Flow	1093 dscm/min	38586 dscf/min
	18.21 dscm/sec	643 dscf/sec
	2013 Acn/min	71095 Acf/min

Velocity	13.173 m/sec	43.22 f/sec
-----------------	--------------	-------------

Temperature	157.6 oC	315.7 oF
--------------------	----------	----------

Moisture	16.9 %
-----------------	--------

Gas Analysis	9.3 % O2
	10.6 % CO2

30.066 Mol. Wt (g/gmole) Dry
28.030 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.5685 dscm	90.705 dscf
Sample Time	120.0 minutes	
Isokineticity	105.3 %	

*** Standard Conditions:** Metric: 20 deg C, 101.325 kPa
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE(Burnaby,B.C)
Source: Unit 3

Date: 20-Jul-23
Run: 3 - Particulate / Metals
Run Time: 11:45 - 13:46

Control Unit (Y)	0.9927	Collection:	Gas Analysis (Vol. %):	Condensate Collection:
Nozzle Diameter (in.)	0.3058	Filter (grams) 0.00010	CO2 O2	Impinger 1 264.0
Pitot Factor	0.8469	Washings (grams) 0.00010	Traverse 1 10.67 9.20	Impinger 2 90.0
Baro. Press. (in. Hg)	30.10		Traverse 2 10.50 9.40	Impinger 3 14.0
Static Press. (in. H2O)	-19.00	Total (grams) 0.00020		Impinger 4 5.0
Stack Height (ft)	30			Impinger 5 4.0
Stack Diameter (in.)	70.90			Impinger 6 2.0
Stack Area (sq.ft.)	27.417			Gel 12.2
Minutes Per Reading	5.0		10.59 9.30	Gain (grams) 391.2
Minutes Per Point	5.0			

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Inlet (oF)	Dry Gas Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	919.572								
1	5.0	923.900	0.45	2.34	90	90	7	314	1.5	105.3
2	10.0	928.280	0.46	2.39	90	90	7	316	4.7	105.5
3	15.0	932.750	0.48	2.50	91	91	8	316	8.4	105.3
4	20.0	937.280	0.49	2.55	92	92	8	316	12.5	105.4
5	25.0	941.660	0.46	2.39	91	91	8	316	17.7	105.3
6	30.0	945.990	0.45	2.34	91	91	8	316	25.2	105.3
7	35.0	949.760	0.34	1.77	91	91	8	316	45.6	105.3
8	40.0	953.360	0.31	1.61	91	91	8	316	53.2	105.3
9	45.0	956.780	0.28	1.46	91	91	8	316	58.3	105.2
10	50.0	960.150	0.27	1.41	92	92	8	317	62.5	105.4
11	55.0	963.450	0.26	1.35	92	92	7	317	66.1	105.2
12	60.0	966.620	0.24	1.25	92	92	7	314	69.4	104.9
Traverse 2	0.0	966.620								
1	5.0	969.860	0.25	1.31	93	93	8	316	1.5	105.0
2	10.0	973.230	0.27	1.41	94	94	8	317	4.7	105.0
3	15.0	976.530	0.26	1.36	93	93	8	317	8.4	105.0
4	20.0	979.770	0.25	1.30	93	93	8	318	12.5	105.2
5	25.0	983.080	0.26	1.36	93	93	8	316	17.7	105.2
6	30.0	986.450	0.27	1.41	93	93	8	317	25.2	105.2
7	35.0	991.130	0.52	2.72	94	94	8	316	45.6	105.4
8	40.0	995.630	0.48	2.51	94	94	8	315	53.2	105.3
9	45.0	1000.280	0.51	2.67	95	95	6	316	58.3	105.5
10	50.0	1004.980	0.52	2.73	95	95	6	315	62.5	105.6
11	55.0	1009.540	0.49	2.58	96	96	7	314	66.1	105.2
12	60.0	1014.180	0.50	2.65	96	96	7	309	69.4	105.7
Average:			0.378	1.974	92.6	92.6	7.6	315.7		105.3

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 3

Date: 25-Jul-23
Run: 1 - Cr⁺⁶
Run Time: 10:00 - 12:02

Concentrations:

Hexavalent Chromium	0.0 mg/dscm	0.0000 gr/dscf
	0.0 mg/Acm	0.0000 gr/Acf
	0.0 mg/dscm (@ 11% O2)	0.0000 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.00 Kg/hr	0.000 lb/hr
--------------------	------------	-------------

Flue Gas Characteristics:

Flow	1201 dscm/min	42399 dscf/min
	20.01 dscm/sec	707 dscf/sec
	2046 Acf/min	72254 Acf/min

Velocity	13.388 m/sec	43.92 f/sec
-----------------	--------------	-------------

Temperature	151.3 oC	304.3 oF
--------------------	----------	----------

Moisture	11.4 %
-----------------	--------

Gas Analysis	9.4 % O2
	10.3 % CO2

30.017 Mol. Wt (g/gmole) Dry
28.642 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.2966 dscm	81.105 dscf
Sample Time	120.0 minutes	
Isokineticity	99.5 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 3

Date: 25-Jul-23
Run: 1 - Cr+6
Run Time: 10:00 - 12:02

Control Unit (Y) 0.9927
Nozzle Diameter (in.) 0.2837
Pitot Factor 0.8489
Baro. Press. (in. Hg) 30.10
Static Press. (in. H2O) -19.00
Stack Height (ft) 30
Stack Diameter (in.) 70.90
Stack Area (sq.ft.) 27.417
Minutes Per Reading 5.0
Minutes Per Point 5.0

Collection:
 Cr+6 (grams) 0.00000044
Total (grams) 0.0000004

Traverse 1
 Traverse 2

Gas Analysis (Vol. %):
 CO2 10.00
 O2 9.50
 10.50 9.33

Condensate Collection:
 Impinger 1 -20.0
 Impinger 2 200.0
 Impinger 3 21.0
 Impinger 4 0.0

10.25 9.42

Gel 21.6
Gain (grams) 222.6

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	16.077								
1	5.0	18.760	0.26	0.96	60	60	69	306	1.5	99.0
2	10.0	21.550	0.28	1.04	60	60	6	306	4.7	99.3
3	15.0	24.500	0.31	1.15	60	60	6	305	8.4	99.7
4	20.0	27.500	0.32	1.20	60	60	6	305	12.5	99.8
5	25.0	30.500	0.32	1.20	60	60	6	306	17.7	99.9
6	30.0	33.350	0.29	1.07	60	60	6	306	25.2	99.6
7	35.0	37.160	0.52	1.93	60	60	6	305	45.6	99.6
8	40.0	40.910	0.50	1.86	62	62	6	305	53.2	99.6
9	45.0	44.880	0.56	2.08	62	62	7	305	58.3	99.7
10	50.0	48.860	0.56	2.09	64	64	7	305	62.5	99.5
11	55.0	52.760	0.54	2.02	64	64	7	305	66.1	99.3
12	60.0	56.460	0.48	1.80	65	65	7	305	69.4	99.7
Traverse 2	0.0	56.460								
1	5.0	60.390	0.54	2.03	67	67	8	305	1.5	99.5
2	10.0	64.320	0.54	2.04	68	68	8	304	4.7	99.3
3	15.0	68.080	0.49	1.85	68	68	8	304	8.4	99.7
4	20.0	71.760	0.47	1.77	66	66	8	303	12.5	99.9
5	25.0	75.390	0.46	1.73	66	66	8	303	17.7	99.6
6	30.0	78.960	0.45	1.69	64	64	8	303	25.2	99.4
7	35.0	82.070	0.34	1.27	62	62	7	303	45.6	99.9
8	40.0	85.080	0.32	1.19	62	62	7	303	53.2	99.6
9	45.0	87.980	0.30	1.12	62	62	7	303	58.3	99.1
10	50.0	90.790	0.28	1.05	62	62	7	303	62.5	99.4
11	55.0	93.540	0.27	1.01	62	62	7	303	66.1	99.0
12	60.0	96.200	0.25	0.95	62	62	7	302	69.4	99.5
Average:			0.402	1.504	62.8	62.8	9.5	304.3		99.5

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C)
Source: Unit 1

Date: 26-Jul-23
Run: 2 - Cr⁺⁶
Run Time: 09:22 - 11:24

Concentrations:

Hexavalent Chromium	0.0 mg/dscm	0.0000 gr/dscf
	0.0 mg/Acm	0.0000 gr/Acf
	0.0 mg/dscm (@ 11% O2)	0.0000 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.00 Kg/hr	0.000 lb/hr
--------------------	------------	-------------

Flue Gas Characteristics:

Flow	1217 dscm/min	42966 dscf/min
	20.28 dscm/sec	716 dscf/sec
	2063 Acf/min	72841 Acf/min

Velocity	13.497 m/sec	44.28 f/sec
-----------------	--------------	-------------

Temperature	154.2 oC	309.6 oF
--------------------	----------	----------

Moisture	10.4 %
-----------------	--------

Gas Analysis	10.1 % O2
	10.0 % CO2

30.002 Mol. Wt (g/gmole) Dry
28.758 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.3020 dscm	81.296 dscf
Sample Time	120.0 minutes	
Isokineticity	98.5 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Client: Metro Vancouver
Jobsite: WTE (Burnaby, B.C.)
Source: Unit 1

Date: 26-Jul-23
Run: 2 - Cr+6
Run Time: 09:22 - 11:24

Control Unit (Y) 0.9927
 Nozzle Diameter (in.) 0.2837
 Pitot Factor 0.8489
 Baro. Press. (in. Hg) 30.10
 Static Press. (in. H2O) -19.00
 Stack Height (ft) 30
 Stack Diameter (in.) 70.90
 Stack Area (sq.ft.) 27.417
 Minutes Per Reading 5.0
 Minutes Per Point 5.0

Collection:
 Cr+6 (grams) 0.00000042
Total (grams) 0.0000004

Traverse 1
 Traverse 2

Gas Analysis (Vol. %):
 CO2 10.00
 O2 10.30
 10.00 9.80

Condensate Collection:
 Impinger 1 -65.0
 Impinger 2 235.0
 Impinger 3 10.0
 Impinger 4 0.0

10.00 10.05

Gel 19.7
Gain (grams) 199.7

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	96.578								
1	5.0	99.360	0.27	1.01	68	68	3	309	1.5	98.5
2	10.0	102.200	0.28	1.05	70	70	3	310	4.7	98.4
3	15.0	105.140	0.30	1.15	70	70	3	310	8.4	98.4
4	20.0	108.180	0.32	1.20	70	70	3	310	12.5	98.6
5	25.0	111.310	0.34	1.28	70	70	3	310	17.7	98.5
6	30.0	114.300	0.31	1.17	71	71	3	310	25.2	98.3
7	35.0	118.420	0.59	2.22	71	71	7	309	45.6	98.4
8	40.0	122.440	0.56	2.11	72	72	4	309	53.2	98.3
9	45.0	126.440	0.55	2.07	72	72	4	310	58.3	98.8
10	50.0	130.470	0.56	2.11	72	72	4	311	62.5	98.7
11	55.0	134.350	0.52	1.96	72	72	4	311	66.1	98.6
12	60.0	137.990	0.46	1.73	72	72	4	310	69.4	98.2
Traverse 2	0.0	137.990								
1	5.0	142.060	0.57	2.15	73	73	4	310	1.5	98.5
2	10.0	146.070	0.55	2.08	75	75	4	310	4.7	98.4
3	15.0	149.940	0.51	1.93	75	75	4	310	8.4	98.6
4	20.0	153.710	0.48	1.82	76	76	4	310	12.5	98.8
5	25.0	157.350	0.45	1.71	76	76	4	310	17.7	98.5
6	30.0	160.920	0.43	1.65	76	76	4	310	25.2	98.8
7	35.0	164.200	0.36	1.37	78	78	5	309	45.6	98.7
8	40.0	167.320	0.33	1.26	78	78	5	309	53.2	98.1
9	45.0	170.360	0.31	1.20	78	78	5	309	58.3	98.6
10	50.0	173.200	0.27	1.03	78	78	5	308	62.5	98.6
11	55.0	175.940	0.25	0.96	78	78	5	308	66.1	98.8
12	60.0	178.560	0.23	0.88	79	79	5	308	69.4	98.3
Average:			0.408	1.546	73.8	73.8	4.1	309.6		98.5

Client: Metro Vancouver
Jobsite: WTE(Burnaby,B.C)
Source: Unit 1

Date: 26-Jul-23
Run: 3 - Cr⁺⁶
Run Time: 12:08 - 14:09

Concentrations:

Hexavalent Chromium	0.0 mg/dscm	0.0000 gr/dscf
	0.0 mg/Acm	0.0000 gr/Acf
	0.0 mg/dscm (@ 11% O2)	0.0000 gr/dscf (@ 11% O2)

Emission Rates:

Particulate	0.00 Kg/hr	0.000 lb/hr
--------------------	------------	-------------

Flue Gas Characteristics:

Flow	1187 dscm/min	41934 dscf/min
	19.79 dscm/sec	699 dscf/sec
	2107 Acm/min	74416 Acf/min

Velocity	13.788 m/sec	45.24 f/sec
-----------------	--------------	-------------

Temperature	155.5 oC	311.8 oF
--------------------	----------	----------

Moisture	14.1 %
-----------------	--------

Gas Analysis	9.8 % O2
	10.3 % CO2

30.031 Mol. Wt (g/gmole) Dry
28.332 Mol. Wt (g/gmole) Wet

Sample Parameters:

Sample Volume	2.3317 dscm	82.345 dscf
Sample Time	120.0 minutes	
Isokineticity	102.2 %	

*** Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

Date: 26-Jul-23
Run: 3 - Cr+6
Run Time: 12:08 - 14:09

Collection:
Cr+6 (grams) 0.00000044

Total (grams) 0.0000004

Condensate Collection:	
Impinger 1	-68.0
Impinger 2	295.0
Impinger 3	39.0
Impinger 4	0.0
<hr/>	
Gel	21.6
Gain (grams)	287.6

Page 26 of 29

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)
Source: Unit 3

Sample Type: HF				
Parameter		Test 1	Test 2	Test 3
Test Date		20-Jul-23	20-Jul-23	20-Jul-23
Test Time		10:10-11:10	11:35-12:35	12:45-13:45
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.10	30.10	30.10
DGM Factor	(Y)	1.0276	1.0276	1.0276
Initial Reading	(m ³)	114.897	115.542	116.193
Final Reading	(m ³)	115.539	116.189	116.880
Temp. Outlet	(Avg. oF)	67.5	73.8	76.8
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm ³)	0.66554	0.66239	0.69937
HF	(mg)	0.051	0.051	0.051
Oxygen	(Vol. %)	9.5	9.9	9.3
HF	(mg/Sm³)	0.077	0.078	0.074
HF	(mg/Sm³ @ 11% O2)	0.067	0.070	0.063
Moisture (isokinetic)	(Vol. %)	15.1	14.1	16.9

*Wet Basis Calculated on moisture from isokinetic tests
Tstd. (oF) 68

Pstd. (in. Hg) 29.92

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)
Source: Unit 3

Sample Type: NH ₃				
Parameter		Test 1	Test 2	Test 3
Test Date		20-Jul-23	20-Jul-23	20-Jul-23
Test Time		10:10-11:10	11:35-12:35	12:45-13:45
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.10	30.10	30.10
DGM Factor	(Y)	1.0365	1.0365	1.0365
Initial Reading	(m ³)	261.978	262.497	262.863
Final Reading	(m ³)	262.482	262.860	263.254
Temp. Outlet	(Avg. oF)	69.5	73.8	79.8
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm ³)	0.52511	0.37434	0.39907
NH ₃	(mg)	4.2	1.6	1.5
Oxygen	(Vol. %)	9.5	9.9	9.3
NH₃	(mg/Sm³)	8.0	4.2	3.8
NH₃	(mg/Sm³ @ 11% O2)	6.9	3.8	3.2
Moisture (isokinetic)	(Vol. %)	15.1	14.1	16.9

*Wet Basis Calculated on moisture from isokinetic tests
Tstd. (oF) 68

Pstd. (in. Hg) 29.92

Client: Metro Vancouver
Jobsite: WTE (Burnaby,B.C)

Parameter: N₂O

Molecular Weight: 44.00 grams/mol **Reportable Detection**
Lab Detection Limit: 0.1 ppm **Limit:** 0.18 mg/Sm³

Sample ID	Date	Time	N ₂ O ppm	N ₂ O mg/Sm ³	N ₂ O mg/Sm ³ @ 11% O ₂
Unit 1 - Run 1	2023-07-19	09:35 - 10:35	0.00	0.18	0.16
Unit 1 - Run 2	2023-07-19	10:51 - 11:51	3.00	5.49	4.83
Unit 1 - Run 3	2023-07-19	12:08 - 13:08	0.00	0.18	0.17
Average					1.72
Unit 2 - Run 1	2023-07-18	10:42 - 11:42	0.00	0.18	0.17
Unit 2 - Run 2	2023-07-18	12:28 - 12:28	0.00	0.18	0.15
Unit 2 - Run 3	2023-07-18	13:44 - 14:44	0.00	0.18	0.16
Average					0.16
Unit 3 - Run 1	2023-07-20	10:10 - 11:10	0.00	0.18	0.16
Unit 3 - Run 2	2023-07-20	11:35 - 12:35	0.00	0.18	0.16
Unit 3 - Run 3	2023-07-20	12:45 - 13:45	0.00	0.18	0.16
Average					0.16

Date:	19-Jul-23			18-Jul-23			20-Jul-23		
	Unit 1			Unit 2			Unit 3		
	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3
Test Times:	09:35 - 10:35	10:51 - 11:51	12:08 - 13:08	10:42 - 11:42	12:28 - 13:28	13:44 - 14:44	10:10 - 11:10	11:35 - 12:35	12:45 - 13:45
Methane (ppmv)	4.50	ND	ND	5.4	ND	ND	ND	ND	ND
Ethane (ppmv)	ND	ND	ND	ND	ND	ND	ND	ND	ND
Ethene (ppmv)	ND	ND	ND	ND	ND	ND	ND	ND	ND
C3 as Propane (ppmv)	ND	ND	ND	ND	ND	ND	ND	ND	ND
C4 as n-Butane (ppmv)	ND	ND	ND	ND	ND	ND	ND	ND	ND
C5 as n-Pentane (ppmv)	ND	ND	ND	ND	ND	ND	ND	ND	ND
C6 as n-Hexane (ppmv)	ND	1.7	ND	ND	ND	ND	ND	ND	ND
C6+ as n-Hexane (ppmv)	ND	ND	ND	2.7	ND	ND	ND	ND	ND

Detection Limits:

Methane	3.4	3.3	3.7	4.2	3.4	3.3	3.7	3.8	3.5
Ethane	1.00	0.98	1.1	1.2	1.0	0.99	1.10	1.1	1.10
Ethene	1.00	0.98	1.1	1.2	1.0	0.99	1.10	1.1	1.10
C3 as Propane	0.85	0.82	0.94	1	0.85	0.83	0.92	0.96	0.88
C4 as n-Butane	0.85	0.82	0.94	1	0.85	0.83	0.92	0.96	0.88
C5 as n-Pentane	0.85	0.82	0.94	1	0.85	0.83	0.92	0.96	0.88
C6 as n-Hexane	0.85	0.82	0.94	1	0.85	0.83	0.92	0.96	0.88
C6+	1.7	1.6	1.9	2.1	1.7	1.7	1.8	1.9	1.8

Using 1/2 DL Convention

Sample Date:	19-Jul-23			18-Jul-23			20-Jul-23		
	Unit 1			Unit 2			Unit 3		
	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3
Test Times:	09:35 - 10:35	10:51 - 11:51	12:08 - 13:08	10:42 - 11:42	12:28 - 13:28	13:44 - 14:44	10:10 - 11:10	11:35 - 12:35	12:45 - 13:45
Methane (ppm)	4.50	1.65	1.85	5.40	1.70	1.65	1.85	1.90	1.75
Ethane (ppm)	0.50	0.49	0.55	0.60	0.50	0.50	0.55	0.55	0.55
Ethene (ppm)	0.50	0.49	0.55	0.60	0.50	0.50	0.55	0.55	0.55
C3 as Propane (ppm)	0.43	0.41	0.47	0.50	0.43	0.42	0.46	0.48	0.44
C4 as n-Butane (ppm)	0.43	0.41	0.47	0.50	0.43	0.42	0.46	0.48	0.44
C5 as n-Pentane (ppm)	0.43	0.41	0.47	0.50	0.43	0.42	0.46	0.48	0.44
C6 as n-Hexane (ppm)	0.43	1.70	0.47	0.50	0.43	0.42	0.46	0.48	0.44
C6+ as n-Hexane (ppm)	0.85	0.80	0.95	2.70	0.85	0.85	0.90	0.95	0.90

Methane (mg/m³ as CH₄)	3.00	1.10	1.23	3.60	1.13	1.10	1.23	1.27	1.17
Ethane (mg/m³ as CH₄)	0.33	0.33	0.37	0.40	0.33	0.33	0.37	0.37	0.37
Ethene (mg/m³ as CH₄)	0.33	0.33	0.37	0.40	0.33	0.33	0.37	0.37	0.37
C3 as Propane (mg/m³ as CH₄)	0.28	0.27	0.31	0.33	0.28	0.28	0.31	0.32	0.29
C4 as n-Butane (mg/m³ as CH₄)	0.28	0.27	0.31	0.33	0.28	0.28	0.31	0.32	0.29
C5 as n-Pentane (mg/m³ as CH₄)	0.28	0.27	0.31	0.33	0.28	0.28	0.31	0.32	0.29
C6 as n-Hexane (mg/m³ as CH₄)	0.28	1.13	0.31	0.33	0.28	0.28	0.31	0.32	0.29
C6+ as n-Hexane (mg/m³ as CH₄)	0.57	0.53	0.63	1.80	0.57	0.57	0.60	0.63	0.60

Total mg/Sm³ @11% O₂ as CH₄	4.01	3.10	2.82	5.51	2.90	2.58	2.63	2.90	2.87
---	------	------	------	------	------	------	------	------	------

All data is corrected to standard conditions (S) of 20 °C, 101.325 kPa (dry) unless otherwise noted.

APPENDIX - D

FIELD DATA SHEETS

METRO VANCOUVER WTE - BURNABY B.C.				NOZZLE PROBE	G-3121 7'C	DIAMETER, IN. Cp	0.3083 0.8489	IMPINGER VOLUMES	INITIAL (mL)	FINAL (mL)	TOTAL GAIN (mL)
SOURCE	Unit #1			PORT LENGTH				Imp. #1	0	216	216
PARAMETER / RUN No	Matsok / Plastic / R-1			STATIC PRESSURE, IN. H2O	-19.5"			Imp. #2	100	195	95
DATE	July 17, 2023			STACK DIAMETER	70.9'			Imp. #3	100	126	26
OPERATOR:	BS			STACK HEIGHT	30.6'			Imp. #4	0	10	10
CONTROL UNIT	CPE AL 1			INITIAL LEAK TEST	0.001 @ 15"			Imp. #5	100	105	5
	Y			FINAL LEAK TEST	0.002 @ 15"			Imp. #6	100	123	23
	ΔH@							Imp. #7	100	100	0
BAROMETRIC PRESSURE, IN. Hg	29.98							Imp. #8	100	100	0
ASSUMED MOISTURE, Bw	15%										

Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites			
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %		
1	11:15	272.565												
2	10	276.46	0.34	1.91	85	289	259	263	45	4				
3		280.47	0.35	1.97	85	287					10.0	9.6		
4	20	284.70	0.40	2.28	90	285	251	257	46	4				
5		289.05	0.41	2.34	91	284								
6	30	293.94	0.57	2.96	93	289	250	255	48	4				
7		298.88	0.53	3.02	94	290								
8	40	304.05	0.58	3.30	94	291	250	256	52	6				
9		308.86	0.50	2.84	93	295					10.0	10.1		
10	50	313.58	0.48	2.73	97	296	249	255	54	6				
11		318.49	0.52	2.96	98	296								
12	60	323.05	0.45	2.56	97	296	250	255	52	6				
		327.46	0.42	2.39	98	297					10.0	10.0		
1		332.02	0.45	2.55	98	300	250	255	54	6				
2	10	336.69	0.47	2.67	99	300					10.0	10.0		
3		341.16	0.43	2.45	100	299	251	255	56	6				
4	20	345.49	0.40	2.28	101	298								
5		349.76	0.39	2.22	100	297	251	255	57	6				
6	30	354.04	0.39	2.23	101	296					10.5	9.0		
7		358.28	0.38	2.18	101	294	250	255	58	7				
8	40	362.44	0.37	2.12	99	292								
9		366.43	0.34	1.95	99	292	250	255	59	5				
10	50	370.25	0.31	1.78	99	291								
11		373.95	0.29	1.67	99	290	251	255	60	4	9.5	10.2		
12	13:14	377.70	0.30	1.73	99	288								

J.H.

[illegible]

JH

[illegible]

METRO VANCOUVER WTE - BURNABY B.C.					NOZZLE	DIAMETER, IN.					IMPINGER	INITIAL	FINAL	TOTAL GAIN	
					PROBE	Cp					VOLUMES	(mL)	(mL)	(mL)	
SOURCE <i>Unit #2</i>										Imp. #1	<i>0</i>	<i>266</i>	<i>266</i>		
PARAMETER / RUN No <i>Metals / Particulate / R-1</i>					PORT LENGTH					Imp. #2	<i>100</i>	<i>196</i>	<i>96</i>		
DATE <i>July 18, 2023</i>					STATIC PRESSURE, IN. H2O <i>-19.5"</i>					Imp. #3	<i>100</i>	<i>122</i>	<i>22</i>		
OPERATOR: <i>OS</i>					STACK DIAMETER <i>70.9'</i>					Imp. #4	<i>0</i>	<i>8</i>	<i>8</i>		
CONTROL UNIT <i>FE 18</i> Y <i>1.0284</i>					STACK HEIGHT <i>30.0'</i>					Imp. #5	<i>100</i>	<i>104</i>	<i>4</i>		
										Imp. #6	<i>100</i>	<i>102</i>	<i>2</i>		
BAROMETRIC PRESSURE, IN. Hg <i>30.13</i>					INITIAL LEAK TEST <i>0.002 @ 15"</i>					Imp. #7	<i>200</i>				
ASSUMED MOISTURE, Bw <i>15%</i>					FINAL LEAK TEST <i>0.003 @ 15"</i>					Imp. #8					
					Temperature °F					Pump Vac.	Fyrites				
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Dry Gas Outlet	Stack	Probe	Box	Impinger Exit	IN. Hg	CO ₂		O ₂		
											Vol. %				
	<i>09:50</i>	<i>578.552</i>													
1		<i>582.66</i>	<i>0.44</i>	<i>2.38</i>	<i>72</i>	<i>300</i>	<i>251</i>	<i>258</i>	<i>63</i>	<i>5</i>					
2	10	<i>586.82</i>	<i>0.45</i>	<i>2.43</i>	<i>73</i>	<i>302</i>					<i>10.0</i>	<i>10.1</i>			
3		<i>591.02</i>	<i>0.46</i>	<i>2.49</i>	<i>73</i>	<i>302</i>	<i>249</i>	<i>249</i>	<i>61</i>	<i>5</i>					
4	20	<i>595.32</i>	<i>0.48</i>	<i>2.60</i>	<i>74</i>	<i>302</i>									
5		<i>599.52</i>	<i>0.46</i>	<i>2.49</i>	<i>74</i>	<i>303</i>	<i>250</i>	<i>250</i>	<i>60</i>	<i>6</i>					
6	30	<i>603.35</i>	<i>0.38</i>	<i>2.06</i>	<i>75</i>	<i>302</i>									
7		<i>607.04</i>	<i>0.35</i>	<i>1.90</i>	<i>77</i>	<i>303</i>	<i>251</i>	<i>251</i>	<i>58</i>	<i>6</i>	<i>9.5</i>	<i>10.3</i>			
8	40	<i>610.58</i>	<i>0.37</i>	<i>1.74</i>	<i>77</i>	<i>303</i>									
9		<i>614.01</i>	<i>0.30</i>	<i>1.64</i>	<i>77</i>	<i>299</i>	<i>250</i>	<i>250</i>	<i>56</i>	<i>7</i>					
10	50	<i>617.28</i>	<i>0.27</i>	<i>1.48</i>	<i>80</i>	<i>302</i>									
11		<i>620.45</i>	<i>0.25</i>	<i>1.38</i>	<i>84</i>	<i>302</i>	<i>250</i>	<i>250</i>	<i>52</i>	<i>6</i>	<i>10.0</i>	<i>9.7</i>			
12	60	<i>623.58</i>	<i>0.24</i>	<i>1.34</i>	<i>88</i>	<i>299</i>									
1		<i>627.08</i>	<i>0.31</i>	<i>1.70</i>	<i>81</i>	<i>301</i>	<i>247</i>	<i>245</i>	<i>55</i>	<i>5</i>					
2	10	<i>630.75</i>	<i>0.34</i>	<i>1.86</i>	<i>81</i>	<i>303</i>					<i>10.0</i>	<i>10.1</i>			
3		<i>634.70</i>	<i>0.30</i>	<i>1.64</i>	<i>82</i>	<i>305</i>	<i>251</i>	<i>250</i>	<i>57</i>	<i>5</i>					
4	20	<i>637.60</i>	<i>0.29</i>	<i>1.60</i>	<i>84</i>	<i>304</i>									
5		<i>640.89</i>	<i>0.28</i>	<i>1.49</i>	<i>85</i>	<i>303</i>	<i>251</i>	<i>251</i>	<i>59</i>	<i>6</i>					
6	30	<i>644.34</i>	<i>0.28</i>	<i>1.63</i>	<i>85</i>	<i>304</i>					<i>10.0</i>	<i>10.1</i>			
7		<i>648.79</i>	<i>0.54</i>	<i>2.98</i>	<i>85</i>	<i>302</i>	<i>250</i>	<i>248</i>	<i>55</i>	<i>7</i>					
8	40	<i>653.98</i>	<i>0.62</i>	<i>3.43</i>	<i>86</i>	<i>302</i>									
9		<i>658.89</i>	<i>0.60</i>	<i>3.32</i>	<i>86</i>	<i>302</i>	<i>247</i>	<i>248</i>	<i>54</i>	<i>8</i>					
10	50	<i>663.86</i>	<i>0.61</i>	<i>3.39</i>	<i>87</i>	<i>301</i>									
11		<i>668.94</i>	<i>0.64</i>	<i>3.55</i>	<i>88</i>	<i>302</i>	<i>248</i>	<i>245</i>	<i>57</i>	<i>8</i>	<i>10.0</i>	<i>10.0</i>			
12	<i>11:52</i>	<i>673.80</i>	<i>0.58</i>	<i>3.24</i>	<i>87</i>	<i>297</i>									

METRO VANCOUVER WTE - BURNABY B.C.					NOZZLE	DIAMETER, IN.		IMPINGER	INITIAL	FINAL	TOTAL GAIN				
SOURCE <i>Unit #2</i>					PROBE	<i>G-3121</i> Cp <i>0.8489</i>		VOLUMES	(mL)	(mL)	(mL)				
PARAMETER / RUN No <i>Metals / Particulate / R-2</i>					PORT LENGTH				Imp. #1	<i>0</i>	<i>278</i>	<i>278</i>			
DATE <i>July 18, 2023</i>					STATIC PRESSURE, IN. H2O <i>-19.5'</i>				Imp. #2	<i>100</i>	<i>209</i>	<i>109</i>			
OPERATOR: <i>DS</i>					STACK DIAMETER <i>70.9'</i>				Imp. #3	<i>100</i>	<i>119</i>	<i>19</i>			
CONTROL UNIT <i>FE18</i> Y <i>1.0284</i>					STACK HEIGHT <i>30.0'</i>				Imp. #4	<i>0</i>	<i>5</i>	<i>5</i>			
ΔH@ <i>1.824</i>									Imp. #5	<i>100</i>	<i>103</i>	<i>3</i>			
BAROMETRIC PRESSURE, IN. Hg <i>30.13</i>					INITIAL LEAK TEST <i>0.002 @ 15"</i>				Imp. #6	<i>100</i>	<i>102</i>	<i>2</i>			
ASSUMED MOISTURE, Bw <i>15%</i>					FINAL LEAK TEST <i>0.001 @ 15"</i>				Imp. #7	<i>200</i>					
									Imp. #8						
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites				
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %			
	<i>12:28</i>	<i>675.890</i>													
1		<i>679.23</i>	<i>0.28</i>	<i>1.54</i>	<i>83</i>	<i>302</i>	<i>243</i>	<i>262</i>	<i>52</i>	<i>4</i>					
2	10	<i>682.69</i>	<i>0.30</i>	<i>1.65</i>	<i>84</i>	<i>304</i>					<i>11.0</i>	<i>8.9</i>			
3		<i>685.98</i>	<i>0.27</i>	<i>1.49</i>	<i>85</i>	<i>305</i>	<i>254</i>	<i>268</i>	<i>54</i>	<i>4</i>					
4	20	<i>689.22</i>	<i>0.26</i>	<i>1.43</i>	<i>87</i>	<i>306</i>									
5		<i>692.64</i>	<i>0.29</i>	<i>1.61</i>	<i>88</i>	<i>305</i>	<i>257</i>	<i>260</i>	<i>55</i>	<i>4</i>					
6	30	<i>696.70</i>	<i>0.82</i>	<i>1.75</i>	<i>83</i>	<i>306</i>									
7		<i>701.16</i>	<i>0.67</i>	<i>3.40</i>	<i>83</i>	<i>305</i>	<i>252</i>	<i>251</i>	<i>54</i>	<i>5</i>	<i>11.0</i>	<i>8.6</i>			
8	40	<i>706.05</i>	<i>0.60</i>	<i>3.30</i>	<i>84</i>	<i>305</i>									
9		<i>710.98</i>	<i>0.61</i>	<i>3.35</i>	<i>84</i>	<i>305</i>	<i>249</i>	<i>250</i>	<i>52</i>	<i>5</i>					
10	50	<i>715.86</i>	<i>0.60</i>	<i>3.30</i>	<i>84</i>	<i>304</i>									
11		<i>720.70</i>	<i>0.59</i>	<i>3.74</i>	<i>84</i>	<i>305</i>	<i>252</i>	<i>251</i>	<i>54</i>	<i>6</i>	<i>11.0</i>	<i>8.7</i>			
12	60	<i>725.40</i>	<i>0.56</i>	<i>3.08</i>	<i>84</i>	<i>304</i>									
1		<i>729.45</i>	<i>0.41</i>	<i>2.26</i>	<i>85</i>	<i>304</i>	<i>250</i>	<i>250</i>	<i>55</i>	<i>7</i>					
2	10	<i>733.60</i>	<i>0.43</i>	<i>2.37</i>	<i>85</i>	<i>304</i>					<i>11.0</i>	<i>8.8</i>			
3		<i>737.75</i>	<i>0.43</i>	<i>2.37</i>	<i>85</i>	<i>303</i>	<i>249</i>	<i>250</i>	<i>54</i>	<i>8</i>					
4	20	<i>742.02</i>	<i>0.45</i>	<i>2.49</i>	<i>86</i>	<i>302</i>									
5		<i>746.18</i>	<i>0.43</i>	<i>2.38</i>	<i>86</i>	<i>303</i>	<i>250</i>	<i>250</i>	<i>60</i>	<i>8</i>					
6	30	<i>749.99</i>	<i>0.36</i>	<i>1.99</i>	<i>86</i>	<i>302</i>					<i>12.0</i>	<i>9.6</i>			
7		<i>753.58</i>	<i>0.37</i>	<i>1.77</i>	<i>86</i>	<i>302</i>	<i>251</i>	<i>251</i>	<i>60</i>	<i>6</i>					
8	40	<i>757.01</i>	<i>0.29</i>	<i>1.67</i>	<i>87</i>	<i>302</i>									
9		<i>760.38</i>	<i>0.28</i>	<i>1.56</i>	<i>87</i>	<i>300</i>	<i>250</i>	<i>250</i>	<i>63</i>	<i>6</i>					
10	50	<i>763.65</i>	<i>0.26</i>	<i>1.45</i>	<i>88</i>	<i>299</i>					<i>11.0</i>	<i>9.1</i>			
11		<i>766.78</i>	<i>0.24</i>	<i>1.34</i>	<i>88</i>	<i>300</i>	<i>251</i>	<i>251</i>	<i>63</i>	<i>6</i>					
12	<i>14:29</i>	<i>769.90</i>	<i>0.24</i>	<i>1.34</i>	<i>87</i>	<i>297</i>									

JH

METRO VANCOUVER WTE - BURNABY B.C.					NOZZLE	G-312		DIAMETER, IN.		0.3083	IMPINGER	INITIAL	FINAL	TOTAL GAIN
					PROBE	71C		Cp		0.8489	VOLUMES	(mL)	(mL)	(mL)
SOURCE Unit #2											Imp. #1	0	240	240
PARAMETER / RUN No Metals/Particulate / R-3					PORT LENGTH						Imp. #2	100	232	132
DATE July 18 2023					STATIC PRESSURE, IN. H2O, -19.5"						Imp. #3	100	128	28
OPERATOR: DS					STACK DIAMETER 70.94						Imp. #4	0	8	8
CONTROL UNIT FE 18 Y 1.0284					STACK HEIGHT 30.0'						Imp. #5	100	105	5
											Imp. #6	100	101	1
											Imp. #7	200g		
BAROMETRIC PRESSURE, IN. Hg 30.13					INITIAL LEAK TEST 0.002 @ 15"						Imp. #8			
ASSUMED MOISTURE, Bw 15%					FINAL LEAK TEST 0.003 @ 15"									
					Temperature °F					Pump Vac.	Fyrites			
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Dry Gas Outlet	Stack	Probe	Box	Impinger Exit	IN. Hg	CO ₂ Vol. %	O ₂ Vol. %		
	14:50	770.233												
1		774.63	0.48	2.66	87	303	250	251	63	6				
2	10	779.12	0.50	2.77	87	304					11.0	9.3		
3		783.69	0.52	2.87	86	305	258	255	58	6				
4	20	788.30	0.53	2.97	86	306								
5		792.73	0.49	2.71	87	305	253	253	59	6				
6	30	796.83	0.47	2.31	86	306								
7		800.28	0.29	1.60	87	306	252	253	58	5	10.0	10.1		
8	40	803.67	0.28	1.55	87	305								
9		807.09	0.30	1.66	87	306	252	250	59	4				
10	50	810.57	0.29	1.61	88	302								
11		813.78	0.26	1.45	88	300	250	250	60	4	10.0	10.0		
12	60	816.98	0.25	1.40	89	299								
1		820.25	0.26	1.45	88	299	251	250	56	4				
2	10	823.38	0.24	1.34	88	299					10.0	9.7		
3		826.76	0.28	1.56	88	298	250	250	58	4				
4	20	830.26	0.30	1.68	88	298								
5		833.94	0.32	1.85	89	297	250	252	59	4				
6	30	837.73	0.35	1.96	89	298								
7		842.82	0.63	3.59	89	296	250	249	56	6	10.0	9.6		
8	40	847.88	0.62	3.49	89	294								
9		853.05	0.65	3.65	89	295	251	250	57	7				
10	50	858.05	0.61	3.42	89	296								
11		862.95	0.58	3.26	90	296	251	250	58	7	10.0	9.8		
12	16:52	867.75	0.56	3.16	90	294								

METRO VANCOUVER WTE - BURNABY B.C.					NOZZLE <u>G-309</u>		DIAMETER, IN. <u>0.3058</u>		IMPINGER		INITIAL		FINAL		TOTAL GAIN		
SOURCE <u>Unit #3</u>					PROBE <u>7A1</u>		Cp <u>0.8469</u>		VOLUMES		(mL)		(mL)		(mL)		
PARAMETER / RUN No <u>Metals / particulate / R-1</u>					PORT LENGTH				Imp. #1								
DATE <u>July 19th, 2023</u>					STATIC PRESSURE, IN. H ₂ O <u>-19.0"</u>				Imp. #2								
OPERATOR: <u>DS</u>					STACK DIAMETER <u>10.9"</u>				Imp. #3								
CONTROL UNIT <u>STC AE 7</u> Y <u>0.9927</u>					STACK HEIGHT <u>30.0'</u>				Imp. #4								
ΔH@ <u>1.795</u>									Imp. #5								
BAROMETRIC PRESSURE, IN. Hg <u>30.06</u>					INITIAL LEAK TEST <u>0.001 @ 15"</u>				Imp. #6								
ASSUMED MOISTURE, Bw <u>15%</u>					FINAL LEAK TEST <u>0.002 @ 15"</u>				Imp. #7								
									Imp. #8								
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites						
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %					
1	<u>10:20</u>	<u>724.241</u>															
2		<u>728.94</u>	<u>0.54</u>	<u>2.80</u>	<u>79</u>	<u>302</u>	<u>251</u>	<u>254</u>	<u>61</u>	<u>5</u>							
3		<u>733.71</u>	<u>0.56</u>	<u>2.90</u>	<u>80</u>	<u>308</u>											
4		<u>738.33</u>	<u>0.52</u>	<u>2.69</u>	<u>81</u>	<u>305</u>	<u>249</u>	<u>246</u>	<u>63</u>	<u>6</u>							
5		<u>742.88</u>	<u>0.51</u>	<u>2.63</u>	<u>81</u>	<u>310</u>											
6		<u>747.38</u>	<u>0.50</u>	<u>2.57</u>	<u>81</u>	<u>312</u>	<u>251</u>	<u>251</u>	<u>61</u>	<u>7</u>							
7		<u>751.66</u>	<u>0.44</u>	<u>2.23</u>	<u>82</u>	<u>312</u>					<u>11.5</u>	<u>9.0</u>					
8		<u>755.30</u>	<u>0.33</u>	<u>1.72</u>	<u>83</u>	<u>302</u>	<u>251</u>	<u>254</u>	<u>58</u>	<u>8</u>							
9		<u>758.69</u>	<u>0.28</u>	<u>1.46</u>	<u>83</u>	<u>305</u>											
10		<u>761.83</u>	<u>0.24</u>	<u>1.24</u>	<u>83</u>	<u>309</u>	<u>250</u>	<u>258</u>	<u>57</u>	<u>5</u>							
11		<u>765.03</u>	<u>0.25</u>	<u>1.29</u>	<u>84</u>	<u>312</u>											
12		<u>768.12</u>	<u>0.23</u>	<u>1.19</u>	<u>86</u>	<u>314</u>	<u>249</u>	<u>253</u>	<u>58</u>	<u>5</u>	<u>11.5</u>	<u>9.5</u>					
		<u>771.16</u>	<u>0.22</u>	<u>1.16</u>	<u>87</u>	<u>303</u>											
1		<u>774.68</u>	<u>0.30</u>	<u>1.56</u>	<u>86</u>	<u>310</u>	<u>250</u>	<u>248</u>	<u>56</u>	<u>6</u>	<u>10.0</u>	<u>10.0</u>					
2		<u>778.26</u>	<u>0.31</u>	<u>1.61</u>	<u>87</u>	<u>311</u>											
3		<u>781.90</u>	<u>0.32</u>	<u>1.66</u>	<u>88</u>	<u>313</u>	<u>251</u>	<u>262</u>	<u>58</u>	<u>5</u>							
4		<u>785.18</u>	<u>0.26</u>	<u>1.35</u>	<u>88</u>	<u>313</u>											
5		<u>788.54</u>	<u>0.27</u>	<u>1.41</u>	<u>89</u>	<u>312</u>	<u>250</u>	<u>261</u>	<u>60</u>	<u>5</u>	<u>10.0</u>	<u>9.5</u>					
6		<u>792.14</u>	<u>0.31</u>	<u>1.61</u>	<u>89</u>	<u>313</u>											
7		<u>796.48</u>	<u>0.45</u>	<u>2.35</u>	<u>90</u>	<u>312</u>	<u>249</u>	<u>274</u>	<u>62</u>	<u>7</u>							
8		<u>801.48</u>	<u>0.60</u>	<u>3.13</u>	<u>91</u>	<u>315</u>											
9		<u>806.56</u>	<u>0.62</u>	<u>3.23</u>	<u>91</u>	<u>316</u>	<u>250</u>	<u>271</u>	<u>55</u>	<u>8</u>							
10		<u>811.49</u>	<u>0.58</u>	<u>3.03</u>	<u>92</u>	<u>315</u>											
11		<u>816.48</u>	<u>0.59</u>	<u>3.10</u>	<u>92</u>	<u>310</u>	<u>251</u>	<u>273</u>	<u>56</u>	<u>8</u>	<u>10.0</u>	<u>9.5</u>					
12	<u>12:23</u>	<u>821.35</u>	<u>0.56</u>	<u>2.96</u>	<u>92</u>	<u>305</u>											

CLIENT	M.V. W.T.F.	NOZZLE	G-309	DIAMETER, IN.	0.3058	IMPINGER	INITIAL	FINAL	TOTAL GAIN
SOURCE	Unit #3	PROBE	7A-1	Cp	0.8469	VOLUMES	(mL)	(mL)	(mL)
PARAMETER / RUN No	Metals / particulate / R-2	PORT LENGTH				Imp. #1	000	210	210
DATE	July 20, 2023	STATIC PRESSURE, IN. H2O	-19.0"			Imp. #2	1000	196	96
OPERATOR	DS	STACK DIAMETER	70.9"			Imp. #3	100	104	4
CONTROL UNIT	STCARE 2 Y 0.9927	STACK HEIGHT	30.0'			Imp. #4	2000	3	3
	ΔH@ 1.795					Imp. #5	100	102	2
BAROMETRIC PRESSURE, IN. Hg	30.10	INITIAL LEAK TEST	0.002 @ 15"			Imp. #6	100	101	1
ASSUMED MOISTURE, Bw	1.5%	FINAL LEAK TEST	0.003 @ 15"			Upstream Diameter	2.000		
						Downstream Diameter			

Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites			
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %		
	09:17	821.406												
1		824.77	0.23	1.19	80	303	247	259	65	4				
2	10	827.91	0.25	1.29	80	304				4	11.0	8.7		
3		831.22	0.26	1.35	80	304	250	256	59	4				
4	20	834.48	0.26	1.35	81	306								
5		837.68	0.25	1.29	82	307	249	248	60	4				
6	30	840.98	0.27	1.40	82	307								
7		848.50	0.50	2.59	82	307	251	253	57	6	11.0	9.6		
8	40	849.89	0.47	2.44	83	305								
9		854.43	0.50	2.61	84	305	250	254	56	6				
10	50	858.88	0.48	2.50	84	304								
11		863.52	0.52	2.71	85	305	250	253	57	6	11.0	9.5		
12	60	868.22	0.53	2.78	86	302								
1		872.73	0.49	2.57	86	304	249	257	55	6	9.5	10.2		
2	10	877.29	0.50	2.62	87	306								
3		881.72	0.47	2.46	88	307	249	263	58	6				
4	20	886.10	0.46	2.41	89	308								
5		890.82	0.53	2.78	90	309	251	258	58	6	9.0	10.6		
6	30	895.72	0.57	2.99	91	309								
7		899.96	0.43	2.25	90	310	249	259	55	5				
8	40	904.68	0.53	2.77	90	310								
9		908.58	0.56	1.88	90	311	251	256	53	3				
10	50	912.22	0.32	1.67	90	311								
11		915.46	0.25	1.31	91	312	250	252	54	3	9.0	10.8		
12	11:18	918.91	0.21	1.10	91	314								

CLIENT	M.V. W.T.F.	NOZZLE	G-309	DIAMETER, IN.	0.3058	IMPINGER	INITIAL	FINAL	TOTAL GAIN
SOURCE	Unit #3	PROBE	TD	Cp	0.8469	VOLUMES	(mL)	(mL)	(mL)
PARAMETER / RUN No	metals/particulate / R-3	PORT LENGTH				Imp. #1	100	264	264
DATE	July 20, 2023	STATIC PRESSURE, IN. H ₂ O	-19.0"			Imp. #2	100	190	10
OPERATOR	BS	STACK DIAMETER	70.9'			Imp. #3	100	114	14
CONTROL UNIT	ST CAE 2	STACK HEIGHT	30.0'			Imp. #4	200	5	154
						Imp. #5	100	104	4
						Imp. #6	100	102	2
BAROMETRIC PRESSURE, IN. Hg	30.10	INITIAL LEAK TEST	0.002 @ 15"			Upstream Diameters			
ASSUMED MOISTURE, Bw	15%	FINAL LEAK TEST	0.001 @ 15"			Downstream Diameters			

Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites			
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %		
	11:45	919.577												
1		923.90	0.45	2.34	90	314	281	259	58	6				
2	5	928.28	0.46	2.39	90	313					11.0	9.0		
3		932.75	0.48	2.50	91	316	244	259	57	6				
4	10	937.28	0.49	2.55	92	313								
5		941.66	0.46	2.39	91	316	244	254	54	8				
6	15	945.99	0.45	2.34	91	316					10.5	9.2		
7		949.76	0.34	1.77	91	316	250	251	55	9				
8	20	953.36	0.31	1.61	91	316								
9		956.78	0.28	1.46	91	316	250	257	56	6				
10	25	960.15	0.27	1.41	92	314					10.5	9.4		
11		963.48	0.26	1.35	92	314	249	255	54	6				
12	30	966.67	0.24	1.25	92	314								
1		969.86	0.25	1.31	93	316	249	252	55	6	10.5	9.4		
2	5	973.73	0.27	1.41	94	317								
3		976.53	0.26	1.36	93	317	250	251	52	6				
4	10	979.77	0.28	1.30	93	318								
5		983.08	0.22	1.36	93	316	250	255	54	6				
6	15	986.45	0.24	1.41	93	317					10.5	9.3		
7		991.13	0.52	2.72	94	316	251	248	55	8				
8	20	995.63	0.48	2.51	94	315								
9		1000.28	0.51	2.67	95	315	249	256	56	8				
10	25	1004.98	0.52	2.73	95	315					10.5	9.5		
11		1009.54	0.49	2.58	96	314	249	250	58	9				
12	13:46	1014.18	0.50	2.65	96	309								

SH

CLIENT		NOZZLE		DIAMETER, IN.		IMPINGER		INITIAL		FINAL		TOTAL GAIN	
SOURCE		PROBE				VOLUMES		(mL)		(mL)		(mL)	
PARAMETER / RUN No		PORT LENGTH				Imp. #1							
DATE		STATIC PRESSURE, IN. H ₂ O				Imp. #2							
OPERATOR		STACK DIAMETER				Imp. #3							
CONTROL UNIT		STACK HEIGHT				Imp. #4							
						Imp. #5							
						Imp. #6							
BAROMETRIC PRESSURE, IN. Hg		INITIAL LEAK TEST				Upstream Diameters							
ASSUMED MOISTURE, Bw		FINAL LEAK TEST				Downstream Diameters							
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Dry Gas Outlet	Stack	Probe	Box	Impinger Exit	Pump Vac. IN. Hg	CO ₂ Vol. %	O ₂ Vol. %	
1	10:00	16.077	0.26	0.96	60	306	N/A	N/A	56	6	10.0	9.3	
2		18.76	0.26	0.96	60	306	N/A	N/A	56	6	10.0	9.3	
3		21.55	0.26	0.96	60	306	N/A	N/A	56	6	10.0	9.3	
4		24.50	0.32	1.13	60	303			57	6			
5		27.50	0.32	1.20	60	303			57	6			
6		30.50	0.32	1.20	60	303			57	6	10.0	9.3	
7		33.33	0.29	1.07	60	306			57	6			
8		37.16	0.33	1.23	60	303			57	6			
9		40.91	0.30	1.56	62	303			57	7			
10		44.88	0.36	2.08	62	303			57	7			
11		48.86	0.36	2.09	64	303			57	7			
12		52.86	0.34	2.02	64	303			57	7	10.0	10.0	
1		56.86	0.48	1.80	63	303							
2		60.39	0.54	2.03	64	303	N/A	N/A	57	8	10.5	9.3	
3		64.32	0.54	2.04	65	304			57	8			
4		68.08	0.49	1.83	65	304			58	8			
5		71.76	0.47	1.74	66	303			58	8	10.5	9.4	
6		75.39	0.46	1.73	66	303			58	8			
7		78.96	0.43	1.69	64	303			58	7			
8		82.07	0.34	1.72	62	303			58	7	10.5	9.3	
9		85.08	0.37	1.19	62	303			58	7			
10		87.98	0.30	1.12	61	303			58	7			
11		90.79	0.28	1.03	62	303			58	7			
12	11:00	93.54	0.27	1.01	62	303			58	7			
		96.20	0.23	0.95	62	302							

CLIENT		NOZZLE		DIAMETER, IN.		IMPINGER		INITIAL		FINAL		TOTAL GAIN	
SOURCE		PROBE		700p		VOLUMES		(mL)		(mL)		(mL)	
PARAMETER / RUN No		PORT LENGTH		Imp. #1		Imp. #2		Imp. #3		Imp. #4		Imp. #5	
DATE		STATIC PRESSURE, IN. H ₂ O		Imp. #6		Upstream Diameters		Downstream Diameters					
OPERATOR		STACK DIAMETER		Imp. #1		Imp. #2		Imp. #3		Imp. #4		Imp. #5	
CONTROL UNIT		STACK HEIGHT		Imp. #6		Imp. #1		Imp. #2		Imp. #3		Imp. #4	
BAROMETRIC PRESSURE, IN. Hg		INITIAL LEAK TEST		Imp. #5		Imp. #6		Imp. #1		Imp. #2		Imp. #3	
ASSUMED MOISTURE, Bw		FINAL LEAK TEST		Imp. #4		Imp. #5		Imp. #6		Imp. #1		Imp. #2	

Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Eyrates		P.H. = 9.0
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %	
1	09:22	96.578											
2		99.36	0.27	1.01	68	309	N/A	N/A	58	6	10.0	9.7	
3		102.20	0.28	1.03	70	310			58	6			
4		103.14	0.30	1.13	70	310			58	6			
5		108.18	0.32	1.20	70	310			58	6			
6		111.31	0.34	1.28	70	310			59	6			
7		114.30	0.31	1.17	71	310			59	6	10.0	10.8	
8		118.42	0.39	1.27	71	309			59	6			
9		122.44	0.56	1.11	72	309			58	7			
10		126.44	0.38	2.07	72	310			58	7	10.0	10.4	
11		130.44	0.36	1.11	72	311			58	7			
12		134.35	0.32	1.96	72	311			58	7			
1		137.99	0.46	1.73	72	310							
2		142.06	0.57	2.15	73	310	N/A	N/A	58	8	10.0	9.8	
3		146.07	0.55	2.08	75	310			58	8			
4		149.94	0.61	1.93	75	310			58	8			
5		153.71	0.48	1.87	76	310			58	8	10.0	9.8	
6		157.35	0.45	1.77	76	310			58	8			
7		160.92	0.43	1.63	76	310			58	7			
8		164.20	0.36	1.37	78	309			58	7	10.0	9.8	
9		167.32	0.33	1.26	78	309			58	7			
10		170.36	0.31	1.20	78	309			58	7			
11		173.20	0.27	1.03	78	308			58	7	10.0	9.8	
12	10:24	176.94	0.23	0.88	78	308			58	7			
		178.56	0.23	0.88	79	308							

CLIENT <i>M.V. W.F.E.</i>		NOZZLE <i>G-292</i> DIAMETER, IN. <i>0.2837</i>		IMPINGER, INITIAL		FINAL		TOTAL GAIN	
SOURCE <i>Unit 3</i>		PROBE <i>7-Cop</i> <i>0.8489</i>		VOLUMES (mL)		(mL)		(mL)	
PARAMETER / RUN No <i>3</i>		PORT LENGTH		Imp. #1 <i>180</i>		<i>180</i>		<i>-68</i>	
DATE <i>July 26/23</i>		STATIC PRESSURE, IN. H ₂ O <i>-19.0</i>		Imp. #2 <i>280</i>		<i>310</i>		<i>295</i>	
OPERATOR:		STACK DIAMETER <i>70.90</i>		Imp. #3 <i>75</i>		<i>119</i>		<i>39</i>	
CONTROL UNIT <i>CAE-2Y</i> <i>0.9927</i>		STACK HEIGHT		Imp. #4 <i>8</i>		<i>8</i>		<i>0</i>	
$\Delta H @$				Imp. #5 <i>200</i>		<i>216</i>		<i>21.6</i>	
BAROMETRIC PRESSURE, IN. Hg <i>30.10</i>		INITIAL LEAK TEST <i>0.001 @ 15"</i>		Upstream Diameters					
ASSUMED MOISTURE, Bw <i>15%</i>		FINAL LEAK TEST <i>0.001 @ 15"</i>		Downstream Diameters					

Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Temperature °F					Pump Vac. IN. Hg	Fyrites				
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO ₂ Vol. %	O ₂ Vol. %			
1	<i>12:08</i>	<i>178.928</i>													
2		<i>183.00</i>	<i>0.36</i>	<i>2.14</i>	<i>78</i>	<i>308</i>	<i>N/A</i>	<i>N/A</i>	<i>58</i>	<i>6</i>					
3		<i>187.02</i>	<i>0.34</i>	<i>2.06</i>	<i>78</i>	<i>308</i>			<i>58</i>	<i>6</i>	<i>10.0</i>	<i>10.2</i>			
4		<i>190.84</i>	<i>0.30</i>	<i>1.91</i>	<i>78</i>	<i>308</i>			<i>58</i>	<i>6</i>					
5		<i>194.65</i>	<i>0.48</i>	<i>1.83</i>	<i>77</i>	<i>310</i>			<i>58</i>	<i>6</i>					
6		<i>198.31</i>	<i>0.43</i>	<i>1.71</i>	<i>77</i>	<i>310</i>			<i>58</i>	<i>6</i>					
7		<i>201.91</i>	<i>0.44</i>	<i>1.67</i>	<i>77</i>	<i>310</i>			<i>58</i>	<i>6</i>					
8		<i>205.36</i>	<i>0.40</i>	<i>1.52</i>	<i>78</i>	<i>312</i>			<i>58</i>	<i>6</i>	<i>10.0</i>	<i>10.1</i>			
9		<i>208.62</i>	<i>0.36</i>	<i>1.37</i>	<i>78</i>	<i>312</i>			<i>58</i>	<i>5</i>					
10		<i>211.60</i>	<i>0.30</i>	<i>1.14</i>	<i>78</i>	<i>312</i>			<i>58</i>	<i>5</i>					
11		<i>214.48</i>	<i>0.28</i>	<i>1.06</i>	<i>78</i>	<i>312</i>			<i>58</i>	<i>5</i>					
12		<i>217.26</i>	<i>0.26</i>	<i>1.00</i>	<i>79</i>	<i>311</i>			<i>58</i>	<i>5</i>	<i>10.5</i>	<i>9.4</i>			
1		<i>219.94</i>	<i>0.24</i>	<i>0.92</i>	<i>79</i>	<i>311</i>									
1		<i>222.83</i>	<i>0.28</i>	<i>1.07</i>	<i>78</i>	<i>310</i>	<i>N/A</i>	<i>N/A</i>	<i>58</i>	<i>5</i>	<i>10.5</i>	<i>9.3</i>			
2		<i>225.82</i>	<i>0.30</i>	<i>1.14</i>	<i>80</i>	<i>313</i>			<i>58</i>	<i>5</i>					
3		<i>228.97</i>	<i>0.32</i>	<i>1.22</i>	<i>80</i>	<i>313</i>			<i>58</i>	<i>5</i>					
4		<i>231.17</i>	<i>0.34</i>	<i>1.30</i>	<i>80</i>	<i>313</i>			<i>58</i>	<i>5</i>					
5		<i>233.26</i>	<i>0.32</i>	<i>1.22</i>	<i>80</i>	<i>313</i>			<i>58</i>	<i>5</i>					
6		<i>238.20</i>	<i>0.30</i>	<i>1.14</i>	<i>81</i>	<i>314</i>			<i>58</i>	<i>6</i>	<i>10.0</i>	<i>9.8</i>			
7		<i>242.50</i>	<i>0.62</i>	<i>2.36</i>	<i>81</i>	<i>314</i>			<i>58</i>	<i>6</i>					
8		<i>246.70</i>	<i>0.59</i>	<i>2.23</i>	<i>81</i>	<i>315</i>			<i>58</i>	<i>6</i>					
9		<i>250.80</i>	<i>0.56</i>	<i>2.13</i>	<i>81</i>	<i>315</i>			<i>58</i>	<i>6</i>					
10		<i>254.94</i>	<i>0.57</i>	<i>2.18</i>	<i>82</i>	<i>314</i>			<i>58</i>	<i>6</i>	<i>10.5</i>	<i>9.6</i>			
11		<i>258.97</i>	<i>0.54</i>	<i>2.06</i>	<i>82</i>	<i>314</i>			<i>58</i>	<i>7</i>					
12	<i>14:09</i>	<i>262.82</i>	<i>0.49</i>	<i>1.88</i>	<i>82</i>	<i>312</i>									

P.H. = 9.4

A. Lanfranco and Associates Inc.

54

Client MUWTE Y LHU-D 1.0276
 Source Unit 1 Cp
 Parameter HF Pbar 30.07 Static
 Date 07/19/23 Operator Bm Lester

Leak Check	Run 1	Run 2	Run 3
Initial	0.0001	0.0001	0.0001
Final	0.0001	0.0001	0.0001

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	9:35	112.7972	73	290				
	9:50	113.0224	89.4					
	9:05	113.2080	99.1	290				
	9:25	113.5552	106.3					
	10:35	113.6518	108.3	290				
2	10:51	113.6532	99.6	290				
	11:13	113.8940	106.6					
	11:40	114.1550	111.2					
	11:51	114.2650	110.8					
3	12:08	114.2686	100.8	290				
	12:24	114.4460	104.2					
	13:08	114.8832	99.4					

Client MUWTE Y LHU-B 1.0365
 Source Unit 1 Cp
 Parameter Ammonia Pbar 30.07 Static
 Date 07/19/23 Operator Bm Lester

Leak Check	Run 1	Run 2	Run 3
Initial	0.0001	0.0001	0.0001
Final	0.0001	0.0001	0.0001

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	9:35	260.5160	77					
	9:50	260.6412	82					
	9:05	260.7680	96.3					
	9:25	260.7240	98					
	10:35	260.9992	101.5					
2	10:51	261.0018	100.5					
	11:13	261.1840	101.4					
	11:40	261.3892	104					
	11:51	261.4824	105.2					
3	12:08	261.4865	100.4					
	12:24	261.6182	100.9					
	13:08	261.9740	101.2					

J.H.

A. Lanfranco and Associates Inc.

Client MU WTE Y LMU-17 | 0276
Source Unit #3 Cp
Parameter HF Pbar 30.10 Static
Date 7-20-23 Operator SG

Client MU WTE Y LMU-13 | 1.0365
Source Unit #3 Cp
Parameter NH₂ Pbar 30.10 Static
Date 7-20-23 Operator SG

Leak Check	Run 1	Run 2	Run 3
Initial	10000	10000	10000
Final	10000	10000	10000

Leak Check	Run 1	Run 2	Run 3
Initial	10000	10000	10000
Final	10000	10000	10000

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m ³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	10:10	114.8965	63					
			66					
			70					
	11:10	115.5384	71					
2	11:35	115.5424	70					
			73					
			75					
	12:35	116.1894	77					
3	12:45	116.1934	72					
			75					
			78					
	13:45	116.6803	82					

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m ³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	10:10	261.9780	64					
			68					
			72					
	11:10	262.4824	74					
2	11:35	262.4970	70					
			73					
			75					
	12:35	262.8595	77					
3	12:45	262.8628	74					
			77					
			83					
	13:45	263.2536	85					

JH

A. Lanfranco and Associates Inc.

Client MVWTE Y LHO-131.0365
 Source Unit 2 Cp
 Parameter HF Pbar 30.13 Static
 Date 07/18/23 Operator Bon Lester

Leak Check	Run 1	Run 2	Run 3
Initial	0.0001	0.0001	0.0001
Final	0.0001	0.0001	0.0001

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	10:42	259.1236	72.5	300	200			
	10:52	259.2152	75.4					
	11:02	259.3045	80.7					
	11:12	259.4120	89.2					
	11:22	259.4756	89.6					
	11:32	259.5874	94.7					
	11:42	259.6132	94.2					
2	12:28	259.6188	80.4	306	200			
	12:38	259.6852	84.2					
	12:48	259.7618	86.7					
	12:58							
	13:08	259.9110	92					
	13:18	259.9752	95.8					
	13:28	260.0515	95.7					
3	13:44	260.0562	91.6	302	200			
	13:44	260.0932	70					
	13:54	260.1400	93					
	14:04	260.2130	94.5					
	14:14	260.2738	96.2					
	14:24							
	14:34	260.5116	99.6					

Client MVWTE Y LHO-D 1.0276
 Source Unit 2 Cp
 Parameter Ammonia Pbar 30.13 Static
 Date 07/18/23 Operator Bon Lester

Leak Check	Run 1	Run 2	Run 3
Initial	0.0001	0.0001	0.0001
Final	0.0001	0.0001	0.0001

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	10:42	110.9600	74	300	200			
	10:52	111.0912	79.2					
	11:02	111.1978	84.4					
	11:12	111.3350	93.5					
	11:22	111.4172	99.7					
	11:32	111.5674	99.2					
	11:42	111.5942	96.3					
2	12:28	111.5990	82.5	306	200			
	12:38	111.6912	84.6					
	12:48	111.7960	87.5					
	12:58							
	13:08	111.9930	94					
	13:18	112.0782	88.4					
	13:28	112.1828	101.5					
3	13:34	112.1862	94.2	302	200			
	13:44	112.2342	95.2					
	13:54	112.3012						
	14:04	112.4020	97.8					
	14:14	112.5800	98.7					
	14:24							
	14:34	112.7926	101.6					

Client Covanta MV WTESource Unit #2Date 18-Jul-23

	Run 1	Run 2	Run 3	Run 4	Run 5
Pbar (in. Hg)	30.13	30.13	30.13		
Canister Number	SC01024	SC02242	SC01916		
Controller Number	0A00091	0A00217	0A01118		
Gauge Number	AVG05342	N/A	NA		
Initial: Start Time	10:42	12:28	13:44		
Flask Vac. (in. Hg)	-32.5	-32.0	-30		
Final: End Time	11:42	13:28	14:44		
Flask Vac. (in. Hg)	-12.5	-9.0	-6.5		

Source Unit #1Date 19-Jul-23

	Run 1	Run 2	Run 3	Run 4	Run 5
Pbar (in. Hg)	30.07	30.07	30.07		
Canister Number	SC00707	SC02241	SC02126		
Controller Number	0A0154	0A02255	0A01544		
Gauge Number	NA	N/A	N/A		
Initial: Start Time	9:35	10:51	12:08		
Flask Vac. (in. Hg)	-30.0	-29.5	-39.0		
Final: End Time	10:35	11:51	13:08		
Flask Vac. (in. Hg)	-8.0	-6.5	-12.0		

Source Unit #3Date 20-Jul-23

	Run 1	Run 2	Run 3	Run 4	Run 5
Pbar (in. Hg)	30.10	30.10	30.16		
Canister Number	SC006405	SC00861	SC0063		
Controller Number	0A00250	0A01809	0A01200		
Gauge Number	N/A	N/A	AVG05313		
Initial: Start Time	10:10	11:35	12:45		
Flask Vac. (in. Hg)	-30.10	-29.0	-29		
Final: End Time	11:10	12:35	13:45		
Flask Vac. (in. Hg)	-10.0	-9.0	-7.0		

Source

Date

	Run 1	Run 2	Run 3	Run 4	Run 5
Pbar (in. Hg)					
Canister Number					
Controller Number					
Gauge Number					
Initial: Start Time					
Flask Vac. (in. Hg)					
Final: End Time					
Flask Vac. (in. Hg)					

S.H.

CEM FIELD DATA SHEET

Client
Source
Date

M.V. W.T.E.
Unit # 1-3
July 2023 (Q-3)
N₂O Analysis

Technician
Ambient Temp (°C)
Barometric Pressure (in. Hg)

OS
30.02

	N ₂	H ₂	1 Gas	2 Gas	3 Gas	4 Gas	5 Gas	O ₂	Comb Air	Low Meth	Mid Meth	High Meth
Cylinder #			619									
Pressure (psi)												
Expiry Date			7-20-26									
O ₂ (%)												
CO ₂ (%)												
CO (ppm)												
THC (ppm)												
SO ₂ (ppm)			91.4									
NO _x (ppm)			90.0									

Analyzer Range	O ₂	CO ₂	CO	THC	SO ₂	NO _x

CEM READINGS

N₂O (ppm)

Time	Source	O ₂	CO ₂	CO	THC	SO ₂	NO _x	Response Time (sec)
Cals:	N ₂	0						O ₂ Up
	1 Gas	91						O ₂ Dn
								CO ₂ Up
								CO ₂ Dn
July 19 th								
Unit #1 R1	0935-1035					0.0		CO Up
R2	1051-1151					3.0		CO Dn
R3	1208-1308					0.0		THC Up
								THC Dn
July 18 th								SO ₂ Up
Unit #2 R1	1042-1142					0.0		SO ₂ Dn
2	1229-1328					0.0		NO _x Up
3	1344-1444					0.0		NO _x Dn
July 20 th								
Unit #3 R1	1010-1110					0.0		
1	1135-1235					0.0		
3	1245-1345					0.0		
Cals:	N ₂	0						
	Gas	91						

APPENDIX – E

CALIBRATION SHEETS and

TECHNICIAN CERTIFICATES

A. LANFRANCO and ASSOCIATES INC.

ENVIRONMENTAL CONSULTANTS

GLASS NOZZLE DIAMETER CALIBRATION FORM

Calibrated by: Christian De La O

Date: 26-Jun-23

Signature:

Chris Del A O

Nozzle I.D.	d1 (inch)	d2 (inch)	d3 (inch)	difference (inch)	average dia. (inch)	average area (ft ²)
A	0.1270	0.1270	0.1255	0.0015	0.1265	0.0000873
G-165	0.1650	0.1660	0.1645	0.0015	0.1652	0.0001488
G-170	0.1700	0.1710	0.1695	0.0015	0.1702	0.0001579
G-178	0.1760	0.1770	0.1790	0.0030	0.1773	0.0001715
E	0.1950	0.1930	0.1960	0.0030	0.1947	0.0002067
L	0.2100	0.2070	0.2090	0.0030	0.2087	0.0002375
P-2240	0.2160	0.2155	0.2170	0.0015	0.2162	0.0002549
G-221	0.2160	0.2185	0.2190	0.0030	0.2178	0.0002588
G-225	0.2190	0.2175	0.2180	0.0015	0.2182	0.0002596
G-218	0.2180	0.2200	0.2210	0.0030	0.2197	0.0002632
G-2232	0.2210	0.2200	0.2215	0.0015	0.2208	0.0002660
P-250	0.2500	0.2495	0.2505	0.0010	0.2500	0.0003409
C-250	0.2500	0.2500	0.2500	0.0000	0.2500	0.0003409
P-251	0.2545	0.2530	0.2540	0.0015	0.2538	0.0003514
P-254	0.2550	0.2540	0.2535	0.0015	0.2542	0.0003523
P-256	0.2540	0.2550	0.2560	0.0020	0.2550	0.0003547
P-280	0.2810	0.2805	0.2815	0.0010	0.2810	0.0004307
C-280	0.2800	0.2800	0.2800	0.0000	0.2800	0.0004276
G-282	0.2820	0.2800	0.2825	0.0025	0.2815	0.0004322
P-281	0.2820	0.2820	0.2815	0.0005	0.2818	0.0004332
G-292	0.2820	0.2840	0.2850	0.0030	0.2837	0.0004389
G-309	0.3045	0.3065	0.3065	0.0020	0.3058	0.0005101
P-311	0.3115	0.3120	0.3120	0.0005	0.3118	0.0005304
P-312	0.3120	0.3110	0.3105	0.0015	0.3112	0.0005281
G-3121	0.3090	0.3085	0.3075	0.0015	0.3083	0.0005185
P-313	0.3140	0.3130	0.3130	0.0010	0.3133	0.0005355
P-314	0.3135	0.3135	0.3140	0.0005	0.3137	0.0005366
P-315	0.3145	0.3145	0.3145	0.0000	0.3145	0.0005395
V-06	0.3220	0.3215	0.3200	0.0020	0.3212	0.0005626
G-345	0.3470	0.3475	0.3475	0.0005	0.3473	0.0006580
P27	0.3490	0.3480	0.3500	0.0020	0.3490	0.0006643
G-367	0.3700	0.3685	0.3690	0.0015	0.3692	0.0007433
P-375	0.3730	0.3750	0.3745	0.0020	0.3742	0.0007636
P-401	0.3980	0.3990	0.4000	0.0020	0.3990	0.0008683
G-433	0.4360	0.4360	0.4355	0.0005	0.4358	0.0010360
G-437	0.4690	0.4690	0.4700	0.0010	0.4693	0.0012014
G-468	0.4700	0.4685	0.4720	0.0035	0.4702	0.0012057
P-7	0.4965	0.4945	0.4975	0.0030	0.4962	0.0013427
G-540	0.5400	0.5410	0.5400	0.0010	0.5403	0.0015924

Where:

- (a) D1, D2, D3 = three different nozzle diameters; each diameter must be measured to within (0.025mm) 0.001 in.
- (b) Difference = maximum difference between any two diameters; must be less than or equal to (0.1mm) 0.004 in.
- (c) Average = average of D1, D2 and D3

Pitot Tube Calibration

Date: 27-Jun-23
Pbar (in.Hg): 29.84

Temp (R): 539
Dn (in.): 0.25

Pitot ID: **7A-1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.075	0.100	18.3	0.8574	0.0105
0.155	0.210	26.3	0.8505	0.0036
0.295	0.400	36.3	0.8502	0.0033
0.460	0.630	45.3	0.8459	0.0010
0.570	0.810	50.5	0.8305	0.0164
Average :			0.8469	0.0070

Pitot ID: **ST 8A**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.055	0.075	15.7	0.8478	0.0019
0.180	0.250	28.4	0.8400	0.0059
0.270	0.365	34.7	0.8515	0.0055
0.450	0.620	44.8	0.8434	0.0025
0.505	0.690	47.5	0.8469	0.0010
Average :			0.8459	0.0034

Pitot ID: **7B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.050	0.072	14.9	0.8250	0.0036
0.130	0.180	24.1	0.8413	0.0199
0.295	0.400	36.3	0.8502	0.0288
0.460	0.630	45.3	0.8459	0.0245
0.560	0.990	50.0	0.7446	0.0768
Average :			0.8214	0.0307

Pitot ID: **ST 8B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.040	0.055	13.4	0.8443	0.0076
0.110	0.155	22.2	0.8340	0.0179
0.300	0.420	36.6	0.8367	0.0152
0.460	0.630	45.3	0.8459	0.0059
0.560	0.680	50.0	0.8984	0.0465
Average :			0.8519	0.0186

Pitot ID: **7 AL GVRD-1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.075	0.105	16.3	0.8367	0.0099
0.160	0.220	19.9	0.8443	0.0024
0.360	0.480	25.3	0.8574	0.0107
0.460	0.630	35.8	0.8459	0.0007
0.500	0.680	48.4	0.8489	0.0023
Average :			0.8466	0.0052

Pitot ID: **ST 8C**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.075	0.105	14.9	0.8367	0.0020
0.160	0.220	19.4	0.8443	0.0055
0.280	0.380	29.0	0.8498	0.0111
0.570	0.810	43.1	0.8305	0.0082
0.615	0.870	52.8	0.8324	0.0064
Average :			0.8387	0.0067

Pitot ID: **7C**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.038	0.051	13.0	0.8546	0.0057
0.110	0.150	16.3	0.8478	0.0011
0.295	0.400	36.3	0.8502	0.0013
0.450	0.620	30.5	0.8434	0.0055
0.540	0.735	47.0	0.8486	0.0003
Average :			0.8489	0.0028

Pitot ID:

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
Average :				

* Average absolute deviation must not exceed 0.01.

Calibrated by: Jeremy Gibb

Signature: 

Date:

June 27, 2023

A.Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: CAE AL1
Serial #: 0028-070611-1

Date: 27-Jun-23
Barometric Pressure: 29.82 (in. Hg)
Theoretical Critical Vacuum: 14.07 (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}((in.Hg)^{0.5}(min)).
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.80	15.00	175.000	191.562	16.562	79.0	79.0	84.0	84.0	73	0.8185	17.0	73.0	75.0	74.0
1.90	17.00	192.100	205.646	13.546	84.0	84.0	82.0	82.0	63	0.5956	20.0	75.0	76.0	75.5
1.10	17.00	205.900	216.455	10.555	82.0	82.0	81.0	81.0	55	0.4606	22.0	76.0	76.0	76.0
0.68	18.00	217.100	225.591	8.491	81.0	81.0	80.0	80.0	48	0.3560	24.0	76.0	77.0	76.5
0.35	17.00	225.800	231.294	5.494	80.0	80.0	80.0	80.0	40	0.2408	25.0	77.0	78.0	77.5

***** RESULTS *****											
--- DRY GAS METER ---			----- ORIFICE -----		-- DRY GAS METER --			----- ORIFICE -----			
VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (cu ft)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (cu ft)	CALIBRATION FACTOR Y		CALIBRATION FACTOR dH@				Ko (value)
					Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)		
16.239	459.9	15.843	448.7	16.084	0.976	-0.010	1.862	47.29	0.042		0.708
13.184	373.4	13.048	369.5	13.283	0.990	0.004	1.758	44.66	-0.062		0.720
10.281	291.2	10.086	285.6	10.277	0.981	-0.004	1.708	43.39	-0.112		0.737
8.277	234.4	8.250	233.6	8.414	0.997	0.011	1.773	45.03	-0.047		0.713
5.356	151.7	5.265	149.1	5.380	0.983	-0.002	2.000	50.80	0.180		0.681
Average Y----->					0.9852	Average dH@----->	1.820	46.2	Average Ko---->	0.712	

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature		Temperature Device		Results
Set-Point (deg F)		Reading (deg F)		Variation (degF)
32		32		0
100		100		0
300		300		0
500		500		0
1000		1000		0
				Percent of Absolute
				0.00%
				0.00%
				0.00%
				0.00%
				0.00%

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Devices, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Justin Ching

Signature:

Justin Ching

Date: June 27, 2023

A.Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: **ST CAE2**
Serial #: **0028-072911-1**

Date: **29-Jun-23**
Barometric Pressure: **29.87** (in. Hg)
Theoretical Critical Vacuum: **14.09** (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}((in.Hg)^{0.5}(min)).
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.80	15.00	471.400	487.620	16.220	81.0	81.0	82.0	82.0	73	0.8185	15.0	84.0	83.0	83.5
1.90	15.00	489.000	500.785	11.785	78.0	78.0	77.0	77.0	63	0.5956	16.0	75.0	77.0	76.0
1.10	15.00	501.100	510.288	9.188	77.0	77.0	77.0	77.0	55	0.4606	17.0	77.0	78.0	77.5
0.66	15.00	510.500	517.455	6.955	77.0	77.0	77.0	77.0	48	0.3560	19.0	78.0	80.0	79.0
0.32	18.00	517.600	523.315	5.715	77.0	77.0	78.0	78.0	40	0.2408	20.0	80.0	81.0	80.5

***** RESULTS *****											
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----		
VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (cu ft)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (cu ft)	CALIBRATION FACTOR Y		CALIBRATION FACTOR dH@				
					Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)	Ko (value)	
15.931	451.2	15.731	445.5	16.226	0.987	-0.005	1.892	48.05	0.097	0.699	
11.607	328.7	11.527	326.4	11.725	0.993	0.000	1.775	45.08	-0.020	0.719	
9.040	256.0	8.901	252.1	9.080	0.985	-0.008	1.725	43.81	-0.070	0.737	
6.835	193.6	6.870	194.6	7.028	1.005	0.012	1.737	44.12	-0.058	0.720	
5.607	158.8	5.569	157.7	5.713	0.993	0.001	1.844	46.84	0.050	0.707	
Average Y----->					0.9927	Average dH@----->	1.795	45.6	Average Ko---->	0.716	

TEMPERATURE CALIBRATION			
Calibration Standard -----> Omega Model CL23A S/N:T-218768			
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Results	
		Variation (degF)	Percent of Absolute
32	32	0	0.00%
100	100	0	0.00%
300	300	0	0.00%
500	500	0	0.00%
1000	1000	0	0.00%

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Devices, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Justin Ching

Signature: _____

Justin Ching

Date: June 29, 2023

A.Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: FE 18
Serial #: 0028-020118-1

Date: 26-Jun-23
Barometric Pressure: 29.87 (in. Hg)
Theoretical Critical Vacuum: (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.65	16.00	452.400	468.970	16.570	73.0	73.0	76.0	76.0	73	0.8185	16.0	75.0	76.0	75.5
1.90	15.00	468.970	480.300	11.330	76.0	76.0	77.0	77.0	63	0.5956	17.5	76.0	80.0	78.0
1.15	19.00	480.300	491.513	11.213	79.0	79.0	78.0	78.0	55	0.4606	19.0	80.0	84.0	82.0
0.68	15.00	491.513	498.229	6.716	78.0	78.0	80.0	80.0	48	0.3560	20.0	80.0	85.0	82.5
0.33	19.00	498.229	504.067	5.838	79.0	79.0	80.0	80.0	40	0.2408	21.5	84.0	87.0	85.5

***** RESULTS *****													
--- DRY GAS METER ---		----- ORIFICE -----			-- DRY GAS METER --		----- ORIFICE -----						
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y		CALIBRATION FACTOR dH@						
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)	Ko (value)			
16.481	466.8	16.904	478.7	17.180	1.026	-0.003	1.814	46.07	-0.010	0.712			
11.179	316.6	11.505	325.8	11.747	1.029	0.001	1.785	45.34	-0.039	0.717			
11.003	311.6	11.228	318.0	11.550	1.021	-0.008	1.813	46.05	-0.011	0.718			
6.576	186.2	6.848	193.9	7.051	1.041	0.013	1.795	45.58	-0.029	0.708			
5.706	161.6	5.851	165.7	6.058	1.025	-0.003	1.912	48.57	0.089	0.697			
Average Y----->					1.0284	Average dH@----->	1.824	46.3	Average Ko----->	0.710			

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Results		
		Variation (degF)	Percent of Absolute	
32	32	0	0.00%	
100	100	0	0.00%	
300	300	0	0.00%	
500	500	0	0.00%	
1000	1000	0	0.00%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Liam Forrer

Signature: 

Date: June 26, 2023

A. Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: **LMU-B**
Serial #: **Wizit 6276**

Date: **29-Jun-23**
Barometric Pressure: **29.87** (in. Hg)
Theoretical Critical Vacuum: **14.09** (in. Hg)

!!!!!!!

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (m³)	Volume Final (m³)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
0.00	18.00	258.3240	258.5548	8.151	78.0	78.0	77.0	77.0	48	0.3560	20.0	73.0	73.0	73.0
0.00	21.00	258.5548	258.8244	9.521	77.0	77.0	78.0	78.0	48	0.3560	20.0	73.0	74.0	73.5
0.00	22.00	258.8244	259.1069	9.976	78.0	78.0	78.0	78.0	48	0.3560	20.0	74.0	74.0	74.0

***** RESULTS *****											
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----		
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y			CALIBRATION FACTOR dH@		
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)		Value (in H2O)	Value (mm H2O)	Variation (in H2O)
7.990	226.3		8.291	234.8	8.387	1.038	0.001		0.000	0.00	0.000
9.333	264.3		9.668	273.8	9.789	1.036	-0.001		0.000	0.00	0.000
9.771	276.7		10.124	286.7	10.260	1.036	0.000		0.000	0.00	0.000
Average Y----->						1.0365		Average dH@----->	0.0000	0.00	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

For Temperature Devicee, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Liam Forrer

Signature: Justin Ching

Date: June 29, 2023

A. Lanfranco & Associates inc.

EPA Method 5

Meter Box Calibration

English Meter Box Units, English K' Factor

Model #: **LMU-D**
Serial #: **Wizit 4618**

Date: **28-Jun-23**
Barometric Pressure: **29.87** (in. Hg)
Theoretical Critical Vacuum: 14.09 (in. Hg)

!!!!!!!

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (m ³)	Volume Final (m ³)	Volume Total (cu ft)	Initial Temps. Inlet (deg F)	Initial Temps. Outlet (deg F)	Final Temps. Inlet (deg F)	Final Temps. Outlet (deg F)	Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
												Initial (deg F)	Final (deg F)	Average (deg F)
0.00	16.00	110.142	110.348	7.278	73.0	73.0	74.0	74.0	48	0.3560	20.0	73.0	74.0	73.5
0.00	27.00	110.348	110.696	12.275	74.0	74.0	77.0	77.0	48	0.3560	20.0	74.0	76.0	75.0
0.00	17.00	110.696	110.914	7.720	77.0	77.0	77.0	77.0	48	0.3560	20.0	76.0	77.0	76.5

***** RESULTS *****										
--- DRY GAS METER ---		----- ORIFICE -----			-- DRY GAS METER --		----- ORIFICE -----			
VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (cu ft)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (cu ft)	CALIBRATION FACTOR Y		CALIBRATION FACTOR dH@			
					Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)	
7.188	203.6	7.366	208.6	7.458	1.025	-0.003	0.000	0.00	0.000	
12.078	342.1	12.413	351.5	12.604	1.028	0.000	0.000	0.00	0.000	
7.575	214.5	7.805	221.0	7.947	1.030	0.003	0.000	0.00	0.000	
Average Y----->					1.0276	Average dH@----->	0.0000	0.00		

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

For Temperature Devicee, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Justin Ching

Signature: Justin Ching

Date: June 28, 2023

BAROMETER CALIBRATION FORM

Device	Cal Date	Pbar Env Canada		Device (inches of Hg)		Difference
		(kPa)	(inches of Hg)	Reading	Elevation Corrected	(Env Can - Elv Corr)
LA	10-Jul-23	101.6	30.01	29.92	29.99	0.02
DS	10-Jul-23	101.6	30.01	29.91	29.98	0.03
CL	10-Jul-23	101.6	30.01	29.92	29.99	0.02
JC	10-Jul-23	101.6	30.01	29.89	29.96	0.05
LF	10-Jul-23	101.6	30.01	29.91	29.98	0.03
SH	10-Jul-23	101.6	30.01	29.90	29.97	0.04
CDO	10-Jul-23	101.6	30.01	29.89	29.96	0.05
JG	10-Jul-23	101.6	30.01	29.87	29.94	0.07
ML	10-Jul-23	101.6	30.01	29.89	29.96	0.05
BL	10-Jul-23	101.6	30.01	29.91	29.98	0.03

Calibrated by: Daryl Sampson

Signature: Daryl Sampson

Date: 10-Jul-23

Performance Specification is

Device Corrected for Elevation must be +/- 0.1 " Hg of ENV CANADA SEA-LEVEL Pbar

Enter Environment Canada Pressure from their website for Vancouver (link below)
and the reading from your barometer on the ground floor of the office.

https://weather.gc.ca/city/pages/bc-74_metric_e.html

A. LANFRANCO and ASSOCIATES INC.
ENVIRONMENTAL CONSULTANTS

TEMPERATURE CALIBRATION FORM

Calibrated by: Daryl Sampson

Date: 8-Jul-23

Signature:

Daryl Sampson

TEMPERATURE DEVICE CALIBRATIONS

Reference Device			Temperature Settings (degrees F)													
Model CL23A Calibrator			32		100		200		300		500		800		1700	
Device	ALA #	Serial #	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation
Omega HH11A	3	300132	32	0.00%	99	-0.18%	201	0.15%	301	0.13%	500	0.00%	800	0.00%	1699	-0.05%
Omega HH11A	4	200167	32	0.00%	99	-0.18%	200	0.00%	303	0.39%	499	-0.10%	799	-0.08%	1697	-0.14%
Omega HH11A	6	600059	33	0.20%	100	0.00%	201	0.15%	300	0.00%	499.2	-0.08%	798	-0.16%	1696	-0.19%
TPI 341K	7	2.0315E+10	31	-0.20%	99.6	-0.07%	199	-0.15%	301	0.13%	499.1	-0.09%	799.1	-0.07%	1695	-0.23%
TPI 341K	8	2.0313E+10	32	0.00%	99.7	-0.05%	200.4	0.06%	301	0.13%	498.5	-0.16%	799.2	-0.06%	1696	-0.19%
Cont Cmpny	10	102008464	31	-0.20%	99.2	-0.14%	199.5	-0.08%	299	-0.13%	499	-0.10%	799.1	-0.07%	1699	-0.05%
Omega HH11	14	409426	32.5	0.10%	99.1	-0.16%	199	-0.15%	298	-0.26%	501	0.10%	799.1	-0.07%	1698	-0.09%
TPI 341K	16	400120029	31	-0.20%	100	0.00%	199.2	-0.12%	299.3	-0.09%	501	0.10%	799.1	-0.07%	1700	0.00%
TPI 341K	18	2.0329E+10	31	-0.20%	99.8	-0.04%	199.2	-0.12%	299.8	-0.03%	500	0.00%	799.5	-0.04%	1701	0.05%
TPI 341K	20	2.0329E+10	31	-0.20%	99.2	-0.14%	199.1	-0.14%	299	-0.13%	499.2	-0.08%	799.2	-0.06%	1699	-0.05%
TPI 341K	22	2.0329E+10	32	0.00%	99.6	-0.07%	199.2	-0.12%	298.4	-0.21%	499.1	-0.09%	798.5	-0.12%	1698	-0.09%
Reference device is a NIST certified digital thermocouple calibrator																
Variation expressed as a percentage of the absolute temperature must be within 1.5 %																

Calibration Certificate

Date: 11-Aug-23
Calibrated by: Louis Agassiz
Authorizing Signature: 

Instrument Calibrated: Testo 1 (330-2LL)
Serial #: 03101345
Customer: ALA

Ambient Conditions: Temperature: 23 °C Barometric Pressure: 101.8 kPa Relative Humidity: 64%

A. Lanfranco and Associates Inc. certifies that the described instrument has been inspected and tested following calibration procedures in the Environment Canada Report EPS 1/PG/7 (Revised 2005). Below are the observed readings after calibrations are complete. Calibration checks should be completed at least every 6 months.

O ₂ Gas	Initial Evaluation				After Calibration				Certified Value (vol %)
	Instrument Reading (vol %)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (vol %)	% Calibration Error	Pass/Fail	Notes	
Zero	0.1	0.10	Pass		0.1	0.10	Pass		0
O ₂	11.1	0.03	Pass		11.1	0.03	Pass		11.07
Ambient	20.9	0.05	Pass		20.9	0.05	Pass		20.95

Performance Specification: +/- 1% O₂ (absolute diff)

CO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	577	22.4%	Fail	Replaced Cell	472	0.1%	Pass		472
2 Gas	251	0.1%	Pass		250	0.3%	Pass		251
3 Gas	2285	19.7%	Fail		1908	0.1%	Pass		1909

Performance Specification: +/- 5% of Certified Gas Value

NO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	492	3.9%	Pass	Re Cal on 1 Gas	474	0.1%	Pass		473
2 Gas	45.5	4.8%	Pass		43.8	0.9%	Pass		43
3 Gas	110	4.1%	Pass		106	0.2%	Pass		106

Performance Specification: +/- 5% of Certified Gas Value

NIST Traceable Calibration Gases:

Cylinder	Cylinder ID Number	Certification Date	Expiration Date	Cylinder Pressure (PSI)	NO (ppm)	O ₂ (Vol. %)	CO (ppm)
Zero Gas (N ₂)	T97227026	10-Nov-2022	9-Nov-2027	2300	0	0	0
1 Gas	SG9107852B	6-May-2021	5-May-2024	1000	473.4	0	471.5
2 Gas	CC22286	18-Nov-2022	19-Nov-2026	1030	43.42	0	250.7
3 Gas	CC36070	13-Feb-2023	14-Feb-2031	1050	105.8	-	1909
O ₂ /CO ₂	CC256047	11-Nov-2022	12-Nov-2030	1320	0	11.07	0

Note: National Institute of Standards and Technology traceable certificates are available upon request.

Calibration Certificate

Date: 08-Aug-23
Calibrated by: Louis Agassiz
Authorizing Signature: 

Instrument Calibrated: Testo 2 (330-2LX)
Serial #: 03282252
Customer: ALA

Ambient Conditions: Temperature: 25 °C Barometric Pressure: 101.6 kPa Relative Humidity: 65%

A. Lanfranco and Associates Inc. certifies that the described instrument has been inspected and tested following calibration procedures in the Environment Canada Report EPS 1/PG/7 (Revised 2005). Below are the observed readings after calibrations are complete. Calibration checks should be completed at least every 6 months.

O ₂	Initial Evaluation				After Calibration				Certified Value (vol %)
	Instrument Reading (vol %)	Calibration Error	Pass/Fail	Notes	Instrument Reading (vol %)	Calibration Error	Pass/Fail	Notes	
Zero	0.1	0.10	Pass		0	0.00	Pass		0
O ₂	11.1	0.03	Pass		11.1	0.03	Pass		11.07
Ambient	21	0.04	Pass		21.0	0.04	Pass		20.96

Performance Specification: +/- 1% O₂ (absolute diff)

CO	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	592	25.6%	Fail	Replaced CO cell	472	0.1%	Pass		472
2 Gas	2154	13.1%	Fail		1900	0.2%	Pass		1904
3 Gas	245	2.3%	Pass		251	0.1%	Pass		251

Performance Specification: +/- 5% of Certified Gas Value

NO	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	428	9.6%	Fail	Re cal on 1	473	0.1%	Pass		473.4
2 Gas	235	8.9%	Fail	Gas	261	1.2%	Pass		258.0
3 Gas	45	3.6%	Pass		45	3.6%	Pass		43.4

Performance Specification: +/- 5% of Certified Gas Value

NIST Traceable Calibration Gases:

Cylinder	Cylinder ID Number	Certification Date	Expiration Date	Cylinder Pressure (PSI)	NO (ppm)	O ₂ (Vol. %)	CO (ppm)
Zero Gas (N ₂)	T97227026	10-Nov-2022	9-Nov-2027	2270	0	0	0
1 Gas	SG9107852B	6-May-2021	5-May-2024	950	473.4	0	471.5
2 Gas	CC320634	23-Mar-2018	23-Mar-2026	520	258	0	1904
3 Gas	CC22286	18-Nov-2022	19-Nov-2026	1030	43.42	0	250.7
O ₂ /CO ₂	CC256047	11-Nov-2022	12-Nov-2030	1320	0	11.07	0

Note: National Institute of Standards and Technology traceable certificates are available upon request.

Canadian Association for Laboratory Accreditation Inc.

Certificate of Accreditation

A. Lanfranco and Associates Inc.
101 - 9488 - 189th Street
Surrey, British Columbia



This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017.
This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated April 2017).

Accreditation No.: A4232
Issued On: February 5, 2021
Accreditation Date: February 5, 2021
Expiry Date: August 6, 2023




President & CEO





MOUNT ROYAL COLLEGE

Faculty of Continuing Education and Extension

Daryl Sampson

has successfully completed

The program of studies and is awarded the certificate in

STACK SAMPLING

May 2005

Date

Donna Spaulding

Dean
Faculty of Continuing Education and Extension

Conflict of Interest Disclosure Statement

A qualified professional ¹ providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

Declaration

I Daryl Sampson, as a member of Air and Waste Management Association
declare

Select one of the following:

☒ Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.

☐ Real or perceived conflict of interest

Description and nature of conflict(s):

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

X Daryl Sampson

Print name: Daryl Sampson

Date: Dec.18, 2020

Witnessed by:

X 

Print name: Mark Lanfranco

¹Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals¹, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional Daryl Sampson

Title Senior Environmental Technician/Project Manager

2. Are you a registered member of a professional association in B.C.? ☐ Yes ☒ No

Name of Association: _____ Registration # _____

3. Brief description of professional services:

Environmental consulting, specializing in air and atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature:

x Daryl Sampson

Print Name: Daryl Sampson

Witnessed by:

x [Signature]

Print Name: Louis Agassiz

Date signed: November 23, 2020

¹Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

Shawn Harrington

has met the requirements of

Stack Testing for Pollutants
(CHSC 7760)

School of Process, Energy and Natural Resources
Chemical Sciences Program

Endorsed by:




Environment
Canada

Environnement
Canada



Province of
British Columbia
Ministry of
Environment,
Lands and Parks


Marsh Hemekey, Dean
School of Process, Energy and Natural Resources

JUNE 21, 2001
Dated



Conflict of Interest Disclosure Statement

A qualified professional¹ providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

Declaration

I Shawn Harrington as a member of Air and Waste Management Association
declare

Select one of the following:

- ☒ Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas

, erring on the side of caution.



☐ Real or perceived conflict of interest

Description and nature of conflict(s):

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

x Shawn Harrington

Print name: Shawn Harrington

Date: Dec. 16, 2020

Witnessed by:

x Mark Lanfranco

Print name: Mark Lanfranco

¹Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.



Declaration of Competency


The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals¹, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.


1. Name of Qualified Professional Shawn Harrington
Title Senior Environmental Technician /Project manager
2. Are you a registered member of a professional association in B.C.? ☐ Yes ☒ No
Name of Association: _____ Registration # _____
3. Brief description of professional services:
Environmental consulting ,specializing in air and atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature: 
Print Name: Shawn Harrington

Witnessed by: 
Print Name: Mark Lanfranco

Date signed: November 26, 2020

¹Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

MOUNT ROYAL UNIVERSITY

Faculty of Continuing Education and Extension

Jeremy Shawn Gibbs

has successfully completed

Stack Sampling

35 Hours / 2019

May 22, 2019

Date

BUM
Dean

Faculty of Continuing Education and Extension



Conflict of Interest Disclosure Statement

A qualified professional¹ providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

Declaration

I Jeremy Gibbs, as a member of Air and Waste Management Association
declare

Select one of the following:

- ☒ Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas

, erring on the side of caution.

☐ Real or perceived conflict of interest

Description and nature of conflict(s):

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

X

Print name:

Jeremy G. B.S.S.

Witnessed by:

X

Print name:

Mark Lanfranco

Date: Dec. 16, 2020

¹Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals¹, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional

Title

Jeremy Gibbs
Environmental technician

2. Are you a registered member of a professional association in B.C.?

☐ Yes ☒ No

Name of Association: _____ Registration # _____

3. Brief description of professional services:

Environmental Consultant Specialize in air and
atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature:

X

Print Name:

Jeremy Gibbs
Nov 1, 2020

Witnessed by:

X

Print Name:

Connor Laan

¹Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

Justin Ching

has successfully completed

Stack Sampling

The Faculty of Continuing Education
Mount Royal University

30 hours | May 26, 2023



Dimitra Fotopoulos, Vice Dean
Professional and Continuing Education

Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals¹, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional Justin Ching
Title Environmental Technician
2. Are you a registered member of a professional association in B.C.? ☐ Yes ☒ No
Name of Association: _____ Registration # _____
3. Brief description of professional services:
Environmental Technician - specialising in air and atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature:

x Justin Ching

Print Name: Justin Ching

Witnessed by:

x Daryl Sampson

Print Name: Daryl Sampson

Date signed: June 28, 2023

¹Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

Conflict of Interest Disclosure Statement

A qualified professional ¹ providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

Declaration

I, Justin Ching, as a member of Air and Waste Management Association
declare

Select one of the following:

- ☒ Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.

☐ Real or perceived conflict of interest

Description and nature of conflict(s):

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

x Justin Ching

Print name: Justin Ching

Date: June 28, 2023

Witnessed by:

x Mark Lanfranco

Print name: Mark Lanfranco

¹Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

Liam Forrer

has successfully completed

Stack Sampling

The Faculty of Continuing Education
Mount Royal University

30 hours | May 26, 2023



Dimitra Fotopoulos, Vice Dean
Professional and Continuing Education

Conflict of Interest Disclosure Statement

A qualified professional¹ providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

Declaration

I Mark Lanfranco, as a member of Air and Waste Management Association
declare

Select one of the following:

- ☒ Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.

☐ Real or perceived conflict of interest

Description and nature of conflict(s):

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.


This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

X 

Print name: Mark Lanfranco

Witnessed by:

X 

Print name: Carter Lanfranco

Date: Dec.16, 2020

¹Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.