

Monthly Operating Reports

September 2020

The following September 2020 operating report was sent to the Ministry of Environment and Climate Change Strategy on November 5, 2020.

Metro Vancouver - Waste-to-Energy Facility CONTINUOUS EMISSION MONITORING SYSTEM

September 2020

1. Monthly Summary Report

| Parameter | Compliance Limit (mg/dscm) | Compliance Period | Maximum Measurement (mg/dscm) | | |
|-----------------|----------------------------|-------------------|-------------------------------|--------|--------|
| | | | Unit 1 | Unit 2 | Unit 3 |
| CO | 50 | 24 hr | 39.8 | 30.9 | 40.4 |
| SO ₂ | 200 | 24 hr | 120.6 | 120.7 | 117.7 |
| NOx | 190 | 24 hr | 128.3 | 132.1 | 131.3 |
| THC | 10 | 24 hr | 0.24 | 0.21 | 0.41 |
| | | | Monthly Average (mg/dscm) | | |
| | | | Unit 1 | Unit 2 | Unit 3 |
| Opacity (%) | | | 0.44 | 0.72 | 1.33 |
| CO | | | 26.0 | 22.8 | 27.1 |
| THC | | | 0.13 | 0.07 | 0.21 |
| SO ₂ | | | 65.9 | 61.6 | 68.8 |
| NOx | | | 124.0 | 128.9 | 129.5 |

Interim Discharge Limits will apply until and including the following dates, at which point the Discharge Limits and Response Limits will apply

a. HCl – December 31, 2022

b. SO₂ – December 31, 2022

2. Monthly Exceedance Report

2.a. Discharge Limit Exceedances

| Unit | Compliance Parameter | Discharge Limit (mg/dscm) | Date | Exceedance Level |
|------|----------------------|---------------------------|------|------------------|
| | | | | |
| | Reason/Action Taken | | | |
| | | | | |

2.b. Response Limit Exceedances

Compliance Parameter: Carbon Monoxide

Response Limit: 100 mg/dscm 1/2 hour average

Unit No. 1

| Date / Time | Duration | Exceedance (mg/dscm) | Action Taken |
|--------------|----------|----------------------|---|
| 11-Sep 14:30 | 30 min | 131.1 | Started gas burners, adjusted airflow, modified feed rate. |
| 28-Sep 10:00 | 30 min | 136.5 | Started gas burners, adjusted airflow, modified feed rate, checked instrumentation. |

Compliance Parameter: Carbon Monoxide
Response Limit: 100 mg/dscm 1/2 hour average
Unit No. 2

| Date / Time | Duration | Exceedance (mg/dscm) | Action Taken |
|--------------|----------|----------------------|---|
| 3-Sep 12:30 | 30 min | 187.3 | Started gas burners, adjusted airflow, modified feed rate, checked instrumentation. |
| 4-Sep 08:30 | 30 min | 103.6 | Adjusted airflow, modified feed rate. |
| 11-Sep 08:00 | 30 min | 142.4 | Started gas burners, adjusted airflow, modified feed rate, checked instrumentation. |
| 19-Sep 08:30 | 30 min | 152.8 | Online boiler wash, started gas burners, adjusted airflow, modified feed rate. |
| 20-Sep 12:30 | 30 min | 119.7 | Started gas burners, adjusted airflow, modified feed rate. |

Compliance Parameter: Carbon Monoxide
Response Limit: 100 mg/dscm 1/2 hour average
Unit No. 3

| Date / Time | Duration | Exceedance (mg/dscm) | Action Taken |
|--------------|----------|----------------------|--|
| 1-Sep 08:00 | 30 min | 114.1 | Feeder hang up, started gas burners, adjusted airflow, modified feed rate. |
| 6-Sep 12:30 | 30 min | 182.5 | Feeder hang up, started gas burners, adjusted airflow, modified feed rate. |
| 30-Sep 10:00 | 30 min | 101.0 | Started gas burners, adjusted airflow, modified feed rate. |
| 30-Sep 12:00 | 30 min | 138.1 | Started gas burners, adjusted airflow, modified feed rate. |
| 30-Sep 14:30 | 30 min | 234.6 | Started gas burners, adjusted airflow, modified feed rate. |

2.c. Transient Conditions

Gas burners unavailable and unable to close feed chute damper during shutdown

| Unit | Duration | Date | Time | |
|--|-------------|------------|-------------|--|
| 2 | 3 hr 57 min | Sept 13-14 | 22:50-02:47 | |
| Cause | | | | |
| <p>A lighting panel breaker failed at the facility and provided a false signal that incoming BC Hydro power was lost. Two boilers were shut down utilizing the emergency backup power, the third boiler was offline at the time. The facility automatically switches from BC Hydro power to emergency generator backup power following detection of a power outage. Auxiliary burners on unit 2 were unavailable as the induced draft fan and the forced draft fan which are required for operation, are not powered during an emergency shutdown. The operator was unable to close the feed chute damper during the shutdown as required.</p> <p>Unit 2 was placed in shutdown mode at 2020-09-13 22:50 following the perceived BC Hydro power outage. The operator was unable to close the feed chute damper as the refuse was above the damper in the feed chute. The Provincial Boiler Pressure Vessel Safety Act and the Provincial Gas Act required a boiler purge following the restart of the fans as the boiler temperature was below the safety permissive. The auxiliary burners were unavailable for a period of 1 hour and 2 minutes between 2020-09-13 22:50 and 2020-09-13 23:52.</p> | | | | |
| Action Taken to Restore Steady State Conditions | | | | |
| <p>Covanta isolated the failed lighting panel and switched back to BC Hydro Power at 2020-09-13 23:15. Isolating the lighting panel interrupted the communications with the facility control system which delayed the return to full operation. Covanta restarted the forced draft fan at 2020-09-13 23:43 and the induced draft fan at 2020-09-13 23:43. The lighting panel was repaired at 2020-09-14 01:35 which restored the lighting and communications with the control system. The natural gas burners were back online at 2020-09-13 23:52. The shutdown was completed at 2020-09-14 02:47.</p> | | | | |
| Remedial Action Planned and/or Taken | | | | |
| None identified | | | | |

Gas burners unavailable and unable to close feed chute damper during shutdown

| Unit | Duration | Date | Time | |
|---|-------------|------------|-------------|--|
| 3 | 4 hr 45 min | Sept 13-14 | 22:50-03:35 | |
| Cause | | | | |
| <p>A lighting panel breaker failed at the facility and provided a false signal that incoming BC Hydro power was lost. Two boilers were shut down utilizing the emergency backup power, the third boiler was offline at the time. The facility automatically switches from BC Hydro power to emergency generator backup power following detection of a power outage. Auxiliary burners on unit 3 were unavailable as the induced draft fan and the forced draft fan which are required for operation, are not powered during an emergency shutdown. The operator was unable to close the feed chute damper during the shutdown as required.</p> <p>Unit 3 was placed in shutdown mode at 2020-09-13 22:50 following the perceived BC Hydro power outage. The operator was unable to close the feed chute damper as the refuse was above the damper in the feed chute. The Provincial Boiler Pressure Vessel Safety Act and the Provincial Gas Act required a boiler purge following the restart of the fans as the boiler temperature was below the safety permissive. The auxiliary burners were unavailable for a period of 2 hours and 3 minutes between 2020-09-13 22:50 and 2020-09-14 00:53.</p> | | | | |
| Action Taken to Restore Steady State Conditions | | | | |
| <p>Covanta isolated the failed lighting panel and switched back to BC Hydro Power at 2020-09-13 23:15. Isolating the lighting panel interrupted the communications with the facility control system which delayed the return to full operation. Covanta restarted the induced draft fan at 2020-09-14 00:41 and the forced draft fan at 2020-09-14 00:42. The lighting panel was repaired at 2020-09-14 01:35 which restored the lighting and communications with the control system. The natural gas burners were back online at 2020-09-14 00:53. The shutdown was completed at 2020-09-14 03:35.</p> | | | | |
| Remedial Action Planned and/or Taken | | | | |
| None identified | | | | |

Gas burners unavailable and unable to close feed chute damper during shutdown

| Unit | Duration | Date | Time | |
|--|----------|-----------|---------------|--|
| 2 | 57 min | 21-Sep-20 | 08:11 - 09:08 | |
| Cause | | | | |
| <p>Auxiliary burners on unit 2 were unavailable, due to a safety permissive, to maintain the secondary combustion zone temperature during a boiler shutdown period as required.</p> <p>Unit 2 was placed in shutdown mode at 2020-09-21 08:11 following a low steam drum level trip. The operators were conducting daily tests of the boiler drum level safety device and a test switch became stuck which initiated the low steam drum level safety trip. This resulted in the induced draft fan and forced draft fan tripping at 2020-09-21 08:10. The Provincial Boiler Pressure Vessel Safety Act and the Provincial Gas Act required a boiler purge following the restart of the fans as the boiler temperature was below the safety permissive. The auxiliary burners were unavailable for a period of 38 minutes between 2020-09-21 08:11 and 2020-09-21 08:49.</p> | | | | |
| Action Taken to Restore Steady State Conditions | | | | |
| <p>Covanta restarted the induced draft fan at 2020-09-21 08:19 and the forced draft fan at 2020-09-21 08:20. The natural gas burners were back online at 2020-09-21 08:49. The shutdown was completed at 2020-09-21 09:08.</p> | | | | |
| Remedial Action Planned and/or Taken | | | | |
| None identified. Covanta's electrician rectified the issue with the low level test switch. | | | | |

Gas burners unavailable and unable to close feed chute damper during shutdown

| Unit | Duration | Date | Time | |
|---|------------|-----------|---------------|--|
| 1 | 1 hr 2 min | 29-Sep-20 | 00:08 - 01:10 | |
| Cause | | | | |
| Auxiliary burners on unit 1 were unavailable, due to a safety permissive, to maintain the secondary combustion zone temperature during a boiler shutdown period as required. The operator was unable to close the feed chute damper during the shutdown as required. | | | | |
| Unit 1 was placed in shutdown mode at 2020-09-29 00:08 following an induced draft fan and forced draft fan trip. The operator was unable to close the feed chute damper as the refuse was above the damper in the feed chute. The Provincial Boiler Pressure Vessel Safety Act and the Provincial Gas Act required a boiler purge following the restart of the fans as the boiler temperature was below the safety permissive. The auxiliary burners were unavailable for a period of 18 minutes between 2020-09-29 00:08 and 2020-09-29 00:26. | | | | |
| Action Taken to Restore Steady State Conditions | | | | |
| Covanta restarted the induced draft fan at 2020-09-29 00:11 and the forced draft fan at 2020-09-29 00:12. The natural gas burners were back online at 2020-09-29 00:26. The shutdown was completed at 2020-09-29 01:10. | | | | |
| Remedial Action Planned and/or Taken | | | | |
| Metro Vancouver's facility operator Covanta determined refuse quality contributed to unstable combustion. Covanta's operators will continue to blend the refuse to ensure a more stable fuel quality. | | | | |

3. CEMS Availability

| Analyzer | Required Availability (% hours per quarter) | Averaging Period | Monthly Availability | | |
|-----------------|--|------------------|----------------------|--------|--------|
| | | | Unit 1 | Unit 2 | Unit 3 |
| Opacity | 90 | Hour | 100 | 100 | 100 |
| Oxygen | 90 | Hour | 100 | 100 | 100 |
| CO | 90 | Hour | 100 | 100 | 100 |
| SO ₂ | 90 | Hour | 100 | 100 | 100 |
| NOx | 90 | Hour | 100 | 100 | 100 |
| THC | 90 | Hour | 100 | 99 | 100 |
| Stack Flow | 90 | Hour | 100 | 98 | 99 |

4. Shutdown Report

Unit 1

| Duration in Hours | Reason | Date |
|-------------------|--|--------------|
| 3.10 | Fabric filter baghouse bag replacement | September 1 |
| 0.17 | Induced draft fan trip | September 1 |
| 0.42 | Turbine trip | September 1 |
| 3.35 | Fabric filter bag replacement | September 3 |
| 1.87 | Fabric filter bag replacement | September 4 |
| 0.08 | Induced draft fan trip | September 11 |
| 302.07 | Annual major maintenance outage | Sept 13 - 26 |
| 13.48 | Both refuse cranes out of service | September 26 |
| 0.35 | Induced draft fan trip | September 27 |
| 0.12 | Induced draft fan trip | September 29 |
| 1.03 | Induced draft fan trip | September 29 |

Unit 2

| Duration in Hours | Reason | Date |
|-------------------|--|--------------|
| 0.42 | Turbine trip | September 1 |
| 1.03 | Steam drum safety valve issue | September 1 |
| 0.68 | Poor refuse quality | September 1 |
| 0.70 | Refuse crane power issue | September 13 |
| 4.05 | Plant tripped due to failed lighting panel | Sept 13-14 |
| 0.97 | Boiler trip due to jammed low water cut out switch | September 21 |
| 3.45 | Ash discharger plug | September 25 |
| 13.27 | Both refuse cranes out of service | September 26 |
| 1.77 | Poor refuse quality | September 27 |
| 3.58 | Poor refuse quality | September 27 |

Unit 3

| Duration in Hours | Reason | Date |
|-------------------|--|--------------|
| 0.25 | Feed chute hang up | September 6 |
| 4.85 | Plant tripped due to failed lighting panel | Sept 13-14 |
| 3.14 | Fabric filter bag replacement | September 19 |
| 0.35 | BC Hydro power interruption | September 24 |
| 12.35 | Both refuse cranes out of service | September 26 |

5. Facility Bypass and Emergency/spill Event Report

| Date/Time | Cause | Duration |
|-----------|--------------|----------|
| | | |
| | Action Taken | |
| | | |

6. Other Data

| | | UNIT 1 | UNIT 2 | UNIT 3 |
|-------------------------|-----------------------|-------------------|--------|--------|
| Waste Received | tonnes/day | 17,653 | | |
| Waste Processed | tonnes/day | 126 | 217 | 231 |
| Maximum Waste Processed | tonnes/day | 246 | 243 | 248 |
| | | Units 1, 2, and 3 | | |
| Natural Gas Consumed | m ³ /day | 6,250 | | |
| | m ³ /month | 187,515 | | |
| Fly ash disposed | tonnes | 689 | | |
| Bottom ash disposed | tonnes | 2,882 | | |

7. Complaints and Responses

| Date/Time | Complaint | Action Taken |
|---|--|--|
| 8/31/2020 12:10:00 PM (received Sept 2, 2020) | Odour Complaint - complainant identified Waste-to-Energy Facility as possible source | Plant Manager did a walk around the facility, detecting no odours. Working with the Metro Vancouver Environmental Regulation & Enforcement Department to determine the source of the odours. |
| 9/1/2020 | Odour Complaint - complainant identified Waste-to-Energy Facility as possible source | Plant Manager did a walk around the facility, detecting no odours. Working with the Metro Vancouver Environmental Regulation & Enforcement Department to determine the source of the odours. |

September 2020 - Monthly CEMS Data

| Date | Boiler #1 | | | | | | | | Boiler #2 | | | | | | | | Boiler #3 | | | | | | | |
|---------|------------|--------------------|--------------------------------------|--------------------------------------|-------------------------|--------------------------|-------------|--------------|------------|--------------------|--------------------------------------|--------------------------------------|-------------------------|--------------------------|-------------|--------------|------------|--------------------|--------------------------------------|--------------------------------------|-------------------------|--------------------------|-------------|--------------|
| | Stack Temp | O ₂ (%) | SO ₂ (mg/m ³) | NO _x (mg/m ³) | CO (mg/m ³) | THC (mg/m ³) | Opacity (%) | Furnace Temp | Stack Temp | O ₂ (%) | SO ₂ (mg/m ³) | NO _x (mg/m ³) | CO (mg/m ³) | THC (mg/m ³) | Opacity (%) | Furnace Temp | Stack Temp | O ₂ (%) | SO ₂ (mg/m ³) | NO _x (mg/m ³) | CO (mg/m ³) | THC (mg/m ³) | Opacity (%) | Furnace Temp |
| 9/1/20 | 157 | 10.5 | 61.7 | 127.6 | 29.8 | 0.06 | 0.42 | 915 | 149 | 9.8 | 55.5 | 128.7 | 22.1 | 0.03 | 0.48 | 911 | 151 | 10.1 | 73.1 | 128.9 | 22.4 | 0.13 | 0.88 | 902 |
| 9/2/20 | 154 | 10.1 | 59.9 | 123.7 | 24.4 | 0.06 | 0.35 | 944 | 148 | 9.3 | 53.5 | 131.9 | 22.3 | 0.02 | 0.75 | 928 | 146 | 10 | 78.8 | 128.4 | 29.3 | 0.17 | 0.88 | 899 |
| 9/3/20 | 156 | 10.3 | 54.5 | 125.8 | 31.2 | 0.10 | 0.61 | 899 | 150 | 9.4 | 51 | 129.4 | 24.7 | 0.10 | 0.78 | 925 | 148 | 10.3 | 58.4 | 129.1 | 34.5 | 0.16 | 0.85 | 892 |
| 9/4/20 | 157 | 10.4 | 55.6 | 124.8 | 27.7 | 0.08 | 0.57 | 921 | 150 | 9.2 | 48.9 | 130.2 | 23.5 | 0.07 | 0.62 | 928 | 151 | 9.9 | 71.5 | 129.9 | 27.8 | 0.18 | 0.85 | 915 |
| 9/5/20 | 158 | 10.6 | 56.7 | 125.9 | 18.2 | 0.10 | 0.37 | 929 | 148 | 9.3 | 58 | 129.4 | 20.2 | 0.02 | 0.54 | 937 | 152 | 9.8 | 77.6 | 130 | 22.3 | 0.17 | 0.82 | 932 |
| 9/6/20 | 158 | 10.8 | 57.9 | 126.1 | 23.5 | 0.12 | 0.35 | 921 | 149 | 9.4 | 63.3 | 129.7 | 18.1 | 0.08 | 0.56 | 933 | 150 | 9.8 | 69.6 | 129.1 | 21.1 | 0.19 | 0.84 | 926 |
| 9/7/20 | 155 | 10 | 75.4 | 123.8 | 18.9 | 0.13 | 0.38 | 946 | 150 | 9.7 | 57.4 | 130 | 21.2 | 0.10 | 0.47 | 921 | 150 | 9.7 | 57.2 | 128.8 | 21.2 | 0.31 | 0.88 | 920 |
| 9/8/20 | 157 | 10.4 | 61.5 | 124.7 | 18.4 | 0.05 | 0.44 | 933 | 151 | 9.9 | 57.8 | 130.3 | 21.9 | 0.05 | 0.93 | 917 | 151 | 9.7 | 64.9 | 128 | 18.2 | 0.12 | 0.93 | 922 |
| 9/9/20 | 159 | 10.5 | 45.1 | 124.1 | 20.4 | 0.10 | 0.48 | 926 | 154 | 9.6 | 50 | 129.3 | 20.6 | 0.02 | 1.30 | 928 | 154 | 9.7 | 63.6 | 129.8 | 20.1 | 0.12 | 0.98 | 919 |
| 9/10/20 | 159 | 10.5 | 44 | 119.3 | 25 | 0.12 | 0.45 | 945 | 153 | 9.8 | 49.8 | 129.4 | 26.6 | 0.08 | 0.94 | 912 | 154 | 9.7 | 65.2 | 128.9 | 23 | 0.13 | 0.97 | 913 |
| 9/11/20 | 157 | 11 | 46.7 | 121.9 | 36.3 | 0.17 | 0.44 | 939 | 153 | 9.6 | 45.5 | 127.7 | 23.6 | 0.05 | 1.10 | 930 | 154 | 9.6 | 57.2 | 128.7 | 23.7 | 0.12 | 0.95 | 921 |
| 9/12/20 | 151 | 11.9 | 44.4 | 117.8 | 39.8 | 0.24 | 0.50 | 903 | 152 | 9.9 | 47.7 | 127.7 | 26.6 | 0.04 | 1.38 | 929 | 153 | 9.4 | 60.4 | 130 | 20.2 | 0.12 | 1.05 | 922 |
| 9/13/20 | | | | | | | | | 150 | 9.9 | 46.8 | 127.6 | 20.7 | 0.02 | 0.73 | 930 | 152 | 10 | 51.7 | 130.1 | 21.9 | 0.25 | 1.07 | 899 |
| 9/14/20 | | | | | | | | | 151 | 10.1 | 35.3 | 127.7 | 30.9 | 0.05 | 0.68 | 897 | 153 | 9.5 | 56.8 | 129.3 | 28.1 | 0.13 | 1.19 | 914 |
| 9/15/20 | | | | | | | | | 150 | 10 | 75.3 | 129 | 27.6 | 0.09 | 0.14 | 900 | 150 | 9.6 | 78.6 | 128.1 | 34 | 0.14 | 1.26 | 906 |
| 9/16/20 | | | | | | | | | 153 | 9.8 | 120.7 | 127.2 | 21.8 | 0.06 | 0.29 | 920 | 155 | 9.5 | 115.2 | 128.4 | 23.9 | 0.20 | 1.26 | 930 |
| 9/17/20 | | | | | | | | | 151 | 9.9 | 94.7 | 128 | 23.6 | 0.16 | 0.08 | 915 | 154 | 9.5 | 104.4 | 129.7 | 25.3 | 0.36 | 1.27 | 922 |
| 9/18/20 | | | | | | | | | 151 | 10 | 67.5 | 129.5 | 21.6 | 0.07 | 0.16 | 909 | 153 | 9.5 | 78.8 | 131.3 | 32.8 | 0.18 | 1.39 | 921 |
| 9/19/20 | | | | | | | | | 152 | 9.8 | 58 | 132.1 | 26.4 | 0.21 | 0.67 | 927 | 152 | 9.6 | 59.5 | 129.1 | 33.8 | 0.21 | 2.17 | 912 |
| 9/20/20 | | | | | | | | | 153 | 9.4 | 119.6 | 127.2 | 24.7 | 0.12 | 0.53 | 939 | 153 | 9.1 | 117.7 | 128.4 | 25.6 | 0.21 | 2.22 | 937 |
| 9/21/20 | | | | | | | | | 154 | 9.3 | 89.3 | 128.6 | 25.5 | 0.06 | 0.67 | 915 | 155 | 9.3 | 81.9 | 129 | 27.3 | 0.29 | 1.97 | 909 |
| 9/22/20 | | | | | | | | | 150 | 9.3 | 85.1 | 130.4 | 23.6 | 0.08 | 0.44 | 924 | 154 | 9.4 | 98.5 | 130.2 | 28.5 | 0.17 | 2.15 | 924 |
| 9/23/20 | | | | | | | | | 151 | 9.4 | 57.2 | 129.7 | 23.8 | 0.05 | 0.54 | 915 | 152 | 9.4 | 45.4 | 130.2 | 32 | 0.19 | 2.27 | 914 |
| 9/24/20 | | | | | | | | | 150 | 9.6 | 41.6 | 127.7 | 20 | 0.12 | 1.12 | 896 | 151 | 9.3 | 45.9 | 130.3 | 28.5 | 0.19 | 1.92 | 891 |
| 9/25/20 | | | | | | | | | 153 | 9.9 | 44.2 | 128.1 | 18.3 | 0.04 | 1.45 | 867 | 155 | 9.8 | 45.6 | 129.1 | 26.7 | 0.33 | 1.91 | 877 |
| 9/26/20 | | | | | | | | | | | | | | | | | | | | | | | | |
| 9/27/20 | 144 | 10.3 | 73.6 | 115 | 24 | 0.20 | 0.41 | 901 | 156 | 10.8 | 44.5 | 129.2 | 16 | 0.08 | 1.31 | 866 | 155 | 10.1 | 57.1 | 130.6 | 28.8 | 0.32 | 1.40 | 883 |
| 9/28/20 | 152 | 9.7 | 79.3 | 127.5 | 31.1 | 0.15 | 0.39 | 882 | 154 | 9.6 | 49.4 | 127 | 24.2 | 0.08 | 1.03 | 901 | 154 | 9.9 | 45.2 | 131.1 | 35.7 | 0.41 | 1.41 | 883 |
| 9/29/20 | 148 | 9.6 | 117 | 128.3 | 24.3 | 0.19 | 0.42 | 902 | 153 | 9.4 | 53.6 | 126.6 | 21.1 | 0.06 | 0.85 | 908 | 156 | 9.8 | 57 | 130.1 | 27.8 | 0.27 | 1.43 | 877 |
| 9/30/20 | 149 | 10.1 | 120.6 | 128.3 | 22.6 | 0.14 | 0.44 | 897 | 152 | 9.5 | 66.2 | 128.9 | 20 | 0.10 | 0.44 | 915 | 154 | 10.7 | 58.1 | 130.7 | 40.4 | 0.41 | 1.46 | 897 |
| Average | 154 | 10.4 | 65.9 | 124.0 | 26.0 | 0.13 | 0.44 | 919 | 151.4 | 9.7 | 61.6 | 128.9 | 22.8 | 0.07 | 0.72 | 915.3 | 152.5 | 9.7 | 68.8 | 129.5 | 27.1 | 0.21 | 1.33 | 909.6 |
| Min | 144 | 9.6 | 44.0 | 115.0 | 18.2 | 0.05 | 0.35 | 882 | 148.0 | 9.2 | 35.3 | 126.6 | 16.0 | 0.02 | 0.08 | 866.0 | 146.0 | 9.1 | 45.2 | 128.0 | 18.2 | 0.12 | 0.82 | 877.0 |
| Max | 159 | 11.9 | 120.6 | 128.3 | 39.8 | 0.24 | 0.61 | 946 | 156.0 | 10.8 | 120.7 | 132.1 | 30.9 | 0.21 | 1.45 | 939.0 | 156.0 | 10.7 | 117.7 | 131.3 | 40.4 | 0.41 | 2.27 | 937.0 |
| St Dev | 4.4 | 0.54 | 23.29 | 3.84 | 6.30 | 0.05 | 0.07 | 19.9 | 1.96 | 0.34 | 21.40 | 1.37 | 3.16 | 0.04 | 0.37 | 17.77 | 2.28 | 0.33 | 19.68 | 0.89 | 5.45 | 0.09 | 0.48 | 16.69 |

Blank days have less than 18 hours of valid data due to unit shut downs or analyzer outage

According to standard guidelines used by Metro Vancouver Air Quality Policy and Environment Division, a minimum of 18 hours of valid data is required to generate a valid 24hr average