

# Metro Vancouver - Waste-to-Energy Facility CONTINUOUS EMISSION MONITORING SYSTEM

July 2025

## 1. Monthly Summary Report

Parameter	Compliance Limit (mg/dscm)	Compliance Period	Maximum Measurement (mg/dscm)		
			Unit 1	Unit 2	Unit 3
CO	50	24 hr	30.1	37.2	42.2
SO <sub>2</sub>	200	24 hr	91.7	101.0	111.2
NOx	190	24 hr	139.1	151.3	150.3
THC	10	24 hr	0.17	0.63	0.57
			Monthly Average (mg/dscm)		
			Unit 1	Unit 2	Unit 3
Opacity (%)			0.44	0.97	0.72
CO			23.3	29.8	31.2
THC			0.03	0.48	0.31
SO <sub>2</sub>			60.9	71.3	77.3
NOx			131.7	132.0	137.5

Interim Discharge Limits will apply until and including the following dates, at which point the Discharge Limits and Response Limits will apply

a. HCl – March 3, 2028

b. SO<sub>2</sub> – March 3, 2028

## 2. Monthly Exceedance Report

### 2.a. Discharge Limit Exceedances

Unit	Compliance Parameter	Discharge Limit (mg/dscm)	Date	Exceedance Level
	Reason/Action Taken			

### 2.b. Response Limit Exceedances

Compliance Parameter: Carbon Monoxide

Response Limit: 100 mg/dscm 1/2 hour average

Unit No. 1

Date / Time	Duration	Exceedance (mg/dscm)	Action Taken
1-Jul 10:00	30 min	119.8	No action required.
8-Jul 12:30	30 min	153.9	Started gas burners, adjusted airflow, modified feed rate.
14-Jul 02:00	30 min	108.8	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
23-Jul 18:30	30 min	105.7	Volatile fuel. Adjusted airflow, modified feed rate.
24-Jul 11:00	30 min	107.2	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate, checked instrumentation.

**Compliance Parameter: Carbon Monoxide**  
**Response Limit: 100 mg/dscm 1/2 hour average**  
**Unit No. 2**

Date / Time	Duration	Exceedance (mg/dscm)	Action Taken
9-Jul 04:30	30 min	113.0	Feeder hang-up. Started gas burners, adjusted airflow, modified feed rate.
11-Jul 06:30	30 min	101.5	Volatile fuel. Started gas burners, adjusted airflow.
14-Jul 14:30	30 min	186.8	Volatile fuel. Adjusted airflow, modified feed rate.
15-Jul 08:30	30 min	106.5	Volatile fuel. Adjusted airflow, modified feed rate.
15-Jul 15:30	30 min	104.8	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
16-Jul 06:30	30 min	131.6	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
17-Jul 18:30	30 min	184.2	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
18-Jul 07:00	30 min	139.6	Adjusted airflow, modified feed rate.
21-Jul 08:30	30 min	105.3	Started gas burners, adjusted airflow, modified feed rate, checked instrumentation.
21-Jul 15:00	30 min	134.6	Started gas burners, adjusted airflow, modified feed rate.
21-Jul 16:30	30 min	108.4	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
22-Jul 14:00	30 min	139.5	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
23-Jul 14:30	30 min	192.8	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
24-Jul 16:30	30 min	132.7	Started gas burners, adjusted airflow, modified feed rate
25-Jul 10:30	30 min	102.8	Feeder hang-up. Started gas burners, adjusted airflow, modified feed rate, checked instrumentation.
25-Jul 13:30	30 min	131.8	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate, checked instrumentation.
25-Jul 18:30	30 min	109.5	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
27-Jul 03:30	30 min	136.3	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
28-Jul 05:00	30 min	122.5	Started gas burners, adjusted airflow, modified feed rate.
31-Jul 14:00	30 min	166.5	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
31-Jul 23:00	30 min	111.2	Started gas burners, adjusted airflow, modified feed rate, checked instrumentation.

**Compliance Parameter: Carbon Monoxide**  
**Response Limit: 100 mg/dscm 1/2 hour average**  
**Unit No. 3**

Date / Time	Duration	Exceedance (mg/dscm)	Action Taken
6-Jul 11:30	30 min	151.9	Started gas burners, adjusted airflow, modified feed rate.
6-Jul 12:30	30 min	111.8	Started gas burners, adjusted airflow, modified feed rate, checked instrumentation.
7-Jul 16:00	30 min	101.6	Poor refuse quality. Started gas burners, adjusted airflow, modified feed rate, checked instrumentation.
12-Jul 23:00	30 min	241.5	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate, checked instrumentation.
14-Jul 02:30	30 min	114.4	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
14-Jul 04:30	30 min	102.0	Volatile fuel. Started gas burners, adjusted airflow.

16-Jul 03:30	30 min	153.6	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
16-Jul 17:00	30 min	114.5	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
17-Jul 17:30	30 min	138.1	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
23-Jul 11:30	30 min	373.3	Started gas burners, adjusted airflow, modified feed rate.
24-Jul 11:00	30 min	103.2	Poor refuse quality. Started gas burners, adjusted airflow, modified feed rate, checked instrumentation.
24-Jul 07:00	30 min	175.2	Started gas burners, adjusted airflow, modified feed rate, checked instrumentation.
24-Jul 16:30	30 min	113.2	Started gas burners, adjusted airflow, modified feed rate.
27-Jul 00:00	30 min	136.8	Started gas burners, adjusted airflow, modified feed rate.
28-Jul 11:30	30 min	209.8	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
29-Jul 09:00	30 min	158.7	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
30-Jul 16:30	30 min	116.8	Started gas burners, adjusted airflow, modified feed rate.
31-Jul 17:30	30 min	251.9	Volatile fuel. Started gas burners, adjusted airflow, modified feed rate.
31-Jul 20:00	30 min	148.1	No action required.

**Compliance Parameter: Opacity**

**Response Limit: 5% 1/2 hour average**

**Unit No. 2**

Date / Time	Duration	Exceedance (mg/dscm)	Action Taken
3-Jul 11:30	30 min	5.4	Inspected fabric filter compartments.

**2.c. Transient Conditions**

**Gas burners unavailable during shutdown and furnace temperature average below 800C**

Unit	Duration	Date	Time	
<b>Cause</b>				
<b>Action Taken to Restore Steady State Conditions</b>				
<b>Remedial Action Planned and/or Taken</b>				

### 3. CEMS Availability

Analyser	Required Availability (% hours per quarter)	Averaging Period	Monthly Availability		
			Unit 1	Unit 2	Unit 3
Opacity	90	Hour	100	100	100
Oxygen	90	Hour	98	99	97
CO	90	Hour	98	99	97
SO <sub>2</sub>	90	Hour	98	99	97
NOx	90	Hour	98	99	97
THC	90	Hour	98	99	97
Stack Flow	90	Hour	100	99	100

### 4. Shutdown Report

#### Unit 1

Duration in Hours	Reason	Date
15.36	Fabric filter baghouse inspection/replacement	July 2-3
3.75	Fabric filter baghouse inspection/replacement	July 3
1.28	Refuse crane malfunction	July 7
0.28	Volatile fuel	July 8
0.48	BC Hydro power interruption	July 9
0.65	BC Hydro power interruption	July 9
7.77	Boiler water wash	July 10
0.53	Volatile fuel	July 12
0.63	BC Hydro power interruption	July 16
45.04	Grate bar replacement	July 19-21
1.18	Grate bar replacement	July 21

#### Unit 2

Duration in Hours	Reason	Date
4.90	Fabric filter baghouse inspection/replacement	July 3
5.17	Fabric filter baghouse inspection/replacement	July 4
1.35	Refuse crane malfunction	July 7
1.47	BC Hydro power interruption	July 9
0.73	BC Hydro power interruption	July 9
0.60	Volatile fuel	July 12
0.50	BC Hydro power interruption	July 16
0.53	Volatile fuel	July 16
0.88	Fabric filter baghouse inspection/replacement	July 19
0.98	BC Hydro power interruption	July 21
0.45	Induced draft fan trip	July 28
49.14	Economizer repair	July 29-31
0.17	Volatile fuel	July 31

### Unit 3

Duration in Hours	Reason	Date
130.92	Tube leak	July 1-6
1.35	Refuse crane malfunction	July 7
0.47	BC Hydro power interruption	July 9
0.75	BC Hydro power interruption	July 9
0.40	BC Hydro power interruption	July 12
0.47	BC Hydro power interruption	July 16
0.83	BC Hydro power interruption	July 21
2.67	Grate bar replacement	July 28
2.47	Volatile fuel	July 29

### 5. Facility Bypass and Emergency/spill Event Report

Date/Time	Cause	Duration
	Action Taken	

### 6. Other Data

		UNIT 1	UNIT 2	UNIT 3
Waste Received	tonnes	18,617		
Waste Processed	tonnes/day	221	226	215
Maximum Waste Processed	tonnes/day	238	262	263
Natural Gas Consumed	m <sup>3</sup> /day	247		
	m <sup>3</sup> /month	7,655		
Fly ash disposed	tonnes	722		
Bottom ash disposed	tonnes	3,212		

### 7. Complaints and Responses

Date/Time	Complaint	Action Taken

# ATTACHMENT 2

## July 2025 - Monthly CEMS Data

Date	Boiler #1								Boiler #2								Boiler #3								
	Stack Temp	O <sub>2</sub> (%)	SO <sub>2</sub> (mg/m <sup>3</sup> )	NO <sub>x</sub> (mg/m <sup>3</sup> )	CO (mg/m <sup>3</sup> )	THC (mg/m <sup>3</sup> )	Opacity (%)	Furnace Temp	Stack Temp	O <sub>2</sub> (%)	SO <sub>2</sub> (mg/m <sup>3</sup> )	NO <sub>x</sub> (mg/m <sup>3</sup> )	CO (mg/m <sup>3</sup> )	THC (mg/m <sup>3</sup> )	Opacity (%)	Furnace Temp	Stack Temp	O <sub>2</sub> (%)	SO <sub>2</sub> (mg/m <sup>3</sup> )	NO <sub>x</sub> (mg/m <sup>3</sup> )	CO (mg/m <sup>3</sup> )	THC (mg/m <sup>3</sup> )	Opacity (%)	Furnace Temp	
7/1/25	155.9	10.3	78.9	129.7	25.3	0.09	0.30	867	152.8	10.1	90.9	131.6	27.8	0.61	0.69	895									
7/2/25									152.3	10	78.2	129.1	29.8	0.48	0.75	889									
7/3/25	155.3	10.4	70.5	131.2	26.8	0.03	0.98	922	152.3	10	97	132.3	25.8	0.52	1.24	893									
7/4/25	156.2	10.3	91.7	128	22.5	0.01	0.36	936	150.6	10	101	127.9	24.3	0.40	1.39	920									
7/5/25	156.3	10.2	57.7	129.5	20.2	0.00	0.41	959	153.7	9.4	85.7	128.6	24.8	0.41	1.04	932									
7/6/25	156.1	9.9	71.9	125.6	22.1	0.00	0.40	947	155.6	9.6	74.2	127.7	27.3	0.44	1.03	914									
7/7/25	155.9	10.4	70.3	129.7	25.4	0.01	0.32	908	155.6	10.2	82.1	128.8	33.5	0.47	1.02	890	142	9.4	85.4	134.5	40.1	0.25	0.54	863	
7/8/25	155.9	10.6	61.2	130.3	30.1	0.07	0.33	946	156.5	10.2	89.6	135.7	30.7	0.45	0.96	897	142.2	9.4	92.6	140	33.4	0.27	0.58	864	
7/9/25	156.9	10.3	55.3	128.1	23.1	0.00	0.38	917	154.2	10.4	70.4	133.5	30.6	0.46	0.91	893	151.3	9.9	83	135.6	28.9	0.13	0.61	869	
7/10/25									151.6	10.1	77.2	139.2	31.4	0.51	0.93	911	154.9	9.9	88.5	136	29.8	0.20	0.63	881	
7/11/25	159.2	10.1	58	130	24.5	0.02	0.39	947	153.5	10	76.5	138.9	25.5	0.45	0.96	917	155.5	9.9	85.2	134.3	24.9	0.21	0.60	888	
7/12/25	159.8	10.1	56.4	133.6	25.2	0.01	0.40	881	153.2	10.1	81.7	130.1	35.4	0.50	0.96	908	155.4	9.4	111.2	132.1	39	0.37	0.61	890	
7/13/25	160.2	10.3	41.1	130.6	28.4	0.03	0.39	926	153.7	10.3	69.4	144.4	26.5	0.53	1.00	898	154.1	9.8	85.9	130.9	28.7	0.22	0.62	879	
7/14/25	157.9	9.7	46.3	132.2	18.5	0.07	0.37	963	151.5	10	61	137.4	29	0.53	0.89	918	153.8	10.1	70.8	130	34.9	0.33	0.57	895	
7/15/25	158.2	9.9	57.5	137.2	21.7	0.00	0.37	950	151.5	9.9	84.5	140.5	28.9	0.47	0.94	909	154.1	10.1	90.1	139.1	30.6	0.22	0.58	894	
7/16/25	158.7	10	45.5	130.9	27.1	0.08	0.38	963	153.5	10	56.6	151.3	36.7	0.57	0.88	891	155.6	9.7	66.4	146.5	39.9	0.40	0.60	897	
7/17/25	157.2	9.9	64.5	131.7	18.5	0.00	0.35	911	153.9	9.7	74.9	138.4	31.2	0.51	0.93	921	154.4	9.9	86.7	150.3	30.8	0.21	0.62	907	
7/18/25	158.9	9.9	50.1	131.7	20.2	0.02	0.46	927	156.5	10.3	58	129.5	32.3	0.40	0.92	908	155.8	10	72.4	140.6	30.6	0.28	0.63	892	
7/19/25									154.4	10.5	70.6	124.3	33.6	0.44	1.34	909	154.2	10.2	84	140.3	22.5	0.33	0.67	885	
7/20/25									153.5	10.8	66.3	128.4	31.7	0.42	0.99	904	149.6	9.9	79	130.8	25.9	0.30	0.69	898	
7/21/25									152	10	47.7	128.9	37.2	0.40	0.92	909	152.2	9.5	62.8	135.1	27.4	0.26	0.66	907	
7/22/25	155.9	10.1	84.4	134.8	19.9	0.00	0.64	977	151.9	10	67.9	126.9	23.6	0.40	0.92	923	152.5	9.7	82.4	132.8	33.5	0.32	0.63	897	
7/23/25	152.9	9.6	42.7	132.4	24	0.17	0.57	949	152.7	9.7	44	128.3	30	0.48	0.93	926	148.1	9.7	46	135.6	34	0.35	0.64	884	
7/24/25	156	9.6	44.4	130.1	22.6	0.10	0.40	933	154.2	9.8	45.4	125.4	30.4	0.38	0.91	918	153.1	9.7	46	135.1	33.9	0.36	0.64	885	
7/25/25	153.1	10	57.6	132.3	18.2	0.01	0.43	923	152.6	10.2	56	129	32.6	0.52	0.89	905	150.7	9.8	61.4	136.1	23.2	0.35	0.68	863	
7/26/25	156.6	9.7	73	129.8	24.8	0.01	0.53	902	153.1	9.9	62.3	125.9	30.4	0.43	0.94	884	154.2	9	81	134.3	22.1	0.31	0.72	855	
7/27/25	155.8	9.9	72.5	133.1	19.4	0.00	0.50	908	151.9	10.1	62.9	125.5	25.8	0.52	0.94	892	154.2	9.3	83.9	142.5	25.1	0.32	0.72	847	
7/28/25	156.5	10.5	63.6	139.1	24.5	0.01	0.46	927	152.5	10.4	65.4	127.8	28.6	0.63	0.90	893	153.9	9.3	78.3	141.1	33.7	0.35	0.83	874	
7/29/25																	155.5	9.7	75.2	142.2	32.3	0.40	1.06	882	
7/30/25	153.7	10.7	49.5	136.9	23.7	0.01	0.46	888									154.7	9.8	62.8	141.3	32.6	0.39	1.30	884	
7/31/25	153.1	10.3	59	133.3	25.7	0.06	0.47	962									154.8	9.7	71.2	140.2	42.2	0.57	1.53	890	
<b>Average</b>	156	10.1	60.9	131.7	23.3	0.03	0.44	930	153.3	10.1	71.3	132.0	29.8	0.48	0.97	906.0	152.7	9.7	77.3	137.5	31.2	0.31	0.72	882.8	
<b>Min</b>	153	9.6	41.1	125.6	18.2	0.00	0.30	867	150.6	9.4	44.0	124.3	23.6	0.38	0.69	884.0	142.0	9.0	46.0	130.0	22.1	0.13	0.54	847.0	
<b>Max</b>	160	10.7	91.7	139.1	30.1	0.17	0.98	977	156.5	10.8	101.0	151.3	37.2	0.63	1.39	932.0	155.8	10.2	111.2	150.3	42.2	0.57	1.53	907.0	
<b>St Dev</b>	2.0	0.30	13.25	3.03	3.20	0.04	0.14	27.7	1.50	0.29	14.82	6.47	3.62	0.06	0.15	12.98	3.72	0.29	14.41	5.01	5.56	0.09	0.24	15.53	

Blank days have less than 18 hours of valid data due to unit shut downs or analyzer outage/maintenance.  
 According to standard guidelines used by Metro Vancouver Air Quality Policy and Environment Division, a minimum of 18 hours of valid data is required to generate a valid 24hr average.