



**A. Lanfranco  
& Associates Inc.**

Environmental Consultants

**Prepared for**

**METRO VANCOUVER**

**Metrotower III**

**4515 Central Boulevard**

**Burnaby, BC V5H 0C6**

**WASTE-TO-ENERGY FACILITY**

**Appendices of Emissions Testing Report**

**November 2025 Survey**

**Fourth Quarter 2025**

# Table of Contents

## Appendix

- A Quality Assurance / Quality Control Results
- B Calculations
- C Laboratory Results
- D Computer Generated Results
- E Field Data Sheets
- F Calibration Sheets and Technician Certificates

## **APPENDIX – A**

### **QUALITY ASSURANCE / QUALITY CONTROL RESULTS**

Quality assurance / quality control (QA/QC) is divided into four categories: administration, preparation, testing, and analysis. The following sections detail results found for the above four categories.

#### **Administration:**

- All field, process, and analytical data was reviewed to ensure data integrity and accuracy.
- Duplicate proof of draft and final report, including data entry, conducted.

#### **Preparation:**

- All glassware cleaned
- Blank samples of reagents collected.

#### **Testing:**

- Stack diameter and absence of cyclonic flow confirmed
- Calibrated magnehelic used for all velocity measurements
- All trains past pre- and post- leak checks.
- Isokinetics all within  $100\% \pm 10\%$ .

Analysis:

- Trace Metals and Mercury analysis conducted at Element Labs, Surrey, B.C.
- Fluoride (HF/HCl) analysis conducted at Element Labs in Surrey, B.C.
- Nitrous Oxide (N<sub>2</sub>O) analysis conducted at Bureau Veritas in Mississauga, ON.
- Volatile Organic Compounds (VOC) analysis conducted at ALS Environmental in Simi Valley, CA.
- Particulate analysis conducted at A. Lanfranco and Associates Inc., Surrey, BC.
- Cr6 analysis conducted at ALS Environmental, Waterloo.
- Chain of Custody protocols followed for all samples.
- Acceptable blank values for all sample types. All samples blank corrected.

Sample Type	Blank Value		
	Unit 1	Unit 2	Unit 3
Fourth Quarter 2025			
Filter	-0.3 mg	-0.2 mg	-0.3 mg
Front Half Washings	-0.3 mg	-0.1 mg	0.3 mg
Mercury Front	<0.025 ug	<0.025 ug	<0.025 ug
Mercury Back	<0.225 ug	<0.131 ug	<0.210 ug
Trace Metals Front *	<59.0 ug	<78.1 ug	<64.6 ug
Trace Metals Back*	<28.8 ug	<34.6 ug	<12.0 ug
Hexavalent Chromium	<0.68 ug	N/A	N/A
Ammonia	14.5 ug	15.2 ug	19.1 ug
Fluoride	<30 ug	<30 ug	<40 ug
Chloride	<50 ug	<50 ug	<60 ug

Sum of all reported elements except Hg\*

**APPENDIX - B**

**CALCULATIONS**

## Appendix B Calculations

The following sections show the equations and define the variables that were used for this survey. The equations are organized in three sections. Equations 1-11 were used to calculate particulate concentration at standard conditions on a dry basis. Equations 12-26 were used to sample within the  $100 \pm 10\%$  isokinetic variation and to confirm that sampling meets this isokinetic variation threshold. Equations 27-29 were used to calculate the volumetric flowrate of the stack flue gas.

### App B.1 Contaminant Concentration Calculations

$$c = \frac{m}{V_{std}} \quad \text{Equation 1}$$

$$m_{part} = m_{filter} + m_{pw} \quad \text{Equation 2}$$

$$m_i = m_{ana,i} - m_{blank} \quad \text{Equation 3}$$

$$V_{std} = \frac{V_{std(imp)}}{35.315} \quad \text{Equation 4}$$

$$V_{std(imp)} = \frac{V_{samp} \times y \times P_m \times (T_{std} + 459.67)}{P_{std} \times (T_{m(ave)} + 459.67)} \quad \text{Equation 5}$$

$$V_{samp} = V_{final} - V_{init} \quad \text{Equation 6}$$

$$P_m = P_B + \frac{\Delta H_{ave}}{13.6} \quad \text{Equation 7}$$

$$\Delta H_{ave} = \frac{1}{n} \sum_{i=1}^n \Delta H_{i(act)}, \text{ where } n = \text{the number of points} \quad \text{Equation 8}$$

$$OC = \frac{20.9 - \%O_{2c}}{20.9 - \%O_{2m}} \quad \text{Equation 9}$$

$$\%O_{2m} = \frac{1}{n} \sum_{i=1}^n \%O_{2i}, \text{ where } n = \text{the number of } O_2 \text{ measurements} \quad \text{Equation 10}$$

$$\%CO_{2m} = \frac{1}{n} \sum_{i=1}^n \%CO_{2i}, \text{ where } n = \text{the number of } CO_2 \text{ measurements} \quad \text{Equation 11}$$

## Appendix B Calculations

---

Where,

$c$	= Contaminant concentration
$m$	= Contaminant mass
$m_i$	= Net analytical mass (mg, ng, or $\mu\text{g}$ )
$m_{ana,i}$	= Analytical mass (mg, ng, or $\mu\text{g}$ )
$m_{blank}$	= Blank analytical mass (mg, ng, or $\mu\text{g}$ )
$m_{part}$	= Total particulate mass (mg)
$m_{filter}$	= Net particulate gain from filter (mg)
$m_{pw}$	= Net particulate gain from probe wash (mg)
$V_{std(imp)}$	= Sample volume at standard conditions ( $\text{ft}^3$ )
$V_{std}$	= Sample volume at standard conditions ( $\text{m}^3$ )
$V_{samp}$	= Sample volume at actual conditions ( $\text{ft}^3$ )
$V_{final}$	= Final gas meter reading ( $\text{ft}^3$ )
$V_{init}$	= Initial gas meter reading ( $\text{ft}^3$ )
$T_{std}$	= Standard temperature (68 °F)
$T_m$	= Gas meter temperature (°F)
$T_{m(ave)}$	= Average gas meter temperature (°F)
$P_m$	= Absolute meter pressure (inches of Hg)
$P_B$	= Barometric pressure (inches of Hg)
$\Delta H_{ave}$	= Average of individual point orifice pressures (inches of $\text{H}_2\text{O}$ )
$\Delta H_{i(act)}$	= Individual recorded point orifice pressures (inches of $\text{H}_2\text{O}$ )
$OC$	= Oxygen correction factor (dimensionless)
$\%O_{2c}$	= Oxygen concentration to correct to (% dry basis)
$\%O_{2m}$	= Average measured stack gas oxygen concentration (% dry basis)
$\%CO_{2m}$	= Average measured stack gas oxygen concentration (% dry basis)

Equation 1 is the general concentration calculation used for all contaminants. The contaminant mass,  $m$ , is the net analytic mass for the given contaminant. For particulate,  $m$  is the sum of the mass contributed from probe washing and filter particulate.

**App B.2 Isokinetic Variation Calculations**

$$\Delta H_i = \frac{2.62 \times 10^7 \times c_p \times A_n \times (1 - B_{wo}) \times M_D \times (T_m + 459.67) \times \Delta p_i}{k_o \times M_w \times (T_{Stk} + 459.67)} \quad \text{Equation 12}$$

$$R_m = 85.49 \times c_p \times \sqrt{\Delta p_i} \times \sqrt{\frac{(T_{Stk_i} + 459.67)}{M_w \times P_B}} \times 60 \times A_n \times \frac{(T_{m_i} + 459.67) \times (1 - B_{wo})}{(T_{Stk_i} + 459.67) \times y} \quad \text{Equation 13}$$

$$A_n = \pi \left( \frac{d_n}{24} \right)^2 \quad \text{Equation 14}$$

$$M_w = M_D \times (1 - B_{wo}) + 18 \times B_{wo} \quad \text{Equation 15}$$

$$M_D = 0.44 \times \%CO_2 + 0.32 \times \%O_2 + 0.28 \times (100 - \%CO_2 - \%O_2) \quad \text{Equation 16}$$

$$T_{Stk} = \frac{1}{n} \sum_{i=1}^n T_{Stk_i}, \text{ where } n = \text{the number of points} \quad \text{Equation 17}$$

$$B_{wo} = \frac{V_{cond}}{V_{cond} + V_{std(imp)}} \quad \text{Equation 18}$$

$$V_{cond} = 0.04707 \times V_{gain} \quad \text{Equation 19}$$

$$Iso = \frac{1}{n} \sum_{i=1}^n Iso_i, \text{ where } n = \text{the number of points} \quad \text{Equation 20}$$

$$Iso_i = \frac{v_{nzi}}{v_i} \quad \text{Equation 21}$$

$$v_i = 85.49 \times c_p \times \sqrt{\Delta p_i} \times \sqrt{\frac{(T_{Stk_i} + 459.67)}{(P_{Stk} \times M_w)}} \quad \text{Equation 22}$$

$$v_{nzi} = \frac{(V_i - V_{i-1}) \times y \times (T_{Stk_i} + 459.67) \times (P_B + \frac{\Delta H_{i(act)}}{13.6})}{A_n \times t_i \times 60 \times (T_{m(i)} + 459.67) \times P_{Stk} \times (1 - B_{wo})} \quad \text{Equation 23}$$

$$P_{Stk} = P_B + \frac{P_g}{13.6} \quad \text{Equation 24}$$

## Appendix B Calculations

$$v_{stk} = \frac{1}{n} \sum_{i=1}^n v_i, \text{ where } n = \text{the number of points}$$

**Equation 25**

$$v_{nz} = \frac{1}{n} \sum_{i=1}^n v_{nzi}, \text{ where } n = \text{the number of points}$$

**Equation 26**

Where,

$A_n$	= Nozzle area (ft <sup>2</sup> )
$d_n$	= Diameter of nozzle (inches)
$c_p$	= Pitot coefficient (dimensionless)
$\Delta p_i$	= Individual point differential pressures (inches of H <sub>2</sub> O)
$T_{stk}$	= Average flue gas temperature (°F), second subscript <i>i</i> , indicates individual point measurements
$\Delta H_{i(act)}$	= Calculated individual point orifice pressures (inches of H <sub>2</sub> O)
$P_g$	= Stack Static pressure (inches of H <sub>2</sub> O)
$P_{stk}$	= Absolute stack pressure (inches of Hg)
$M_w$	= Wet gas molecular weight (g/gmol)
$M_D$	= Dry gas molecular weight (g/gmol)
%CO <sub>2</sub>	= Stack gas carbon dioxide concentration (% dry basis)
%O <sub>2</sub>	= Stack gas oxygen concentration (% dry basis)
$B_{wo}$	= Stack gas water vapour, proportion by volume
$V_{cond}$	= Total volume of water vapor collected, corrected to standard conditions (ft <sup>3</sup> )
$V_{gain}$	= Condensate gain of impinger contents (mL)
$P_{std}$	= Standard pressure (29.92 inches of Hg)
$V_{stk}$	= Average flue gas velocity (ft/sec)
$v_i$	= Individual point flue gas velocity (ft/sec)
$v_{nz}$	= Average velocity at nozzle (ft/sec)
$v_{nzi}$	= Individual point velocity at nozzle (ft/sec)
$ISO_i$	= Individual point isokinetic variation (%)
$ISO$	= Average isokinetic variation (%)
$R_m$	= Isokinetic sampling rate (ft <sup>3</sup> /min)

**App B.3 Volumetric Flowrate Calculations**

$$Q_S = Q_A \times \frac{(T_{Std} + 459.67)}{(T_{Stk} + 459.67)} \times \frac{P_{Stk}}{P_{Std}} \quad \text{Equation 27}$$

$$Q_A = \frac{v_{stk} \times 60 \times A_{stk}}{35.315} \quad \text{Equation 28}$$

$$A_{stk} = \pi \left( \frac{d}{24} \right)^2 \quad \text{Equation 29}$$

Where,

$Q_A$	= Actual flowrate ( $Am^3/min$ )
$Q_S$	= Flowrate ( $m^3/min$ ) at standard conditions on a dry basis
$A_{stk}$	= Area of stack ( $ft^2$ )
$d$	= Diameter of stack (inches)

**APPENDIX - C**

**LABORATORY RESULTS**

## Appendix C - Particulate Analysis

**Client:** Metro Vancouver **Sample Date:** Nov 17 -20, 2025  
**Source:** Units 1, 2, and 3 **Location:** WTE (Burnaby, B.C)

### A. Lanfranco & Associates Standard Operating Procedure:

SOP 1.2.1 Gravimetric determination of total particulate matter

#### Filter Collection:

Test #	Initial (grams)	Final (grams)	Net Diference (grams)	Blank Adjusted (grams)
Unit 1 Blank	0.4451	0.4448	-0.0003	
Unit 1 Run 1	0.4767	0.4763	-0.0004	ND
Unit 1 Run 2	0.4685	0.4690	0.0005	0.0008
Unit 1 Run 3	0.4469	0.4466	-0.0003	ND
Unit 2 Blank	0.4473	0.4471	-0.0002	
Unit 2 Run 1	0.4491	0.4494	0.0003	0.0005
Unit 2 Run 2	0.4466	0.4465	-0.0001	0.0001
Unit 2 Run 3	0.4439	0.4445	0.0006	0.0008
Unit 3 Blank	0.4494	0.4491	-0.0003	
Unit 3 Run 1	0.4502	0.4476	-0.0026	ND
Unit 3 Run 2	0.4479	0.4487	0.0008	0.0011
Unit 3 Run 3	0.4492	0.4491	-0.0001	0.0002

#### Front Half Washings:

Test #	Initial (grams)	Final (grams)	Net Diference (grams)	Blank Adjusted (grams)
Unit 1 Blank	85.6022	85.6019	-0.0003	
Unit 1 Run 1	84.3667	84.3696	0.0029	0.0032
Unit 1 Run 2	122.2418	122.2431	0.0013	0.0016
Unit 1 Run 3	84.9576	84.9579	0.0003	0.0006
Unit 2 Blank	97.4702	97.4701	-0.0001	
Unit 2 Run 1	118.9946	118.9964	0.0018	0.0019
Unit 2 Run 2	127.1409	127.1409	0.0000	0.0001
Unit 2 Run 3	86.4737	86.4740	0.0003	0.0004
Unit 3 Blank	119.3290	119.3293	0.0003	
Unit 3 Run 1	129.1969	129.1984	0.0015	0.0012
Unit 3 Run 2	126.9769	126.9778	0.0009	0.0006
Unit 3 Run 3	122.9326	122.9337	0.0011	0.0008

Task	Unit	Personnel	Date	Quality Control	Y/N
Filter Recovery:	Unit 1	J. Ching	18-Nov-25	Adequate PW volume:	Y
	Unit 2	J. Ching	19-Nov-25	No sample leakage:	Y
	Unit 3	J. Ching	20-Nov-25	Filter not compromised:	Y
PW Initial Analysis:	Unit 1	J. Ching	21-Nov-25		
	Unit 2	J. Ching	21-Nov-25		
	Unit 3	J. Ching	21-Nov-25		
PW, Filter Final Analysis:	Unit 1	J. Ching	25-Nov-25		
	Unit 2	J. Ching	25-Nov-25		
	Unit 3	J. Ching	25-Nov-25		
Data Entered to Computer:	All	L. Agassiz	04-Dec-25		

#### Comments:

No problems encountered in sample analysis.

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Filter Reagent Blanks Project Location: LSD: P.O.:	Lot ID: <b>1861966</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 17, 2025 Report Number: 3216463 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Contact	Company	Address
<b>Mark Lanfranco</b>	<b>A. Lanfranco &amp; Associates</b>	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
<b>Missy</b>	<b>A. Lanfranco &amp; Associates</b>	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Filter Reagent Blanks Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1861966</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 17, 2025 Report Number: 3216463 Report Type: Final Report
Attn: Missy Sampled By: Company:		

Reference Number	1861966-1	1861966-2	1861966-3
Sample Date	Nov 17, 2025	Nov 17, 2025	Nov 17, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Reagent Blank Unit 1 Container 1 (filter) / 18.2 °C	Reagent Blank Unit 2 Container 1 (filter) / 18.2 °C	Reagent Blank Unit 3 Container 1 (filter) / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	<5	<5	<5	5
Antimony	µg	<2	<2	5	2.5
Arsenic	µg	<1	3.3	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	<0.2	0.48	<0.2	0.2
Cobalt	µg	0.7	0.8	<0.3	0.25
Copper	µg	<0.3	<0.3	<0.3	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	<0.3	<0.3	<0.3	0.25
Nickel	µg	<0.5	<0.5	<0.5	0.5
Phosphorus	µg	43	51	49	2.5
Selenium	µg	26.9	<2	<2	1.5
Tellurium	µg	3.7	<2	<2	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2	1	2.7	0.5
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	250	250	250
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02

Approved by:



Carol Nam, Dipl. T.  
Quality Assurance Coordinator

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

**Methodology and Notes**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Filter Reagent Blanks Project Location: LSD: P.O.:	Lot ID: <b>1861966</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 17, 2025 Report Number: 3216463 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

**Method of Analysis**

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Dec 12, 2025	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29  * Reference Method Modified	Dec 05, 2025	Element Vancouver

**References**

EMC                      Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.  
 Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Reagent Blanks Project Location: LSD: P.O.:	Lot ID: <b>1861957</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 17, 2025 Report Number: 3216451 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Contact	Company	Address
<b>Mark Lanfranco</b>	<b>A. Lanfranco &amp; Associates</b>	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
<b>Missy</b>	<b>A. Lanfranco &amp; Associates</b>	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Reagent Blanks Project Location: LSD: P.O.:	Lot ID: <b>1861957</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 17, 2025 Report Number: 3216451 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Reference Number	1861957-1	1861957-2	1861957-3
Sample Date	Nov 17, 2025	Nov 17, 2025	Nov 17, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Reagent Blank Unit 1 / 18.2 °C	Reagent Blank Unit 2 / 18.2 °C	Reagent Blank Unit 3 / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	<5	<5	6	5
Antimony	µg	20	10	<2	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	0.2	<0.2	0.64	0.2
Cobalt	µg	2	0.6	<0.3	0.25
Copper	µg	<0.3	<0.3	<0.3	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	<0.3	<0.3	<0.3	0.25
Nickel	µg	<0.5	<0.5	<0.5	0.5
Phosphorus	µg	4	<2	10	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	8.2	8.8	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2	2	2.8	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	<5	<5	9	5
Antimony	µg	<3	5	<3	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	0.6	<0.3	0.4	0.25
Chromium	µg	<0.2	0.96	<0.2	0.2
Cobalt	µg	<0.3	<0.3	<0.3	0.25
Copper	µg	<0.3	<0.3	<0.3	0.25
Lead	µg	<2	2	<2	1.5
Manganese	µg	<0.3	0.8	<0.3	0.25
Nickel	µg	<0.5	0.9	<0.5	0.5
Phosphorus	µg	10	20	10	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	14	<2	<2	2
Thallium	µg	3.3	4.0	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	1.0	0.9	1	0.5
Volume	Sample	mL	207	214	210
Volume	aliquot volume	mL	157	164	160
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Reagent Blanks Project Location: LSD: P.O.:	Lot ID: <b>1861957</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 17, 2025 Report Number: 3216451 Report Type: Final Report
Attn: Missy	Proj. Acct. code:	
Sampled By:		
Company:		

Reference Number	1861957-1	1861957-2	1861957-3
Sample Date	Nov 17, 2025	Nov 17, 2025	Nov 17, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Reagent Blank Unit 1 / 18.2 °C	Reagent Blank Unit 2 / 18.2 °C	Reagent Blank Unit 3 / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Mercury by CVAA - Continued</b>					
Volume	Sample	mL	250	250	250
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02
Mercury	As Tested	µg/L	0.09	0.10	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	207	214	210
Volume	aliquot volume	mL	5.0	5.0	5.0
Volume	Final	mL	40	42	42
Mercury	Fraction 2B	µg/sample	0.2	0.2	<0.09
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	103	101	100
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3A	µg/sample	<0.008	<0.008	<0.008
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	500	500	500
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3B	µg/sample	<0.04	<0.04	<0.04
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	200	200	200
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3C	µg/sample	<0.02	<0.02	<0.02

Approved by: \_\_\_\_\_



Carol Nam, Dipl. T.  
Quality Assurance Coordinator

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

**Methodology and Notes**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Reagent Blanks Project Location: LSD: P.O.:	Lot ID: <b>1861957</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 17, 2025 Report Number: 3216451 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

**Method of Analysis**

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Dec 05, 2025	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Dec 05, 2025	Element Vancouver

\* Reference Method Modified

**References**

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

## Report Transmission Cover Page

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Field Blanks Project Location: LSD: P.O.:	Lot ID: <b>1861962</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 17, 2025 Report Number: 3216455 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Contact	Company	Address
<b>Mark Lanfranco</b>	<b>A. Lanfranco &amp; Associates</b>	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
<b>Missy</b>	<b>A. Lanfranco &amp; Associates</b>	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Field Blanks Project Location: LSD: P.O.:	Lot ID: <b>1861962</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 17, 2025 Report Number: 3216455 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Reference Number	1861962-1	1861962-2	1861962-3
Sample Date	Nov 18, 2025	Nov 19, 2025	Nov 20, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Field Blank Unit 1 (MV Unit 1 BLK + 4 Bottles) / 18.2 °C	Field Blank Unit 2 (MV Unit 2 BLK + 4 Bottles) / 18.2 °C	Field Blank Unit 3 (Unit 3 Blank + 4 Bottles) / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	6	20	10	5
Antimony	µg	<2	10	8	2.5
Arsenic	µg	<1	<1	3.6	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	<0.2	<0.2	<0.2	0.2
Cobalt	µg	1	<0.3	<0.3	0.25
Copper	µg	<0.3	<0.3	<0.3	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	<0.3	<0.3	<0.3	0.25
Nickel	µg	1	<0.5	<0.5	0.5
Phosphorus	µg	49	40	41	2.5
Selenium	µg	<2	<2	2	1.5
Tellurium	µg	<2	6.1	<2	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2	2	3.7	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	<5	9	<5	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<1.0	<0.9	<0.9	1
Cadmium	µg	<0.2	0.3	<0.2	0.25
Chromium	µg	<0.2	<0.2	<0.2	0.2
Cobalt	µg	0.6	0.7	<0.2	0.25
Copper	µg	<0.2	<0.2	<0.2	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	0.4	0.3	<0.2	0.25
Nickel	µg	<0.5	<0.5	<0.5	0.5
Phosphorus	µg	20	20	10	2.5
Selenium	µg	<1	3.3	<1	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	6.8	<1	<1	1.5
Vanadium	µg	<1.0	<0.9	<0.9	1
Zinc	µg	1	1	2	0.5
Volume	Sample	mL	360	367	372
Volume	aliquot volume	mL	301	317	322
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05

**Analytical Report**

Bill To: A. Lanfranco & Associates  
 #101, 9488 - 189 Street  
 Surrey, BC, Canada  
 V4N 4W7  
 Attn: Missy  
 Sampled By:  
 Company:

Project ID: Metro Vancouver WTE  
 Project Name: Field Blanks  
 Project Location:  
 LSD:  
 P.O.:  
 Proj. Acct. code:

Lot ID: **1861962**  
 Control Number:  
 Date Received: Nov 25, 2025  
 Date Reported: Dec 17, 2025  
 Report Number: 3216455  
 Report Type: Final Report

Reference Number	1861962-1	1861962-2	1861962-3
Sample Date	Nov 18, 2025	Nov 19, 2025	Nov 20, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Field Blank Unit 1 (MV Unit 1 BLK + 4 Bottles) / 18.2 °C	Field Blank Unit 2 (MV Unit 2 BLK + 4 Bottles) / 18.2 °C	Field Blank Unit 3 (Unit 3 Blank + 4 Bottles) / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Mercury by CVAA - Continued</b>					
Dilution Factor	As Tested	1	1	1	
Volume	Sample mL	250	250	250	
Volume	aliquot volume mL	25	25	25	
Volume	Final mL	40	40	40	
Mercury	Fraction 1B µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample mL	360	367	372	
Volume	aliquot volume mL	5.0	5.0	5.0	
Volume	Final mL	40	40	40	
Mercury	Fraction 2B µg/sample	<0.1	<0.1	<0.1	
Mercury	As Tested µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample mL	97	101	100	
Volume	aliquot volume mL	25	25	25	
Volume	Final mL	40	40	40	
Mercury	Fraction 3A µg/sample	<0.008	<0.008	<0.008	
Mercury	As Tested µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample mL	500	500	500	
Volume	aliquot volume mL	25	25	25	
Volume	Final mL	40	40	40	
Mercury	Fraction 3B µg/sample	<0.04	<0.04	<0.04	
Mercury	As Tested µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample mL	200	200	200	
Volume	aliquot volume mL	25	25	25	
Volume	Final mL	40	40	40	
Mercury	Fraction 3C µg/sample	<0.02	<0.02	<0.02	

Approved by: 

Carol Nam, Dipl. T.  
 Quality Assurance Coordinator

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

### Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Field Blanks Project Location: LSD: P.O.:	Lot ID: <b>1861962</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 17, 2025 Report Number: 3216455 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

### Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Dec 05, 2025	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Dec 05, 2025	Element Vancouver

\* Reference Method Modified

### References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.  
 Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.:	Lot ID: <b>1861800</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 16, 2025 Report Number: 3216199 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Contact	Company	Address
<b>Mark Lanfranco</b>	<b>A. Lanfranco &amp; Associates</b>	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
<b>Missy</b>	<b>A. Lanfranco &amp; Associates</b>	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.:	Lot ID: <b>1861800</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 16, 2025 Report Number: 3216199 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Reference Number	1861800-1	1861800-2	1861800-3
Sample Date	Nov 17, 2025	Nov 18, 2025	Nov 18, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit 1 Run 1 (MV Unit 1 R1 + 4 Bottles) / 18.2 °C	Unit 1 Run 2 (MV Unit 1 Run 2 + 4 Bottles) / 18.2 °C	Unit 1 Run 3 (MV Unit 1 Run 3 + 4 Bottles) / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	20	10	9	5
Antimony	µg	7	7	20	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	<0.2	1.4	<0.2	0.2
Cobalt	µg	0.5	<0.3	2	0.25
Copper	µg	0.9	0.5	<0.3	0.25
Lead	µg	3.0	<2	<2	1.5
Manganese	µg	2	2	0.9	0.25
Nickel	µg	0.8	<0.5	<0.5	0.5
Phosphorus	µg	54	61	39	2.5
Selenium	µg	<2	<2	4.8	1.5
Tellurium	µg	6.0	<2	<2	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	34.1	26.9	26.2	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	27	23	10	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	3.9	<0.9	<0.9	1
Cadmium	µg	0.2	<0.2	0.6	0.25
Chromium	µg	<0.2	1.1	0.52	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	<0.2	<0.2	0.8	0.25
Lead	µg	<1	<1	1	1.5
Manganese	µg	0.4	0.5	1	0.25
Nickel	µg	<0.4	<0.4	<0.4	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	<1	<1	15	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	3.5	2.6	2.4	0.5
Volume	Sample	mL	735	768	722
Volume	aliquot volume	mL	685	718	672
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.:	Lot ID: <b>1861800</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 16, 2025 Report Number: 3216199 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Reference Number	1861800-1	1861800-2	1861800-3
Sample Date	Nov 17, 2025	Nov 18, 2025	Nov 18, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit 1 Run 1 (MV Unit 1 R1 + 4 Bottles) / 18.2 °C	Unit 1 Run 2 (MV Unit 1 Run 2 + 4 Bottles) / 18.2 °C	Unit 1 Run 3 (MV Unit 1 Run 3 + 4 Bottles) / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Mercury by CVAA - Continued</b>					
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	250	250	250
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	735	768	722
Volume	aliquot volume	mL	5.0	5.0	5.0
Volume	Final	mL	40	40	40
Mercury	Fraction 2B	µg/sample	<0.3	<0.3	<0.3
Mercury	As Tested	µg/L	<0.05	<0.05	0.09
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	97	101	101
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3A	µg/sample	<0.008	<0.008	0.01
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	500	500	500
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3B	µg/sample	<0.04	<0.04	<0.04
Mercury	As Tested	µg/L	0.46	0.17	0.48
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	200	200	200
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3C	µg/sample	0.15	0.056	0.15

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.:	Lot ID: <b>1861800</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 16, 2025 Report Number: 3216199 Report Type: Final Report
Attn: Missy	Proj. Acct. code:	
Sampled By:		
Company:		

Reference Number	1861800-4	1861800-5	1861800-6
Sample Date	Nov 18, 2025	Nov 19, 2025	Nov 19, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit 2 Run 1 (Unit 2 R1 + 4 Bottles) / 18.2 °C	Unit 2 Run 2 (Unit 2 R2 + 4 Bottles) / 18.2 °C	Unit 2 Run 3 (MV Unit 2 Run 3 + 4 Bottles) / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	20	<5	<5	5
Antimony	µg	10	4	<2	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	11.9	0.29	0.51	0.2
Cobalt	µg	0.3	0.4	2	0.25
Copper	µg	<0.3	<0.3	<0.3	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	6.2	0.4	<0.3	0.25
Nickel	µg	27.8	1	<0.5	0.5
Phosphorus	µg	52	63	51	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	7.8	<2	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	18	16	18	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	24	7	7	5
Antimony	µg	<2	<2	2	2.5
Arsenic	µg	<0.9	0.9	<0.9	1
Cadmium	µg	0.7	<0.2	0.5	0.25
Chromium	µg	0.27	0.58	1.5	0.2
Cobalt	µg	1	<0.2	<0.2	0.25
Copper	µg	<0.2	<0.2	<0.2	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	0.7	0.5	2.3	0.25
Nickel	µg	<0.4	<0.4	<0.4	0.5
Phosphorus	µg	10	23	23	2.5
Selenium	µg	4.8	<1	<1	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	3.5	2	3.7	0.5
Volume	Sample	mL	691	751	687
Volume	aliquot volume	mL	641	701	637
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.:	Lot ID: <b>1861800</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 16, 2025 Report Number: 3216199 Report Type: Final Report
Attn: Missy	Proj. Acct. code:	
Sampled By:		
Company:		

Reference Number	1861800-4	1861800-5	1861800-6
Sample Date	Nov 18, 2025	Nov 19, 2025	Nov 19, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit 2 Run 1 (Unit 2 R1 + 4 Bottles) / 18.2 °C	Unit 2 Run 2 (Unit 2 R2 + 4 Bottles) / 18.2 °C	Unit 2 Run 3 (MV Unit 2 Run 3 + 4 Bottles) / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Mercury by CVAA - Continued</b>					
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	250	250	
Volume	aliquot volume	mL	25	25	
Volume	Final	mL	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	691	751	687
Volume	aliquot volume	mL	5.0	5.0	5.0
Volume	Final	mL	40	40	40
Mercury	Fraction 2B	µg/sample	<0.3	<0.3	<0.3
Mercury	As Tested	µg/L	0.68	<0.05	<0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	100	99	99
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3A	µg/sample	0.11	<0.008	<0.008
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	500	500	500
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3B	µg/sample	<0.04	<0.04	<0.04
Mercury	As Tested	µg/L	0.42	<0.05	0.12
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	200	200	200
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3C	µg/sample	0.13	<0.02	0.040

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.:	Lot ID: <b>1861800</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 16, 2025 Report Number: 3216199 Report Type: Final Report
Attn: Missy	Proj. Acct. code:	
Sampled By:		
Company:		

Reference Number	1861800-7	1861800-8	1861800-9
Sample Date	Nov 19, 2025	Nov 20, 2025	Nov 20, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit 3 Run 1 (MV U3 R-1 + 4 Bottles / 18.2 °C	Unit 3 Run 2 (Unit 3 Run 2 + 4 Bottles) / 18.2 °C	Unit 3 Run 3 (MV Unit 3 R-3 + 4 Bottles) / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples


Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	8	20	9	5
Antimony	µg	3	20	6	2.5
Arsenic	µg	3.9	<1	<1	1
Cadmium	µg	<0.3	<0.3	0.5	0.25
Chromium	µg	5.86	0.86	0.26	0.2
Cobalt	µg	<0.3	<0.3	2	0.25
Copper	µg	<0.3	0.7	1.0	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	1	0.6	0.6	0.25
Nickel	µg	3.0	<0.5	1	0.5
Phosphorus	µg	42	37	42	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	5.8	<2	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	7.1	2.9	4.0	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	<4	6	10	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<0.9	<0.9	<0.9	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	0.29	0.57	3.01	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	<0.2	<0.2	<0.2	0.25
Lead	µg	5.0	<1	<1	1.5
Manganese	µg	0.3	0.3	2	0.25
Nickel	µg	<0.4	0.9	1	0.5
Phosphorus	µg	20	20	26	2.5
Selenium	µg	<1	<1	<1	1.5
Tellurium	µg	<2	10	<2	2
Thallium	µg	<1	14	9.5	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	2	2.3	4.1	0.5
Volume	Sample	mL	680	657	730
Volume	aliquot volume	mL	630	607	680
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05

**Analytical Report**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.:	Lot ID: <b>1861800</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 16, 2025 Report Number: 3216199 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Reference Number	1861800-7	1861800-8	1861800-9
Sample Date	Nov 19, 2025	Nov 20, 2025	Nov 20, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit 3 Run 1 (MV U3 R-1 + 4 Bottles) / 18.2 °C	Unit 3 Run 2 (Unit 3 Run 2 + 4 Bottles) / 18.2 °C	Unit 3 Run 3 (MV Unit 3 R-3 + 4 Bottles) / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Mercury by CVAA - Continued</b>					
Dilution Factor	As Tested	1	1	1	
Volume	Sample mL	250	250	250	
Volume	aliquot volume mL	25	25	25	
Volume	Final mL	40	40	40	
Mercury	Fraction 1B µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample mL	680	657	730	
Volume	aliquot volume mL	5.0	5.0	5.0	
Volume	Final mL	40	40	40	
Mercury	Fraction 2B µg/sample	<0.3	<0.3	<0.3	
Mercury	As Tested µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample mL	99	99	103	
Volume	aliquot volume mL	25	25	25	
Volume	Final mL	40	40	40	
Mercury	Fraction 3A µg/sample	<0.008	<0.008	<0.008	
Mercury	As Tested µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample mL	500	500	500	
Volume	aliquot volume mL	25	25	25	
Volume	Final mL	40	40	40	
Mercury	Fraction 3B µg/sample	<0.04	<0.04	<0.04	
Mercury	As Tested µg/L	<0.05	0.10	0.22	0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample mL	200	200	200	
Volume	aliquot volume mL	25	25	25	
Volume	Final mL	40	40	40	
Mercury	Fraction 3C µg/sample	<0.02	0.03	0.070	

Approved by:   
 Rachel Eden, B. Sc.  
 Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

**Methodology and Notes**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.:	Lot ID: <b>1861800</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 16, 2025 Report Number: 3216199 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

**Method of Analysis**

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Dec 10, 2025	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Dec 05, 2025	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	Dec 05, 2025	Element Vancouver

\* Reference Method Modified

**References**

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

## Report Transmission Cover Page

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Gas Blanks Project Location: LSD: P.O.:	Lot ID: <b>1861899</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 2, 2025 Report Number: 3216309 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Contact	Company	Address
<b>Mark Lanfranco</b>	<b>A. Lanfranco &amp; Associates</b>	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
<b>Missy</b>	<b>A. Lanfranco &amp; Associates</b>	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

### Notes To Clients:

- Sample 1861899-2; 10336494: Reduction of analytical volume was necessary for anion analysis due to matrix effects in lot 1861899. Detection limits are adjusted accordingly.


The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Gas Blanks Project Location: LSD: P.O.:	Lot ID: <b>1861899</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 2, 2025 Report Number: 3216309 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Reference Number	1861899-1	1861899-2	1861899-3
Sample Date	Nov 18, 2025	Nov 19, 2025	Nov 20, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit #1 Gas Blank / 18.2 °C	Unit #2 Gas Blank / 18.2 °C	Unit #3 Gas Blank / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Air Quality</b>					
Volume	Sample	mL	93.0	92.0	119
Dilution Factor	chloride		10.00	10.00	10.00
Chloride	As Tested	mg/L	<0.5	<0.5	<0.5
Chloride	Water Soluble	µg/sample	<50	<50	<60
Dilution Factor	fluoride		10.00	10.00	10.00
Fluoride	As Tested	mg/L	<0.3	<0.3	<0.3
Fluoride	Water Soluble	µg/sample	<30	<30	<40
Ammonium - N	As Tested	µg/L	241	237	208
Dilution Factor	As Tested		1.00	1.00	1.00
Sample Volume	Sample volume	mL	60.0	64.0	92.0
Ammonium - N		µg/sample	14.5	15.2	19.1

Approved by:   
 Reena Sharma  
 Operations Chemist

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

## Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Gas Blanks Project Location: LSD: P.O.:	Lot ID: <b>1861899</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 2, 2025 Report Number: 3216309 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Ammonium in Impingers	APHA	* Automated Phenate Method, 4500-NH3 G	Dec 02, 2025	Element Edmonton - Roper Road
Anions by IEC in air (VAN)	EMC	* Determination of Hydrogen Halide & Halogen Emissions from Stationary Sources (Isokinetic), 26A  <i>* Reference Method Modified</i>	Nov 26, 2025	Element Vancouver

## References

APHA Standard Methods for the Examination of Water and Wastewater  
 EMC Emission Measurement Center of EPA

## Comments:

- Sample 1861899-2; 10336494: Reduction of analytical volume was necessary for anion analysis due to matrix effects in lot 1861899. Detection limits are adjusted accordingly.

Please direct any inquiries regarding this report to our Client Services group.  
 Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

## Report Transmission Cover Page

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Gas Samples Project Location: LSD: P.O.:	Lot ID: <b>1861942</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 2, 2025 Report Number: 3216435 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Contact	Company	Address
<b>Mark Lanfranco</b>	<b>A. Lanfranco &amp; Associates</b>	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
<b>Missy</b>	<b>A. Lanfranco &amp; Associates</b>	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

### Notes To Clients:

- Reduction of analytical volume was necessary for anion analysis due to matrix effects in lot 1861942. Detection limits are adjusted accordingly.

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

**Analytical Report**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Gas Samples Project Location: LSD: P.O.:	Lot ID: <b>1861942</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 2, 2025 Report Number: 3216435 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

Reference Number	1861942-1	1861942-2	1861942-3
Sample Date	Nov 18, 2025	Nov 18, 2025	Nov 18, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit # 1 Gas Run 1 / 18.2 °C	Unit # 1 Gas Run 2 / 18.2 °C	Unit # 1 Gas Run 3 / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Air Quality</b>					
Volume	Sample	mL	107	113	130
Dilution Factor	chloride		10.00	10.00	10.00
Chloride	As Tested	mg/L	7.7	46.0	90.1
Chloride	Water Soluble	µg/sample	820	5200	11700
Dilution Factor	fluoride		10.00	10.00	10.00
Fluoride	As Tested	mg/L	<0.3	<0.3	<0.3
Fluoride	Water Soluble	µg/sample	<30	<30	<40
Ammonium - N	As Tested	µg/L	1400	8950	13300
Dilution Factor	As Tested		1.00	1.00	10.0
Sample Volume	Sample volume	mL	80.0	85.0	98.0
Ammonium - N		µg/sample	112	761	1300

## Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Gas Samples Project Location: LSD: P.O.:	Lot ID: <b>1861942</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 2, 2025 Report Number: 3216435 Report Type: Final Report
Attn: Missy	Proj. Acct. code:	
Sampled By:		
Company:		

Reference Number	1861942-4	1861942-5	1861942-6
Sample Date	Nov 19, 2025	Nov 19, 2025	Nov 19, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit # 2 Gas Run 1 / 18.2 °C	Unit # 2 Gas Run 2 / 18.2 °C	Unit # 2 Gas Run 3 / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples


Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Air Quality</b>					
Volume	Sample	mL	113	111	110
Dilution Factor	chloride		10.00	10.00	10.00
Chloride	As Tested	mg/L	46.8	48.0	61.5
Chloride	Water Soluble	µg/sample	5280	5330	6770
Dilution Factor	fluoride		10.00	10.00	10.00
Fluoride	As Tested	mg/L	<0.3	<0.3	<0.3
Fluoride	Water Soluble	µg/sample	<30	<30	<30
Ammonium - N	As Tested	µg/L	10200	8030	7060
Dilution Factor	As Tested		10.0	1.00	1.00
Sample Volume	Sample volume	mL	86.0	84.0	85.0
Ammonium - N		µg/sample	876	675	600

### Analytical Report

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Gas Samples Project Location: LSD: P.O.:	Lot ID: <b>1861942</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 2, 2025 Report Number: 3216435 Report Type: Final Report
Attn: Missy	Proj. Acct. code:	
Sampled By:		
Company:		

Reference Number	1861942-7	1861942-8	1861942-9
Sample Date	Nov 20, 2025	Nov 20, 2025	Nov 20, 2025
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit # 3 Gas Run 1 / 18.2 °C	Unit # 3 Gas Run 2 / 18.2 °C	Unit # 3 Gas Run 3 / 18.2 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Air Quality</b>					
Volume	Sample mL	106	106	93.0	
Dilution Factor	chloride	10.00	10.00	10.00	
Chloride	As Tested mg/L	26.6	109	196	0.05
Chloride	Water Soluble µg/sample	2820	11600	18200	
Dilution Factor	fluoride	10.00	10.00	10.00	
Fluoride	As Tested mg/L	<0.3	<0.3	<0.3	0.03
Fluoride	Water Soluble µg/sample	<30	<30	<30	
Ammonium - N	As Tested µg/L	8310	9460	6410	25
Dilution Factor	As Tested	1.00	1.00	1.00	
Sample Volume	Sample volume mL	80.0	76.0	66.0	
Ammonium - N	µg/sample	665	719	423	

Approved by:   
 Reena Sharma  
 Operations Chemist

### Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Gas Samples Project Location: LSD: P.O.:	Lot ID: <b>1861942</b> Control Number: Date Received: Nov 25, 2025 Date Reported: Dec 2, 2025 Report Number: 3216435 Report Type: Final Report
Attn: Missy Sampled By: Company:	Proj. Acct. code:	

### Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Ammonium in Impingers	APHA	* Automated Phenate Method, 4500-NH3 G	Dec 02, 2025	Element Edmonton - Roper Road
Anions by IEC in air (VAN)	EMC	* Determination of Hydrogen Halide & Halogen Emissions from Stationary Sources (Isokinetic), 26A  <i>* Reference Method Modified</i>	Nov 26, 2025	Element Vancouver

### References

APHA Standard Methods for the Examination of Water and Wastewater  
 EMC Emission Measurement Center of EPA

### Comments:

- Reduction of analytical volume was necessary for anion analysis due to matrix effects in lot 1861942. Detection limits are adjusted accordingly.

Please direct any inquiries regarding this report to our Client Services group.  
 Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.



**CERTIFICATE OF ANALYSIS**

<b>Work Order</b>	: <b>VA25D1544</b>	<b>Laboratory</b>	: ALS Environmental - Vancouver
<b>Client</b>	: <b>A. Lanfranco &amp; Associates Inc.</b>	<b>Account Manager</b>	: Brent Mack
<b>Contact</b>	: Mark Lanfranco	<b>Address</b>	: 8081 Lougheed Highway
<b>Address</b>	: Unit # 101 9488 - 189 St Surrey British Columbia Canada V4N 4W7		: Burnaby BC Canada V5A 1W9
<b>Telephone</b>	: 604 881 2582	<b>E-mail</b>	: Brent.Mack@ALSGlobal.com
<b>Project</b>	: MV WTE UNIT 1	<b>Telephone</b>	: 778-370-3279
<b>PO</b>	: ----	<b>Date Samples Received</b>	: 25-Nov-2025 15:45
<b>C-O-C number</b>	: ----	<b>Date Analysis Commenced</b>	: 02-Dec-2025
<b>Sampler</b>	: ----	<b>Issue Date</b>	: 03-Dec-2025 11:49
<b>Site</b>	: ----		
<b>Quote number</b>	: Standing Offer		
<b>No. of samples received</b>	: 4		
<b>No. of samples analysed</b>	: 4		

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

**Signatories**

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Laboratory Department</i>
Nik Perkio	Senior Analyst	Metals, Waterloo, Ontario



## General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key: CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances.  
LOR: Limit of Reporting (detection limit).

<i>Unit</i>	<i>Description</i>
mL	millilitres
µg	micrograms

<: less than.

>: greater than.

Surrogate: An analyte that is similar in behavior to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.



**Analytical Results**

**Sub-Matrix: Impinger**  
**(Matrix: Air)**

					Client sample ID	MV WTE Unit 1 - Cr+6 Blank	MV WTE Unit 1 - Cr+6 Run 1	MV WTE Unit 1 - Cr+6 Run 2	MV WTE Unit 1 - Cr+6 Run 3	----
					Client sampling date / time	20-Nov-2025 00:00	20-Nov-2025 00:00	21-Nov-2025 00:00	21-Nov-2025 00:00	----
Analyte	CAS Number	Method/Lab	LOR	Unit	VA25D1544-001	VA25D1544-002	VA25D1544-003	VA25D1544-004	----	
					Result	Result	Result	Result	----	
<b>Sample Preparation</b>										
<b>Volume, impinger</b>	n/a	EP532C/WT	0.1	mL	678	1295	1105	1280	----	
<b>Speciated Metals</b>										
<b>Chromium, hexavalent [Cr VI]</b>	18540-29-9	E532C/WT	0.20	µg	<0.68	<1.30	<1.10	<1.28	----	

Please refer to the General Comments section for an explanation of any qualifiers detected.




---

## QUALITY CONTROL INTERPRETIVE REPORT

---

<p><b>Work Order</b> : <b>VA25D1544</b></p> <p><b>Client</b> : <b>A. Lanfranco &amp; Associates Inc.</b></p> <p><b>Contact</b> : Mark Lanfranco</p> <p><b>Address</b> : Unit # 101 9488 - 189 St Surrey BC Canada V4N 4W7</p> <p><b>Telephone</b> : 604 881 2582</p> <p><b>Project</b> : MV WTE UNIT 1</p> <p><b>PO</b> : ----</p> <p><b>C-O-C number</b> : ----</p> <p><b>Sampler</b> : ----</p> <p><b>Site</b> : ----</p> <p><b>Quote number</b> : Standing Offer</p> <p><b>No. of samples received</b> : 4</p> <p><b>No. of samples analysed</b> : 4</p>	<p><b>Page</b> : 1 of 5</p> <p><b>Laboratory</b> : ALS Environmental - Vancouver</p> <p><b>Account Manager</b> : Brent Mack</p> <p><b>Address</b> : 8081 Lougheed Highway Burnaby, British Columbia Canada V5A 1W9</p> <p><b>Telephone</b> : 778-370-3279</p> <p><b>Date Samples Received</b> : 25-Nov-2025 15:45</p> <p><b>Issue Date</b> : 03-Dec-2025 11:48</p>
---	--

---

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

**Key**

- Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.
- CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.
- DQO: Data Quality Objective.
- LOR: Limit of Reporting (detection limit).
- RPD: Relative Percent Difference.

---

### ***Workorder Comments***

Holding times are displayed as "----" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

---

### ***Summary of Outliers***

#### ***Outliers : Quality Control Samples***

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

#### ***Outliers: Reference Material (RM) Samples***

- No Reference Material (RM) Sample outliers occur.

***Outliers : Analysis Holding Time Compliance (Breaches)***

- No Analysis Holding Time Outliers exist.

***Outliers : Frequency of Quality Control Samples***

- No Quality Control Sample Frequency Outliers occur.



## Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and /or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Matrix: Air

Evaluation: ✖ = Holding time exceedance ; ✔ = Within Holding Time

Analyte Group : Analytical Method Container / Client Sample ID(s)	Method	Sampling Date	Extraction / Preparation				Analysis			
			Preparation Date	Holding Times		Eval	Analysis Date	Holding Times		Eval
				Rec	Actual			Rec	Actual	
<b>Speciated Metals : Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)</b>										
HDPE MV WTE Unit 1 - Cr+6 Run 2	E532C	21-Nov-2025	02-Dec-2025	14 days	11 days	✔	02-Dec-2025	14 days	11 days	✔
<b>Speciated Metals : Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)</b>										
HDPE MV WTE Unit 1 - Cr+6 Run 3	E532C	21-Nov-2025	02-Dec-2025	14 days	11 days	✔	02-Dec-2025	14 days	11 days	✔
<b>Speciated Metals : Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)</b>										
HDPE MV WTE Unit 1 - Cr+6 Blank	E532C	20-Nov-2025	02-Dec-2025	14 days	12 days	✔	02-Dec-2025	14 days	12 days	✔
<b>Speciated Metals : Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)</b>										
HDPE MV WTE Unit 1 - Cr+6 Run 1	E532C	20-Nov-2025	02-Dec-2025	14 days	12 days	✔	02-Dec-2025	14 days	12 days	✔

### Legend & Qualifier Definitions

Rec. HT: ALS recommended hold time (see units).



## Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Matrix: Air

Evaluation: ✖ = QC frequency outside specification; ✔ = QC frequency within specification.

Quality Control Sample Type	Method	QC Lot #	Count		Frequency (%)		
			QC	Regular	Actual	Expected	Evaluation
<b>Analytical Methods</b>							
<b>Laboratory Duplicates (DUP)</b>							
Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)	E532C	2364129	1	4	25.0	5.0	✔
<b>Laboratory Control Samples (LCS)</b>							
Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)	E532C	2364129	1	4	25.0	5.0	✔
<b>Method Blanks (MB)</b>							
Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)	E532C	2364129	1	4	25.0	5.0	✔
<b>Matrix Spikes (MS)</b>							
Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)	E532C	2364129	1	4	25.0	5.0	✔



## Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by "mod").

<i>Analytical Methods</i>	<i>Method / Lab</i>	<i>Matrix</i>	<i>Method Reference</i>	<i>Method Descriptions</i>
Hexavalent Chromium (Cr VI) by IC (Impinger, ug/sample)	E532C ALS Environmental - Waterloo	Air	EPA 7199 / EPA 306	Impinger samples are analyzed by ion chromatography with UV/Vis detector using diphenylcarbazide in a sulphuric acid solution.
<i>Preparation Methods</i>	<i>Method / Lab</i>	<i>Matrix</i>	<i>Method Reference</i>	<i>Method Descriptions</i>
Preparation of Hexavalent Chromium (Impinger)	EP532C ALS Environmental - Waterloo	Air	APHA 3500-Cr C (Ion Chromatography)	pH of a homogenized impinger sample is adjusted to pH 9 by NaOH for Ion Chromatography analysis.



## QUALITY CONTROL REPORT

<b>Work Order</b>	<b>: VA25D1544</b>	<b>Page</b>	: 1 of 3
<b>Client</b>	: A. Lanfranco & Associates Inc.	<b>Laboratory</b>	: ALS Environmental - Vancouver
<b>Contact</b>	: Mark Lanfranco	<b>Account Manager</b>	: Brent Mack
<b>Address</b>	: Unit # 101 9488 - 189 St Surrey BC Canada V4N 4W7	<b>Address</b>	: 8081 Lougheed Highway Burnaby, British Columbia Canada V5A 1W9
<b>Telephone</b>	: 604 881 2582	<b>Telephone</b>	: 778-370-3279
<b>Project</b>	: MV WTE UNIT 1	<b>Date Samples Received</b>	: 25-Nov-2025 15:45
<b>PO</b>	: ----	<b>Date Analysis Commenced</b>	: 02-Dec-2025
<b>C-O-C number</b>	: ----	<b>Issue Date</b>	: 03-Dec-2025 11:48
<b>Sampler</b>	: ----		
<b>Site</b>	: ----		
<b>Quote number</b>	: Standing Offer		
<b>No. of samples received</b>	: 4		
<b>No. of samples analysed</b>	: 4		

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

- Laboratory Duplicate (DUP) Report; Relative Percent Difference (RPD) and Data Quality Objectives
- Matrix Spike (MS) Report; Recovery and Data Quality Objectives
- Method Blank (MB) Report; Recovery and Data Quality Objectives
- Laboratory Control Sample (LCS) Report; Recovery and Data Quality Objectives

### Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Laboratory Department</i>
Nik Perkio	Senior Analyst	Waterloo Metals, Waterloo, Ontario



## General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

Key :

- Anonymous = Refers to samples which are not part of this work order, but which formed part of the QC process lot.
- CAS Number = Chemical Abstracts Service number is a unique identifier assigned to discrete substances.
- DQO = Data Quality Objective.
- LOR = Limit of Reporting (detection limit).
- RPD = Relative Percent Difference
- # = Indicates a QC result that did not meet the ALS DQO.

## Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

## Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test-specific).

Sub-Matrix: Air

					Laboratory Duplicate (DUP) Report						
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier
<b>Sample Preparation (QC Lot: 2364129)</b>											
VA25D1544-002	MV WTE Unit 1 - Cr+6 Run 1	Volume, impinger	n/a	EP532C	0.1	mL	1295	1295		Diff <2x LOR	----
<b>Speciated Metals (QC Lot: 2364129)</b>											
VA25D1544-002	MV WTE Unit 1 - Cr+6 Run 1	Chromium, hexavalent [Cr VI]	18540-29-9	E532C	1.30	µg	<1.30	<1.30	0	Diff <2x LOR	----



### Method Blank (MB) Report

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: Air

Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
<b>Sample Preparation (QCLot: 2364129)</b>						
Volume, impinger	n/a	EP532C	0.1	mL	200	----
<b>Speciated Metals (QCLot: 2364129)</b>						
Chromium, hexavalent [Cr VI]	18540-29-9	E532C	0.2	µg	<0.20	----

### Laboratory Control Sample (LCS) Report

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: Air

Laboratory Control Sample (LCS) Report										
					Spike		Recovery (%)		Recovery Limits (%)	
Analyte	CAS Number	Method	LOR	Unit	Target Concentration	LCS	Low	High	Qualifier	
<b>Speciated Metals (QCLot: 2364129)</b>										
Chromium, hexavalent [Cr VI]	18540-29-9	E532C	0.2	µg	10 µg	103	90.0	110	----	

### Matrix Spike (MS) Report

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DQO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for the associated sample (or similar samples) may be subject to bias. ND – Recovery not determined, background level >= 1x spike level.

Sub-Matrix: Air

Matrix Spike (MS) Report										
					Spike		Recovery (%)		Recovery Limits (%)	
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	Concentration	Target	MS	Low	High	Qualifier
<b>Sample Preparation (QCLot: 2364129)</b>										
VA25D1544-002	MV WTE Unit 1 - Cr+6 Run 1	Volume, impinger	n/a	EP532C	----	----		0	0	----
<b>Speciated Metals (QCLot: 2364129)</b>										
VA25D1544-002	MV WTE Unit 1 - Cr+6 Run 1	Chromium, hexavalent [Cr VI]	18540-29-9	E532C	54.0 µg	51.8 µg	104	75.0	125	----





Your Project #: MVWTE  
 Site#: C595952  
 Site Location: BURNABY, BC  
 Your C.O.C. #: NA

**Attention: Shanaz Akbar**

Bureau Veritas  
 4606 Canada Way  
 Burnaby, BC  
 CANADA V5G 1K5

**Report Date: 2025/11/28**  
 Report #: R8659523  
 Version: 1 - Final

**CERTIFICATE OF ANALYSIS**

**BUREAU VERITAS JOB #: C5E9078**

**Received: 2025/11/25, 08:55**

Sample Matrix: Air  
 # Samples Received: 7

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Nitrous Oxide	7	N/A	2025/11/26	CAM SOP-00203	GC/ECD

**Remarks:**

Bureau Veritas is accredited to ISO/IEC 17025 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by Bureau Veritas are based upon recognized Provincial, Federal or US method compendia such as CCME, EPA, APHA or the Quebec Ministry of Environment.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in Bureau Veritas' profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and Bureau Veritas in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

Bureau Veritas liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. Bureau Veritas has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by Bureau Veritas, unless otherwise agreed in writing. Bureau Veritas is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.

Results relate to samples tested. When sampling is not conducted by Bureau Veritas, results relate to the supplied samples tested.

This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.

\* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.



Your Project #: MVWTE  
Site#: C595952  
Site Location: BURNABY, BC  
Your C.O.C. #: NA

**Attention: Shanaz Akbar**

Bureau Veritas  
4606 Canada Way  
Burnaby, BC  
CANADA V5G 1K5

**Report Date: 2025/11/28**  
Report #: R8659523  
Version: 1 - Final

**CERTIFICATE OF ANALYSIS**

**BUREAU VERITAS JOB #: C5E9078**

**Received: 2025/11/25, 08:55**

Encryption Key

Julian Tong  
Project Manager Assistant  
28 Nov 2025 09:36:18

Please direct all questions regarding this Certificate of Analysis to:  
Julian Tong, Project Manager Assistant  
Email: Julian.Tong@bureauveritas.com  
Phone# (905) 817-5700

=====  
This report has been generated and distributed using a secure automated process.  
Bureau Veritas has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports.  
For Service Group specific validation, please refer to the Validation Signatures page if included, otherwise available by request. For Department specific Analyst/Supervisor validation names, please refer to the Test Summary section if included, otherwise available by request. This report is authorized by Rodney Major, General Manager responsible for Ontario Environmental laboratory operations.



BUREAU  
VERITAS

Bureau Veritas Job #: C5E9078

Report Date: 2025/11/28

Bureau Veritas

Client Project #: MVWTE

Site Location: BURNABY, BC

### COMPRESSED GAS PARAMETERS (AIR)

<b>Bureau Veritas ID</b>		AXRM90	AXRM91	AXRM94	AXRM95		
<b>Sampling Date</b>		2025/11/18 09:11	2025/11/18 10:19	2025/07/16 11:33	2025/07/16 12:45		
<b>COC Number</b>		NA	NA	NA	NA		
	<b>UNITS</b>	<b>DXJ654-UNIT3 BAG 1</b>	<b>DXJ655-UNIT3 BAG 2</b>	<b>DXJ658-UNIT2 BAG 2</b>	<b>DXJ659-UNIT2 BAG 3</b>	<b>RDL</b>	<b>QC Batch</b>

<b>Gas</b>							
Nitrous Oxide	ppmv	3.4	4.1	1.6	3.1	0.1	A062854
RDL = Reportable Detection Limit							
QC Batch = Quality Control Batch							

<b>Bureau Veritas ID</b>		AXRM96	AXRM96	AXRM97	AXRM98		
<b>Sampling Date</b>		2025/07/15 09:21	2025/07/15 09:21	2025/07/15 10:30	2025/07/15 11:38		
<b>COC Number</b>		NA	NA	NA	NA		
	<b>UNITS</b>	<b>DXJ660-UNIT1 BAG 1</b>	<b>DXJ660-UNIT1 BAG 1 Lab-Dup</b>	<b>DXJ661-UNIT1 BAG 2</b>	<b>DXJ662-UNIT1 BAG 3</b>	<b>RDL</b>	<b>QC Batch</b>

<b>Gas</b>							
Nitrous Oxide	ppmv	3.6	3.7	4.2	3.3	0.1	A062854
RDL = Reportable Detection Limit							
QC Batch = Quality Control Batch							
Lab-Dup = Laboratory Initiated Duplicate							



Bureau Veritas Job #: C5E9078  
 Report Date: 2025/11/28

Bureau Veritas  
 Client Project #: MVWTE  
 Site Location: BURNABY, BC

### TEST SUMMARY

**Bureau Veritas ID:** AXRM90  
**Sample ID:** DXJ654-UNIT3 BAG 1  
**Matrix:** Air

**Collected:** 2025/11/18  
**Shipped:**  
**Received:** 2025/11/25

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	A062854	N/A	2025/11/26	Cathy Li

**Bureau Veritas ID:** AXRM91  
**Sample ID:** DXJ655-UNIT3 BAG 2  
**Matrix:** Air

**Collected:** 2025/11/18  
**Shipped:**  
**Received:** 2025/11/25

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	A062854	N/A	2025/11/26	Cathy Li

**Bureau Veritas ID:** AXRM94  
**Sample ID:** DXJ658-UNIT2 BAG 2  
**Matrix:** Air

**Collected:** 2025/07/16  
**Shipped:**  
**Received:** 2025/11/25

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	A062854	N/A	2025/11/26	Cathy Li

**Bureau Veritas ID:** AXRM95  
**Sample ID:** DXJ659-UNIT2 BAG 3  
**Matrix:** Air

**Collected:** 2025/07/16  
**Shipped:**  
**Received:** 2025/11/25

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	A062854	N/A	2025/11/26	Cathy Li

**Bureau Veritas ID:** AXRM96  
**Sample ID:** DXJ660-UNIT1 BAG 1  
**Matrix:** Air

**Collected:** 2025/07/15  
**Shipped:**  
**Received:** 2025/11/25

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	A062854	N/A	2025/11/26	Cathy Li

**Bureau Veritas ID:** AXRM96 Dup  
**Sample ID:** DXJ660-UNIT1 BAG 1  
**Matrix:** Air

**Collected:** 2025/07/15  
**Shipped:**  
**Received:** 2025/11/25

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	A062854	N/A	2025/11/26	Cathy Li

**Bureau Veritas ID:** AXRM97  
**Sample ID:** DXJ661-UNIT1 BAG 2  
**Matrix:** Air

**Collected:** 2025/07/15  
**Shipped:**  
**Received:** 2025/11/25

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	A062854	N/A	2025/11/26	Cathy Li



Bureau Veritas Job #: C5E9078  
Report Date: 2025/11/28

Bureau Veritas  
Client Project #: MVWTE  
Site Location: BURNABY, BC

### TEST SUMMARY

**Bureau Veritas ID:** AXRM98  
**Sample ID:** DXJ662-UNIT1 BAG 3  
**Matrix:** Air

**Collected:** 2025/07/15  
**Shipped:**  
**Received:** 2025/11/25

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Nitrous Oxide	GC/ECD	A062854	N/A	2025/11/26	Cathy Li



### GENERAL COMMENTS

Sample AXRM90 [DXJ654-UNIT3 BAG 1] : The sample was analysed 8 days after the date of sampling. The recommended holding time is 2 days.

Sample AXRM91 [DXJ655-UNIT3 BAG 2] : The sample was analysed 8 days after the date of sampling. The recommended holding time is 2 days.

Sample AXRM94 [DXJ658-UNIT2 BAG 2] : The sample was analysed 133 days after the date of sampling. The recommended holding time is 2 days.

Sample AXRM95 [DXJ659-UNIT2 BAG 3] : The sample was analysed 133 days after the date of sampling. The recommended holding time is 2 days.

Sample AXRM96 [DXJ660-UNIT1 BAG 1] : The sample was analysed 134 days after the date of sampling. The recommended holding time is 2 days.

Sample AXRM97 [DXJ661-UNIT1 BAG 2] : The sample was analysed 134 days after the date of sampling. The recommended holding time is 2 days.

Sample AXRM98 [DXJ662-UNIT1 BAG 3] : The sample was analysed 134 days after the date of sampling. The recommended holding time is 2 days.

**Results relate only to the items tested.**



Bureau Veritas Job #: C5E9078  
Report Date: 2025/11/28

## QUALITY ASSURANCE REPORT

Bureau Veritas  
Client Project #: MVWTE  
Site Location: BURNABY, BC

QC Batch	Parameter	Date	Method Blank		RPD	
			Value	UNITS	Value (%)	QC Limits
A062854	Nitrous Oxide	2025/11/26	<0.1	ppmv	NC	N/A

N/A = Not Applicable  
Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.  
Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.  
NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference  $\leq 2 \times$  RDL).



BUREAU  
VERITAS

Bureau Veritas Job #: C5E9078

Report Date: 2025/11/28

Bureau Veritas

Client Project #: MVWTE

Site Location: BURNABY, BC

### VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by:

Tom Mitchell, B.Sc, Supervisor, Compressed Gases

---

Bureau Veritas has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation, please refer to the Validation Signatures page if included, otherwise available by request. For Department specific Analyst/Supervisor validation names, please refer to the Test Summary section if included, otherwise available by request. This report is authorized by Rodney Major, General Manager responsible for Ontario Environmental laboratory operations.

**C5E9078**  
**2025/11/25 08:55**

Sent to: Bureau Veritas Campbell  
 6740 Campbell Road  
 Mississauga, ON, L5N 2L8  
 Tel: (905) 817-5700

**BUREAU VERITAS INTERLAB CHAIN OF CUSTODY RECORD**

COC # C595952-ONTV-01-01



REPORT INFORMATION				ANALYSIS REQUESTED				Job Barcode Label			
Company: Bureau Veritas											
Address: 4606 Canada Way, Burnaby, British Columbia, V5G 1K5											
Contact Name: Shanaz Akbar											
Email: Shanaz.Akbar@bureauveritas.com, Customersolutionswest@bureauveritas.com											
Phone: C595952											
BV Project #: A. LANFRANCO & ASSOCIATES INC. (1301)											
Client Invoice To: A. LANFRANCO & ASSOCIATES INC. (1301)											
Client Report To: A. LANFRANCO & ASSOCIATES INC. (1301)											
#	SAMPLE ID	MATRIX	DATE SAMPLED (YYYY/MM/DD)	TIME SAMPLED (HH:MM)	SAMPLER INITIALS	# CONT.	Incl. on Report? Yes / No	ADDITIONAL SAMPLE INFORMATION			
1	DXU654-UNIT3 BAG 1	AIR	2025/11/18	09:11		1	X	(P-01)			
2	DXU655-UNIT3 BAG 2	AIR	2025/11/18	10:19		1	X	(P-01)			
3	DXU656-UNIT3 BAG 3	AIR	2025/11/18	11:26		1	X	(P-01)			
4	DXU657-UNIT2 BAG 1	AIR	2025/07/16	10:24		1	X	(P-01)			
5	DXU658-UNIT2 BAG 2	AIR	2025/07/16	11:33		1	X	(P-01)			
6	DXU659-UNIT2 BAG 3	AIR	2025/07/16	12:45		1	X	(P-01)			
7	DXU660-UNIT1 BAG 1	AIR	2025/07/15	09:21		1	X	(P-01)			
8	DXU661-UNIT1 BAG 2	AIR	2025/07/15	10:30		1	X	(P-01)			
9	DXU662-UNIT1 BAG 3	AIR	2025/07/15	11:38		1	X	(P-01)			
10											
SITE LOCATION: BURNABY, BC											
SITE #:											
PROJECT #:											
M/V/W/T/E											
PO/A/E, TASK ORDER/SERVICE ORDER, LINE ITEM:											
REGULATORY CRITERIA											
SPECIAL INSTRUCTIONS				Please inform Bureau Veritas immediately if you are not accredited for the requested test(s) or the hold time is approaching. **Please return a copy of this form with the report.**				REQUIRED EDDS: National Excel (N001)			
TURNAROUND TIME								<input type="checkbox"/> Rush Required Date Required: <b>2025/12/08</b> Please inform us if rush charges will be incurred.			
RECEIVING LAB USE ONLY								Bureau Veritas Job #			
COOLER ID:								COOLER ID:			
Custody Seal Present				YES NO				Custody Seal Present			
Custody Seal Intact				YES NO				Custody Seal Intact			
Cooling Media Present				YES NO				Cooling Media Present			
TEMPERATURE								Temp: (°C)			
RELINQUISHED BY: (SIGN & PRINT)				DATE: (YYYY/MM/DD)				TIME: (HH:MM)			
1. Alfred Ngan				2025/11/24 17:30				ANAND PREET SINGH			
2.								2025/11/25 08:55			



## LABORATORY REPORT

---

December 18, 2025

Mark Lanfranco  
A. Lanfranco and Associates Inc.  
Unit 101 - 9488 189 St.  
Surrey, BC V4N 4W7

**RE: Metro Vancouver WTEF**

Dear Mark:

Enclosed are the results of the samples submitted to our laboratory on December 4, 2025. For your reference, these analyses have been assigned our service request number P2504581.

All analyses were performed according to our laboratory's NELAP and DoD-ELAP-approved quality assurance program. The test results meet requirements of the current NELAP and DoD-ELAP standards, where applicable, and except as noted in the laboratory case narrative provided. For a specific list of NELAP and DoD-ELAP-accredited analytes, refer to the certifications section at [www.alsglobal.com](http://www.alsglobal.com). Results are intended to be considered in their entirety and apply only to the samples analyzed and reported herein.

If you have any questions, please call me at (805) 526-7161.

ALS | Environmental

By Sue Anderson at 4:43 pm, Dec 18, 2025

Sue Anderson  
Project Manager



Client: A. Lanfranco and Associates Inc.  
Project: Metro Vancouver WTEF

Service Request No: P2504581

## CASE NARRATIVE

---

The samples were received intact under chain of custody on December 4, 2025 and were stored in accordance with the analytical method requirements. Please refer to the sample acceptance check form for additional information. The results reported herein are applicable only to the condition of the samples at the time of sample receipt.

### C3 through C6 Hydrocarbons, Methane, Ethene and Ethane Analysis

The samples were analyzed per modified EPA Method TO-3 for C3 through >C6 hydrocarbons and methane, ethene and ethane using a gas chromatograph equipped with a flame ionization detector (FID). This procedure is described in laboratory SOP VOA-TO3C1C6. This method is included on the laboratory's DoD-ELAP scope of accreditation; however, it is not part of the NELAP or AIHA-LAP, LLC accreditation.

---

*The results of analyses are given in the attached laboratory report. All results are intended to be considered in their entirety, and ALS Environmental (ALS) is not responsible for utilization of less than the complete report.*

*Use of ALS Environmental (ALS)'s Name. Client shall not use ALS's name or trademark in any marketing or reporting materials, press releases or in any other manner ("Materials") whatsoever and shall not attribute to ALS any test result, tolerance or specification derived from ALS's data ("Attribution") without ALS's prior written consent, which may be withheld by ALS for any reason in its sole discretion. To request ALS's consent, Client shall provide copies of the proposed Materials or Attribution and describe in writing Client's proposed use of such Materials or Attribution. If ALS has not provided written approval of the Materials or Attribution within ten (10) days of receipt from Client, Client's request to use ALS's name or trademark in any Materials or Attribution shall be deemed denied. ALS may, in its discretion, reasonably charge Client for its time in reviewing Materials or Attribution requests. Client acknowledges and agrees that the unauthorized use of ALS's name or trademark may cause ALS to incur irreparable harm for which the recovery of money damages will be inadequate. Accordingly, Client acknowledges and agrees that a violation shall justify preliminary injunctive relief. For questions contact the laboratory.*



## CERTIFICATIONS, ACCREDITATIONS, AND REGISTRATIONS

Agency	Web Site	Number
Alaska DEC	<a href="https://dec.alaska.gov/spar/csp/lab-approval/list-of-approved-labs">https://dec.alaska.gov/spar/csp/lab-approval/list-of-approved-labs</a>	17-019
Arizona DHS	<a href="http://www.azdhs.gov/preparedness/state-laboratory/lab-licensure-certification/index.php#laboratory-licensure-home">http://www.azdhs.gov/preparedness/state-laboratory/lab-licensure-certification/index.php#laboratory-licensure-home</a>	AZ0694
Florida DOH (NELAP)	<a href="http://www.floridahealth.gov/licensing-and-regulation/environmental-laboratories/index.html">http://www.floridahealth.gov/licensing-and-regulation/environmental-laboratories/index.html</a>	E871020
Louisiana DEQ (NELAP)	<a href="https://internet.deq.louisiana.gov/portal/divisions/lelap/accredited-laboratories">https://internet.deq.louisiana.gov/portal/divisions/lelap/accredited-laboratories</a>	203013
Maine DHHS	<a href="http://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtm">http://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtm</a>	CA012627
Minnesota DOH (NELAP)	<a href="http://www.health.state.mn.us/accreditation">http://www.health.state.mn.us/accreditation</a>	006-999-456
New Jersey DEP (NELAP)	<a href="https://dep.nj.gov/dsr/oqa/certified-laboratories/">https://dep.nj.gov/dsr/oqa/certified-laboratories/</a>	CA009
New York DOH (NELAP)	<a href="http://www.wadsworth.org/labcert/elap/elap.html">http://www.wadsworth.org/labcert/elap/elap.html</a>	11221
Oklahoma DEQ (NELAP)	<a href="http://labaccreditation.deq.ok.gov/labaccreditation/">labaccreditation.deq.ok.gov/labaccreditation/</a>	2207
Oregon PHD (NELAP)	<a href="http://www.oregon.gov/oha/ph/LaboratoryServices/EnvironmentalLaboratoryAccreditation/Pages/index.aspx">http://www.oregon.gov/oha/ph/LaboratoryServices/EnvironmentalLaboratoryAccreditation/Pages/index.aspx</a>	4068
Pennsylvania DEP	<a href="http://www.dep.pa.gov/Business/OtherPrograms/Labs/Pages/Laboratory-Accreditation-Program.aspx">http://www.dep.pa.gov/Business/OtherPrograms/Labs/Pages/Laboratory-Accreditation-Program.aspx</a>	68-03307 (Registration only)
PJLA (DoD ELAP)	<a href="http://www.pjlabs.com/search-accredited-labs">http://www.pjlabs.com/search-accredited-labs</a>	65818 (Testing)
Texas CEQ (NELAP)	<a href="http://www.tceq.texas.gov/agency/qa/env_lab_accreditation.html">http://www.tceq.texas.gov/agency/qa/env_lab_accreditation.html</a>	T104704413
Utah DOH (NELAP)	<a href="https://uphl.utah.gov/certifications/environmental-laboratory-certification/">https://uphl.utah.gov/certifications/environmental-laboratory-certification/</a>	CA01627
Washington DOE	<a href="http://www.ecy.wa.gov/programs/eap/labs/lab-accreditation.html">http://www.ecy.wa.gov/programs/eap/labs/lab-accreditation.html</a>	C946

Analyses were performed according to our laboratory's NELAP and DoD-ELAP approved quality assurance program. A complete listing of specific NELAP and DoD-ELAP certified analytes can be found in the certifications section at [www.alsglobal.com](http://www.alsglobal.com), or at the accreditation body's website.

Each of the certifications listed above have an explicit Scope of Accreditation that applies to specific matrices/methods/analytes; therefore, please contact the laboratory for information corresponding to a particular certification.

**ALS ENVIRONMENTAL**

**DETAIL SUMMARY REPORT**

Client: A. Lanfranco and Associates Inc.  
 Project ID: Metro Vancouver WTEF

Service Request: P2504581

Date Received: 12/4/2025  
 Time Received: 10:08

TO-3 Modified - C1C6+ Can	TO-3 Modified - MEEPP Can
---------------------------	---------------------------

Client Sample ID	Lab Code	Matrix	Date Collected	Time Collected	Container ID	Pi1 (psig)	Pf1 (psig)	TO-3 Modified - C1C6+ Can	TO-3 Modified - MEEPP Can
MV WTE Unit 1 RUN #1	P2504581-001	Air	11/18/2025	10:11	SC01905	-2.48	3.97	X	X
MV WTE Unit 1 RUN #2	P2504581-002	Air	11/18/2025	11:19	SC02288	-2.36	4.03	X	X
MV WTE Unit 1 RUN #3	P2504581-003	Air	11/18/2025	12:26	SC01716	-1.92	4.15	X	X
MV WTE Unit 2 RUN #1	P2504581-004	Air	11/18/2025	10:24	SC00831	-2.73	3.99	X	X
MV WTE Unit 2 RUN #2	P2504581-005	Air	11/18/2025	11:33	SC01890	-0.01	3.75	X	X
MV WTE Unit 2 RUN #3	P2504581-006	Air	11/18/2025	12:45	SC00121	-2.82	4.06	X	X
MV WTE Unit 3 RUN #1	P2504581-007	Air	11/18/2025	09:21	SC00884	-2.55	4.30	X	X
MV WTE Unit 3 RUN #2	P2504581-008	Air	11/18/2025	10:30	SC01602	-2.06	4.05	X	X



# Air - Chain of Custody Record & Analytical Service Request

2655 Park Center Drive, Suite A  
 Simi Valley, California 93065  
 Phone (805) 526-7161  
 Fax (805) 526-7270

**Requested Turnaround Time in Business Days (Surcharges) please circle**

1 Day (100%) 2 Day (75%) 3 Day (50%) 4 Day (35%) 5 Day (25%) 10 Day-Standard

ALS Project No. **P104581**

<b>Company Name &amp; Address (Reporting Information)</b> A. Lanfranco & Associates Inc. Unit 101 - 9488 189 street, Surrey, BC V4N 4W7				<b>Project Name</b> Metro Vancouver WTEF				<b>ALS Contact:</b>		<b>Comments</b> e.g. Actual Preservative or specific instructions
				<b>Project Number</b>				<b>Analysis Method</b> TO-15 (list on file)		
<b>Project Manager</b> Mark Lanfranco				<b>P.O. # / Billing Information</b>						
<b>Phone</b> 604 881 2582				<b>Bill to account</b> Liam Forrer						
<b>Fax</b>				<b>Email Address for Result Reporting</b> mark.lanfranco@alanfranco.com						

Client Sample ID	Laboratory ID Number	Date Collected	Time Collected	Canister ID (Bar code # - AC, SC, etc.)	Flow Controller ID (Bar code # - FC #)	Canister Start Pressure "Hg	Canister End Pressure "Hg/psig	Sample Volume		
MV WTE Unit 1 RUN #1	1	Nov. 18	1011	sc00658	oa2014	-30	-8	6L	✓	
MV WTE Unit 1 RUN #2	2	Nov. 18	1119	sc02315	oa00152	-30	-7.5	6L	✓	
MV WTE Unit 1 RUN #3	3	Nov. 18	1226	sc00374	oa01156	-30	-8	6L	✓	
MV WTE Unit 2 RUN #1	4	Nov. 19	1024	sc01479	oa00843	-29	-8	6L	✓	
MV WTE Unit 2 RUN #2	5	Nov. 19	1133	sc02303	oa01501	-18	-3	6L	✓	
MV WTE Unit 2 RUN #3	6	Nov. 19	1245	sc02040	oa00100	-29	-8	6L	✓	
MV WTE Unit 3 RUN #1	7	Nov. 20	0921	sc01882	oa02223	-30	-6.5	6L	✓	
MV WTE Unit 3 RUN #2	8	Nov. 20	1030	sc01973	oa00465	-28	-6	6L	✓	
									✓	

<b>Report Tier Levels - please select</b>						<b>Chain of Custody Seal: (Circle)</b> INTACT    BROKEN    ABSENT			<b>Project Requirements (MRLs, QAPP)</b>
Tier I - Results (Default if not specified) _____		Tier III (Results + QC & Calibration Summaries) _____		EDD required Yes / No _____					
Tier II (Results + QC Summaries) _____		Tier IV (Data Validation Package) 10% Surcharge _____							
Relinquished by: (Signature) <i>Mark Lanfranco</i>		Date: <i>Nov 24</i>		Time: <i>11:00</i>		Received by: (Signature) <i>[Signature]</i>		Date: _____ Time: _____	
Relinquished by: (Signature) <i>[Signature]</i>		Date: _____		Time: _____		Received by: (Signature) <i>[Signature]</i>		Date: <i>12-4-20</i> Time: <i>10:08</i>	
Cooler / Blank Temperature _____ °C									

## Sue Anderson

---

**From:** Louis Agassiz <louis.agassiz@alanfranco.com>  
**Sent:** Thursday, December 4, 2025 3:31 PM  
**To:** Sue Anderson  
**Cc:** Melissa; Daryl Sampson; Mark Lanfranco  
**Subject:** [EXTERNAL] - RE: Metro Vancouver - Can ID questions

**CAUTION: This email originated from outside of ALS. Do not click links or open attachments unless you recognize the sender and are sure content is relevant to you.**

Hi Sue,

Apologies for the confusion, to answer your question:

Unit 1 Run 2:

- Canister SC02288

Unit 2 Run 1:

- Canister SC00831

The third canister did not maintain vacuum before we tried to use it and does not contain a sample.

For confirmation, here is what I have from the field notes:

Canister Number	Sample ID
SC01905	Unit 1 Run 1
SC02288	Unit 1 Run 2
SC01716	Unit 1 Run 3
SC00831	Unit 2 Run 1
SC01890	Unit 2 Run 2
SC00121	Unit 2 Run 3
SC00884	Unit 3 Run 1
SC01602	Unit 3 Run 2
??	Canister was at atmospheric pressure when we opened the valve.

Let me know if you have any other questions.

Cheers,

Louis Agassiz BSc, EP  
Senior Project Manager

A. Lanfranco & Associates  
Unit 101 - 9488 189 St.  
Surrey, BC V4N 4W7  
Phone: 604-881-2582  
Mobile: 604-992-6064  
Email: [louis.agassiz@alanfranco.com](mailto:louis.agassiz@alanfranco.com)

**ALS Environmental  
Sample Acceptance Check Form**

Client: A. Lanfranco and Associates Inc. Work order: P2504581  
 Project: Metro Vancouver WTEF  
 Sample(s) received on: 12/4/2025 Date opened: 12/4/2025 by: ADAVID

**Note:** This form is used for all samples received by ALS. The use of this form for custody seals is strictly meant to indicate presence/absence and not as an indication of compliance or nonconformity. Thermal preservation and pH will only be evaluated either at the request of the client and/or as required by the method/SOP.

- |   | <b>Yes</b>                          | <b>No</b>                           | <b>N/A</b>                          |
|---|-------------------------------------|-------------------------------------|-------------------------------------|
| 1 Were <b>sample containers</b> properly marked with client sample ID?  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 2 Did <b>sample containers</b> arrive in good condition?  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 3 Were <b>chain-of-custody</b> papers used and filled out?  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 4 Did <b>sample container labels</b> and/or tags agree with custody papers?                                     | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 5 Was <b>sample volume</b> received adequate for analysis?  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 6 Are samples within specified holding times?   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 7 Was proper <b>temperature</b> (thermal preservation) of cooler at receipt adhered to?                         | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 8 Were <b>custody seals</b> on outside of cooler/Box/Container?   | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |                                     |
| Location of seal(s)? _____ Sealing Lid?   | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Were signature and date included?   | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Were seals intact?  | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 9 Do containers have appropriate <b>preservation</b> , according to method/SOP or Client specified information? | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Is there a client indication that the submitted samples are <b>pH</b> preserved?                                | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Were <b>VOA vials</b> checked for presence/absence of air bubbles?  | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Does the client/method/SOP require that the analyst check the sample pH and <u>if necessary</u> alter it?       | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 10 <b>Tubes:</b> Are the tubes capped and intact?   | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 11 <b>Badges:</b> Are the badges properly capped and intact?  | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Are dual bed badges separated and individually capped and intact?   | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 12 Lab Notification: Analyst and PM were alerted of Short HT or RUSH samples?                                   | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 13 Client Notification: Client has been notified regarding HT exceedances and/or other CoC discrepancies?       | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |

Lab Sample ID	Container Description	Required pH *	Received pH	Adjusted pH	VOA Headspace (Presence/Absence)	Receipt / Preservation Comments
P2504581-001.01	6.0 L Source Can					
P2504581-002.01	6.0 L Source Can					
P2504581-003.01	6.0 L Source Can					
P2504581-004.01	6.0 L Source Can					
P2504581-005.01	6.0 L Source Can					
P2504581-006.01	6.0 L Source Can					
P2504581-007.01	6.0 L Source Can					
P2504581-008.01	6.0 L Source Can					
P2504581-009.01	6.0 L Source Can					

Explain any discrepancies: (include lab sample ID numbers): \_\_\_\_\_  
 Can IDs listed on COC are incorrect, the client sent field notes to clarify the cans/IDs  
 The COC notes TO-15 but the correct analyses are TO-3 Mod as logged in.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 1 RUN #1  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-001

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890 II/GC8/FID  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC01905

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/17/25  
 Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -2.48      Final Pressure (psig): 3.97

Container Dilution Factor: 1.53

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	1.5	
C <sub>4</sub> as n-Butane	ND	1.5	
C <sub>5</sub> as n-Pentane	ND	1.5	
C <sub>6</sub> as n-Hexane	ND	9.2	
C <sub>6</sub> + as n-Hexane	ND	1.5	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 1 RUN #2  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-002

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890 II/GC8/FID  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC02288

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/17/25  
 Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -2.36      Final Pressure (psig): 4.03

Container Dilution Factor: 1.52

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	1.5	
C <sub>4</sub> as n-Butane	ND	1.5	
C <sub>5</sub> as n-Pentane	ND	1.5	
C <sub>6</sub> as n-Hexane	ND	9.1	
C <sub>6</sub> + as n-Hexane	ND	1.5	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 1 RUN #3  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-003

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890 II/GC8/FID  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC01716

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/17/25  
 Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -1.92      Final Pressure (psig): 4.15

Container Dilution Factor: 1.47

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	1.5	
C <sub>4</sub> as n-Butane	ND	1.5	
C <sub>5</sub> as n-Pentane	ND	1.5	
C <sub>6</sub> as n-Hexane	ND	8.8	
C <sub>6</sub> + as n-Hexane	ND	1.5	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 2 RUN #1  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-004

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890 II/GC8/FID  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC00831

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/17/25  
 Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -2.73      Final Pressure (psig): 3.99

Container Dilution Factor: 1.56

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	1.6	
C <sub>4</sub> as n-Butane	ND	1.6	
C <sub>5</sub> as n-Pentane	ND	1.6	
C <sub>6</sub> as n-Hexane	ND	9.4	
C <sub>6</sub> + as n-Hexane	ND	1.6	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 2 RUN #2  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-005

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890 II/GC8/FID  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC01890

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/17/25  
 Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -0.01      Final Pressure (psig): 3.75

Container Dilution Factor: 1.26

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	1.3	
C <sub>4</sub> as n-Butane	ND	1.3	
C <sub>5</sub> as n-Pentane	<b>1.6</b>	1.3	
C <sub>6</sub> as n-Hexane	ND	7.6	
C <sub>6</sub> + as n-Hexane	ND	1.3	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** MV WTE Unit 2 RUN #3

**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581

ALS Sample ID: P2504581-006

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Stephanie Reynoso

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC00121

Date Collected: 11/18/25

Date Received: 12/4/25

Date Analyzed: 12/17/25

Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -2.82      Final Pressure (psig): 4.06

Container Dilution Factor: 1.58

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	1.6	
C <sub>4</sub> as n-Butane	ND	1.6	
C <sub>5</sub> as n-Pentane	ND	1.6	
C <sub>6</sub> as n-Hexane	ND	9.5	
C <sub>6</sub> + as n-Hexane	ND	1.6	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 3 RUN #1  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-007

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890 II/GC8/FID  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC00884

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/17/25  
 Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -2.55      Final Pressure (psig): 4.30

Container Dilution Factor: 1.56

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	1.6	
C <sub>4</sub> as n-Butane	ND	1.6	
C <sub>5</sub> as n-Pentane	ND	1.6	
C <sub>6</sub> as n-Hexane	ND	9.4	
C <sub>6</sub> + as n-Hexane	ND	1.6	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 3 RUN #2  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-008

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890 II/GC8/FID  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC01602

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/17/25  
 Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -2.06      Final Pressure (psig): 4.05

Container Dilution Factor: 1.48

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	1.5	
C <sub>4</sub> as n-Butane	ND	1.5	
C <sub>5</sub> as n-Pentane	ND	1.5	
C <sub>6</sub> as n-Hexane	ND	8.9	
C <sub>6</sub> + as n-Hexane	ND	1.5	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Method Blank

**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581

ALS Sample ID: P251217-MB

Test Code: EPA TO-3 Modified

Instrument ID: HP5890 II/GC8/FID

Analyst: Stephanie Reynoso

Sampling Media: 6.0 L Summa Canister

Test Notes:

Date Collected: NA

Date Received: NA

Date Analyzed: 12/17/25

Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	1.0	
C <sub>4</sub> as n-Butane	ND	1.0	
C <sub>5</sub> as n-Pentane	ND	1.0	
C <sub>6</sub> as n-Hexane	ND	6.0	
C <sub>6</sub> + as n-Hexane	ND	1.0	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

**ALS ENVIRONMENTAL**

LABORATORY CONTROL SAMPLE / DUPLICATE LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** Duplicate Lab Control Sample  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P251217-DLCS

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890 II/GC8/FID  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:

Date Collected: NA  
 Date Received: NA  
 Date Analyzed: 12/17/25  
 Volume(s) Analyzed: NA ml(s)

Compound	Spike Amount		Result		% Recovery		ALS	RPD	RPD	Data
	LCS / DLCS	LCS	DLCS	LCS	DLCS	Acceptance	RPD	RPD	Qualifier	
	ppmV	ppmV	ppmV	LCS	DLCS	Limits		Limit		
Propane	1,000	1,130	1,150	113	115	92-120	2	6		
n-Butane	1,000	1,140	1,150	114	115	91-121	0.9	6		
n-Pentane	1,000	1,110	1,120	111	112	89-118	0.9	6		
n-Hexane	1,000	1,150	1,160	115	116	92-125	0.9	6		

**ALS ENVIRONMENTAL**

RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 1 RUN #1  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-001

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890A/GC10/FID/TCD  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC01905

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/15/25  
 Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -2.48      Final Pressure (psig): 3.97

Container Dilution Factor: 1.53

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.0	ND	3.1	
74-85-1	Ethene	ND	1.1	ND	0.92	
74-84-0	Ethane	ND	1.1	ND	0.92	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 1 RUN #2  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-002

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890A/GC10/FID/TCD  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC02288

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/15/25  
 Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -2.36      Final Pressure (psig): 4.03

Container Dilution Factor: 1.52

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.0	ND	3.0	
74-85-1	Ethene	ND	1.0	ND	0.91	
74-84-0	Ethane	ND	1.1	ND	0.91	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 1 RUN #3  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-003

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890A/GC10/FID/TCD  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC01716

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/15/25  
 Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -1.92      Final Pressure (psig): 4.15

Container Dilution Factor: 1.47

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	1.9	ND	2.9	
74-85-1	Ethene	ND	1.0	ND	0.88	
74-84-0	Ethane	ND	1.1	ND	0.88	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 2 RUN #1  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-004

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890A/GC10/FID/TCD  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC00831

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/15/25  
 Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -2.73      Final Pressure (psig): 3.99

Container Dilution Factor: 1.56

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.0	ND	3.1	
74-85-1	Ethene	ND	1.1	ND	0.94	
74-84-0	Ethane	ND	1.2	ND	0.94	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 2 RUN #2  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-005

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890A/GC10/FID/TCD  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC01890

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/15/25  
 Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -0.01      Final Pressure (psig): 3.75

Container Dilution Factor: 1.26

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	2.4	1.7	3.6	2.5	
74-85-1	Ethene	ND	0.87	ND	0.76	
74-84-0	Ethane	ND	0.93	ND	0.76	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 2 RUN #3  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-006

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890A/GC10/FID/TCD  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC00121

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/15/25  
 Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -2.82      Final Pressure (psig): 4.06

Container Dilution Factor: 1.58

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.1	ND	3.2	
74-85-1	Ethene	ND	1.1	ND	0.95	
74-84-0	Ethane	ND	1.2	ND	0.95	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 3 RUN #1  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-007

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890A/GC10/FID/TCD  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC00884

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/15/25  
 Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -2.55      Final Pressure (psig): 4.30

Container Dilution Factor: 1.56

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.0	ND	3.1	
74-85-1	Ethene	ND	1.1	ND	0.94	
74-84-0	Ethane	ND	1.2	ND	0.94	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** MV WTE Unit 3 RUN #2  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P2504581-008

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890A/GC10/FID/TCD  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:  
 Container ID: SC01602

Date Collected: 11/18/25  
 Date Received: 12/4/25  
 Date Analyzed: 12/15/25  
 Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -2.06      Final Pressure (psig): 4.05

Container Dilution Factor: 1.48

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	1.9	ND	3.0	
74-85-1	Ethene	ND	1.0	ND	0.89	
74-84-0	Ethane	ND	1.1	ND	0.89	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** Method Blank  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P251215-MB

**Test Code:** EPA TO-3 Modified  
**Instrument ID:** HP5890A/GC10/FID/TCD  
**Analyst:** Stephanie Reynoso  
**Sampling Media:** 6.0 L Summa Canister  
**Test Notes:**

**Date Collected:** NA  
**Date Received:** NA  
**Date Analyzed:** 12/15/25  
**Volume(s) Analyzed:** 0.50 ml(s)

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	1.3	ND	2.0	
74-85-1	Ethene	ND	0.69	ND	0.60	
74-84-0	Ethane	ND	0.74	ND	0.60	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## DUPLICATE LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** Duplicate Lab Control Sample  
**Client Project ID:** Metro Vancouver WTEF

ALS Project ID: P2504581  
 ALS Sample ID: P251215-DLCS

Test Code: EPA TO-3 Modified  
 Instrument ID: HP5890A/GC10/FID/TCD  
 Analyst: Stephanie Reynoso  
 Sampling Media: 6.0 L Summa Canister  
 Test Notes:

Date Collected: NA  
 Date Received: NA  
 Date Analyzed: 12/15/25  
 Volume(s) Analyzed: NA ml(s)

CAS #	Compound	Spike Amount		Result			ALS		RPD	RPD Limit	Data Qualifier
		LCS / DLCS ppmV	LCS ppmV	DLCS ppmV	% Recovery LCS DLCS		Acceptance Limits				
74-82-8	Methane	7.79	7.48	7.63	<b>96</b>	<b>98</b>	70-130	2	15		
74-85-1	Ethene	7.74	7.54	7.62	<b>97</b>	<b>98</b>	70-130	1	15		
74-84-0	Ethane	7.68	7.76	7.78	<b>101</b>	<b>101</b>	70-130	0	15		

**APPENDIX - D**

**COMPUTER GENERATED RESULTS**

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, BC)  
**Source:** Unit 1

**Date:** 17-Nov-25  
**Run:** 1 - Particulate / Metals  
**Run Time:** 12:27 - 14:29

---

**Concentrations:**

<b>Particulate</b>	1.12 mg/dscm	0.00049 gr/dscf
	0.63 mg/Acm	0.00027 gr/Acf
	1.01 mg/dscm (@ 11% O2)	0.00044 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.086 Kg/hr	0.190 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1286 dscm/min	45422 dscf/min
	21.44 dscm/sec	757 dscf/sec
	2292 Acm/min	80941 Acf/min

<b>Velocity</b>	14.997 m/sec	49.20 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	149.7 oC	301.5 oF
--------------------	----------	----------

<b>Moisture</b>	14.6 %
-----------------	--------

<b>Gas Analysis</b>	9.9 % O2
	9.9 % CO2

29.983 Mol. Wt (g/gmole) Dry  
28.229 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.9136 dscm	102.894 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	103.1 %	

\* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver  
 Jobsite: WTE (Burnaby, BC)  
 Source: Unit 1

Date: 17-Nov-25  
 Run: 1 - Particulate / Metals  
 Run Time: 08:30 - 10:34

Control Unit (Y) 1.0323  
 Nozzle Diameter (in.) 0.3034  
 Pitot Factor 0.8568  
 Baro. Press. (in. Hg) 29.77  
 Static Press. (in. H2O) -19.00  
 Stack Height (ft) 30  
 Stack Diameter (in.) 70.90  
 Stack Area (sq.ft.) 27.417  
 Minutes Per Reading 5.0  
 Minutes Per Point 5.0

Collection:  
 Filter (grams) 0.00005  
 Washings (grams) 0.00320  
 Total (grams) 0.00325

Gas Analysis (Vol. %):  
 CO2 O2  
 Traverse 1 10.17 9.77  
 Traverse 2 9.67 10.07  
 9.92 9.92

Condensate Collection:  
 Impinger 1 212.0  
 Impinger 2 112.0  
 Impinger 3 30.0  
 Impinger 4 2.0  
 Impinger 5 1.0  
 Impinger 6 0.0  
 Gel 18.0  
 Gain (grams) 375.0

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1										
	0.0	98.343								
1	5.0	102.600	0.51	2.68	60	60	4	290	1.5	102.9
2	10.0	106.950	0.53	2.78	60	60	4	292	4.7	103.3
3	15.0	111.200	0.51	2.66	60	60	6	296	8.4	103.1
4	20.0	115.280	0.47	2.45	61	61	6	298	12.5	103.0
5	25.0	119.430	0.49	2.54	61	61	6	302	17.7	102.9
6	30.0	123.620	0.50	2.59	61	61	6	304	25.2	103.0
7	35.0	127.750	0.49	2.52	61	61	6	310	45.6	103.0
8	40.0	131.800	0.47	2.41	62	62	6	313	53.2	103.1
9	45.0	135.720	0.44	2.26	62	62	6	313	58.3	103.1
10	50.0	139.540	0.42	2.15	62	62	6	313	62.5	102.8
11	55.0	143.280	0.40	2.05	62	62	5	313	66.1	103.1
12	60.0	146.930	0.38	1.97	62	62	5	306	69.4	102.7
Traverse 2										
	0.0	146.930								
1	5.0	151.120	0.49	2.57	63	63	6	298	1.5	103.3
2	10.0	155.260	0.48	2.52	63	63	6	296	4.7	102.9
3	15.0	159.280	0.45	2.36	64	64	6	300	8.4	103.3
4	20.0	163.200	0.43	2.24	64	64	6	303	12.5	103.2
5	25.0	167.220	0.45	2.36	65	65	6	301	17.7	103.1
6	30.0	171.280	0.46	2.41	65	65	6	302	25.2	103.1
7	35.0	175.440	0.48	2.52	66	66	6	301	45.6	103.2
8	40.0	179.680	0.50	2.63	66	66	6	300	53.2	103.0
9	45.0	184.090	0.54	2.84	67	67	6	300	58.3	102.9
10	50.0	188.480	0.53	2.80	67	67	6	298	62.5	103.3
11	55.0	192.780	0.51	2.70	67	67	6	296	66.1	103.0
12	60.0	197.020	0.49	2.62	68	68	6	290	69.4	103.0
<b>Average:</b>			0.476	2.485	63.3	63.3	5.8	301.5		103.1

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 1

**Date:** 18-Nov-25  
**Run:** 2 - Particulate / Metals  
**Run Time:** 08:53 - 10:55

---

**Concentrations:**

<b>Particulate</b>	0.87 mg/dscm	0.00038 gr/dscf
	0.49 mg/Acm	0.00021 gr/Acf
	0.77 mg/dscm (@ 11% O2)	0.00033 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.063 Kg/hr	0.138 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1198 dscm/min	42303 dscf/min
	19.96 dscm/sec	705 dscf/sec
	2137 Acf/min	75483 Acf/min

<b>Velocity</b>	13.986 m/sec	45.89 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	150.6 oC	303.1 oF
--------------------	----------	----------

<b>Moisture</b>	15.4 %	
-----------------	--------	--

<b>Gas Analysis</b>	9.6 % O2	
	10.2 % CO2	

30.011 Mol. Wt (g/gmole) Dry  
28.157 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.7485 dscm	97.062 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	104.4 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver  
 Jobsite: WTE (Burnaby, B.C)  
 Source: Unit 1

Date: 18-Nov-25  
 Run: 2 - Particulate / Metals  
 Run Time: 08:53 - 10:55

Control Unit (Y) 1.0323  
 Nozzle Diameter (in.) 0.3034  
 Pitot Factor 0.8568  
 Baro. Press. (in. Hg) 30.06  
 Static Press. (in. H2O) -19.00  
 Stack Height (ft) 30  
 Stack Diameter (in.) 70.90  
 Stack Area (sq.ft.) 27.417  
 Minutes Per Reading 5.0  
 Minutes Per Point 5.0

Collection:  
 Filter (grams) 0.00080  
 Washings (grams) 0.00160  
 Total (grams) 0.00240

Gas Analysis (Vol. %):  
 CO2 O2  
 Traverse 1 10.17 9.57  
 Traverse 2 10.17 9.63  
 10.17 9.60

Condensate Collection:  
 Impinger 1 225.0  
 Impinger 2 121.0  
 Impinger 3 7.0  
 Impinger 4 5.0  
 Impinger 5 2.0  
 Impinger 6 1.0  
 Gel 15.5  
 Gain (grams) 376.5

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	197.438								
1	5.0	200.890	0.32	1.79	56	56	4	292	1.5	107.4
2	10.0	204.260	0.33	1.71	56	56	4	296	4.7	103.5
3	15.0	207.620	0.33	1.70	56	56	5	301	8.4	103.6
4	20.0	210.880	0.31	1.59	57	57	5	305	12.5	103.7
5	25.0	214.030	0.29	1.49	57	57	5	305	17.7	103.6
6	30.0	217.140	0.28	1.44	57	57	5	305	25.2	104.1
7	35.0	220.690	0.44	2.07	58	58	5	304	45.6	94.7
8	40.0	225.020	0.53	2.77	59	59	5	303	53.2	105.1
9	45.0	229.390	0.54	2.86	59	59	5	302	58.3	105.0
10	50.0	233.600	0.50	2.62	60	60	5	302	62.5	104.9
11	55.0	237.750	0.48	2.52	61	61	5	302	66.1	105.3
12	60.0	241.820	0.46	2.43	62	62	5	300	69.4	105.1
Traverse 2	0.0	241.820								
1	5.0	245.940	0.47	2.48	63	63	5	302	1.5	105.2
2	10.0	250.180	0.50	2.64	64	64	5	304	4.7	105.0
3	15.0	254.340	0.48	2.53	65	65	5	305	8.4	105.0
4	20.0	258.380	0.45	2.38	67	67	5	306	12.5	104.9
5	25.0	262.520	0.47	2.49	68	68	6	306	17.7	105.0
6	30.0	266.700	0.48	2.54	69	69	6	307	25.2	104.8
7	35.0	270.920	0.49	2.59	68	68	6	307	45.6	104.9
8	40.0	274.930	0.44	2.33	69	69	6	307	53.2	105.0
9	45.0	278.750	0.40	2.12	69	69	6	306	58.3	104.8
10	50.0	282.540	0.39	2.07	69	69	6	306	62.5	105.2
11	55.0	286.180	0.36	1.92	70	70	6	302	66.1	104.7
12	60.0	289.620	0.32	1.72	70	70	6	299	69.4	104.7
<b>Average:</b>			0.419	2.200	62.9	62.9	5.3	303.1		104.4

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 1

**Date:** 18-Nov-25  
**Run:** 3 - Particulate / Metals  
**Run Time:** 11:20 - 13:21

---

**Concentrations:**

<b>Particulate</b>	0.2 mg/dscm	0.0001 gr/dscf
	0.1 mg/Acm	0.0001 gr/Acf
	0.2 mg/dscm (@ 11% O2)	0.0001 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.017 Kg/hr	0.038 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1166 dscm/min	41164 dscf/min
	19.43 dscm/sec	686 dscf/sec
	2062 Acm/min	72836 Acf/min

<b>Velocity</b>	13.496 m/sec	44.28 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	150.1 oC	302.2 oF
--------------------	----------	----------

<b>Moisture</b>	14.8 %	
-----------------	--------	--

<b>Gas Analysis</b>	9.7 % O2	
	10.2 % CO2	

30.013 Mol. Wt (g/gmole) Dry  
28.232 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.6719 dscm	94.360 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	104.3 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 1

**Date:** 18-Nov-25  
**Run:** 3 - Particulate / Metals  
**Run Time:** 11:20 - 13:21

**Control Unit (Y)** 1.0323  
**Nozzle Diameter (in.)** 0.3034  
**Pitot Factor** 0.8568  
**Baro. Press. (in. Hg)** 30.06  
**Static Press. (in. H2O)** -19.00  
**Stack Height (ft)** 30  
**Stack Diameter (in.)** 70.90  
**Stack Area (sq.ft.)** 27.417  
**Minutes Per Reading** 5.0  
**Minutes Per Point** 5.0

**Collection:**  
 Filter (grams) 0.00005  
 Washings (grams) 0.00060  
**Total (grams) 0.00065**

**Gas Analysis (Vol. %):**  
 CO2 O2  
 Traverse 1 9.67 10.07  
 Traverse 2 10.67 9.23  
**10.17 9.65**

**Condensate Collection:**  
 Impinger 1 234.0  
 Impinger 2 89.0  
 Impinger 3 7.0  
 Impinger 4 2.0  
 Impinger 5 0.0  
 Impinger 6 0.0  
 Gel 17.0  
**Gain (grams) 349.0**

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	290.340								
1	5.0	294.120	0.38	2.07	68	68	5	285	1.5	104.5
2	10.0	297.920	0.39	2.09	68	68	5	297	4.7	104.5
3	15.0	301.720	0.39	2.09	68	68	5	298	8.4	104.6
4	20.0	305.640	0.42	2.24	68	68	5	301	12.5	104.2
5	25.0	309.620	0.43	2.29	69	69	5	302	17.7	104.4
6	30.0	313.540	0.42	2.23	68	68	5	304	25.2	104.4
7	35.0	317.560	0.44	2.34	68	68	6	304	45.6	104.6
8	40.0	321.280	0.38	2.02	68	68	6	305	53.2	104.2
9	45.0	325.200	0.42	2.23	68	68	7	305	58.3	104.5
10	50.0	328.980	0.39	2.07	68	68	7	304	62.5	104.4
11	55.0	332.720	0.38	2.02	68	68	7	302	66.1	104.5
12	60.0	336.050	0.30	1.61	68	68	7	296	69.4	104.2
Traverse 2	0.0	336.050								
1	5.0	339.380	0.30	1.60	68	68	7	299	1.5	104.4
2	10.0	342.820	0.32	1.71	69	69	7	302	4.7	104.5
3	15.0	346.250	0.32	1.70	69	69	7	306	8.4	104.4
4	20.0	349.560	0.30	1.59	69	69	7	305	12.5	104.0
5	25.0	352.820	0.29	1.54	69	69	7	304	17.7	104.1
6	30.0	355.940	0.27	1.43	69	69	7	306	25.2	103.4
7	35.0	359.850	0.42	2.23	68	68	7	305	45.6	104.2
8	40.0	364.200	0.52	2.75	68	68	7	306	53.2	104.4
9	45.0	368.520	0.51	2.71	68	68	8	305	58.3	104.6
10	50.0	372.750	0.49	2.60	68	68	8	306	62.5	104.5
11	55.0	376.850	0.46	2.44	68	68	8	305	66.1	104.4
12	60.0	380.910	0.45	2.41	69	69	8	300	69.4	104.0
<b>Average:</b>			0.391	2.084	68.3	68.3	6.6	302.2		104.3

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)  
**Source:** Unit 1

**Sample Type:** HF, HCl, NH<sub>3</sub>

Parameter		Test 1	Test 2	Test 3
Test Date		18-Nov-25	18-Nov-25	18-Nov-25
Test Time		09:11 - 10:11	10:19 - 11:19	11:26 - 12:26
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.06	30.06	30.06
DGM Factor	(Y)	1.0258	1.0258	1.0258
Initial Reading	(m <sup>3</sup> )	194.940	195.072	195.200
Final Reading	(m <sup>3</sup> )	195.071	195.198	195.388
Temp. Outlet	(Avg. oF)	57.0	60.0	60.5
Orifice Press.	(ΔH in.H <sub>2</sub> O)	0.50	0.50	0.50
Gas Volume	(Sm <sup>3</sup> )	0.14	0.13	0.20
HF	(mg)	0.016	0.016	0.021
HCl	(mg)	1.44	9.2	13.7
NH <sub>3</sub>	(mg)	0.1	0.9	1.6
Oxygen	(Vol. %)	9.9	9.6	9.7
<b>HF</b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>0.114</b>	<b>0.120</b>	<b>0.107</b>
<b>HF</b>	<b>(mg/Sm<sup>3</sup> @ 11% O<sub>2</sub>)</b>	<b>0.103</b>	<b>0.105</b>	<b>0.094</b>
<b>HCl</b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>10.4</b>	<b>69.7</b>	<b>69.4</b>
<b>HCl</b>	<b>(mg/Sm<sup>3</sup> @ 11% O<sub>2</sub>)</b>	<b>9.38</b>	<b>61.1</b>	<b>61.1</b>
<b>NH<sub>3</sub></b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>0.857</b>	<b>6.88</b>	<b>7.94</b>
<b>NH<sub>3</sub></b>	<b>(mg/Sm<sup>3</sup> @ 11% O<sub>2</sub>)</b>	<b>0.773</b>	<b>6.02</b>	<b>6.99</b>
<b>Moisture</b>	<b>(Vol. %)</b>	<b>15.4</b>	<b>15.4</b>	<b>14.8</b>

Tstd. (oF) 68

Pstd. (in. Hg) 29.92

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 2

**Date:** 18-Nov-25  
**Run:** 1 - Particulate / Metals  
**Run Time:** 10:55 - 12:56

---

**Concentrations:**

<b>Particulate</b>	0.9 mg/dscm	0.0004 gr/dscf
	0.5 mg/Acm	0.0002 gr/Acf
	0.8 mg/dscm (@ 11% O2)	0.0004 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.062 Kg/hr	0.138 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1132 dscm/min	39963 dscf/min
	18.86 dscm/sec	666 dscf/sec
	1986 Acm/min	70140 Acf/min

<b>Velocity</b>	12.996 m/sec	42.64 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	149.2 oC	300.6 oF
--------------------	----------	----------

<b>Moisture</b>	15.1 %	
-----------------	--------	--

<b>Gas Analysis</b>	9.8 % O2	
	8.9 % CO2	

29.816 Mol. Wt (g/gmole) Dry  
28.028 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.6083 dscm	92.113 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	102.5 %	

\* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver  
 Jobsite: WTE (Burnaby, B.C)  
 Source: Unit 2

Date: 18-Nov-25  
 Run: 1 - Particulate / Metals  
 Run Time: 10:55 - 12:56

Control Unit (Y) 0.9998  
 Nozzle Diameter (in.) 0.3070  
 Pitot Factor 0.8510  
 Baro. Press. (in. Hg) 30.08  
 Static Press. (in. H2O) -15.50  
 Stack Height (ft) 30  
 Stack Diameter (in.) 70.90  
 Stack Area (sq.ft.) 27.417  
 Minutes Per Reading 5.0  
 Minutes Per Point 5.0

Collection:  
 Filter (grams) 0.00050  
 Washings (grams) 0.00190  
 Total (grams) 0.00240

Gas Analysis (Vol. %):  
 CO2 O2  
 Traverse 1 8.95 9.88  
 Traverse 2 8.88 9.65  
 8.91 9.76

Condensate Collection:  
 Impinger 1 148.0  
 Impinger 2 129.0  
 Impinger 3 32.0  
 Impinger 4 17.0  
 Impinger 5 5.0  
 Impinger 6 2.0  
 Gel 16.0  
 Gain (grams) 349.0

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	307.243								
1	5.0	311.660	0.52	2.67	60	60	3	315	1.5	102.6
2	10.0	316.010	0.50	2.58	60	60	3	309	4.7	102.7
3	15.0	320.320	0.49	2.54	60	60	3	308	8.4	102.7
4	20.0	324.690	0.50	2.60	61	61	3	305	12.5	102.7
5	25.0	328.880	0.46	2.39	61	61	3.5	305	17.7	102.6
6	30.0	332.910	0.42	2.20	63	63	3.5	303	25.2	102.7
7	35.0	336.530	0.34	1.78	61	61	3.5	300	45.6	102.6
8	40.0	339.700	0.26	1.37	61	61	3.5	295	53.2	102.3
9	45.0	342.750	0.24	1.27	61	61	4	295	58.3	102.4
10	50.0	345.680	0.22	1.17	62	62	4	292	62.5	102.3
11	55.0	348.540	0.21	1.11	62	62	3.5	295	66.1	102.4
12	60.0	351.320	0.20	1.05	62	62	3.5	299	69.4	102.3
Traverse 2	0.0	351.320								
1	5.0	354.860	0.32	1.70	64	64	3.5	294	1.5	102.4
2	10.0	358.510	0.34	1.81	64	64	3.5	294	4.7	102.5
3	15.0	362.150	0.34	1.80	64	64	4	297	8.4	102.4
4	20.0	365.680	0.32	1.69	65	65	4	300	12.5	102.3
5	25.0	368.980	0.28	1.48	65	65	4	301	17.7	102.3
6	30.0	372.400	0.30	1.58	65	65	4	302	25.2	102.5
7	35.0	376.950	0.53	2.80	66	66	4	302	45.6	102.7
8	40.0	381.370	0.50	2.63	66	66	4	303	53.2	102.7
9	45.0	385.770	0.49	2.60	68	68	4	300	58.3	102.7
10	50.0	389.990	0.45	2.39	68	68	4	300	62.5	102.7
11	55.0	393.970	0.40	2.13	69	69	4	300	66.1	102.5
12	60.0	397.690	0.35	1.86	69	69	4	300	69.4	102.4
<b>Average:</b>			0.374	1.967	63.6	63.6	3.7	300.6		102.5

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 2

**Date:** 19-Nov-25  
**Run:** 2 - Particulate / Metals  
**Run Time:** 08:52 - 11:55

---

**Concentrations:**

<b>Particulate</b>	0.09 mg/dscm	0.00004 gr/dscf
	0.05 mg/Acm	0.00002 gr/Acf
	0.07 mg/dscm (@ 11% O2)	0.00003 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.005 Kg/hr	0.012 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1052 dscm/min	37150 dscf/min
	17.53 dscm/sec	619 dscf/sec
	1882 Acn/min	66468 Acf/min

<b>Velocity</b>	12.316 m/sec	40.41 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	144.1 oC	291.4 oF
--------------------	----------	----------

<b>Moisture</b>	16.7 %
-----------------	--------

<b>Gas Analysis</b>	9.1 % O2
	10.8 % CO2

30.086 Mol. Wt (g/gmole) Dry  
28.067 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.3391 dscm	82.607 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	105.2 %	

\* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver  
 Jobsite: WTE (Burnaby, B.C.)  
 Source: Unit 2

Date: 19-Nov-25  
 Run: 2 - Particulate / Metals  
 Run Time: 08:52 - 11:55

Control Unit (Y) 0.9998  
 Nozzle Diameter (in.) 0.3034  
 Pitot Factor 0.8568  
 Baro. Press. (in. Hg) 30.01  
 Static Press. (in. H2O) -19.5  
 Stack Height (ft) 30  
 Stack Diameter (in.) 70.90  
 Stack Area (sq.ft.) 27.417  
 Minutes Per Reading 5.0  
 Minutes Per Point 5.0

Collection:  
 Filter (grams) 0.00010  
 Washings (grams) 0.00010  
 Total (grams) 0.00020

Gas Analysis (Vol. %):  
 CO2 O2  
 Traverse 1 10.83 9.09  
 Traverse 2 10.67 9.18  
 10.75 9.14

Condensate Collection:  
 Impinger 1 224.0  
 Impinger 2 87.0  
 Impinger 3 16.0  
 Impinger 4 5.0  
 Impinger 5 3.0  
 Impinger 6 1.0  
 Gel 16.0  
 Gain (grams) 352.0

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	398.667								
1	5.0	401.850	0.28	1.40	49	49	3	292	1.5	105.3
2	10.0	405.780	0.43	2.14	49	49	3	295	4.7	105.3
3	15.0	409.790	0.45	2.23	48	48	3	297	8.4	105.4
4	20.0	413.880	0.47	2.33	47	47	3	296	12.5	105.3
5	25.0	418.020	0.48	2.38	47	47	3	295	17.7	105.4
6	30.0	421.940	0.43	2.14	48	48	3	294	25.2	105.1
7	35.0	424.950	0.25	1.25	49	49	3	292	45.6	105.3
8	40.0	427.850	0.23	1.16	50	50	3	290	53.2	105.4
9	45.0	430.620	0.21	1.06	50	50	3	288	58.3	105.2
10	50.0	433.320	0.20	1.01	50	50	3	287	62.5	105.0
11	55.0	436.020	0.20	1.01	50	50	3	285	66.1	104.9
12	60.0	438.740	0.20	1.02	51	51	3	281	69.4	105.1
Traverse 2	0.0	438.740								
1	5.0	441.840	0.26	1.32	52	52	3	285	1.5	105.3
2	10.0	444.980	0.27	1.37	53	53	3	285	4.7	104.4
3	15.0	448.140	0.27	1.37	54	54	3	290	8.4	105.2
4	20.0	451.230	0.26	1.32	54	54	3	291	12.5	104.9
5	25.0	454.280	0.25	1.25	55	55	3	292	17.7	105.5
6	30.0	457.200	0.23	1.17	56	56	3	292	25.2	105.0
7	35.0	460.900	0.37	1.88	57	57	4	294	45.6	105.1
8	40.0	464.890	0.43	2.18	58	58	4	296	53.2	105.1
9	45.0	469.030	0.46	2.33	59	59	4	296	58.3	105.3
10	50.0	473.390	0.51	2.59	60	60	4	297	62.5	105.2
11	55.0	477.460	0.44	2.25	61	61	4	294	66.1	105.3
12	60.0	481.460	0.42	2.17	63	63	4	290	69.4	105.2
<b>Average:</b>			0.333	1.680	52.9	52.9	3.3	291.4		105.2

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 2

**Date:** 19-Nov-25  
**Run:** 3 - Particulate / Metals  
**Run Time:** 12:05 - 14:06

---

**Concentrations:**

<b>Particulate</b>	0.5 mg/dscm	0.0002 gr/dscf
	0.3 mg/Acm	0.0001 gr/Acf
	0.4 mg/dscm (@ 11% O2)	0.0002 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.03 Kg/hr	0.071 lb/hr
--------------------	------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1083 dscm/min	38262 dscf/min
	18.06 dscm/sec	638 dscf/sec
	1887 Acm/min	66654 Acf/min

<b>Velocity</b>	12.350 m/sec	40.52 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	146.7 oC	296.0 oF
--------------------	----------	----------

<b>Moisture</b>	13.9 %
-----------------	--------

<b>Gas Analysis</b>	9.8 % O2
	10.0 % CO2

29.990 Mol. Wt (g/gmole) Dry  
28.320 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.4337 dscm	85.946 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	102.3 %	

\* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver  
 Jobsite: WTE (Burnaby, B.C)  
 Source: Unit 2

Date: 19-Nov-25  
 Run: 3 - Particulate / Metals  
 Run Time: 12:05 - 14:06

Control Unit (Y) 0.9998  
 Nozzle Diameter (in.) 0.3034  
 Pitot Factor 0.8568  
 Baro. Press. (in. Hg) 30.01  
 Static Press. (in. H2O) -19.50  
 Stack Height (ft) 30  
 Stack Diameter (in.) 70.90  
 Stack Area (sq.ft.) 27.417  
 Minutes Per Reading 5.0  
 Minutes Per Point 5.0

Collection:  
 Filter (grams) 0.00080  
 Washings (grams) 0.00040  
 Total (grams) 0.0012

Gas Analysis (Vol. %):  
 CO2 O2  
 Traverse 1 10.83 9.08  
 Traverse 2 9.17 10.43  
 10.00 9.75

Condensate Collection:  
 Impinger 1 196.0  
 Impinger 2 64.0  
 Impinger 3 15.0  
 Impinger 4 2.0  
 Impinger 5 1.0  
 Impinger 6 1.0  
 Gel 16.5  
 Gain (grams) 295.5

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	482.206								
1	5.0	485.420	0.27	1.40	62	62	4	285	1.5	102.1
2	10.0	488.690	0.28	1.45	63	63	4	287	4.7	102.0
3	15.0	491.960	0.28	1.45	63	63	4	288	8.4	102.1
4	20.0	495.170	0.27	1.39	62	62	4	292	12.5	102.5
5	25.0	498.200	0.24	1.23	63	63	4	295	17.7	102.6
6	30.0	501.090	0.22	1.13	63	63	4	296	25.2	102.2
7	35.0	504.880	0.38	1.94	64	64	4	298	45.6	102.1
8	40.0	508.960	0.44	2.25	64	64	4	298	53.2	102.3
9	45.0	513.090	0.45	2.30	64	64	5	298	58.3	102.4
10	50.0	517.430	0.50	2.56	64	64	5	298	62.5	102.1
11	55.0	521.480	0.43	2.20	65	65	5	299	66.1	102.5
12	60.0	525.420	0.41	2.11	65	65	5	295	69.4	101.9
Traverse 2	0.0	525.420								
1	5.0	528.750	0.29	1.49	65	65	6	296	1.5	102.3
2	10.0	532.700	0.41	2.10	66	66	6	298	4.7	102.1
3	15.0	536.800	0.44	2.26	66	66	6	298	8.4	102.4
4	20.0	540.990	0.46	2.36	66	66	6	299	12.5	102.4
5	25.0	545.320	0.49	2.51	66	66	6	298	17.7	102.5
6	30.0	549.420	0.44	2.26	66	66	6	298	25.2	102.4
7	35.0	552.580	0.26	1.33	67	67	4	300	45.6	102.3
8	40.0	555.620	0.24	1.23	67	67	4	301	53.2	102.5
9	45.0	558.520	0.22	1.13	67	67	4	299	58.3	102.0
10	50.0	561.440	0.22	1.13	68	68	4	298	62.5	102.4
11	55.0	564.280	0.21	1.08	68	68	4	298	66.1	102.0
12	60.0	567.080	0.20	1.04	68	68	4	292	69.4	102.6
<b>Average:</b>			0.335	1.722	65.1	65.1	3.0	296.0		102.3

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)  
**Source:** Unit 2

**Sample Type:** HF, HCl, NH<sub>3</sub>

Parameter		Test 1	Test 2	Test 3
Test Date		19-Nov-25	19-Nov-25	19-Nov-25
Test Time		10:24 - 11:24	11:33 - 12:33	12:45 - 13:45
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	29.97	29.97	29.97
DGM Factor	(Y)	1.0258	1.0258	1.0258
Initial Reading	(m <sup>3</sup> )	195.591	195.723	195.848
Final Reading	(m <sup>3</sup> )	195.722	195.847	195.969
Temp. Outlet	(Avg. oF)	62.5	65.5	67.0
Orifice Press.	(ΔH in.H <sub>2</sub> O)	0.50	0.50	0.50
Gas Volume	(Sm <sup>3</sup> )	0.14	0.13	0.12
HF	(mg)	0.016	0.016	0.016
HCl	(mg)	10.49	8.3	7.3
NH <sub>3</sub>	(mg)	1.0	0.8	0.7
Oxygen	(Vol. %)	9.8	9.1	9.8
<b>HF</b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>0.116</b>	<b>0.124</b>	<b>0.126</b>
<b>HF</b>	<b>(mg/Sm<sup>3</sup> @ 11% O<sub>2</sub>)</b>	<b>0.103</b>	<b>0.104</b>	<b>0.112</b>
<b>HCl</b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>76.8</b>	<b>64.6</b>	<b>58.1</b>
<b>HCl</b>	<b>(mg/Sm<sup>3</sup> @ 11% O<sub>2</sub>)</b>	<b>68.3</b>	<b>54.4</b>	<b>51.6</b>
<b>NH<sub>3</sub></b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>7.67</b>	<b>6.28</b>	<b>5.69</b>
<b>NH<sub>3</sub></b>	<b>(mg/Sm<sup>3</sup> @ 11% O<sub>2</sub>)</b>	<b>6.81</b>	<b>5.29</b>	<b>5.06</b>
<b>Moisture</b>	<b>(Vol. %)</b>	<b>15.4</b>	<b>15.4</b>	<b>14.8</b>

Tstd. (oF) 68

Pstd. (in. Hg) 29.92

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 3

**Date:** 19-Nov-25  
**Run:** 1 - Particulate / Metals  
**Run Time:** 11:30 - 13:34

---

**Concentrations:**

<b>Particulate</b>	0.48 mg/dscm	0.00021 gr/dscf
	0.28 mg/Acm	0.00012 gr/Acf
	0.44 mg/dscm (@ 11% O2)	0.00019 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.032 Kg/hr	0.071 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1118 dscm/min	39491 dscf/min
	18.64 dscm/sec	658 dscf/sec
	1959 Acm/min	69184 Acf/min

<b>Velocity</b>	12.819 m/sec	42.06 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	150.1 oC	302.3 oF
--------------------	----------	----------

<b>Moisture</b>	13.9 %	
-----------------	--------	--

<b>Gas Analysis</b>	10.0 % O2	
	10.0 % CO2	

29.999 Mol. Wt (g/gmole) Dry  
28.337 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.5892 dscm	91.438 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	103.4 %	

\* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 3

**Date:** 19-Nov-25  
**Run:** 1 - Particulate / Metals  
**Run Time:** 11:30 - 13:34

**Control Unit (Y)** 0.9860  
**Nozzle Diameter (in.)** 0.3063  
**Pitot Factor** 0.8376  
**Baro. Press. (in. Hg)** 29.95  
**Static Press. (in. H2O)** -18.00  
**Stack Height (ft)** 30  
**Stack Diameter (in.)** 70.90  
**Stack Area (sq.ft.)** 27.417  
**Minutes Per Reading** 5.0  
**Minutes Per Point** 5.0

**Collection:**  
 Filter (grams) 0.00005  
 Washings (grams) 0.00120  
**Total (grams) 0.00125**

**Gas Analysis (Vol. %):**  
 CO2 O2  
 Traverse 1 10.00 9.90  
 Traverse 2 10.00 10.05  
**10.00 9.98**

**Condensate Collection:**  
 Impinger 1 152.0  
 Impinger 2 112.0  
 Impinger 3 16.0  
 Impinger 4 12.0  
 Impinger 5 3.0  
 Impinger 6 2.0  
 Gel 15.5  
**Gain (grams) 312.5**

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	765.400								
1	5.0	769.620	0.45	2.10	55	55	5	302	1.5	105.2
2	10.0	774.150	0.52	2.42	56	56	5	303	4.7	105.0
3	15.0	778.680	0.52	2.42	56	56	6	304	8.4	105.1
4	20.0	783.130	0.50	2.33	58	58	6	304	12.5	104.8
5	25.0	787.440	0.47	2.19	58	58	6	304	17.7	104.7
6	30.0	791.520	0.42	1.96	58	58	6	303	25.2	104.7
7	35.0	794.790	0.27	1.26	60	60	6	303	45.6	104.1
8	40.0	798.060	0.27	1.26	62	62	6	302	53.2	103.6
9	45.0	801.140	0.24	1.12	62	62	5	300	58.3	103.3
10	50.0	803.950	0.20	0.93	62	62	5	298	62.5	103.1
11	55.0	806.760	0.20	0.93	62	62	4	299	66.1	103.2
12	60.0	809.370	0.18	0.84	63	63	4	300	69.4	100.9
Traverse 2	0.0	809.370								
1	5.0	812.820	0.30	1.40	64	64	5	303	1.5	103.4
2	10.0	816.380	0.32	1.49	64	64	5	302	4.7	103.3
3	15.0	819.700	0.28	1.30	64	64	5	303	8.4	103.0
4	20.0	823.020	0.28	1.30	65	65	5	304	12.5	102.9
5	25.0	826.220	0.26	1.21	66	66	5	304	17.7	102.7
6	30.0	829.540	0.28	1.30	68	68	5	305	25.2	102.3
7	35.0	833.750	0.45	2.10	67	67	5	303	45.6	102.6
8	40.0	838.290	0.52	2.42	68	68	5	304	53.2	102.9
9	45.0	842.920	0.54	2.52	68	68	4	304	58.3	103.0
10	50.0	847.530	0.54	2.52	68	68	4	302	62.5	102.4
11	55.0	852.240	0.56	2.61	69	69	4	300	66.1	102.5
12	60.0	856.770	0.52	2.42	69	69	4	298	69.4	102.1
<b>Average:</b>			0.379	1.765	63.0	63.0	5.0	302.3		103.4

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 3

**Date:** 20-Nov-25  
**Run:** 2 - Particulate / Metals  
**Run Time:** 09:05 - 11:06

---

**Concentrations:**

<b>Particulate</b>	0.62 mg/dscm	0.00027 gr/dscf
	0.35 mg/Acm	0.00015 gr/Acf
	0.57 mg/dscm (@ 11% O2)	0.00025 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.045 Kg/hr	0.100 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1226 dscm/min	43307 dscf/min
	20.44 dscm/sec	722 dscf/sec
	2144 Acf/min	75720 Acf/min

<b>Velocity</b>	14.030 m/sec	46.03 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	147.7 oC	297.9 oF
--------------------	----------	----------

<b>Moisture</b>	13.9 %
-----------------	--------

<b>Gas Analysis</b>	10.2 % O2 9.6 % CO2
---------------------	------------------------

29.942 Mol. Wt (g/gmole) Dry  
28.282 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.7518 dscm	97.181 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	102.2 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver  
 Jobsite: WTE (Burnaby, B.C)  
 Source: Unit 3

Date: 20-Nov-25  
 Run: 2 - Particulate / Metals  
 Run Time: 09:05 - 11:06

Control Unit (Y) 0.9986  
 Nozzle Diameter (in.) 0.3034  
 Pitot Factor 0.8568  
 Baro. Press. (in. Hg) 29.97  
 Static Press. (in. H2O) -19.50  
 Stack Height (ft) 30  
 Stack Diameter (in.) 70.90  
 Stack Area (sq.ft.) 27.417  
 Minutes Per Reading 5.0  
 Minutes Per Point 5.0

Collection:  
 Filter (grams) 0.00110  
 Washings (grams) 0.00060  
 Traverse 1  
 Traverse 2  
 Total (grams) 0.00170

Gas Analysis (Vol. %):  
 CO2 O2  
 9.67 10.23  
 9.50 10.20  
 9.58 10.22

Condensate Collection:  
 Impinger 1 190.0  
 Impinger 2 67.0  
 Impinger 3 45.0  
 Impinger 4 12.0  
 Impinger 5 3.0  
 Impinger 6 1.0  
 Gel 15.5  
 Gain (grams) 333.5

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	857.448								
1	5.0	862.280	0.62	2.63	60	60	4	292	1.5	102.2
2	10.0	867.250	0.66	2.78	59	59	4	298	4.7	102.5
3	15.0	872.280	0.68	2.85	59	59	4	301	8.4	102.5
4	20.0	877.160	0.64	2.68	60	60	4	302	12.5	102.3
5	25.0	881.960	0.62	2.60	60	60	4	302	17.7	102.2
6	30.0	886.480	0.55	2.30	60	60	4	302	25.2	102.1
7	35.0	889.980	0.33	1.39	61	61	4	300	45.6	101.5
8	40.0	893.450	0.32	1.35	61	61	4	299	53.2	102.1
9	45.0	896.680	0.28	1.18	62	62	3	299	58.3	101.4
10	50.0	899.850	0.26	1.10	62	62	3	300	62.5	103.3
11	55.0	902.880	0.24	1.02	62	62	3	295	66.1	102.4
12	60.0	905.780	0.22	0.94	62	62	3	291	69.4	102.1
Traverse 2	0.0	905.780								
1	5.0	909.060	0.28	1.20	64	64	3.5	290	1.5	102.0
2	10.0	912.280	0.27	1.15	65	65	3.5	295	4.7	102.1
3	15.0	915.560	0.28	1.19	66	66	4	297	8.4	102.0
4	20.0	918.890	0.29	1.24	66	66	4	298	12.5	101.9
5	25.0	922.230	0.29	1.24	67	67	4	299	17.7	102.1
6	30.0	925.900	0.35	1.49	68	68	4	300	25.2	102.0
7	35.0	930.200	0.48	2.04	69	69	5	303	45.6	102.2
8	40.0	934.690	0.52	2.23	70	70	5	299	53.2	102.1
9	45.0	939.440	0.58	2.48	70	70	5	300	58.3	102.4
10	50.0	944.300	0.61	2.61	70	70	5	300	62.5	102.2
11	55.0	948.980	0.56	2.42	71	71	5	296	66.1	102.2
12	60.0	953.500	0.52	2.25	71	71	5	292	69.4	102.1
<b>Average:</b>			0.435	1.848	64.4	64.4	4.0	297.9		102.2

**Client:** Metro Vancouver  
**Jobsite:** WTE(Burnaby,B.C)  
**Source:** Unit 3

**Date:** 20-Nov-25  
**Run:** 3 - Particulate / Metals  
**Run Time:** 11:30 - 13:31

---

**Concentrations:**

<b>Particulate</b>	0.34 mg/dscm	0.00015 gr/dscf
	0.20 mg/Acm	0.00009 gr/Acf
	0.32 mg/dscm (@ 11% O2)	0.00014 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.027 Kg/hr	0.059 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1300 dscm/min	45894 dscf/min
	21.66 dscm/sec	765 dscf/sec
	2274 Acm/min	80314 Acf/min

<b>Velocity</b>	14.881 m/sec	48.82 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	146.6 oC	296.0 oF
--------------------	----------	----------

<b>Moisture</b>	14.2 %	
-----------------	--------	--

<b>Gas Analysis</b>	10.2 % O2	
	9.6 % CO2	

29.941 Mol. Wt (g/gmole) Dry  
28.245 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.9222 dscm	103.199 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	102.4 %	

\* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver  
 Jobsite: WTE(Burnaby,B.C)  
 Source: Unit 3

Date: 20-Nov-25  
 Run: 3 - Particulate / Metals  
 Run Time: 11:30 - 13:31

Control Unit (Y)	0.9986	Collection:	Gas Analysis (Vol. %):	Condensate Collection:
Nozzle Diameter (in.)	0.3034	Filter (grams) 0.00020	CO2	O2
Pitot Factor	0.8568	Washings (grams) 0.00080	9.83	9.97
Baro. Press. (in. Hg)	29.97		9.33	10.43
Static Press. (in. H2O)	-19.50	<b>Total (grams) 0.00100</b>	9.58	10.20
Stack Height (ft)	30			
Stack Diameter (in.)	70.90			
Stack Area (sq.ft.)	27.417			
Minutes Per Reading	5.0			
Minutes Per Point	5.0			
				Impinger 1 238.0
				Impinger 2 87.0
				Impinger 3 17.0
				Impinger 4 2.0
				Impinger 5 1.0
				Impinger 6 0.0
				Gel 18.0
				<b>Gain (grams) 363.0</b>

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	954.137								
1	5.0	957.680	0.32	1.38	68	68	5	290	1.5	102.6
2	10.0	961.280	0.33	1.42	69	69	5	293	4.7	102.7
3	15.0	964.870	0.33	1.42	69	69	5	296	8.4	102.6
4	20.0	968.490	0.34	1.42	69	69	5	299	12.5	102.1
5	25.0	972.110	0.34	1.45	69	69	5	302	17.7	102.3
6	30.0	975.990	0.39	1.66	69	69	5	302	25.2	102.4
7	35.0	981.080	0.67	2.86	70	70	6	302	45.6	102.6
8	40.0	986.140	0.66	2.82	70	70	6	302	53.2	102.8
9	45.0	991.170	0.65	2.78	71	71	7	302	58.3	102.8
10	50.0	996.080	0.62	2.65	71	71	7	303	62.5	102.7
11	55.0	1000.900	0.60	2.56	71	71	7	303	66.1	102.5
12	60.0	1005.700	0.59	2.54	71	71	7	298	69.4	102.6

Traverse 2	0.0	1005.700								
1	5.0	1010.730	0.65	2.81	71	71	7	295	1.5	102.3
2	10.0	1015.800	0.68	2.93	72	72	7	297	4.7	100.8
3	15.0	1021.040	0.70	3.03	72	72	8	296	8.4	102.6
4	20.0	1026.150	0.66	2.86	73	73	8	295	12.5	102.8
5	25.0	1031.230	0.65	2.84	74	74	8	291	17.7	102.5
6	30.0	1036.090	0.59	2.58	75	75	8	290	25.2	102.6
7	35.0	1039.890	0.36	1.58	76	76	6	291	45.6	102.3
8	40.0	1043.650	0.35	1.53	77	77	6	292	53.2	102.5
9	45.0	1047.250	0.32	1.40	77	77	6	292	58.3	102.6
10	50.0	1050.780	0.31	1.36	77	77	6	291	62.5	102.2
11	55.0	1054.260	0.30	1.32	78	78	6	291	66.1	102.2
12	60.0	1057.630	0.28	1.23	78	78	6	290	69.4	102.3
<b>Average:</b>			0.487	2.101	72.4	72.4	6.3	296.0		102.4

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)  
**Source:** Unit 3

**Sample Type:** HF, HCl, NH<sub>3</sub>

Parameter		Test 1	Test 2	Test 3
Test Date		20-Nov-25	20-Nov-25	20-Nov-25
Test Time		09:21 - 10:21	10:30 - 11:30	11:38 - 12:38
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	29.95	29.95	29.95
DGM Factor	(Y)	1.0258	1.0258	1.0258
Initial Reading	(m <sup>3</sup> )	195.970	196.111	196.252
Final Reading	(m <sup>3</sup> )	196.110	196.251	196.391
Temp. Outlet	(Avg. oF)	57.5	59.5	61.0
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm <sup>3</sup> )	0.15	0.15	0.14
HF	(mg)	0.016	0.016	0.016
HCl	(mg)	2.90	11.9	18.7
NH <sub>3</sub>	(mg)	0.8	0.9	0.5
Oxygen	(Vol. %)	10.0	10.2	10.2
<b>HF</b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>0.108</b>	<b>0.108</b>	<b>0.109</b>
<b>HF</b>	<b>(mg/Sm<sup>3</sup> @ 11% O2)</b>	<b>0.098</b>	<b>0.100</b>	<b>0.101</b>
<b>HCl</b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>19.8</b>	<b>81.7</b>	<b>129.1</b>
<b>HCl</b>	<b>(mg/Sm<sup>3</sup> @ 11% O2)</b>	<b>17.9</b>	<b>75.7</b>	<b>119.4</b>
<b>NH<sub>3</sub></b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>5.36</b>	<b>5.83</b>	<b>3.39</b>
<b>NH<sub>3</sub></b>	<b>(mg/Sm<sup>3</sup> @ 11% O2)</b>	<b>4.85</b>	<b>5.40</b>	<b>3.14</b>
<b>Moisture</b>	<b>(Vol. %)</b>	<b>15.4</b>	<b>15.4</b>	<b>14.8</b>

Tstd. (oF) 68

Pstd. (in. Hg) 29.92

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 1

**Date:** 20-Nov-25  
**Run:** 1 - Cr<sup>+6</sup>  
**Run Time:** 12:00 - 14:05

---

**Concentrations:**

<b>Hexavalent Chromium</b>	0.0 mg/dscm	0.0000 gr/dscf
	0.0 mg/Acm	0.0000 gr/Acf
	0.0 mg/dscm (@ 11% O2)	0.0000 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.00 Kg/hr	0.000 lb/hr
--------------------	------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1191 dscm/min	42064 dscf/min
	19.85 dscm/sec	701 dscf/sec
	2077 Acm/min	73334 Acf/min

<b>Velocity</b>	13.588 m/sec	44.58 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	150.8 oC	303.4 oF
--------------------	----------	----------

<b>Moisture</b>	13.3 %
-----------------	--------

<b>Gas Analysis</b>	10.0 % O2
	9.9 % CO2

29.984 Mol. Wt (g/gmole) Dry  
28.388 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.7500 dscm	97.115 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	103.1 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver  
 Jobsite: WTE (Burnaby, B.C.)  
 Source: Unit 1

Date: 20-Nov-25  
 Run: 1 - Cr+6  
 Run Time: 12:00 - 14:05

Control Unit (Y) 1.0278  
 Nozzle Diameter (in.) 0.3063  
 Pitot Factor 0.8376  
 Baro. Press. (in. Hg) 30.01  
 Static Press. (in. H2O) -18.75  
 Stack Height (ft) 30  
 Stack Diameter (in.) 70.90  
 Stack Area (sq.ft.) 27.417  
 Minutes Per Reading 5.0  
 Minutes Per Point 5.0

Collection:  
 Cr+6 (grams) 0.00000065  
 Total (grams) 0.00000065

Gas Analysis (Vol. %):	
CO2	O2
9.97	10.09
9.83	9.92
<hr/>	
9.90	10.01

Condensate Collection:	
Impinger 1	-80.0
Impinger 2	180.0
Impinger 3	170.0
Impinger 4	25.0
<hr/>	
Gel	22.0
Gain (grams)	317.0

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	384.500								
1	5.0	387.450	0.24	1.23	58	58	2	302	1.5	103.8
2	10.0	390.640	0.28	1.43	60	60	2	303	4.7	103.6
3	15.0	394.060	0.32	1.64	62	62	2	302	8.4	103.5
4	20.0	397.470	0.32	1.64	60	60	2	304	12.5	103.7
5	25.0	400.980	0.34	1.74	60	60	2	304	17.7	103.6
6	30.0	404.490	0.34	1.74	60	60	2	306	25.2	103.8
7	35.0	408.920	0.54	2.76	60	60	6	306	45.6	104.2
8	40.0	413.340	0.54	2.76	61	61	6	304	53.2	103.6
9	45.0	417.890	0.57	2.92	62	62	6	302	58.3	103.5
10	50.0	422.470	0.58	2.97	62	62	6	302	62.5	103.3
11	55.0	426.560	0.46	2.36	62	62	6	300	66.1	103.3
12	60.0	430.520	0.44	2.25	62	62	6	298	69.4	102.1
Traverse 2	0.0	430.520								
1	5.0	434.190	0.37	1.89	62	62	4	306	1.5	103.6
2	10.0	438.100	0.42	2.15	62	62	4	304	4.7	103.6
3	15.0	442.090	0.44	2.25	63	63	4	304	8.4	103.1
4	20.0	446.220	0.47	2.41	64	64	4	306	12.5	103.2
5	25.0	450.350	0.47	2.41	64	64	4	306	17.7	103.2
6	30.0	454.560	0.49	2.51	65	65	4	306	25.2	102.9
7	35.0	458.770	0.49	2.51	66	66	4	307	45.6	102.7
8	40.0	462.810	0.45	2.30	68	68	4	306	53.2	102.4
9	45.0	466.720	0.42	2.15	68	68	4	305	58.3	102.4
10	50.0	470.390	0.37	1.89	68	68	4	302	62.5	102.2
11	55.0	473.960	0.35	1.79	69	69	4	300	66.1	101.8
12	60.0	477.370	0.32	1.64	70	70	4	297	69.4	101.3
<b>Average:</b>			0.418	2.139	63.3	63.3	4.0	303.4		103.1

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 1

**Date:** 21-Nov-25  
**Run:** 2 - Cr<sup>+6</sup>  
**Run Time:** 08:43 - 10:46

---

**Concentrations:**

<b>Hexavalent Chromium</b>	0.0 mg/dscm	0.0000 gr/dscf
	0.0 mg/Acm	0.0000 gr/Acf
	0.0 mg/dscm (@ 11% O2)	0.0000 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.00 Kg/hr	0.000 lb/hr
--------------------	------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1138 dscm/min	40192 dscf/min
	18.97 dscm/sec	670 dscf/sec
	1991 Acm/min	70305 Acf/min

<b>Velocity</b>	13.027 m/sec	42.74 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	150.4 oC	302.8 oF
--------------------	----------	----------

<b>Moisture</b>	13.9 %
-----------------	--------

<b>Gas Analysis</b>	9.8 % O2
	10.0 % CO2

29.990 Mol. Wt (g/gmole) Dry  
28.328 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.6590 dscm	93.902 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	104.3 %	

\* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver  
 Jobsite: WTE (Burnaby, B.C.)  
 Source: Unit 1

Date: 21-Nov-25  
 Run: 2 - Cr+6  
 Run Time: 08:43 - 10:46

Control Unit (Y) 1.0278  
 Nozzle Diameter (in.) 0.3063  
 Pitot Factor 0.8376  
 Baro. Press. (in. Hg) 30.05  
 Static Press. (in. H2O) -18.50  
 Stack Height (ft) 30  
 Stack Diameter (in.) 70.90  
 Stack Area (sq.ft.) 27.417  
 Minutes Per Reading 5.0  
 Minutes Per Point 5.0

Collection:  
 Cr+6 (grams) 0.00000055  
 Total (grams) 0.0000006

Gas Analysis (Vol. %):	
CO2	O2
10.00	9.75
10.00	9.75
<hr/>	
10.00	9.75

Condensate Collection:	
Impinger 1	-75.0
Impinger 2	205.0
Impinger 3	170.0
Impinger 4	0.0
<hr/>	
Gel	21.0
Gain (grams)	321.0

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	479.900								
1	5.0	483.320	0.32	1.64	54	54	4	303	1.5	105.8
2	10.0	486.840	0.34	1.74	56	56	4	305	4.7	105.4
3	15.0	490.360	0.34	1.74	56	56	4	306	8.4	105.4
4	20.0	493.970	0.36	1.84	57	57	4	306	12.5	104.9
5	25.0	497.380	0.32	1.64	56	56	4	304	17.7	105.1
6	30.0	500.690	0.30	1.54	56	56	4	304	25.2	105.4
7	35.0	504.740	0.45	2.30	57	57	6	304	45.6	105.2
8	40.0	509.050	0.51	2.61	58	58	6	304	53.2	105.1
9	45.0	513.390	0.52	2.66	58	58	6	304	58.3	104.8
10	50.0	517.520	0.47	2.41	59	59	6	302	62.5	104.5
11	55.0	521.560	0.45	2.30	60	60	5	300	66.1	104.1
12	60.0	525.600	0.45	2.30	60	60	5	297	69.4	103.9

Traverse 2	0.0	525.600								
1	5.0	529.170	0.35	1.79	62	62	5	303	1.5	104.0
2	10.0	532.840	0.37	1.89	62	62	5	302	4.7	103.9
3	15.0	536.520	0.37	1.89	61	61	5	304	8.4	104.6
4	20.0	540.090	0.35	1.79	62	62	5	304	12.5	104.1
5	25.0	543.660	0.35	1.79	62	62	5	303	17.7	104.0
6	30.0	547.420	0.39	2.00	63	63	5	302	25.2	103.5
7	35.0	551.180	0.39	2.00	63	63	5	302	45.6	103.5
8	40.0	555.090	0.42	2.15	64	64	5	303	53.2	103.7
9	45.0	558.760	0.37	1.89	64	64	4	302	58.3	103.5
10	50.0	562.270	0.34	1.74	65	65	4	301	62.5	103.0
11	55.0	565.680	0.32	1.64	64	64	4	301	66.1	103.3
12	60.0	569.090	0.32	1.64	65	65	4	300	69.4	103.0
<b>Average:</b>			0.382	1.955	60.2	60.2	4.8	302.8		104.3

**Client:** Metro Vancouver  
**Jobsite:** WTE(Burnaby,B.C)  
**Source:** Unit 1

**Date:** 21-Nov-25  
**Run:** 3 - Cr<sup>+6</sup>  
**Run Time:** 11:11 - 13:13

---

**Concentrations:**

<b>Hexavalent Chromium</b>	0.0 mg/dscm	0.0000 gr/dscf
	0.0 mg/Acm	0.0000 gr/Acf
	0.0 mg/dscm (@ 11% O2)	0.0000 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.00 Kg/hr	0.000 lb/hr
--------------------	------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1064 dscm/min	37584 dscf/min
	17.74 dscm/sec	626 dscf/sec
	1875 Acm/min	66219 Acf/min

<b>Velocity</b>	12.270 m/sec	40.25 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	153.9 oC	309.0 oF
--------------------	----------	----------

<b>Moisture</b>	13.8 %	
-----------------	--------	--

<b>Gas Analysis</b>	9.3 % O2	
	10.3 % CO2	

30.011 Mol. Wt (g/gmole) Dry  
28.356 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.4857 dscm	87.784 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	104.3 %	

**\* Standard Conditions:**

Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

Client: Metro Vancouver  
 Jobsite: WTE(Burnaby,B.C)  
 Source: Unit 1

Date: 21-Nov-25  
 Run: 3 - Cr+6  
 Run Time: 11:11 - 13:13

Control Unit (Y) 1.0278  
 Nozzle Diameter (in.) 0.3063  
 Pitot Factor 0.8376  
 Baro. Press. (in. Hg) 30.05  
 Static Press. (in. H2O) -18.50  
 Stack Height (ft) 30  
 Stack Diameter (in.) 70.90  
 Stack Area (sq.ft.) 27.417  
 Minutes Per Reading 5.0  
 Minutes Per Point 5.0

Collection:  
 Cr+6 (grams) 0.00000064  
 Total (grams) 0.0000006

Gas Analysis (Vol. %):  
 CO2 O2  
 Traverse 1 10.50 9.17  
 Traverse 2 10.00 9.38  
 10.25 9.27

Condensate Collection:  
 Impinger 1 -70.0  
 Impinger 2 258.0  
 Impinger 3 90.0  
 Impinger 4 0.0  
 Gel 20.0  
 Gain (grams) 298.0

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Inlet (oF)	Dry Gas Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	570.850								
1	5.0	574.320	0.33	1.69	60	60	3	303	1.5	104.4
2	10.0	577.890	0.35	1.79	62	62	3	307	4.7	104.2
3	15.0	581.460	0.35	1.79	60	60	3	310	8.4	104.8
4	20.0	585.140	0.37	1.89	60	60	3	311	12.5	105.2
5	25.0	588.950	0.40	2.05	60	60	5	311	17.7	104.8
6	30.0	592.870	0.42	2.15	61	61	5	311	25.2	105.0
7	35.0	596.790	0.42	2.15	60	60	5	310	45.6	105.2
8	40.0	600.600	0.40	2.05	60	60	5	305	53.2	104.4
9	45.0	604.320	0.38	1.95	61	61	4	309	58.3	104.6
10	50.0	607.890	0.35	1.79	61	61	4	310	62.5	104.6
11	55.0	611.300	0.32	1.64	62	62	4	306	66.1	104.0
12	60.0	614.720	0.32	1.64	62	62	4	299	69.4	103.8
Traverse 2	0.0	614.720								
1	5.0	617.540	0.22	1.13	61	61	3	311	1.5	104.1
2	10.0	620.230	0.20	1.02	62	62	3	311	4.7	104.0
3	15.0	622.920	0.20	1.02	62	62	3	312	8.4	104.0
4	20.0	625.470	0.18	0.92	62	62	3	312	12.5	103.9
5	25.0	628.430	0.24	1.23	62	62	3	311	17.7	104.5
6	30.0	631.380	0.24	1.23	63	63	3	312	25.2	104.0
7	35.0	635.190	0.40	2.05	63	63	3	301	45.6	103.5
8	40.0	639.320	0.47	2.41	64	64	3	310	53.2	104.0
9	45.0	643.220	0.42	2.15	63	63	3	312	58.3	104.2
10	50.0	647.120	0.42	2.15	64	64	3	314	62.5	104.1
11	55.0	650.930	0.40	2.05	64	64	3	316	66.1	104.3
12	60.0	654.540	0.36	1.84	65	65	3	302	69.4	103.0
<b>Average:</b>			0.340	1.741	61.8	61.8	3.5	309.0		104.3

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)

**Parameter:** N<sub>2</sub>O

**Molecular Weight:** 44.00                      grams/mol                      **Reportable Detection**  
**Lab Detection Limit:** 0.1                      ppm                      **Limit:** 0.18                      mg/Sm<sup>3</sup>

Sample ID	Date	Time	N <sub>2</sub> O ppm	N <sub>2</sub> O mg/Sm <sup>3</sup>	N <sub>2</sub> O mg/Sm <sup>3</sup> @ 11% O <sub>2</sub>
Unit 1 - Run 1	18-Nov-25	09:11 - 10:11	3.65	6.68	6.03
Unit 1 - Run 2	18-Nov-25	10:19 - 11:19	4.20	7.69	6.74
Unit 1 - Run 3	18-Nov-25	11:26 - 12:26	3.30	6.04	5.32
<b>Average</b>					<b>6.03</b>
Unit 2 - Run 1	19-Nov-25	10:24 - 11:24	-	-	-
Unit 2 - Run 2	19-Nov-25	11:33 - 12:33	1.60	2.93	2.47
Unit 2 - Run 3	19-Nov-25	12:45 - 13:45	3.10	5.67	5.04
<b>Average</b>					<b>3.76</b>
Unit 3 - Run 1	20-Nov-25	09:21 - 10:21	3.40	6.22	5.64
Unit 3 - Run 2	20-Nov-25	10:30 - 11:30	4.10	7.50	6.96
Unit 3 - Run 3	20-Nov-25	11:40 - 12:40	-	-	-
<b>Average</b>					<b>6.30</b>

Unit 2 Run 1 and Unit 3 Run 3 sample bags were compromised in transport and analytical was not completed.

Date:	18-Nov-25			19-Nov-25			20-Nov-25		
	Unit 1			Unit 2			Unit 3		
	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3
<b>Test Times:</b>	09:11 - 10:11	10:19 - 11:19	11:26 - 12:26	10:24 - 11:24	11:33 - 12:33	12:45 - 13:45	09:21 - 10:21	10:30 - 11:30	Bad Canister
<b>Methane (ppmv)</b>	ND	ND	ND	ND	3.6	ND	ND	ND	-
<b>Ethane (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	-
<b>Ethene (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	-
<b>C3 as Propane (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	-
<b>C4 as n-Butane (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	-
<b>C5 as n-Pentane (ppmv)</b>	ND	ND	ND	ND	1.6	ND	ND	ND	-
<b>C6 as n-Hexane (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	-
<b>C6+ as n-Hexane (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	-

**Detection Limits:**

Methane	3.1	3.0	2.9	3.1	2.5	3.2	3.1	3.0	-
Ethane	0.92	0.91	0.88	0.94	0.76	0.95	0.94	0.89	-
Ethene	0.92	0.91	0.88	0.94	0.76	0.95	0.94	0.89	-
C3 as Propane	1.50	1.5	1.5	1.6	1.3	1.60	1.60	1.5	-
C4 as n-Butane	1.50	1.5	1.5	1.6	1.3	1.60	1.60	1.5	-
C5 as n-Pentane	1.50	1.5	1.5	1.6	1.3	1.60	1.60	1.5	-
C6 as n-Hexane	9.20	9.1	8.8	9.4	7.6	9.50	9.40	8.9	-
C6+	1.5	1.5	1.5	1.6	1.3	1.6	1.6	1.5	-

**Using 1/2 DL Convention**

Sample Date:	18-Nov-25			19-Nov-25			20-Nov-25		
	Unit 1			Unit 2			Unit 3		
	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3
<b>Test Times:</b>	09:11 - 10:11	10:19 - 11:19	11:26 - 12:26	10:24 - 11:24	11:33 - 12:33	12:45 - 13:45	09:21 - 10:21	10:30 - 11:30	Bad Canister
<b>Methane (ppm)</b>	1.55	1.50	1.45	1.55	3.60	1.60	1.55	1.50	-
<b>Ethane (ppm)</b>	0.46	0.46	0.44	0.47	0.38	0.48	0.47	0.45	-
<b>Ethene (ppm)</b>	0.46	0.46	0.44	0.47	0.38	0.48	0.47	0.45	-
<b>C3 as Propane (ppm)</b>	0.75	0.75	0.75	0.80	0.65	0.80	0.80	0.75	-
<b>C4 as n-Butane (ppm)</b>	0.75	0.75	0.75	0.80	0.65	0.80	0.80	0.75	-
<b>C5 as n-Pentane (ppm)</b>	0.75	0.75	0.75	0.80	1.60	0.80	0.80	0.75	-
<b>C6 as n-Hexane (ppm)</b>	4.60	4.55	4.40	4.70	3.80	4.75	4.70	4.45	-
<b>C6+ as n-Hexane (ppm)</b>	0.75	0.75	0.75	0.80	0.65	0.80	0.80	0.75	-

<b>Methane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	1.03	1.00	0.97	1.03	2.40	1.07	1.03	1.00	-
<b>Ethane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.31	0.30	0.29	0.31	0.25	0.32	0.31	0.30	-
<b>Ethene (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.31	0.30	0.29	0.31	0.25	0.32	0.31	0.30	-
<b>C3 as Propane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.50	0.50	0.50	0.53	0.43	0.53	0.53	0.50	-
<b>C4 as n-Butane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.50	0.50	0.50	0.53	0.43	0.53	0.53	0.50	-
<b>C5 as n-Pentane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.50	0.50	0.50	0.53	1.07	0.53	0.53	0.50	-
<b>C6 as n-Hexane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	3.07	3.04	2.94	3.14	2.54	3.17	3.14	2.97	-
<b>C6+ as n-Hexane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.50	0.50	0.50	0.53	0.43	0.53	0.53	0.50	-
<b>Total mg/Sm<sup>3</sup> @11% O<sub>2</sub> as CH<sub>4</sub></b>	5.12	5.06	4.92	5.50	6.19	5.26	4.49	4.73	-

All data is corrected to standard conditions (S) of 20 °C, 101.325 kPa (dry) unless otherwise noted.

**APPENDIX - E**

**FIELD DATA SHEETS**

<b>METRO VANCOUVER WTE - BURNABY B.C.</b>				NOZZLE <i>G-304</i>	DIAMETER, IN. <i>0.3034</i>	IMPINGER	INITIAL	FINAL	TOTAL GAIN
				PROBE <i>7' AL GVRD</i>	Cp <i>0.8568</i>	VOLUMES	(mL)	(mL)	(mL)
SOURCE <i>Unit #1</i>						Imp. #1	<i>0</i>	<i>212</i>	<i>212</i>
PARAMETER / RUN No <i>Modals/Particulate / R-1</i>				PORT LENGTH		Imp. #2	<i>100</i>	<i>212</i>	<i>112</i>
DATE <i>Nov. 17, 2025</i>				STATIC PRESSURE, IN. H2O <i>-19.0'</i>		Imp. #3	<i>100</i>	<i>130</i>	<i>30</i>
OPERATOR: <i>DS</i>				STACK DIAMETER <i>70.9"</i>		Imp. #4	<i>0</i>	<i>2</i>	<i>2</i>
CONTROL UNIT <i>FE18</i>	Y <i>1.0323</i>			STACK HEIGHT <i>30.0'</i>		Imp. #5	<i>100</i>	<i>101</i>	<i>1</i>
				ΔH@ <i>1.875</i>		Imp. #6	<i>100</i>	<i>100</i>	
BAROMETRIC PRESSURE, IN. Hg <i>29.77</i>				INITIAL LEAK TEST <i>0.001 @ 15"</i>		Imp. #7	<i>200g</i>		
ASSUMED MOISTURE, Bw <i>15%</i>				FINAL LEAK TEST <i>0.002 @ 15"</i>		Imp. #8			

S Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyriles	
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %
<i>MIN</i>	<i>12:27</i>	<i>98.343</i>										
1		<i>102.60</i>	<i>0.51</i>	<i>2.68</i>	<i>60</i>	<i>290</i>	<i>249</i>	<i>249</i>	<i>49</i>	<i>4</i>		
2	<i>10</i>	<i>106.95</i>	<i>0.53</i>	<i>2.78</i>	<i>60</i>	<i>292</i>	<i>249</i>	<i>249</i>	<i>49</i>	<i>4</i>	<i>10.5</i>	<i>9.5</i>
3		<i>111.20</i>	<i>0.51</i>	<i>2.66</i>	<i>60</i>	<i>296</i>	<i>248</i>	<i>253</i>	<i>50</i>	<i>6</i>		
4	<i>20</i>	<i>115.28</i>	<i>0.47</i>	<i>2.45</i>	<i>61</i>	<i>298</i>						
5		<i>119.43</i>	<i>0.49</i>	<i>2.54</i>	<i>61</i>	<i>302</i>	<i>251</i>	<i>251</i>	<i>52</i>	<i>6</i>		
6	<i>30</i>	<i>123.62</i>	<i>0.50</i>	<i>2.59</i>	<i>61</i>	<i>304</i>						
7		<i>127.75</i>	<i>0.49</i>	<i>2.52</i>	<i>61</i>	<i>310</i>	<i>250</i>	<i>251</i>	<i>54</i>	<i>6</i>	<i>10.0</i>	<i>9.8</i>
8	<i>40</i>	<i>131.80</i>	<i>0.47</i>	<i>2.41</i>	<i>62</i>	<i>313</i>						
9		<i>135.72</i>	<i>0.44</i>	<i>2.26</i>	<i>62</i>	<i>313</i>	<i>249</i>	<i>250</i>	<i>52</i>	<i>6</i>		
10	<i>50</i>	<i>139.54</i>	<i>0.42</i>	<i>2.15</i>	<i>62</i>	<i>313</i>						
11		<i>143.28</i>	<i>0.40</i>	<i>2.05</i>	<i>62</i>	<i>313</i>	<i>249</i>	<i>250</i>	<i>50</i>	<i>5</i>	<i>10.0</i>	<i>10.0</i>
12	<i>60</i>	<i>146.93</i>	<i>0.38</i>	<i>1.97</i>	<i>62</i>	<i>306</i>						
1		<i>151.12</i>	<i>0.49</i>	<i>2.57</i>	<i>63</i>	<i>298</i>	<i>250</i>	<i>251</i>	<i>52</i>	<i>6</i>		
2	<i>10</i>	<i>155.26</i>	<i>0.48</i>	<i>2.52</i>	<i>63</i>	<i>296</i>					<i>9.5</i>	<i>10.2</i>
3		<i>159.28</i>	<i>0.45</i>	<i>2.36</i>	<i>64</i>	<i>300</i>	<i>249</i>	<i>251</i>	<i>54</i>	<i>6</i>		
4	<i>20</i>	<i>163.20</i>	<i>0.43</i>	<i>2.24</i>	<i>64</i>	<i>303</i>						
5		<i>167.22</i>	<i>0.45</i>	<i>2.36</i>	<i>65</i>	<i>301</i>	<i>250</i>	<i>251</i>	<i>52</i>	<i>6</i>		
6	<i>30</i>	<i>171.28</i>	<i>0.46</i>	<i>2.41</i>	<i>65</i>	<i>302</i>						
7		<i>175.44</i>	<i>0.48</i>	<i>2.52</i>	<i>66</i>	<i>301</i>	<i>249</i>	<i>251</i>	<i>54</i>	<i>6</i>	<i>10.0</i>	<i>9.6</i>
8	<i>40</i>	<i>179.68</i>	<i>0.50</i>	<i>2.63</i>	<i>66</i>	<i>300</i>						
9		<i>184.09</i>	<i>0.54</i>	<i>2.84</i>	<i>67</i>	<i>300</i>	<i>249</i>	<i>249</i>	<i>55</i>	<i>6</i>		
10	<i>50</i>	<i>188.48</i>	<i>0.53</i>	<i>2.80</i>	<i>67</i>	<i>298</i>						
11		<i>192.78</i>	<i>0.51</i>	<i>2.70</i>	<i>67</i>	<i>296</i>	<i>249</i>	<i>250</i>	<i>52</i>	<i>6</i>	<i>9.5</i>	<i>10.4</i>
12	<i>1429</i>	<i>197.02</i>	<i>0.49</i>	<i>2.62</i>	<i>68</i>	<i>290</i>						

LA

<b>METRO VANCOUVER WTE - BURNABY B.C.</b>				NOZZLE <i>G-304</i> DIAMETER, IN. <i>0.3034</i>	IMPINGER	INITIAL	FINAL	TOTAL GAIN
				PROBE <i>7" AL GURD</i> Cp <i>0.8568</i>	VOLUMES	(mL)	(mL)	(mL)
SOURCE <i>Unit #1</i>					Imp. #1	<i>0</i>	<i>225</i>	<i>225</i>
PARAMETER / RUN No <i>Metals / particulate / R-2</i>				PORT LENGTH	Imp. #2	<i>100</i>	<i>221</i>	<i>121</i>
DATE <i>Nov. 18, 2025</i>				STATIC PRESSURE, IN. H2O <i>-19.0"</i>	Imp. #3	<i>100</i>	<i>107</i>	<i>7</i>
OPERATOR: <i>DS</i>				STACK DIAMETER <i>70.94</i>	Imp. #4	<i>0</i>	<i>5</i>	<i>5</i>
CONTROL UNIT <i>FE18</i>	Y <i>1.0323</i>			STACK HEIGHT <i>30.0'</i>	Imp. #5	<i>100</i>	<i>102</i>	<i>2</i>
	ΔH@ <i>1.875</i>				Imp. #6	<i>100</i>	<i>101</i>	<i>1</i>
BAROMETRIC PRESSURE, IN. Hg <i>30.06</i>				INITIAL LEAK TEST <i>0.002 @ 15"</i>	Imp. #7	<i>200g</i>		
ASSUMED MOISTURE, Bw <i>15%</i>				FINAL LEAK TEST <i>0.003 @ 15"</i>	Imp. #8			

5 Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites	
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %
<i>mm</i>	<i>0853</i>	<i>197.438</i>										
1		<i>200.89</i>	<i>0.32</i>	<i>1.79</i>	<i>56</i>	<i>292</i>	<i>236</i>	<i>242</i>	<i>45</i>	<i>4</i>		
2	10	<i>204.26</i>	<i>0.33</i>	<i>1.71</i>	<i>56</i>	<i>296</i>					<i>10.5</i>	<i>9.3</i>
3		<i>207.62</i>	<i>0.33</i>	<i>1.70</i>	<i>56</i>	<i>301</i>	<i>240</i>	<i>245</i>	<i>48</i>	<i>5</i>		
4	20	<i>210.88</i>	<i>0.31</i>	<i>1.59</i>	<i>57</i>	<i>305</i>						
5		<i>214.03</i>	<i>0.29</i>	<i>1.49</i>	<i>57</i>	<i>305</i>	<i>252</i>	<i>252</i>	<i>50</i>	<i>5</i>		
6	30	<i>217.14</i>	<i>0.28</i>	<i>1.44</i>	<i>57</i>	<i>305</i>					<i>10.0</i>	<i>9.6</i>
7		<i>220.69</i>	<i>0.44</i>	<i>2.07</i>	<i>58</i>	<i>304</i>	<i>248</i>	<i>233</i>	<i>52</i>	<i>5</i>		
8	40	<i>225.02</i>	<i>0.53</i>	<i>2.74</i>	<i>59</i>	<i>303</i>						
9		<i>229.39</i>	<i>0.54</i>	<i>2.83</i>	<i>59</i>	<i>302</i>	<i>249</i>	<i>234</i>	<i>54</i>	<i>5</i>	<i>10.0</i>	<i>9.8</i>
10	50	<i>233.60</i>	<i>0.50</i>	<i>2.62</i>	<i>60</i>	<i>302</i>						
11		<i>237.75</i>	<i>0.48</i>	<i>2.52</i>	<i>61</i>	<i>302</i>	<i>250</i>	<i>239</i>	<i>56</i>	<i>5</i>		
12	60	<i>241.82</i>	<i>0.46</i>	<i>2.43</i>	<i>62</i>	<i>300</i>						
1		<i>245.94</i>	<i>0.47</i>	<i>2.48</i>	<i>63</i>	<i>302</i>	<i>252</i>	<i>268</i>	<i>54</i>	<i>5</i>		
2	10	<i>250.18</i>	<i>0.50</i>	<i>2.64</i>	<i>64</i>	<i>304</i>					<i>10.0</i>	<i>9.8</i>
3		<i>254.34</i>	<i>0.48</i>	<i>2.53</i>	<i>65</i>	<i>305</i>	<i>253</i>	<i>262</i>	<i>56</i>	<i>5</i>		
4	20	<i>258.38</i>	<i>0.45</i>	<i>2.38</i>	<i>67</i>	<i>306</i>						
5		<i>262.52</i>	<i>0.47</i>	<i>2.49</i>	<i>68</i>	<i>306</i>	<i>250</i>	<i>248</i>	<i>57</i>	<i>6</i>		
6	30	<i>266.70</i>	<i>0.48</i>	<i>2.54</i>	<i>69</i>	<i>307</i>					<i>10.5</i>	<i>9.3</i>
7		<i>270.92</i>	<i>0.49</i>	<i>2.59</i>	<i>68</i>	<i>307</i>	<i>250</i>	<i>246</i>	<i>59</i>	<i>6</i>		
8	40	<i>274.93</i>	<i>0.44</i>	<i>2.33</i>	<i>69</i>	<i>307</i>						
9		<i>278.75</i>	<i>0.40</i>	<i>2.12</i>	<i>69</i>	<i>306</i>	<i>250</i>	<i>248</i>	<i>60</i>	<i>6</i>		
10	50	<i>282.54</i>	<i>0.39</i>	<i>2.07</i>	<i>69</i>	<i>306</i>					<i>10.0</i>	<i>9.8</i>
11		<i>286.18</i>	<i>0.36</i>	<i>1.92</i>	<i>70</i>	<i>302</i>	<i>249</i>	<i>248</i>	<i>62</i>	<i>6</i>		
12	<i>1055</i>	<i>289.62</i>	<i>0.32</i>	<i>1.72</i>	<i>70</i>	<i>299</i>						

*Testo #2*

4A

<b>METRO VANCOUVER WTE - BURNABY B.C.</b>				NOZZLE <i>G-304</i>	DIAMETER, IN. <i>0.3034</i>	IMPINGER	INITIAL	FINAL	TOTAL GAIN
				PROBE <i>7' ALGVL0</i>	Cp <i>0.8568</i>	VOLUMES	(mL)	(mL)	(mL)
SOURCE <i>Unit #</i>						Imp. #1	<i>0</i>	<i>234</i>	
PARAMETER / RUN No <i>Metals / particulate / R-3</i>	PORT LENGTH					Imp. #2	<i>100</i>	<i>189</i>	
DATE <i>Nov. 18 2025</i>	STATIC PRESSURE, IN. H2O <i>-19.0"</i>					Imp. #3	<i>100</i>	<i>107</i>	
OPERATOR: <i>DS</i>	STACK DIAMETER <i>70.94"</i>					Imp. #4	<i>0</i>	<i>2</i>	
CONTROL UNIT <i>FE 18</i>	Y <i>1.0323</i>	STACK HEIGHT <i>30.0</i>				Imp. #5	<i>100</i>	<i>100</i>	
		ΔH@ <i>1.875</i>				Imp. #6	<i>100</i>	<i>100</i>	
BAROMETRIC PRESSURE, IN. Hg <i>30.06</i>		INITIAL LEAK TEST <i>0.002 @ 15"</i>				Imp. #7	<i>200g</i>		
ASSUMED MOISTURE, Bw <i>15%</i>		FINAL LEAK TEST <i>0.002 @ 15"</i>				Imp. #8			

Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites	
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %
1	<i>11:20</i>	<i>290.340</i>										
2	10	<i>294.12</i>	<i>0.38</i>	<i>2.07</i>	<i>68</i>	<i>285</i>	<i>235</i>	<i>255</i>	<i>42</i>	<i>5</i>	<i>9.5</i>	<i>10.1</i>
3		<i>297.92</i>	<i>0.39</i>	<i>2.09</i>	<i>68</i>	<i>297</i>						
4	20	<i>301.72</i>	<i>0.39</i>	<i>2.09</i>	<i>68</i>	<i>298</i>	<i>242</i>	<i>254</i>	<i>46</i>	<i>5</i>	<i>10.5</i>	<i>9.5</i>
5		<i>305.64</i>	<i>0.42</i>	<i>2.24</i>	<i>68</i>	<i>301</i>						
6	30	<i>309.61</i>	<i>0.43</i>	<i>2.29</i>	<i>69</i>	<i>302</i>	<i>254</i>	<i>252</i>	<i>50</i>	<i>5</i>		
7		<i>313.54</i>	<i>0.42</i>	<i>2.23</i>	<i>68</i>	<i>304</i>						
8	40	<i>317.56</i>	<i>0.44</i>	<i>2.34</i>	<i>68</i>	<i>304</i>	<i>252</i>	<i>254</i>	<i>52</i>	<i>6</i>		
9		<i>321.28</i>	<i>0.38</i>	<i>2.02</i>	<i>68</i>	<i>305</i>						
10	50	<i>328.20</i>	<i>0.42</i>	<i>2.23</i>	<i>68</i>	<i>305</i>	<i>249</i>	<i>250</i>	<i>54</i>	<i>7</i>	<i>9.0</i>	<i>10.6</i>
11		<i>328.98</i>	<i>0.39</i>	<i>2.07</i>	<i>68</i>	<i>304</i>						
12	60	<i>332.72</i>	<i>0.38</i>	<i>2.02</i>	<i>68</i>	<i>302</i>	<i>250</i>	<i>252</i>	<i>52</i>	<i>7</i>		
		<i>336.05</i>	<i>0.30</i>	<i>1.61</i>	<i>68</i>	<i>298</i>						
1		<i>339.38</i>	<i>0.30</i>	<i>1.60</i>	<i>68</i>	<i>299</i>	<i>257</i>	<i>247</i>	<i>52</i>	<i>7</i>		
2	10	<i>342.82</i>	<i>0.32</i>	<i>1.71</i>	<i>69</i>	<i>302</i>					<i>10.5</i>	<i>9.2</i>
3		<i>346.25</i>	<i>0.32</i>	<i>1.70</i>	<i>69</i>	<i>303</i>	<i>235</i>	<i>244</i>	<i>55</i>	<i>7</i>		
4	20	<i>349.56</i>	<i>0.30</i>	<i>1.59</i>	<i>69</i>	<i>305</i>						
5		<i>352.82</i>	<i>0.29</i>	<i>1.54</i>	<i>69</i>	<i>304</i>	<i>245</i>	<i>247</i>	<i>56</i>	<i>7</i>	<i>11.5</i>	<i>8.5</i>
6	30	<i>355.94</i>	<i>0.27</i>	<i>1.43</i>	<i>69</i>	<i>306</i>						
7		<i>359.85</i>	<i>0.42</i>	<i>2.23</i>	<i>68</i>	<i>305</i>	<i>249</i>	<i>250</i>	<i>57</i>	<i>7</i>		
8	40	<i>364.70</i>	<i>0.52</i>	<i>2.75</i>	<i>68</i>	<i>306</i>						
9		<i>368.52</i>	<i>0.51</i>	<i>2.71</i>	<i>68</i>	<i>305</i>	<i>252</i>	<i>248</i>	<i>45</i>	<i>8</i>		
10	50	<i>372.75</i>	<i>0.49</i>	<i>2.60</i>	<i>68</i>	<i>306</i>					<i>10.0</i>	<i>10.0</i>
11		<i>376.85</i>	<i>0.46</i>	<i>2.44</i>	<i>68</i>	<i>305</i>	<i>251</i>	<i>246</i>	<i>48</i>	<i>8</i>		
12	<i>13:21</i>	<i>380.91</i>	<i>0.45</i>	<i>2.41</i>	<i>69</i>	<i>300</i>						

*Testo #2*

4

CLIENT: Metro Van		NOZZLE	DIAMETER, IN.		IMPINGER	INITIAL	FINAL	TOTAL GAIN				
SOURCE: On-site		PROBE	Cp		VOLUMES	(mL)	(mL)	(mL)				
PARAMETER / RUN No: Partic / Metals R1		PORT LENGTH			Imp. #1	1000	148	148				
DATE: 18 MAY 25		STATIC PRESSURE, IN. H2O			Imp. #2	100	229	129				
OPERATOR: JGF/JD		STACK DIAMETER			Imp. #3	100	132	32				
CONTROL UNIT: CAC 1099 Y 9998		STACK HEIGHT			Imp. #4	200	17	17				
BAROMETRIC PRESSURE, IN. Hg: 30.68		INITIAL LEAK TEST: 0.001 @ 15"			Imp. #5	100	105	5				
ASSUMED MOISTURE, Bw: 15%		FINAL LEAK TEST: 0.001 @ 15"			Imp. #6	100	102	2				
Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites	
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %
	10:55	307.243										
1		311.66	1.52	7.67	60	315	250	252	58	3.0		
2		316.01	1.50	7.58	60	309						
3		320.32	1.49	7.54	60	308	251	248	58	3.0	8.90	9.75
4		324.69	1.50	7.60	61	305						
5		328.84	1.46	7.39	61	303	250	249	55	3.5		
6		332.91	1.42	7.10	63	303						
7		336.53	1.34	6.78	61	300	250	250	58	3.5		
8		339.70	1.26	6.57	61	295						
9		342.75	1.24	6.27	61	295	250	251	59	4.0		
10		345.68	1.22	6.17	62	292						
11		348.54	1.21	6.11	62	295	249	257	54	3.5	9.0	10.0
12		351.32	1.20	6.05	62	299						
1		354.86	1.32	6.70	64	294	250	250	58	3.5		
2		358.51	1.34	6.81	64	294						
3		362.15	1.34	6.80	64	297	251	251	54	4.0	8.85	9.55
4		365.68	1.32	6.69	65	300						
5		368.98	1.28	6.48	65	301	250	250	54	4.0		
6		372.61	1.30	6.58	65	302						
7		376.05	1.37	7.20	66	302	250	250	58	4.0		
8		381.37	1.30	7.03	66	303						
9		385.97	1.49	7.63	68	303	250	249	54	4.0	9.90	9.74
10		389.99	1.45	7.39	68	300						
11		393.91	1.40	7.13	68	300	251	250	54	4.0		
12	12:57	397.69	1.35	6.86	69	300						

LK

METRO VANCOUVER WTE - BURNABY B.C.				NOZZLE	G-304	DIAMETER, IN.	0.3034	IMPINGER	INITIAL	FINAL	TOTAL GAIN	
				PROBE	7' ALGARD	Cp	0.8568	VOLUMES	(mL)	(mL)	(mL)	
SOURCE	Unit #2							Imp. #1	0	224	224	
PARAMETER / RUN No	Metals / Particulate / R-2			PORT LENGTH				Imp. #2	100	187	87	
DATE	Nov. 19, 2025			STATIC PRESSURE, IN. H2O				Imp. #3	100	116	16	
OPERATOR:	DS.1			STACK DIAMETER				Imp. #4	0	5	5	
CONTROL UNIT	CAE J099 Y 0.9998			STACK HEIGHT				Imp. #5	100	103	3	
				ΔH@ 1.826				Imp. #6	100	101	1	
BAROMETRIC PRESSURE, IN. Hg	30.01			INITIAL LEAK TEST				Imp. #8	0.002 @ 15"	0.003 @ 15"		
ASSUMED MOISTURE, Bw	15%			FINAL LEAK TEST				Tests #3				
5 Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites	
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %
MAN	08.52	398.667										
1		401.85	0.28	1.40	49	292	256	235	47	3		
2	10	405.78	0.43	2.14	49	295				3	10.5	9.6
3		409.79	0.45	2.23	48	297	254	241	48	3		
4	20	413.88	0.47	2.33	47	296				3		
5		418.02	0.48	2.38	47	295	253	262	49	3		
6	30	421.94	0.43	2.14	48	294				3	10.0	9.83
7		424.95	0.25	1.25	49	292	256	242	50	3		
8	40	427.85	0.23	1.16	50	290				3		
9		430.62	0.21	1.06	50	288	245	252	52	3		
10	50	433.32	0.20	1.01	50	287				3	12.0	7.85
11		436.02	0.20	1.01	50	285	242	250	54	3		
12	60	438.79	0.20	1.02	51	281						
1		441.84	0.26	1.32	52	285	252	256	52	3		
2	10	444.98	0.27	1.37	53	285				3	10.5	9.30
3		448.14	0.27	1.37	54	290	256	257	54	3		
4	20	451.73	0.26	1.32	54	291				3		
5		454.28	0.25	1.25	55	292	256	263	55	3		
6	30	457.20	0.23	1.17	56	292				3	10.5	9.42
7		460.90	0.37	1.88	57	294	256	262	54	4		
8	40	464.89	0.43	2.18	58	295				4		
9		469.03	0.41	2.33	59	295	257	261	56	4		
10	50	473.39	0.51	2.59	60	297				4	11.0	8.83
11		477.46	0.44	2.25	61	294	256	261	57	4		
12	11.55	481.46	0.42	2.17	63	290						

44

METRO VANCOUVER WTE - BURNABY B.C.					NOZZLE	G-304	DIAMETER, IN.	0.3034	IMPINGER	INITIAL	FINAL	TOTAL GAIN	
					PROBE	7' ALBURO	Cp	0.8568	VOLUMES	(mL)	(mL)	(mL)	
SOURCE	Unit #2									Imp. #1	0	196	196
PARAMETER / RUN No	Metals/Particulate / R-3				PORT LENGTH					Imp. #2	100	164	64
DATE	Nov. 19, 2025				STATIC PRESSURE, IN. H2O					Imp. #3	100	115	15
OPERATOR:	DS				STACK DIAMETER					Imp. #4	0	2	2
CONTROL UNIT	CAF 5099 Y 0.9998				STACK HEIGHT					Imp. #5	100	101	1
					ΔH@					Imp. #6	100	101	1
					BAROMETRIC PRESSURE, IN. Hg					Imp. #8	2009	2009	
					ASSUMED MOISTURE, Bw					INITIAL LEAK TEST			
					15%					0.002 @ 15"			
										FINAL LEAK TEST			
										0.003 @ 15"			
S Point ran	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites		
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %	
1		482.206											
1		485.42	0.27	1.40	62	285	242	246	45	4			
2	10	488.69	0.28	1.45	63	287				4	11.0	8.85	
3		491.93	0.28	1.45	63	288	246	249	47	4			
4	20	495.17	0.27	1.39	62	292							
5		498.20	0.24	1.23	63	295	250	250	49	4			
6	30	501.09	0.22	1.13	63	296				4	10.5	9.34	
7		504.88	0.38	1.94	64	298	252	251	52	4			
8	40	508.93	0.44	2.25	64	298							
9		513.09	0.45	2.30	64	298	249	246	54	5			
10	50	517.43	0.50	2.56	64	298				5	11.00	9.05	
11		521.48	0.43	2.20	65	299	251	250	55	5			
12	60	525.42	0.41	2.11	65	295							
1		528.75	0.29	1.49	65	296	256	242	56	6			
2	10	532.70	0.41	2.10	66	298					8.5	11.27	
3		536.80	0.44	2.26	66	298	249	249	55	6			
4	20	540.99	0.46	2.36	66	299							
5		545.32	0.49	2.51	66	298	252	252	54	6			
6	30	549.42	0.44	2.26	66	298				6	9.5	10.21	
7		552.58	0.26	1.33	67	300	254	246	52	4			
8	40	555.62	0.24	1.23	67	301				4			
9		558.52	0.22	1.13	67	299	255	248	53	4			
10	50	561.44	0.22	1.13	68	298					9.5	9.85	
11		564.28	0.21	1.08	68	298	252	247	55	4			
12	14:06	567.08	0.20	1.04	68	292							

16.28 4.66ΔH

4

CLIENT: MURD	NOZZLE G3121	DIAMETER, IN. 3063	IMPINGER VOLUMES	INITIAL (mL)	FINAL (mL)	TOTAL GAIN (mL)
SOURCE: Unit #3	PROBE 7C	Cp 8376	Imp. #1	0	152	152
PARAMETER / RUN No: Metal Partic	PORT LENGTH		Imp. #2	100	212	112
DATE: Nov 19/95	STATIC PRESSURE, IN. H2O	18.00	Imp. #3	100	116	16
OPERATOR: CLF	STACK DIAMETER	78.9	Imp. #4	0	12	12
CONTROL UNIT: AU 15 Y 9860	STACK HEIGHT	30'	Imp. #5	100	103	3
			Imp. #6	100	102	2
BAROMETRIC PRESSURE, IN. Hg: 29.95	INITIAL LEAK TEST	0.002 @ 15"	Upstream Diameters			
ASSUMED MOISTURE, Bw: 15%	FINAL LEAK TEST	0.002 @ 15"	Downstream Diameters			

Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites	
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %
1	11:30	765.400	45	2.10	55	302	250	250	52	5		
2		764.15	52	2.42	56	303	250	250	52	5	10.0	9.8
3		778.60	52	2.42	56	304	250	250	52	6		
4		783.10	50	2.33	58	304	250	250	52	6		
5		787.44	47	2.19	58	304	250	250	52	6		
6		794.52	42	1.96	58	303	250	250	51	6	10.0	10.0
7		794.79	27	1.26	60	303	250	250	51	6	10.0	10.0
8		798.06	27	1.26	62	302	250	250	51	6		
9		801.14	24	1.02	62	300	250	250	51	5		
10		803.95	20	0.83	62	298	250	250	50	4		
11		806.76	20	0.83	62	299	250	250	50	4		
12		809.57	18	0.81	63	300	250	250	50	4	10.0	9.9
13		812.82	30	1.40	64	303	250	250	50	5		
14		816.38	32	1.49	64	302	250	250	50	5		
15		819.70	26	1.20	64	303	250	250	48	5	10.0	10.1
16		823.22	26	1.20	65	304	250	250	48	5		
17		826.92	26	1.21	66	304	250	250	48	5		
18		829.71	26	1.20	68	305	250	250	50	5		
19		833.70	45	2.10	67	303	250	250	50	5		
20		837.70	52	2.42	68	304	250	250	50	4	10.0	10.0
21		841.92	51	2.52	68	304	250	250	50	4		
22		847.13	51	2.52	68	302	250	250	50	4		
23	13:34	851.24	55	2.61	69	300	250	250	48	4		
24		856.77	52	2.42	69	298	250	250	48	4		

CA

METRO VANCOUVER WTE - BURNABY B.C.				NOZZLE	G-304	DIAMETER, IN.	0.3039	IMPINGER	INITIAL	FINAL	TOTAL GAIN	
				PROBE	7' ALGARD	Cp	0.8568	VOLUMES	(mL)	(mL)	(mL)	
SOURCE	Unit #3							Imp. #1	0	190		
PARAMETER / RUN No	Metals/Particulate / R-2			PORT LENGTH				Imp. #2	100	167		
DATE	NOV. 20, 2025			STATIC PRESSURE, IN. H2O	-19.5"			Imp. #3	100	145		
OPERATOR:	DS			STACK DIAMETER	70.9"			Imp. #4	0	12		
CONTROL UNIT	AVIS			STACK HEIGHT	30.0			Imp. #5	100	103		
				Y	0.9986			Imp. #6	100	101		
				ΔH@	1.517			Imp. #7	200g			
BAROMETRIC PRESSURE, IN. Hg	29.97			INITIAL LEAK TEST	0.004 @ 15"			Imp. #8				
ASSUMED MOISTURE, Bw	15%			FINAL LEAK TEST	0.003 @ 15"							
											Test #4 (New)	
Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites	
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %
1	0905	857.448										
2	10	862.28	0.62	2.63	60	297	260	251	47	4		
3		867.25	0.66	2.48	59	298					9.5	10.5
4	20	872.28	0.68	2.85	59	301	249	255	48	4		
5		877.16	0.64	2.68	60	302						
6	30	881.96	0.62	2.60	60	302	249	256	50	4		
7		886.48	0.55	2.30	60	302					10.0	10.0
8	40	889.98	0.32	1.39	61	300	250	250	52	4		
9		893.45	0.32	1.35	61	299						
10	50	896.68	0.28	1.18	62	299	250	250	54	3		
11		899.85	0.26	1.10	62	300						
12	60	902.88	0.24	1.02	62	295	252	249	52	3	9.5	10.2
		905.78	0.22	0.94	62	297						
1		909.06	0.28	1.20	64	290	250	250	50	3.5		
2	10	912.28	0.27	1.15	65	295					9.5	10.4
3		915.56	0.28	1.19	66	297	249	248	49	4		
4	20	918.89	0.29	1.24	66	298						
5		922.23	0.29	1.24	67	299	251	250	47	4		
6	30	925.90	0.35	1.49	68	300						
7		930.20	0.48	2.04	69	303	250	251	46	5	9.5	10.0
8	40	934.69	0.52	2.23	70	299						
9		939.44	0.58	2.48	70	300	251	248	50	5		
10	50	944.30	0.61	2.61	70	300						
11		948.98	0.56	2.42	71	296	252	250	52	5	9.5	10.2
12	1106	953.50	0.52	2.25	71	292						

4A

CLIENT: <b>M.V. W.T.E</b>	NOZZLE <b>G-304</b> DIAMETER, IN. <b>0.3034</b>	IMPINGER	INITIAL	FINAL	TOTAL GAIN
SOURCE: <b>Unit #3</b>	PROBE <b>7' ALBURD</b> Cp <b>0.8568</b>	VOLUMES	(mL)	(mL)	(mL)
PARAMETER / RUN No <b>Metals/particulate / R-3</b>	PORT LENGTH	Imp. #1	0	238	238
DATE <b>NOV. 20, 2025</b>	STATIC PRESSURE, IN. H2O <b>-19.5"</b>	Imp. #2	100	187	87
OPERATOR: <b>DS</b>	STACK DIAMETER <b>70.9"</b>	Imp. #3	100	117	17
CONTROL UNIT <b>AUTS</b> Y <b>0.9986</b>	STACK HEIGHT <b>30.0'</b>	Imp. #4	0	2	2
	$\Delta H@$ <b>1.517</b>	Imp. #5	100	101	1
BAROMETRIC PRESSURE, IN. Hg <b>29.97</b>	INITIAL LEAK TEST <b>0.002 @ 15"</b>	Imp. #6	100	100	0
ASSUMED MOISTURE, Bw <b>15%</b>	FINAL LEAK TEST <b>0.002 @ 15"</b>	Upstream Diameter <b>60"</b>			
		Downstream Diameter			

S Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot $\Delta P$ IN. H <sub>2</sub> O	Orifice $\Delta H$ IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites	
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %
1	11:30	954.137										
2		957.68	0.32	1.38	68	290	228	292	46	5		
3		961.28	0.33	1.42	69	293					10.5	9.2
4		964.84	0.33	1.42	69	296	245	245	48	5		
5		968.49	0.39	1.42	69	299						
6		972.11	0.39	1.45	69	302	252	252	50	5		
7		975.99	0.39	1.66	69	302					9.5	10.3
8		981.08	0.67	2.86	70	302	259	258	52	6		
9		986.18	0.66	2.82	70	302						
10		991.17	0.65	2.78	71	302	252	251	54	7		
11		996.08	0.62	2.65	71	303						
12		1000.70	0.60	2.56	71	303	251	253	51	7	9.5	10.4
		1005.70	0.59	2.54	71	298						
		<del>1010.39</del>	<del>0.55</del>	<del>2.53</del>	<del>71</del>	<del>295</del>	<del>251</del>	<del>252</del>	<del>51</del>	<del>7</del>		
1		1010.73	0.65	2.81	71	295	251	253	51	7		
2		1015.80	0.68	2.93	72	297					9.0	10.6
3		1021.04	0.70	3.03	72	296	250	241	52	8		
4		1026.15	0.66	2.81	73	295						
5		1031.23	0.65	2.84	74	291	249	252	54	8		
6		1036.09	0.59	2.58	75	290					9.5	10.5
7		1039.89	0.36	1.58	76	291	252	251	49	8		
8		1043.65	0.35	1.53	77	292						
9		1047.25	0.32	1.40	77	292	251	250	46	6		
10		1050.78	0.31	1.36	77	291					9.5	10.2
11		1054.26	0.30	1.32	78	291	249	249	44	6		
12	13:31	1057.63	0.28	1.23	78	290						





4A

Client MUNTE

Source Unit #1

Date 18 Nov 25

	Run 1	Run 2	Run 3	Run 4	Run 5
Pbar (in. Hg)	30.06	30.06	30.06		
Canister Number	SC01905	SC02288	SC01716		
Controller Number	0A01890	0A01890	0A01890		
Gauge Number					
Initial: Start Time	09:11	10:19	11:26		
Flask Vac. (in. Hg)	-30	-30	-30		
Final: End Time	10:11	11:19	12:26		
Flask Vac. (in. Hg)	-8	-7.5	-8		

Source Unit #2

Date 19 Nov 25

	Run 1	Run 2	Run 3	Run 4	Run 5
Pbar (in. Hg)	29.97	29.92	29.97		
Canister Number	SC00881	SC01890	SC00121		
Controller Number	0A01890	0A01890	0A01890		
Gauge Number					
Initial: Start Time	10:24	11:33	12:45		
Flask Vac. (in. Hg)	-29	-18	-29		
Final: End Time	11:24	12:33	13:45		
Flask Vac. (in. Hg)	-8	-3	-8		

Source Unit #3

Date 20 Nov had canisters

	Run 1	Run 2	Run 3	Run 4	Run 5
Pbar (in. Hg)	29.95	29.97			
Canister Number	SC00884	SC01602			
Controller Number	0A01290	0A01290			
Gauge Number					
Initial: Start Time	09:21	10:30			
Flask Vac. (in. Hg)	-30	-28			
Final: End Time	10:5	11:6			
Flask Vac. (in. Hg)	10:21	11:30			

Source \_\_\_\_\_

Date \_\_\_\_\_

	Run 1	Run 2	Run 3	Run 4	Run 5
Pbar (in. Hg)					
Canister Number					
Controller Number					
Gauge Number					
Initial: Start Time					
Flask Vac. (in. Hg)					
Final: End Time					
Flask Vac. (in. Hg)					

16.02 5.122H

4

A. Lanfranco and Associates Inc.

CLIENT: MURD	NOZZLE G-3121	DIAMETER, IN. 3063	IMPINGER	INITIAL	FINAL	TOTAL GAIN
SOURCE: UNIT #1	PROBE TC	Cp .8376	VOLUMES	(mL)	(mL)	(mL)
PARAMETER / RUN No CR6+ 1	PORT LENGTH		Imp. #1	150	70	
DATE Nov. 20/25	STATIC PRESSURE, IN. H2O -18.75		Imp. #2	75	250	
OPERATOR: C.L. + C.D.	STACK DIAMETER 10.9"		Imp. #3	75	245	
CONTROL UNIT FE18	STACK HEIGHT 30"		Imp. #4		25	
Y 10278			Imp. #5			
ΔH@			Imp. #6			
BAROMETRIC PRESSURE, IN. Hg 30.01	INITIAL LEAK TEST 0.002 @ 15"		Upstream Diameters			
ASSUMED MOISTURE, Bw 15%	FINAL LEAK TEST 0.001 @ 15"		Downstream Diameters			

Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites	
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %
1	12:00	384.500	.24	1.23	58	302	N/A	N/A	58	2		
2		390.64	.28	1.43	60	303			58	2	9.9	10.3
3		394.06	.32	1.64	62	302			60	2		
4		397.47	.32	1.64	60	304	↓	↓	60	2		
5		400.98	.34	1.74	60	304			58	2		
6		404.49	.34	1.74	60	306			60	2		
7		408.92	.54	2.76	60	306			56	6	10.0	10.0
8		413.34	.54	2.76	61	304			58	6		
9		417.81	.57	2.97	62	302			58	6		
10		422.47	.56	2.97	62	302			58			
11		426.52	.46	2.32	62	300			58		10.0	9.98
12		430.52	.44	2.25	62	298						
1		434.19	.37	1.89	63	306	N/A	N/A	56	4		
2		438.10	.45	2.15	63	304			52	4		
3		442.09	.44	2.27	63	304			52	4	10.0	9.70
4		446.22	.47	2.41	64	306			52	4		
5		450.35	.47	2.41	64	306	↓	↓	52	4		
6		454.56	.49	2.51	65	306			50	4		
7		458.77	.49	2.51	66	307			50	4	10.0	9.55
8		462.81	.45	2.30	68	306			50	4		
9		466.82	.47	2.15	68	305			50	4		
10		470.89	.37	1.89	68	302			52	4	9.5	10.50
11		475.96	.35	1.70	69	300						
12	14:05	477.37	.32	1.64	70	297						

02.87

√6.02 5.12ΔH

4A

CLIENT: MWRP					NOZZLE	DIAMETER, IN.		IMPINGER	INITIAL	FINAL	TOTAL GAIN	
SOURCE: Unit #1					PROBE	Cp		VOLUMES	(mL)	(mL)	(mL)	
PARAMETER / RUN No C567-2					PORT LENGTH							
DATE Nov. 21 / 25					STATIC PRESSURE, IN. H2O -18.50							
OPERATOR: W. F. C. D.					STACK DIAMETER 18.94							
CONTROL UNIT FE 18 Y 1.0278					STACK HEIGHT 30							
BAROMETRIC PRESSURE, IN. Hg 30.05					INITIAL LEAK TEST 0.004 @ 15"							
ASSUMED MOISTURE, Bw 15%					FINAL LEAK TEST 0.002 @ 15"							
					Upstream Diameters							
					Downstream Diameters							
					TEST #3							
Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites	
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %
	08:43	479.90										
1		483.32	.32	.64	54	303	N/A	N/A	45	4	10.0	10.05
2		486.84	.34	.68	56	305						
3		490.26	.36	.72	56	306			48	4		
4		493.67	.36	.72	57	306						
5		497.38	.32	.64	56	304			48	4	10.0	9.45
6		500.69	.30	.60	55	304						
7		504.74	.40	.80	57	304			48	6		
8		509.05	.51	1.02	58	304						
9		513.39	.52	1.04	58	304			50	6		
10		517.52	.47	.94	59	302					10.0	9.75
11		521.50	.45	.90	60	300			52	5		
12		525.60	.45	.90	60	297						
1		529.17	.35	.70	62	303			52	5		
2		532.84	.34	.68	62	302						
3		536.52	.34	.68	61	304			52	5		
4		540.09	.30	.60	62	304					10.0	9.50
5		543.66	.35	.70	62	303			54	5		
6		547.42	.30	.60	63	302						
7		551.18	.30	.60	63	303			54	5		
8		555.01	.42	.84	64	303						
9		558.76	.37	.74	64	302			55	4	10.0	10.0
10		562.24	.34	.68	65	301						
11		565.68	.34	.68	64	301			56	4		
12	10:46	569.09	.32	.64	65	300						

16.02 5.12AM

4

CLIENT: <b>NWRD</b>	NOZZLE <b>G3/21</b>	DIAMETER, IN. <b>3.063</b>	IMPINGER	INITIAL	FINAL	TOTAL GAIN
SOURCE: <b>Unit #1</b>	PROBE <b>Fe</b>	Cp <b>.8376</b>	VOLUMES	(mL)	(mL)	(mL)
PARAMETER / RUN No <b>CR67-3</b>	PORT LENGTH		Imp. #1	150	300	
DATE <b>Nov. 21/25</b>	STATIC PRESSURE, IN. H2O <b>-18.50</b>		Imp. #2	15	333	
OPERATOR: <b>CEFC</b>	STACK DIAMETER <b>10.9"</b>		Imp. #3	75	165	
CONTROL UNIT <b>FE 18</b>	STACK HEIGHT <b>30'</b>		Imp. #4			
	$\Delta H@$		Imp. #5			
BAROMETRIC PRESSURE, IN. Hg <b>30.05</b>	INITIAL LEAK TEST <b>0.002 @ 15"</b>		Imp. #6			
ASSUMED MOISTURE, Bw <b>15%</b>	FINAL LEAK TEST <b>0.002 @ 15"</b>		Upstream Diameters			
			Downstream Diameters			

TEST #3

Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot $\Delta P$ IN. H <sub>2</sub> O	Orifice $\Delta H$ IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites	
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %
	11:11	570.850										
1		574.32	.33	1.69	60	300	N/A	N/A	49	3		
2		577.81	.35	1.79	62	302			52	3	10.5	9.33
3		581.46	.35	1.80	60	300			52	3		
4		585.14	.37	1.81	60	299			50	5		
5		589.45	.40	2.05	60	301			50	5		
6		593.87	.42	2.15	61	302			50	5	10.5	9.00
7		596.79	.42	2.15	60	302			50	5		
8		600.60	.40	2.05	60	303			52	4		
9		604.32	.38	1.95	61	301			52	4		
10		607.89	.35	1.79	61	300			52	4		
11		611.30	.32	1.64	62	300			52	4		
12		614.72	.32	1.64	62	299						
1		617.54	.32	1.63	61	295			50	3		
2		620.33	.30	1.52	62	292			50	3	10.0	9.50
3		622.92	.30	1.52	62	290			50	3		
4		625.44	.18	0.92	62	290			52	3		
5		628.43	.24	1.23	62	296			52	3		
6		631.38	.24	1.23	63	294			50	3		
7		635.19	.40	2.05	63	294			50	3		
8		639.32	.47	2.41	64	295			50	3		
9		643.23	.42	2.15	64	295			50	3	10.0	9.26
10		647.05	.42	2.15	64	293			52	3		
11	13:13	650.95	.40	2.05	64	292						
12		654.54	.36	1.84	65	292						

**APPENDIX – F**

**CALIBRATION SHEETS and**

**TECHNICIAN CERTIFICATES**

**A. LANFRANCO and ASSOCIATES INC.**

ENVIRONMENTAL CONSULTANTS

**GLASS NOZZLE DIAMETER CALIBRATION FORM**

Calibrated by: Christian De La O  
Date: 24-Jun-25

Signature: 

Nozzle I.D.	d1	d2	d3	difference	average dia.	average area
	(inch)	(inch)	(inch)	(inch)	(inch)	(ft <sup>2</sup> )
A	0.1270	0.1270	0.1255	0.0015	0.1265	0.0000873
G-165	0.1650	0.1660	0.1645	0.0015	0.1652	0.0001488
G-170	0.1700	0.1710	0.1695	0.0015	0.1702	0.0001579
G-178	0.1760	0.1770	0.1790	0.0030	0.1773	0.0001715
J	0.1881	0.1884	0.1874	0.0010	0.1880	0.0001927
E	0.1950	0.1930	0.1960	0.0030	0.1947	0.0002067
Q	0.2030	0.2040	0.2050	0.0020	0.2040	0.0002270
L	0.2100	0.2070	0.2090	0.0030	0.2087	0.0002375
P-2240	0.2160	0.2155	0.2170	0.0015	0.2162	0.0002549
P-224	0.2160	0.2170	0.2150	0.0020	0.2160	0.0002545
G-221	0.2160	0.2185	0.2190	0.0030	0.2178	0.0002588
G-2232	0.2210	0.2200	0.2215	0.0015	0.2208	0.0002660
P-223	0.2297	0.2296	0.2298	0.0002	0.2297	0.0002878
C-250	0.2500	0.2500	0.2500	0.0000	0.2500	0.0003409
P-250	0.2500	0.2495	0.2505	0.0010	0.2500	0.0003409
P-254	0.2535	0.2535	0.2530	0.0005	0.2533	0.0003500
P-256	0.2520	0.2510	0.2515	0.0010	0.2515	0.0003450
C-280	0.2800	0.2800	0.2800	0.0000	0.2800	0.0004276
C-281	0.2800	0.2820	0.2780	0.0040	0.2800	0.0004276
P-281	0.2820	0.2820	0.2815	0.0005	0.2818	0.0004332
C-282	0.2800	0.2800	0.2800	0.0000	0.2800	0.0004276
C-283	0.2800	0.2800	0.2800	0.0000	0.2800	0.0004276
G-2825	0.2825	0.2820	0.2825	0.0005	0.2823	0.0004348
G-304	0.3038	0.3028	0.3035	0.0010	0.3034	0.0005020
G-3121	0.3055	0.3063	0.3070	0.0015	0.3063	0.0005116
P-307	0.3070	0.3065	0.3075	0.0010	0.3070	0.0005140
G-3092	0.3100	0.3085	0.3090	0.0015	0.3092	0.0005213
P-31	0.3120	0.312	0.3120	0.0000	0.3120	0.0005309
P-311	0.3105	0.3115	0.3110	0.0010	0.3110	0.0005275
P-312	0.3120	0.312	0.3120	0.0000	0.3120	0.0005309
P-314	0.3135	0.3135	0.3140	0.0005	0.3137	0.0005366
P-315	0.3145	0.3145	0.3145	0.0000	0.3145	0.0005395
V-06	0.3210	0.3200	0.3200	0.0010	0.3203	0.0005597
P-34	0.3430	0.3430	0.3430	0.0000	0.3430	0.0006417
343-GS	0.3430	0.3430	0.3430	0.0000	0.3430	0.0006417
P-343	0.3425	0.3420	0.3425	0.0005	0.3423	0.0006392
G-345	0.3470	0.3475	0.3475	0.0005	0.3473	0.0006580
G-349	0.3655	0.3659	0.3665	0.0010	0.3660	0.0007305
G-367	0.3680	0.3660	0.3658	0.0022	0.3666	0.0007330
G-372	0.3669	0.3700	0.3668	0.0032	0.3679	0.0007382
P-375	0.3705	0.3710	0.3709	0.0005	0.3708	0.0007499
C-3751	0.3675	0.3672	0.3673	0.0003	0.3673	0.0007359
P-38	0.3750	0.3750	0.3750	0.0000	0.3750	0.0007670
P-381	0.3800	0.3800	0.3800	0.0000	0.3800	0.0007876
P-401	0.3980	0.3990	0.4000	0.0020	0.3990	0.0008683
P-405	0.4047	0.4055	0.4056	0.0009	0.4053	0.0008958
P-407	0.4065	0.4070	0.4072	0.0007	0.4069	0.0009030
P-406	0.4058	0.4062	0.4060	0.0004	0.4060	0.0008990
P-41	0.4060	0.4060	0.4060	0.0000	0.4060	0.0008990
G-433	0.4360	0.4360	0.4355	0.0005	0.4358	0.0010360
P-47	0.4680	0.4680	0.4680	0.0000	0.4680	0.0011946
P-29	0.4681	0.4683	0.4685	0.0004	0.4683	0.0011961
G-468	0.4700	0.4685	0.4720	0.0035	0.4702	0.0012057
P-7	0.4965	0.4945	0.4975	0.0030	0.4962	0.0013427
G-540	0.5400	0.5410	0.5400	0.0010	0.5403	0.0015924

- (a) D1, D2, D3 = three different nozzle diameters; each diameter must be measured to within (0.025mm) 0.001 in.
- (b) Difference = maximum difference between any two diameters; must be less than or equal to (0.1mm) 0.004 in.
- (c) Average = average of D1, D2 and D3

## Pitot Tube Calibration

Date: 02-Jul-25  
Pbar (in.Hg): 29.94

Temp (R): 539  
Dn (in.): 0.25

Pitot ID: **7A-1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.025	0.035	10.6	0.8367	0.0061
0.140	0.195	25.0	0.8388	0.0040
0.225	0.310	31.7	0.8434	0.0006
0.510	0.695	47.7	0.8481	0.0052
0.820	1.120	60.4	0.8471	0.0043
Average :			0.8428	0.0040

Pitot ID: **ST 8A**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.220	0.300	31.3	0.8478	0.0128
0.340	0.480	38.9	0.8332	0.0018
0.430	0.610	43.8	0.8312	0.0038
0.520	0.740	48.1	0.8299	0.0051
0.630	0.890	53.0	0.8329	0.0021
Average :			0.8350	0.0051

Pitot ID: **7B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.050	0.070	14.9	0.8367	0.0020
0.150	0.205	25.8	0.8468	0.0082
0.260	0.360	34.0	0.8413	0.0027
0.420	0.595	43.3	0.8318	0.0069
0.750	1.050	57.8	0.8367	0.0020
Average :			0.8387	0.0043

Pitot ID: **ST 8B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.050	0.070	14.9	0.8367	0.0091
0.175	0.240	27.9	0.8454	0.0005
0.330	0.450	38.3	0.8478	0.0019
0.560	0.760	49.9	0.8498	0.0040
0.810	1.100	60.1	0.8495	0.0037
Average :			0.8458	0.0038

Pitot ID: **7 AL GVRD-1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.060	0.080	16.3	0.8574	0.0006
0.175	0.235	19.9	0.8543	0.0025
0.320	0.430	25.3	0.8540	0.0028
0.505	0.670	35.8	0.8595	0.0027
0.790	1.050	48.4	0.8587	0.0019
Average :			0.8568	0.0021

Pitot ID: **ST 8C**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.030	0.040	14.9	0.8574	0.0093
0.160	0.220	19.4	0.8443	0.0038
0.255	0.360	29.0	0.8332	0.0149
0.580	0.790	43.1	0.8483	0.0002
0.900	1.200	52.8	0.8574	0.0093
Average :			0.8481	0.0075

Pitot ID: **7C**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.025	0.035	10.6	0.8367	0.0143
0.140	0.190	16.3	0.8498	0.0012
0.255	0.345	33.7	0.8511	0.0001
0.425	0.565	30.5	0.8586	0.0076
0.700	0.930	47.0	0.8589	0.0079
Average :			0.8510	0.0062

Pitot ID:

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
Average :				

\* Average absolute deviation must not exceed 0.01.

Calibrated by: Jack Dennis

Signature: 

Date: July 2, 2024

# A.Lanfranco & Associates inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

**Model #:** AU 15  
**Serial #:** 0028SPC-081915-1

**Date:** 02-Jul-25  
**Barometric Pressure:** 29.84 (in. Hg)  
**Theoretical Critical Vacuum:** 14.08 (in. Hg)

!!!!!!!  
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>/((in.Hg)<sup>3</sup>(min)).  
!!!!!!!

----- DRY GAS METER READINGS -----										-CRITICAL ORIFICE READINGS-				
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps. (deg F)		Final Temps. (deg F)		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature -- Initial Final Average (deg F) (deg F) (deg F)		
3.30	20.00	428.332	449.940	21.608	77.0	77.0	80.0	80.0	73	0.8185	17.0	73.0	75.0	74.0
1.70	16.00	415.837	428.332	12.495	76.0	76.0	77.0	77.0	63	0.5956	20.0	74.0	73.0	73.5
1.00	18.00	393.355	404.309	10.954	74.0	74.0	74.0	74.0	55	0.4606	22.0	71.0	71.0	71.0
0.51	25.00	404.329	415.837	11.508	74.0	74.0	76.0	76.0	48	0.3560	23.0	71.0	74.0	72.5
0.26	17.00	387.945	393.355	5.410	73.0	73.0	74.0	74.0	40	0.2408	24.0	70.0	71.0	70.5

***** RESULTS *****												
-- DRY GAS METER --			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----			
VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (cu ft)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (cu ft)	CALIBRATION FACTOR Y Value (number)	Variation (number)	CALIBRATION FACTOR dH@ Value (in H2O)	Value (mm H2O)	Variation (in H2O)	Ko (value)		
21.293	603.0	21.139	598.6	21.445	0.993	-0.006	1.625	41.27	0.108	0.755		
12.311	348.6	12.311	348.7	12.478	1.000	0.002	1.585	40.26	0.068	0.761		
10.824	306.5	10.736	304.0	10.830	0.992	-0.007	1.559	39.60	0.042	0.774		
11.337	321.1	11.509	325.9	11.643	1.015	0.017	1.332	33.84	-0.185	0.818		
5.341	151.3	5.303	150.2	5.345	0.993	-0.006	1.483	37.67	-0.034	0.793		
Average Y----->					0.9986	Average dH@----->		1.517	38.5	Average Ko----->		0.780

TEMPERATURE CALIBRATION										
Calibration Standard -----> Omega Model CL23A S/N:T-218768										
Reference Set-Point (deg F)	Stack (deg F)	(% diff)	Hot Box (deg F)	(% diff)	Probe (deg F)	(% diff)	Imp Out (deg F)	(% diff)	Aux (deg F)	(% diff)
32	32	0.00%	31	-0.20%	32	0.00%	32	0.00%	31	-0.20%
100	100	0.00%	99	-0.18%	99	-0.18%	100	0.00%	99	-0.18%
300	299	-0.13%	298	-0.26%	298	-0.26%	299	-0.13%	299	-0.13%
500	499	-0.10%	498	-0.21%	498	-0.21%	498	-0.21%	498	-0.21%
1000	998	-0.14%	998	-0.14%	998	-0.14%	998	-0.14%	998	-0.14%

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.  
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.  
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Justin Ching

Signature: 

Date: July 2, 2025

# A.Lanfranco & Associates inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

**Model #:** FE 18  
**Serial #:** 0028-020118-1

Date: 2-Jul-25  
Barometric Pressure: 29.84 (in. Hg)  
Theoretical Critical Vacuum: 14.08 (in. Hg)

!!!!!!!  
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)\*(min)).  
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.75	24.00	558.207	583.030	24.823	71.0	71.0	75.0	75.0	73	0.8185	16.0	73.0	75.0	74.0
1.95	48.00	583.030	619.120	36.090	75.0	75.0	80.0	80.0	63	0.5956	17.0	75.0	78.0	76.5
1.20	25.00	619.120	633.836	14.716	80.0	80.0	81.0	81.0	55	0.4606	18.0	78.0	79.0	78.5
0.69	25.00	633.836	645.061	11.225	81.0	81.0	82.0	82.0	48	0.3560	20.0	79.0	81.0	80.0
0.35	19.00	645.061	650.963	5.902	82.0	82.0	83.0	83.0	40	0.2408	21.0	81.0	83.0	82.0

***** RESULTS *****											
--- DRY GAS METER ---		----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----			
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y		CALIBRATION FACTOR dH@				Ko
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)		(value)
24.741	700.7	25.366	718.4	25.734	1.025	-0.007	1.866	47.38	-0.010		0.705
35.513	1005.7	36.831	1043.0	37.539	1.037	0.005	1.825	46.36	-0.050		0.706
14.374	407.1	14.807	419.3	15.148	1.030	-0.002	1.875	47.62	-0.001		0.702
10.930	309.5	11.429	323.7	11.724	1.046	0.013	1.806	45.87	-0.069		0.705
5.732	162.3	5.864	166.1	6.038	1.023	-0.009	2.006	50.95	0.131		0.684
Average Y----->					1.0323	Average dH@----->	1.875	47.6	Average Ko---->	0.701	

TEMPERATURE CALIBRATION										
Calibration Standard ----->		Omega Model CL23A S/N:T-218768								
Reference Set-Point (deg F)	Stack		Hot Box		Temperature Device Reading Probe		Imp Out		Aux	
	(deg F)	(% diff)	(deg F)	(% diff)	(deg F)	(% diff)	(deg F)	(% diff)	(deg F)	(% diff)
32	32	0.00%	32	0.00%	31	-0.20%	31	-0.20%	31	-0.20%
100	99	-0.18%	99	-0.18%	99	-0.18%	98	-0.36%	98	-0.36%
300	298	-0.26%	299	-0.13%	299	-0.13%	298	-0.26%	298	-0.26%
500	499	-0.10%	498	-0.21%	498	-0.21%	497	-0.31%	498	-0.21%
1000	998	-0.14%	998	-0.14%	997	-0.21%	997	-0.21%	998	-0.14%

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.  
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.  
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Justin Ching

Signature: 

Date: July 2, 2025

# A.Lanfranco & Associates inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

**Model #:** CAE JO99  
**Serial #:** 0028-022210-1

**Date:** 2-Jul-25  
**Barometric Pressure:** 29.84 (in. Hg)  
**Theoretical Critical Vacuum:** 14.08 (in. Hg)

!!!!!!!  
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>/(in.Hg)<sup>2</sup>(min).  
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume	Volume	Volume	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
		Initial (cu ft)	Final (cu ft)	Total (cu ft)	Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.60	28.00	718.802	748.895	30.093	73.0	73.0	76.0	76.0	73	0.8185	17.0	73.0	74.0	73.5
1.95	33.00	748.895	774.661	25.766	76.0	76.0	79.0	79.0	63	0.5956	20.0	74.0	76.0	75.0
1.20	50.00	774.661	805.121	30.460	79.0	79.0	81.0	81.0	55	0.4606	21.0	76.0	81.0	78.5
0.67	25.00	805.121	816.794	11.673	81.0	81.0	82.0	82.0	48	0.3560	23.0	81.0	82.0	81.5
0.33	24.00	816.794	824.342	7.548	82.0	82.0	82.0	82.0	40	0.2408	24.0	82.0	81.0	82.5

***** RESULTS *****													
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----				
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y		CALIBRATION FACTOR dH@					
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)	Ko (value)		
29.899	846.7		29.608	838.5	30.009	0.9903	-0.010	1.784	45.32	-0.042	0.723		
25.354	718.0		25.357	718.1	25.772	1.0001	0.000	1.820	46.23	-0.006	0.710		
29.779	843.4		29.614	838.7	30.296	0.9945	-0.005	1.876	47.66	0.050	0.704		
11.366	321.9		11.413	323.2	11.741	1.0041	0.004	1.759	44.67	-0.068	0.721		
7.336	207.8		7.411	209.9	7.624	1.0101	0.010	1.891	48.04	0.065	0.691		
Average Y----->						0.9998	Average dH@---->		1.826	46.4	Average Ko---->		0.710

TEMPERATURE CALIBRATION										
Calibration Standard ----->		Omega Model CL23A S/N:T-218768								
Reference Set-Point	Stack		Hot Box		Temperature Device Reading Probe		Imp Out		Aux	
(deg F)	(deg F)	(% diff)	(deg F)	(% diff)	(deg F)	(% diff)	(deg F)	(% diff)	(deg F)	(% diff)
32	31	-0.20%	30	-0.41%	32	0.00%	32	0.00%	30	-0.41%
100	99	-0.18%	99	-0.18%	100	0.00%	100	0.00%	98	-0.36%
300	298	-0.26%	299	-0.13%	300	0.00%	299	-0.13%	298	-0.26%
500	498	-0.21%	499	-0.10%	499	-0.10%	499	-0.10%	498	-0.21%
1000	998	-0.14%	998	-0.14%	998	-0.14%	998	-0.14%	997	-0.21%

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.  
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.  
For Temperature Devices, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Justin Ching

Signature: 

Date: July 6, 2025

# A. Lanfranco & Associates Inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

**Model #:** LMU-C  
**Serial #:** Wizit 4615

**Date:** 02-Jul-25  
**Barometric Pressure:** 29.84 (in. Hg)  
**Theoretical Critical Vacuum:** 14.08 (in. Hg)

!!!!!!!  
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>/((in.Hg)<sup>3</sup>(min)).  
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (m <sup>3</sup> )	Volume Final (m <sup>3</sup> )	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
0.00	16.00	169.472	169.677	7.264	76.0	76.0	81.0	81.0	48	0.3560	20.0	78.0	83.0	80.5
0.00	25.00	169.677	170.002	11.467	81.0	81.0	86.0	86.0	48	0.3560	20.0	83.0	86.0	84.5
0.00	17.00	170.002	170.224	7.836	86.0	86.0	87.0	87.0	48	0.3560	20.0	86.0	88.0	87.0

***** RESULTS *****											
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----		
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y		CALIBRATION FACTOR dH@			
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)	
7.101	201.1		7.311	207.0	7.507	1.030	0.004	0.000	0.00	0.000	
11.105	314.5		11.381	322.3	11.773	1.025	-0.001	0.000	0.00	0.000	
7.548	213.8		7.722	218.7	8.024	1.023	-0.003	0.000	0.00	0.000	
<b>Average Y-----&gt;</b>						<b>1.0258</b>	<b>Average dH@-----&gt;</b>		<b>0.0000</b>	<b>0.00</b>	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.  
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.  
For Temperature Devices, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Justin Ching

Signature: 

Date: July 2, 2025

# Calibration Certificate

Date:  
Calibrated by:  
Authorizing Signature:

29-Oct-25  
Daryl Sampson  
*Daryl Sampson*

Instrument Calibrated: Testo 2 (330-2LX)  
Serial #: 03282252  
Customer: ALA

Ambient Conditions: Temperature: 15 °C Barometric Pressure: 102 kPa Relative Humidity: 78%

A. Lanfranco and Associates Inc. certifies that the described instrument has been inspected and tested following calibration procedures in the Environment Canada Report EPS 1/PG/7 (Revised 2005). Below are the observed readings after calibrations are complete. Calibration checks should be completed at least every 6 months.

O <sub>2</sub> Gas	Initial Evaluation				After Calibration				Certified Value (vol %)
	Instrument Reading (vol %)	Calibration Error	Pass/Fail	Notes	Instrument Reading (vol %)	Calibration Error	Pass/Fail	Notes	
Zero	0.04	0.04	Pass		0.04	0.04	Pass		0
O <sub>2</sub>	10.90	0.01	Pass		10.95	0.04	Pass		10.91
Ambient	20.9	0.06	Pass		20.9	0.06	Pass		20.96

Performance Specification: +/- 1% O<sub>2</sub> (absolute diff)

CO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	955	0.2%	Pass		953	0.0%	Pass		952.9
2 Gas	504	2.2%	Pass		496	0.5%	Pass		493.3
3 Gas	249	2.1%	Pass		247	1.4%	Pass		243.5

Performance Specification: +/- 5% of Certified Gas Value

NO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	1	0.3%	Pass		0.5	0.2%	Pass		0
1 Gas	252	1.0%	Pass		251	0.6%	Pass		249.6
2 Gas	89.6	2.5%	Pass		87.8	0.5%	Pass		87.4
3 Gas	46.2	4.2%	Pass		44.1	0.5%	Pass		44.33

Performance Specification: +/- 5% of Certified Gas Value

**NIST Traceable Calibration Gases:**

Cylinder	Cylinder ID Number	Certification Date	Expiration Date	Cylinder Pressure (PSI)	NO (ppm)	O <sub>2</sub> (Vol. %)	CO (ppm)
Zero Gas (N <sub>2</sub> )	72Y	02-May-25	1-May-30	1200	0	0	0
1 Gas	K2K	22-May-24	22-May-32	1150	249.6	0	952.9
2 Gas	DK8	16-Sep-25	16-Sep-33	900	87.4	0	493.3
3 Gas	435	30-May-25	30-May-28	600	44.33	0	243.5
O <sub>2</sub> /CO <sub>2</sub>	LD9	Jul 7, 2025	7-Jul-33	1450	0	10.91	0

Note: National Institute of Standards and Technology traceable certificates are available upon request.

# Calibration Certificate

Date: 29-Oct-25  
 Calibrated by: Daryl Sampson  
 Authorizing Signature: *Daryl Sampson*

Instrument Calibrated: Testo 3 (340)  
 Serial #: 64057016  
 Customer: ALA

Ambient Conditions: Temperature: 15 °C Barometric Pressure: 102.1 kPa Relative Humidity: 77%

A. Lanfranco and Associates Inc. certifies that the described instrument has been inspected and tested following calibration procedures in the Environment Canada Report EPS 1/PG/7 (Revised 2005). Below are the observed readings after calibrations are complete. Calibration checks should be completed at least every 6 months.

O <sub>2</sub> Gas	Initial Evaluation				After Calibration				Certified Value (vol %)
	Instrument Reading (vol %)	Calibration Error	Pass/Fail	Notes	Instrument Reading (vol %)	Calibration Error	Pass/Fail	Notes	
Zero	0.1	0.10	Pass		0.0	0.10	Pass		0
O <sub>2</sub>	10.90	0.01	Pass		10.89	0.02	Pass		10.91
Ambient	20.86	0.10	Pass		20.9	0.06	Pass		20.96

Performance Specification: +/- 1% O<sub>2</sub> (absolute diff)

CO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	1	0.3%	Pass		2	0.0%	Pass		0
1 Gas	957	0.4%	Pass		955	0.2%	Pass		952.9
2 Gas	499	1.2%	Pass		493	0.1%	Pass		493.3
3 Gas	246	1.0%	Pass		244	0.2%	Pass		243.5

Performance Specification: +/- 5% of Certified Gas Value

NO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	2	0.3%	Pass		1	0.0%	Pass		0
1 Gas	252	1.0%	Pass		251	0.6%	Pass		249.6
2 Gas	90	3.0%	Pass		88	0.7%	Pass		87.4
3 Gas	47	6.0%	Fail		45	1.5%	Pass		44.33

Performance Specification: +/- 5% of Certified Gas Value

**NIST Traceable Calibration Gases:**

Cylinder	Cylinder ID Number	Certification Date	Expiration Date	Cylinder Pressure (PSI)	NO (ppm)	O <sub>2</sub> (Vol. %)	CO (ppm)
Zero Gas (N <sub>2</sub> )	72Y	02-May-25	1-May-30	1200	0	0	0
1 Gas	K2K	22-May-24	22-May-32	1150	249.6	0	952.9
2 Gas	DK8	16-Sep-25	16-Sep-33	900	87.4	0	493.3
3 Gas	435	30-May-25	30-May-28	600	44.33	0	243.5
O <sub>2</sub> /CO <sub>2</sub>	LD9	Jul 7, 2025	7-Jul-33	1450	0	10.91	0

Note: National Institute of Standards and Technology traceable certificates are available upon request.

# Kalibrier-Protokoll

Certificate of conformity • Protocole d'étalonnage  
Certificato di taratura • Informe de calibración



Gerät / Module type / Type de modèle / Prodotto / Modelo:

T310 II

Seriennummer / Serial No. / No. de série / No. Serie strumento / n° de serie:

64910282

Temperaturmessung Temperature measurement Mesure de température Misura della temperatura Medición de temperatura	Sollwert Reference Référence Valore campione Referencia	Istwert Actual value Valeur effective Valore misurato Valor medido	zulässige Abweichung Permissible deviation Différence admissible Scostamento ammesso Desviación permitida
Verbrennungslufttemp./ Ambient air temp. Température d'air de combustion Temperatura aria comburente Temperatura ambiente	60.1 °C	60.1 °C	± 1.0 °C
Abgastemperatur / Flue gas temperature Température des fumées Temperatura fumi Temperatura gases	60.1 °C	60.1 °C	± 1.0 °C
Druckmessung Pressure measurement Mesure de pression Misura della tiraggio Medición de presión	1.00 hPa	1.00 hPa	± 0.50 hPa

## Gasmeßwerte / Gas values / Valeurs de gaz mesurées / Parametri di misura dei gas / Gases patrón

Reg. Nr. Reg. No. Reg. No. Num. reg. n° certi	Gas Gas Gaz Gas Gas	Sollwert Reference Référence Valore campione Referencia	Istwert Actual value Valeur effective Valore misurato Valor medido	zulässige Abweichung Permissible deviation Différence admissible Scostamento ammesso Desviación permitida
409D704082	O2	2.5 %	2.5 %	±0.2 %
408D328084	O2	0.0 %	0.0 %	±0.2 %
409D704082	CO	700 ppm	701 ppm	±35 ppm
408D328084	CO	100 ppm	103 ppm	±20 ppm

Datum/Date/Date/Data/Fecha: 13.02.2025 Prüfer/Inspector/Vérificateur/Verificatore/Verificador: 7092

**A. LANFRANCO and ASSOCIATES INC.**  
**ENVIRONMENTAL CONSULTANTS**

**TEMPERATURE CALIBRATION FORM**

Calibrated by: Christian De La O  
 Date: 2-Jul-25

Signature: 

**TEMPERATURE DEVICE CALIBRATIONS**

Reference Device Model CL23A Calibrator			Temperature Settings (degrees F)													
			32		100		200		300		500		800		1700	
Device	ALA #	Serial #	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation
TPI 341K	7	20314590036		-6.51%		-17.87%		-30.32%		-39.49%		-52.10%		-63.51%		-78.72%
TPI 341K	8	20313490047	30.8	-0.24%	99.1	-0.16%	198.6	-0.21%	298.1	-0.25%	497.7	-0.24%	796.9	-0.25%	1695	-0.23%
TPI 341K	11	20345510024	31.6	-0.08%	99.7	-0.05%	199.7	-0.05%	299.1	-0.12%	498.5	-0.16%	798.5	-0.12%	1696	-0.19%
TPI 341K	12	20345510031		-6.51%		-17.87%		-30.32%		-39.49%		-52.10%		-63.51%		-78.72%
TPI 341K	18	20329480036		-6.51%		-17.87%		-30.32%		-39.49%		-52.10%		-63.51%		-78.72%
TPI 341K	20	20329480013	31	-0.20%	99.5	-0.09%	199.1	-0.14%	298.6	-0.18%	498.6	-0.15%	798.2	-0.14%	1698	-0.09%
TPI 341K	22	20329480041	30.4	-0.33%	98.4	-0.29%	198	-0.30%	298.1	-0.25%	497.4	-0.27%	797.3	-0.21%	1696	-0.19%
TPI 341K	24	20142030017		-6.51%		-17.87%		-30.32%		-39.49%		-52.10%		-63.51%		-78.72%
TPI 341K	26	20345510036		-6.51%		-17.87%		-30.32%		-39.49%		-52.10%		-63.51%		-78.72%
TPI 341K	28	20142030009		-6.51%		-17.87%		-30.32%		-39.49%		-52.10%		-63.51%		-78.72%
TPI 341K	30	20345510023		-6.51%		-17.87%		-30.32%		-39.49%		-52.10%		-63.51%		-78.72%
TPI 341K	32	20142030028	28.9	-0.63%	97.6	-0.43%	198.4	-0.24%	298.4	-0.21%	498.5	-0.16%	798.4	-0.13%	1697	-0.14%

Reference device is a NIST certified digital thermocouple calibrator

Variation expressed as a percentage of the absolute temperature must be within 1.5 %

**BAROMETER CALIBRATION FORM**

Device	Cal Date	Pbar Env Canada		Device (inches of Hg)		Difference
		(kPa)	(inches of Hg)	Reading	Elevation Corrected	(Env Can - Elv Corr)
LA	2-Jul-25	101.4	29.95	29.88	29.95	0.00
DS	2-Jul-25	101.4	29.95	29.86	29.93	0.02
CL	2-Jul-25	101.4	29.95	29.88	29.95	0.00
JC	2-Jul-25	101.4	29.95	29.88	29.95	0.00
LF	2-Jul-25	101.4	29.95	29.85	29.92	0.03
SV	2-Jul-25	101.4	29.95	29.85	29.92	0.03
CDO	2-Jul-25	101.4	29.95	29.85	29.92	0.03
JG	2-Jul-25	101.4	29.95	29.85	29.92	0.03
ML	2-Jul-25	101.4	29.95	29.85	29.92	0.03
JD	2-Jul-25	101.4	29.95	29.87	29.94	0.01

Calibrated by: Louis Agassiz      Signature:       Date: 02-Jul-25

**Performance Specification is**

**Device Corrected for Elevation must be +/- 0.1 " Hg of ENV CANADA SEA-LEVEL Pbar**

Enter Environment Canada Pressure from their website for Vancouver (link below) and the reading from your barometer on the ground floor of the office.

[https://weather.gc.ca/city/pages/bc-74\\_metric\\_e.html](https://weather.gc.ca/city/pages/bc-74_metric_e.html)

# Canadian Association for Laboratory Accreditation Inc.

## Certificate of Accreditation

A. Lanfranco and Associates Inc.  
101 - 9488 - 189th Street  
Surrey, British Columbia



This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017.  
This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated April 2017).



Accreditation No.: 1004232  
Issued On: 5/15/2025  
Accreditation Date: 2/5/2021  
Expiry Date: 11/14/2027

A handwritten signature in black ink, appearing to read "K. McKinley", written over a thin horizontal line.

President and CEO



This certificate is the property of the Canadian Association for Laboratory Accreditation Inc. and must be returned on request; reproduction must follow policy in place at date of issue.  
For the specific tests to which this accreditation applies, please refer to the laboratory's scope of accreditation at [www.cala.ca](http://www.cala.ca).



# MOUNT ROYAL COLLEGE

Faculty of Continuing Education and Extension

**Carter Lanfranco**

has successfully completed

**Stack Sampling**

May 2009

Date

Dean  
Faculty of Continuing Education and Extension



Conflict of Interest Disclosure Statement

A qualified professional <sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

Declaration

I Carter Lanfranco, as a member of Air and Waste Management Association declare

**Select one of the following:**

Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.



Real or perceived conflict of interest

Description and nature of conflict(s):

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.


In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.


This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

X 

Print name: Carter Lanfranco

Witnessed by:

X 

Print name: Mark Lanfranco

Date: Dec. 16, 2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who  
a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and  
b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.



Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional Carter Lanfanco
Title Chief operations officer / analyst

2. Are you a registered member of a professional association in B.C.? [ ] Yes [X] No

Name of Association: Registration #

3. Brief description of professional services:

This declaration of competency is collected under section 26(c) of the Freedom of Information and Protection of Privacy Act for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature: [Handwritten Signature]
Print Name: Carter Lanfanco

Witnessed by: [Handwritten Signature]
Print Name: Shawn Harrington

Date signed: Dec. 7/2020

1 Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who
a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

# Christian Gonzalo De La O

has successfully completed

## Stack Sampling

The Faculty of Continuing Education  
Mount Royal University

30 hours | May 1, 2024



---

Dimitra Fotopoulos, Vice Dean  
Professional and Continuing Education

## Conflict of Interest Disclosure Statement

A qualified professional <sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy (“ministry”), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person’s business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

### Declaration

I Christian De La O, as a member of Air and Waste Management Association  
declare

#### **Select one of the following:**

Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.

Real or perceived conflict of interest

Description and nature of conflict(s):

---

---

---

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

---

---


---

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:


X



Print name: Christian De La O

Witnessed by:

X



Print name: Mark Lanfranco

Date: ██████████ 29 August 2024

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

## Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.


1. Name of Qualified Professional Christian De La O  
Title Environmental Air Quality Technician
2. Are you a registered member of a professional association in B.C.?  Yes  No  
Name of Association: \_\_\_\_\_ Registration # \_\_\_\_\_
3. Brief description of professional services:  
Environmental consulting, specializing in air and atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

## Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature:

X  \_\_\_\_\_

Print Name: Christian De La O

Witnessed by:

X  \_\_\_\_\_

Print Name: Daryl Sampson

Date signed: 29 August 2024

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.



# **MOUNT ROYAL COLLEGE**

**Faculty of Continuing Education and Extension**

**Daryl Sampson**

has successfully completed

The program of studies and is awarded the certificate in

**STACK SAMPLING**

**May 2005**

Date

Dean  
Faculty of Continuing Education and Extension

## Conflict of Interest Disclosure Statement

A qualified professional <sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy (“ministry”), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person’s business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

### Declaration

I Daryl Sampson, as a member of Air and Waste Management Association  
declare

#### **Select one of the following:**

- Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.



Real or perceived conflict of interest

Description and nature of conflict(s):

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

X Daryl Sampson

Print name: Daryl Sampson

Date: Dec.18, 2020

Witnessed by:

X 

Print name: Mark Lanfranco

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who  
a) is registered in British Columbia with a professional association, is acting under that organization’s code of ethics, and is subject to disciplinary action by that association, and  
b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

## Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional Daryl Sampson  
Title Senior Environmental Technician/Project Manager
2. Are you a registered member of a professional association in B.C.?  Yes  No  
Name of Association: \_\_\_\_\_ Registration # \_\_\_\_\_
3. Brief description of professional services:  
Environmental consulting, specializing in air and atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

## Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature:

X *Daryl Sampson*

Print Name: Daryl Sampson

Witnessed by:

X *Louis Agassiz*

Print Name: Louis Agassiz

Date signed: November 23, 2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

# MOUNT ROYAL UNIVERSITY

Faculty of Continuing Education and Extension

**Jeremy Shawn Gibbs**

has successfully completed

**Stack Sampling**

35 Hours / 2019

May 22, 2019

*Date*

*BSU*  
Dean

*Faculty of Continuing Education and Extension*





Conflict of Interest Disclosure Statement

A qualified professional <sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

Declaration

I Jeremy Gibbs, as a member of Air and Waste Management Association declare

**Select one of the following:**

Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.



Real or perceived conflict of interest

Description and nature of conflict(s):

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

X

Print name:

Jeremy Gibbs

Witnessed by:

X

Print name:

Mark Lanfranco

Date: Dec. 16, 2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who  
a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and  
b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.



Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional Jeremy Gibbs  
Title Environmental technician

2. Are you a registered member of a professional association in B.C.?  Yes  No  
Name of Association: \_\_\_\_\_ Registration # \_\_\_\_\_

3. Brief description of professional services:  
Environmental Consultant specialize in air and atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature: [Handwritten Signature]

Witnessed by: [Handwritten Signature]

Print Name: Jeremy Gibbs

Print Name: Connor Lean

Date signed: Nov 1, 2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who  
a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and  
b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

# Justin Ching

has successfully completed

## Stack Sampling

The Faculty of Continuing Education  
Mount Royal University

30 hours | May 26, 2023



---

Dimitra Fotopoulos, Vice Dean  
Professional and Continuing Education

## Conflict of Interest Disclosure Statement

A qualified professional <sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy (“ministry”), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person’s business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

### Declaration

I, Justin Ching, as a member of Air and Waste Management Association  
declare

#### **Select one of the following:**

- Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.

Real or perceived conflict of interest

Description and nature of conflict(s):

---

---

---

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

---

---

---

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

X Justin Ching

Print name: Justin Ching

Witnessed by:

X Mark Lanfranco

Print name: Mark Lanfranco

Date: June 28, 2023

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

## Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional Justin Ching  
Title Environmental Technician
2. Are you a registered member of a professional association in B.C.?  Yes  No  
Name of Association: \_\_\_\_\_ Registration # \_\_\_\_\_
3. Brief description of professional services:  
Environmental Technician - specialising in air and atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

## Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature:

x Justin Ching

Print Name: Justin Ching

Witnessed by:

x Daryl Sampson

Print Name: Daryl Sampson

Date signed: June 28, 2023

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

# Liam Forrer

has successfully completed

## Stack Sampling

The Faculty of Continuing Education  
Mount Royal University

30 hours | May 26, 2023



---

Dimitra Fotopoulos, Vice Dean  
Professional and Continuing Education

## Conflict of Interest Disclosure Statement

A qualified professional <sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy (“ministry”), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person’s business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

### Declaration

I Liam Forrer, as a member of Air and Waste Management Association  
declare

#### **Select one of the following:**

- Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.



Real or perceived conflict of interest

Description and nature of conflict(s):

---

---

---

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

---

---

---

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

Liam Forrer

Print name: Liam Forrer

Date: July 12, 2023

Witnessed by:



Print name: Mark Lanfranco

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who  
a) is registered in British Columbia with a professional association, is acting under that organization’s code of ethics, and is subject to disciplinary action by that association, and  
b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

## Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional Liam Forrer  
Title Environmental Technician
2. Are you a registered member of a professional association in B.C.?  Yes  No  
Name of Association: \_\_\_\_\_ Registration # \_\_\_\_\_
3. Brief description of professional services:  
Environmental consulting, specializing in air and atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

## Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature:

x Liam Forrer

Print Name: Liam Forrer

Witnessed by:

x Daryl Sampson

Print Name: Daryl Sampson

Date signed: July 12, 2023

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.