

2024 Annual Report

The 2024 Annual Report was sent to the Ministry of Environment and Climate Change Strategy on March 25, 2025.



Metro Vancouver - Waste-to-Energy Facility

CONTINUOUS EMISSION MONITORING SYSTEM

2024 Annual Emission Report

1. ANNUAL SUMMARY REPORT

Parameter	Limit (mg/m ³)	Compliance Period	Maximum Measurement (mg/m ³)		
			Unit 1	Unit 2	Unit 3
Carbon Monoxide (CO)	50	24 hr	43.8	43.0	48.7
Sulphur Dioxide (SO ₂)	200	24 hr ⁽¹⁾	146.6	140.7	136.4
Nitrogen Oxides (NO _x)	190	24 hr	153.6	161.7	175.6
			Annual Average (mg/m ³)		
			Unit 1	Unit 2	Unit 3
Opacity			1.0	0.7	1.2
Carbon Monoxide (CO)			28.9	27.8	27.1
Sulphur Dioxide (SO ₂)			64.4	73.4	66.3
Nitrogen Oxides (NO _x)			128.5	130.0	137.0

1. Interim Discharge Limits will apply until and including the following dates, at which point the Discharge Limits will apply:

a. HCl – March 3, 2025

b. SO₂ – March 3, 2025

2. ANNUAL EXCEEDANCE REPORT

2.a. Discharge Limit Exceedances

Unit	Compliance Parameter	Discharge Limit (mg/dscm)	Date	Exceedance Level

2.b. 30 Minute Response Limit Exceedances Summary

	Carbon Monoxide			Total Hydrocarbons		
	Unit 1	Unit 2	Unit 3	Unit 1	Unit 2	Unit 3
January	1.5	3.5	3.5			
February	4.5	6	5			
March	3	2	1.5			
April	4	2.5	5			
May	2.5	3	5			
June	3.5	4	11			0.5
July	3	2.5	7.5			
August	3	2	2.5			
September	3.5	6	2.5			
October	6	3	4	0.5		
November	6	6	4.5			
December	3	5	4.5			
Total	43.5	45.5	56.5	0.5	0	0.5

Nitrous Oxides				Opacity		
	Unit 1	Unit 2	Unit 3	Unit 1	Unit 2	Unit 3
January			0.5			
February						0.5
March						
April					0.5	
May						
June						
July				0.5		
August	0.5					
September						
October						
November						
December						
Total	0.5	0	0.5	0.5	0.5	0.5

2.c. Transient Conditions

Gas Burners unavailable during shutdown and furnace temperature average below 800C

Unit	Duration	Date	Time
#2	59 min	30-Sep-24	23:00-23:59

3. ANALYZER AVAILABILITY

Analyzer	Required Availability (% hours per annum)	Averaging Period	Annual Availability		
			Unit 1	Unit 2	Unit 3
Opacity	95	Hour	100	100	100
Oxygen	95	Hour	98	99	98
Carbon Monoxide (CO)	95	Hour	98	99	98
Sulphur Dioxide (SO ₂)	95	Hour	98	99	98
Nitrogen Oxides (NO _x)	95	Hour	98	99	98

4. ANNUAL MANUAL STACK TESTING SUMMARY

Manual Stack Tests:	Units	Discharge Regulatory Limit	Maximum Value		
			Unit 1	Unit 2	Unit 3
Particulate Matter	mg/dscm	9	1.37	1.12	1.72
HF	mg/dscm	1	0.08	0.08	0.07
Hg	ug/dscm	20	0.11	0.06	0.23
Cd	ug/dscm	7	0.44	0.22	0.22
Sum of Lead (Pb), Arsenic (As), Chromium (Cr)	ug/dscm	64	7.44	6.89	6.91
Trace Organics Tests:					Unit 3
PCDD/PCDF	ng/dscm	0.08			0.004
Chlorophenols	ug/dscm	1			0.009
Chlorobenzenes	ug/dscm	1			0.307
PAH's	ug/dscm	5			0.079
PCB	ug/dscm	1			0.024

Manual Stack Tests:	Units	Annual Average		
		Unit 1	Unit 2	Unit 3
Particulate Matter	mg/dscm	0.98	0.71	1.05
HF	mg/dscm	0.04	0.03	0.04
Hg	ug/dscm	0.07	0.05	0.10
Cd	ug/dscm	0.29	0.12	0.14
Sum of Lead (Pb), Arsenic (As), Chromium (Cr)	ug/dscm	4.83	4.76	5.01

5. SHUTDOWN REPORT

Reason	Hours		
	Unit 1	Unit 2	Unit 3
Annual Scheduled Maintenance Outages	290.65	317.11	271.07
Unplanned Maintenance Outages	440.18	266.56	330.93
Waste Quality	9.57	24.81	12.11
Boiler Wash	332.05	177.85	180.52

6. FACILITY BYPASS AND EMERGENCY/SPILL EVENT REPORT

Date/Time	Duration	Cause	Action Taken

7. OVERVIEW OF PLANT PERFORMANCE AND OPERATIONAL INFORMATION

Summaries/interpretation of compliance and complaints information	1 transient condition exceedance reported in section 2. No other compliance issues reported.
	No complaints were received.
Status of Operations and Maintenance of Various Equipment	Scheduled outages were completed on all three boilers. The turbogenerator returned to service on July 13, 2024 and ran with an annual availability of 47.38%. There were a total of 2 turbogenerator outages resulting in 2.0 hours offline.
Incidences of Emergencies and Response Measures Implemented	No incidents reported.
Evaluation of monitoring programs	All monitoring programs were completed as per the Operational Certificate. Manual stack testing was completed on February 12-15, May 16-17, Jun 4-5, July 16-19, July 24-26 (semi-volatile organics), Nov 18-20, and Dec 12-13, 2024.
Bottom ash and fly ash disposal method	Both bottom and fly ash are treated with a patented system used throughout the industry to inhibit metals leaching. Bottom ash was disposed at the Vancouver Landfill. Fly ash was disposed at the Columbia Ridge Landfill and Recycling Center located in Arlington, Oregon. Prior to hauling, each fly ash load is tested by an independent laboratory to confirm the material meets disposal criteria. 14 loads did not meet the criteria for disposal and were reprocessed on site. The failed loads resulted from an inconsistent fly ash flow which impacted the fly ash to phosphoric acid mixing ratio. The remaining fly ash loads were released for disposal.

Overview of Plant Performance	Plant Availability	%	90.0%
	Waste Received	Tonnes	243,168
	Waste Processed	Tonnes	242,333
	Energy Generated	MWh	76,030
	Natural Gas Consumed	GJ	80,230
	Bottom Ash	Tonnes	39,563
	Fly Ash	Tonnes	8,637
	Ferrous Metal	Tonnes	5,207
	Non-Ferrous Metal	Tonnes	300
Waste Received	Municipal Garbage	Tonnes	224,900
	International Airline Waste	Tonnes	3,080
	International Marine Waste	Tonnes	5,881
	Police loads	Tonnes	98.4
	Pharmaceuticals	Tonnes	88.1
	Pocket Coil Mattresses	Tonnes	26.8
	Special Handle Waste	Tonnes	2,226
	Wastewater Treatment Plant Residuals	Tonnes	6,830
	Out of Region Waste	Tonnes	37.2
Summary of operation; performance, and maintenance of emissions control devices			
CEMS Calibration Data	Calibrated	Description of Calibration	
Opacity	Daily	RATA tests on Units 1, 2, and 3 were completed June 11-13, results were within the requirements. Analysers are calibrated daily against a zero value and a known reference value.	
Oxygen	Daily		
CO	Daily		
SO2	Daily		
NOx	Daily		

Metro Vancouver - Waste-to-Energy Facility

CONTINUOUS EMISSION MONITORING SYSTEM

2024 Annual Emission Report

1. ANNUAL SUMMARY REPORT

Parameter	Limit (mg/m ³)	Compliance Period	Maximum Measurement (mg/m ³)		
			Unit 1	Unit 2	Unit 3
Carbon Monoxide (CO)	50	24 hr	43.8	43.0	48.7
Sulphur Dioxide (SO ₂)	200	24 hr ⁽¹⁾	146.6	140.7	136.4
Nitrogen Oxides (NO _x)	190	24 hr	153.6	161.7	175.6
			Annual Average (mg/m ³)		
			Unit 1	Unit 2	Unit 3
Opacity			1.0	0.7	1.2
Carbon Monoxide (CO)			28.9	27.8	27.1
Sulphur Dioxide (SO ₂)			64.4	73.4	66.3
Nitrogen Oxides (NO _x)			128.5	130.0	137.0

1. Interim Discharge Limits will apply until and including the following dates, at which point the Discharge Limits will apply:

a. HCl – March 3, 2025

b. SO₂ – March 3, 2025

2. ANNUAL EXCEEDANCE REPORT

2.a. Discharge Limit Exceedances

Unit	Compliance Parameter	Discharge Limit (mg/dscm)	Date	Exceedance Level

2.b. 30 Minute Response Limit Exceedances Summary

	Carbon Monoxide			Total Hydrocarbons		
	Unit 1	Unit 2	Unit 3	Unit 1	Unit 2	Unit 3
January	1.5	3.5	3.5			
February	4.5	6	5			
March	3	2	1.5			
April	4	2.5	5			
May	2.5	3	5			
June	3.5	4	11			0.5
July	3	2.5	7.5			
August	3	2	2.5			
September	3.5	6	2.5			
October	6	3	4	0.5		
November	6	6	4.5			
December	3	5	4.5			
Total	43.5	45.5	56.5	0.5	0	0.5

	Nitrous Oxides			Opacity		
	Unit 1	Unit 2	Unit 3	Unit 1	Unit 2	Unit 3
January			0.5			
February						0.5
March						
April					0.5	
May						
June						
July				0.5		
August	0.5					
September						
October						
November						
December						
Total	0.5	0	0.5	0.5	0.5	0.5

2.c. Transient Conditions

Gas Burners unavailable during shutdown and furnace temperature average below 800C

Unit	Duration	Date	Time
#2	59 min	30-Sep-24	23:00-23:59

3. ANALYZER AVAILABILITY

Analyzer	Required Availability (% hours per annum)	Averaging Period	Annual Availability		
			Unit 1	Unit 2	Unit 3
Opacity	95	Hour	100	100	100
Oxygen	95	Hour	98	99	98
Carbon Monoxide (CO)	95	Hour	98	99	98
Sulphur Dioxide (SO ₂)	95	Hour	98	99	98
Nitrogen Oxides (NO _x)	95	Hour	98	99	98

4. ANNUAL MANUAL STACK TESTING SUMMARY

Manual Stack Tests:	Units	Discharge Regulatory Limit	Maximum Value		
			Unit 1	Unit 2	Unit 3
Particulate Matter	mg/dscm	9	1.37	1.12	1.72
HF	mg/dscm	1	0.08	0.08	0.07
Hg	ug/dscm	20	0.11	0.06	0.23
Cd	ug/dscm	7	0.44	0.22	0.22
Sum of Lead (Pb), Arsenic (As), Chromium (Cr)	ug/dscm	64	7.44	6.89	6.91
Trace Organics Tests:					Unit 3
PCDD/PCDF	ng/dscm	0.08			0.004
Chlorophenols	ug/dscm	1			0.009
Chlorobenzenes	ug/dscm	1			0.307
PAH's	ug/dscm	5			0.079
PCB	ug/dscm	1			0.024

Manual Stack Tests:	Units	Annual Average		
		Unit 1	Unit 2	Unit 3
Particulate Matter	mg/dscm	0.98	0.71	1.05
HF	mg/dscm	0.04	0.03	0.04
Hg	ug/dscm	0.07	0.05	0.10
Cd	ug/dscm	0.29	0.12	0.14
Sum of Lead (Pb), Arsenic (As), Chromium (Cr)	ug/dscm	4.83	4.76	5.01

5. SHUTDOWN REPORT

Reason	Hours		
	Unit 1	Unit 2	Unit 3
Annual Scheduled Maintenance Outages	290.65	317.11	271.07
Unplanned Maintenance Outages	440.18	266.56	330.93
Waste Quality	9.57	24.81	12.11
Boiler Wash	332.05	177.85	180.52

6. FACILITY BYPASS AND EMERGENCY/SPILL EVENT REPORT

Date/Time	Duration	Cause	Action Taken

7. OVERVIEW OF PLANT PERFORMANCE AND OPERATIONAL INFORMATION

Summaries/interpretation of compliance and complaints information	1 transient condition exceedance reported in section 2. No other compliance issues reported.
	No complaints were received.
Status of Operations and Maintenance of Various Equipment	Scheduled outages were completed on all three boilers. The turbogenerator returned to service on July 13, 2024 and ran with an annual availability of 47.38%. There were a total of 2 turbogenerator outages resulting in 2.0 hours offline.
Incidences of Emergencies and Response Measures Implemented	No incidents reported.
Evaluation of monitoring programs	All monitoring programs were completed as per the Operational Certificate. Manual stack testing was completed on February 12-15, May 16-17, Jun 4-5, July 16-19, July 24-26 (semi-volatile organics), Nov 18-20, and Dec 12-13, 2024.
Bottom ash and fly ash disposal method	Both bottom and fly ash are treated with a patented system used throughout the industry to inhibit metals leaching. Bottom ash was disposed at the Vancouver Landfill. Fly ash was disposed at the Columbia Ridge Landfill and Recycling Center located in Arlington, Oregon. Prior to hauling, each fly ash load is tested by an independent laboratory to confirm the material meets disposal criteria. 14 loads did not meet the criteria for disposal and were reprocessed on site. The failed loads resulted from an inconsistent fly ash flow which impacted the fly ash to phosphoric acid mixing ratio. The remaining fly ash loads were released for disposal.

Overview of Plant Performance	Plant Availability	%	90.0%
	Waste Received	Tonnes	243,168
	Waste Processed	Tonnes	242,333
	Energy Generated	MWh	76,030
	Natural Gas Consumed	GJ	80,230
	Bottom Ash	Tonnes	39,563
	Fly Ash	Tonnes	8,637
	Ferrous Metal	Tonnes	5,207
	Non-Ferrous Metal	Tonnes	300
Waste Received	Municipal Garbage	Tonnes	224,900
	International Airline Waste	Tonnes	3,080
	International Marine Waste	Tonnes	5,881
	Police loads	Tonnes	98.4
	Pharmaceuticals	Tonnes	88.1
	Pocket Coil Mattresses	Tonnes	26.8
	Special Handle Waste	Tonnes	2,226
	Wastewater Treatment Plant Residuals	Tonnes	6,830
	Out of Region Waste	Tonnes	37.2
Summary of operation; performance, and maintenance of emissions control devices			
CEMS Calibration Data	Calibrated	Description of Calibration	
Opacity	Daily	RATA tests on Units 1, 2, and 3 were completed June 11-13, results were within the requirements. Analysers are calibrated daily against a zero value and a known reference value.	
Oxygen	Daily		
CO	Daily		
SO2	Daily		
NOx	Daily		