



**A. Lanfranco  
& Associates Inc.**

Environmental Consultants

**Prepared for**

**METRO VANCOUVER**

**Metrotower III**

**4515 Central Boulevard**

**Burnaby, BC V5H 0C6**

**WASTE-TO-ENERGY FACILITY**

**Appendices of Emissions Testing Report**

**May 2023 Survey**

**Second Quarter 2023**

# Table of Contents

## **Appendix**

A	Quality Assurance / Quality Control Results
B	Calculations
C	Laboratory Results
D	Computer Generated Results
E	Field Data Sheets
F	Calibration Sheets and Technician Certificates

## **APPENDIX – A**

### **QUALITY ASSURANCE / QUALITY CONTROL RESULTS**

Quality assurance / quality control (QA/QC) is divided into four categories: administration, preparation, testing, and analysis. The following sections detail results found for the above four categories.

#### **Administration:**

- All field, process, and analytical data was reviewed to ensure data integrity and accuracy.
- Duplicate proof of draft and final report, including data entry, conducted.

#### **Preparation:**

- All glassware cleaned
- Blank samples of reagents collected.

#### **Testing:**

- Stack diameter and absence of cyclonic flow confirmed
- Calibrated magnehelic used for all velocity measurements
- All trains past pre- and post- leak checks.
- Isokinetics all within  $100\% \pm 10\%$ .

Analysis:

- Trace Metals and Mercury analysis conducted at Element Labs, Surrey, B.C.
- Fluoride (HF) analysis conducted at Element Labs in Surrey, B.C.
- Nitrous Oxide (N<sub>2</sub>O) analysis conducted with portable analyzer by A. Lanfranco and Associates.
- Volatile Organic Compounds (VOC) analysis conducted at ALS Environmental in Simi Valley, CA.
- Particulate analysis conducted at A. Lanfranco and Associates Inc., Surrey, BC.
- Chain of Custody protocols followed for all samples.
- Acceptable blank values for all sample types. All samples blank corrected.

Sample Type	Blank Value		
Second Quarter 2023	Unit 1	Unit 2	Unit 3
Filter	0.2 mg	0.2 mg	0.3 mg
Front Half Washings	-0.5 mg	0.9 mg	0.3 mg
Mercury Front	<0.05 ug	<0.05 ug	<0.05 ug
Mercury Back	<0.203 ug	<0.20 ug	<0.209 ug
Trace Metals Front *	<14.9 ug	<17.0 ug	<22.2 ug
Trace Metals Back*	<44.6 ug	<44.6 ug	<25.2 ug
Ammonia	7.3 ug	<5.6 ug	23 ug
Fluoride	<8 ug	<7 ug	<7 ug

Sum of all reported elements except Hg\*

# **APPENDIX - B**

## **CALCULATIONS**

## Appendix 2 Calculations

The following sections show the equations and define the variables that were used for this survey. The equations are organized in three sections. Equations 1-12 were used to calculate particulate concentration at standard conditions on a dry basis. Equations 13-27 were used to sample within the  $100 \pm 10\%$  isokinetic variation and to confirm that sampling meets this isokinetic variation threshold. Equations 28-30 were used to calculate the volumetric flowrate of the stack flue gas.

### A2.1 Contaminant Concentration Calculations

$$c = \frac{m}{V_{std}} \quad \text{Equation 1}$$

$$m_{part} = m_{filter} + m_{pw} \quad \text{Equation 2}$$

$$m_i = m_{ana,i} - m_{blank} \quad \text{Equation 3}$$

$$V_{std} = \frac{V_{std(imp)}}{35.315} \quad \text{Equation 4}$$

$$V_{std(imp)} = \frac{V_{samp} \times y \times P_m \times (T_{std} + 459.67)}{P_{std} \times (T_{m(ave)} + 459.67)} \quad \text{Equation 5}$$

$$V_{samp} = V_{final} - V_{init} \quad \text{Equation 6}$$

$$P_m = P_B + \frac{\Delta H_{ave}}{13.6} \quad \text{Equation 7}$$

$$\Delta H_{ave} = \frac{1}{n} \sum_{i=1}^n \Delta H_{i(act)}, \text{ where } n = \text{the number of points} \quad \text{Equation 8}$$

$$OC = \frac{20.9 - \%O_{2c}}{20.9 - \%O_{2m}} \quad \text{Equation 9}$$

$$CO2C = \frac{\%CO_{2c}}{\%CO_{2m}} \quad \text{Equation 10}$$

$$\%O_{2m} = \frac{1}{n} \sum_{i=1}^n \%O_{2i}, \text{ where } n = \text{the number of } O_2 \text{ measurements} \quad \text{Equation 11}$$

$$\%CO_{2m} = \frac{1}{n} \sum_{i=1}^n \%CO_{2i}, \text{ where } n = \text{the number of } CO_2 \text{ measurements} \quad \text{Equation 12}$$

## Appendix 2 Calculations

---

Where,

$c$	= Contaminant concentration
$m$	= Contaminant mass
$m_i$	= Net analytical mass (mg, ng, or $\mu\text{g}$ )
$m_{ana,i}$	= Analytical mass (mg, ng, or $\mu\text{g}$ )
$m_{blank}$	= Blank analytical mass (mg, ng, or $\mu\text{g}$ )
$m_{part}$	= Total particulate mass (mg)
$m_{filter}$	= Net particulate gain from filter (mg)
$m_{pw}$	= Net particulate gain from probe wash (mg)
$V_{std(imp)}$	= Sample volume at standard conditions ( $\text{ft}^3$ )
$V_{std}$	= Sample volume at standard conditions ( $\text{m}^3$ )
$V_{samp}$	= Sample volume at actual conditions ( $\text{ft}^3$ )
$V_{final}$	= Final gas meter reading ( $\text{ft}^3$ )
$V_{init}$	= Initial gas meter reading ( $\text{ft}^3$ )
$T_{std}$	= Standard temperature (68 °F)
$T_m$	= Gas meter temperature (°F)
$T_{m(ave)}$	= Average gas meter temperature (°F)
$P_m$	= Absolute meter pressure (inches of Hg)
$P_B$	= Barometric pressure (inches of Hg)
$\Delta H_{ave}$	= Average of individual point orifice pressures (inches of $\text{H}_2\text{O}$ )
$\Delta H_{i(act)}$	= Individual recorded point orifice pressures (inches of $\text{H}_2\text{O}$ )
$OC$	= Oxygen correction factor (dimensionless)
$CO_2C$	= Carbon dioxide correction factor (dimensionless)
$\%O_{2c}$	= Oxygen concentration to correct to (% dry basis)
$\%O_{2m}$	= Average measured stack gas oxygen concentration (% dry basis)
$\%CO_{2c}$	= Carbon dioxide concentration to correct to (% dry basis)
$\%CO_{2m}$	= Average measured stack gas oxygen concentration (% dry basis)

Equation 1 is the general concentration calculation used for all contaminants. The contaminant mass,  $m$ , is the net analytic mass for the given contaminant. For particulate,  $m$  is the sum of the mass contributed from probe washing and filter particulate.

## Appendix 2 Calculations

### A2.2 Isokinetic Variation Calculations

$$\Delta H_i = \frac{2.62 \times 10^7 \times c_p \times A_n \times (1 - B_{wo}) \times M_D \times (T_m + 459.67) \times \Delta p_i}{k_o \times M_w \times (T_{stk} + 459.67)} \quad \text{Equation 13}$$

$$R_m = 85.49 \times c_p \times \sqrt{\Delta p_i} \times \sqrt{\frac{(T_{stk_i} + 459.67)}{M_w \times P_B}} \times 60 \times A_n \times \frac{(T_{m_i} + 459.67) \times (1 - B_{wo})}{(T_{stk_i} + 459.67) \times y} \quad \text{Equation 14}$$

$$A_n = \pi \left( \frac{d_n}{24} \right)^2 \quad \text{Equation 15}$$

$$M_w = M_D \times (1 - B_{wo}) + 18 \times B_{wo} \quad \text{Equation 16}$$

$$M_D = 0.44 \times \%CO_2 + 0.32 \times \%O_2 + 0.28 \times (100 - \%CO_2 - \%O_2) \quad \text{Equation 17}$$

$$T_{stk} = \frac{1}{n} \sum_{i=1}^n T_{stk_i}, \text{ where } n = \text{the number of points} \quad \text{Equation 18}$$

$$B_{wo} = \frac{V_{cond}}{V_{cond} + V_{std(imp)}} \quad \text{Equation 19}$$

$$V_{cond} = 0.04707 \times V_{gain} \quad \text{Equation 20}$$

$$Iso = \frac{1}{n} \sum_{i=1}^n Iso_i, \text{ where } n = \text{the number of points} \quad \text{Equation 21}$$

$$Iso_i = \frac{v_{nzi}}{v_i} \quad \text{Equation 22}$$

$$v_i = 85.49 \times c_p \times \sqrt{\Delta p_i} \times \sqrt{\frac{(T_{stk_i} + 459.67)}{(P_{stk} \times M_w)}} \quad \text{Equation 23}$$

$$v_{nzi} = \frac{(V_i - V_{i-1}) \times y \times (T_{stk_i} + 459.67) \times (P_B + \frac{\Delta H_{i(act)}}{13.6})}{A_n \times t_i \times 60 \times (T_{m(i)} + 459.67) \times P_{stk} \times (1 - B_{wo})} \quad \text{Equation 24}$$

$$P_{stk} = P_B + \frac{P_g}{13.6} \quad \text{Equation 25}$$

## Appendix 2 Calculations

$$v_{stk} = \frac{1}{n} \sum_{i=1}^n v_i, \text{ where } n = \text{the number of points}$$

**Equation 26**

$$v_{nz} = \frac{1}{n} \sum_{i=1}^n v_{nzi}, \text{ where } n = \text{the number of points}$$

**Equation 27**

Where,

$A_n$	= Nozzle area (ft <sup>2</sup> )
$d_n$	= Diameter of nozzle (inches)
$c_p$	= Pitot coefficient (dimensionless)
$\Delta p_i$	= Individual point differential pressures (inches of H <sub>2</sub> O)
$T_{stk}$	= Average flue gas temperature (°F), second subscript i, indicates individual point measurements
$\Delta H_{i(act)}$	= Calculated individual point orifice pressures (inches of H <sub>2</sub> O)
$P_g$	= Stack Static pressure (inches of H <sub>2</sub> O)
$P_{stk}$	= Absolute stack pressure (inches of Hg)
$M_w$	= Wet gas molecular weight (g/gmol)
$M_D$	= Dry gas molecular weight (g/gmol)
%CO <sub>2</sub>	= Stack gas carbon dioxide concentration (% dry basis)
%O <sub>2</sub>	= Stack gas oxygen concentration (% dry basis)
$B_{wo}$	= Stack gas water vapour, proportion by volume
$V_{cond}$	= Total volume of water vapor collected, corrected to standard conditions (ft <sup>3</sup> )
$V_{gain}$	= Condensate gain of impinger contents (mL)
$P_{std}$	= Standard pressure (29.92 inches of Hg)
$V_{stk}$	= Average flue gas velocity (ft/sec)
$v_i$	= Individual point flue gas velocity (ft/sec)
$v_{nz}$	= Average velocity at nozzle (ft/sec)
$v_{nzi}$	= Individual point velocity at nozzle (ft/sec)
$ISO_i$	= Individual point isokinetic variation (%)
$ISO$	= Average isokinetic variation (%)
$R_m$	= Isokinetic sampling rate (ft <sup>3</sup> /min)

**A2.3 Volumetric Flowrate Calculations**

$$Q_S = Q_A \times \frac{(T_{Std} + 459.67)}{(T_{Stk} + 459.67)} \times \frac{P_{Stk}}{P_{Std}} \quad \text{Equation 28}$$

$$Q_A = \frac{v_{stk} \times 60 \times A_{stk}}{35.315} \quad \text{Equation 29}$$

$$A_{stk} = \pi \left( \frac{d}{24} \right)^2 \quad \text{Equation 30}$$

Where,

$Q_A$	= Actual flowrate ( $Am^3/min$ )
$Q_S$	= Flowrate ( $m^3/min$ ) at standard conditions on a dry basis
$A_{stk}$	= Area of stack ( $ft^2$ )
$d$	= Diameter of stack (inches)

**APPENDIX - C**

**LABORATORY RESULTS**

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Field Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653254**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 14, 2023  
Report Number: 2876520

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

**Notes To Clients:**

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Field Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653254**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 14, 2023  
Report Number: 2876520

		Reference Number	1653254-1	1653254-2	1653254-3
		Sample Date	May 16, 2023	May 17, 2023	May 18, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Field Blank Unit 1 (MV Unit 1 BLK + 4 Bottles)	Field Blank Unit 2 (MV Unit 2 BLK + 4 Bottles)	Field Blank Unit 3 (MV Unit 3 BLK + 4 Bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	<5	7	<5	5
Antimony	µg	<2	<2	4	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	<0.2	<0.2	1.1	0.2
Cobalt	µg	<0.3	<0.3	<0.3	0.25
Copper	µg	<0.3	<0.3	<0.3	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	<0.3	<0.3	0.3	0.25
Nickel	µg	0.9	1	1	0.5
Phosphorus	µg	10	7	9	2.5
Selenium	µg	2	<2	<2	1.5
Tellurium	µg	<2	<2	4.8	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2	2	2	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	7	6	<5	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<1.0	<0.9	<0.9	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	1.4	0.86	0.86	0.2
Cobalt	µg	<0.2	0.7	<0.2	0.25
Copper	µg	1	<0.2	1	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	0.3	0.4	0.3	0.25
Nickel	µg	2	<0.5	1	0.5
Phosphorus	µg	25	20	20	2.5
Selenium	µg	<1	2.7	<1	1.5
Tellurium	µg	5.9	<2	<2	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	<1.0	<0.9	<0.9	1
Zinc	µg	2	2.7	2	0.5
Volume	Sample	mL	302	324	319
Volume	aliquot volume	mL	252	274	269
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Field Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653254**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 14, 2023  
Report Number: 2876520

		Reference Number	1653254-1	1653254-2	1653254-3
		Sample Date	May 16, 2023	May 17, 2023	May 18, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Field Blank Unit 1 (MV Unit 1 BLK + 4 Bottles)	Field Blank Unit 2 (MV Unit 2 BLK + 4 Bottles)	Field Blank Unit 3 (MV Unit 3 BLK + 4 Bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Mercury by CVAA - Continued</b>					
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	250	250	250
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	302	324	319
Volume	aliquot volume	mL	5.0	5.0	5.0
Volume	Final	mL	40	40	40
Mercury	Fraction 2B	µg/sample	<0.1	<0.1	<0.1
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	151	128	145
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3A	µg/sample	<0.01	<0.01	<0.01
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	1000	500	1000
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3B	µg/sample	<0.08	<0.04	<0.08
Mercury	As Tested	µg/L	0.09	<0.05	0.18
Dilution Factor	As Tested	1	1	1	
Volume	Sample	mL	200	200	200
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3C	µg/sample	0.03	<0.02	0.059

Approved by:



Max Hewitt  
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

## Methodology and Notes

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Field Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653254**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 14, 2023  
Report Number: 2876520

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 25, 2023	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 25, 2023	Element Vancouver

\* Reference Method Modified

## References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Filter Reagent Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653268**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 14, 2023  
Report Number: 2876512

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

**Notes To Clients:**

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Filter Reagent Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653268**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 14, 2023  
Report Number: 2876512

		Reference Number	1653268-1	1653268-2	1653268-3
		Sample Date	May 15, 2023	May 15, 2023	May 15, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Reagent Blank Unit 1 Container 1 (filter)	Reagent Blank Unit 2 Container 1 (filter)	Reagent Blank Unit 3 Container 1 (filter)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	6	180	<5	5
Antimony	µg	<2	7	<2	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	0.84	<0.2	<0.2	0.2
Cobalt	µg	<0.3	<0.3	<0.3	0.25
Copper	µg	<0.3	<0.3	<0.3	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	0.3	0.4	0.3	0.25
Nickel	µg	<0.5	<0.5	0.6	0.5
Phosphorus	µg	10	26	10	2.5
Selenium	µg	7.3	<2	<2	1.5
Tellurium	µg	9.2	<2	6.5	2
Thallium	µg	5.3	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2	13	2	0.5
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	250	250	250
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02

Approved by:



Max Hewitt  
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

## Methodology and Notes

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Filter Reagent Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653268**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 14, 2023  
Report Number: 2876512

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 25, 2023	Element Vancouver

*\* Reference Method Modified*

## References

EMC      Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

## Appendix B - Particulate Analysis

**Client:** Metro Vancouver  
**Source:** Units 1, 2, and 3  
**Sample Date:** May 15-18, 2023  
**Location:** WTE (Burnaby, B.C)

### A. Lanfranco & Associates Standard Operating Procedure:

SOP 1.2.1 Gravimetric determination of total particulate matter

#### Filter Collection:

Test #	Initial (grams)	Final (grams)	Net Difference (grams)	Blank Adjusted (grams)
Unit 1 Blank	0.4656	0.4658	0.0002	
Unit 1 Run 1	0.4670	0.4669	-0.0001	ND
Unit 1 Run 2	0.4669	0.4674	0.0005	0.0003
Unit 1 Run 3	0.4662	0.4662	0.0000	ND
Unit 2 Blank	0.4673	0.4675	0.0002	
Unit 2 Run 1	0.4675	0.4669	-0.0006	ND
Unit 2 Run 2	0.4656	0.4673	0.0017	0.0015
Unit 2 Run 3	0.4654	0.4657	0.0003	0.0001
Unit 3 Blank	0.4649	0.4652	0.0003	
Unit 3 Run 1	0.4674	0.4724	0.0050	0.0047
Unit 3 Run 2	0.4679	0.4766	0.0087	0.0084
Unit 3 Run 3	0.4635	0.4700	0.0065	0.0062

#### Front Half Washings:

Test #	Initial (grams)	Final (grams)	Net Difference (grams)	Blank Adjusted (grams)
Unit 1 Blank	121.3313	121.3308	-0.0005	
Unit 1 Run 1	102.5383	102.5400	0.0017	0.0022
Unit 1 Run 2	119.7613	119.7622	0.0009	0.0014
Unit 1 Run 3	97.5817	97.5820	0.0003	0.0008
Unit 2 Blank	114.3618	114.3627	0.0009	
Unit 2 Run 1	119.9495	119.9503	0.0008	ND
Unit 2 Run 2	92.7512	92.7521	0.0009	ND
Unit 2 Run 3	117.7447	117.7450	0.0003	ND
Unit 3 Blank	121.7991	121.7994	0.0003	
Unit 3 Run 1	87.9210	87.9223	0.0013	0.0010
Unit 3 Run 2	95.9973	95.9991	0.0018	0.0015
Unit 3 Run 3	123.7625	123.7645	0.0020	0.0017

Task	Unit	Personnel	Date	Quality Control	Y/N
Filter Recovery:	Unit 1	S.Harrington	15-16-May-23	Adequate PW volume:	Y
	Unit 2	S.Harrington	16-17-May-23	No sample leakage:	Y
	Unit 3	S.Harrington	17-18-May-23	Filter not compromised:	Y
PW Initial Analysis:	Unit 1	J. Ching	19-May-23		
	Unit 2	J. Ching	19-May-23		
	Unit 3	J. Ching	19-May-23		
PW, FilterFinal Analysis:	Unit 1	D. Sampson	24-May-23		
	Unit 2	D. Sampson	24-May-23		
	Unit 3	D. Sampson	24-May-23		
Data entered to computer:	All	S. Harrington	26-May-23		

#### Comments:

No problems encountered in sample analysis.

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: HF Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652737**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 25, 2023  
Report Number: 2875824

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

**Notes To Clients:**

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: HF Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652737**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 25, 2023  
Report Number: 2875824

		Reference Number	1652737-1	1652737-2	1652737-3	
		Sample Date	May 16, 2023	May 17, 2023	May 18, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit #1 HF Blank / 19.8 °C	Unit #2 HF Blank / 19.8 °C	Unit #3 HF Blank / 19.8 °C	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Air Quality						
Volume	Sample	mL	255	247	247	
Dilution Factor	fluoride		1.00000000	1.00000000	1.00000000	
Fluoride	As Tested	mg/L	<0.03	<0.03	<0.03	0.03
Fluoride	Water Soluble	µg/sample	<8	<7	<7	

Approved by:



Max Hewitt  
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

## Methodology and Notes

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: HF Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652737**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 25, 2023  
Report Number: 2875824

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Anions by IEC in air (VAN)	EMC	* Determination of Hydrogen Halide & Halogen Emissions from Stationary Sources (Isokinetic), 26A	May 24, 2023	Element Vancouver

*\* Reference Method Modified*

## References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: HF Samples Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1652732</b> Control Number: Date Received: May 23, 2023 Date Reported: May 25, 2023 Report Number: 2875817
Attn: Missy Sampled By: Company:		

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com

Delivery	Format	Deliverables
Email	PDF	COA / COC
Email	PDF	COC / Test Report

Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
-------	---------------------------	---

Delivery	Format	Deliverables
Email	PDF	Invoice

**Notes To Clients:**

- May 24, 2023 - Reduction of analytical volume was necessary for anion analysis due to matrix effects in lot 1652732. Detection limits are adjusted accordingly.

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: HF Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652732**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 25, 2023  
Report Number: 2875817

		Reference Number	1652732-1	1652732-2	1652732-3	Nominal Detection Limit
		Sample Date	May 16, 2023	May 16, 2023	May 16, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit #1 HF Run 1 / 19.8 °C	Unit #1 HF Run 2 / 19.8 °C	Unit #1 HF Run 3 / 19.8 °C	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	
Air Quality						
Volume	Sample	mL	308	340	413	
Dilution Factor	fluoride		1.00000000	10.00	10.00	
Fluoride	As Tested	mg/L	<0.03	<0.3	<0.3	0.03
Fluoride	Water Soluble	µg/sample	<9	<10	<10	

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: HF Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652732**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 25, 2023  
Report Number: 2875817

Reference Number	1652732-4	1652732-5	1652732-6
Sample Date	May 17, 2023	May 17, 2023	May 17, 2023
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit #2 HF Run 1 / 19.8 °C	Unit #2 HF Run 2 / 19.8 °C	Unit #2 HF Run 3 / 19.8 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Air Quality</b>					
Volume	Sample	mL	373	366	350
Dilution Factor	fluoride	10.00	10.00	10.00	
Fluoride	As Tested	mg/L	<0.3	<0.3	<0.3
Fluoride	Water Soluble	µg/sample	<10	<10	<10

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: HF Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652732**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 25, 2023  
Report Number: 2875817

Reference Number	1652732-7	1652732-8	1652732-9
Sample Date	May 18, 2023	May 18, 2023	May 18, 2023
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit #3 HF Run 1 / 19.8 °C	Unit #3 HF Run 2 / 19.8 °C	Unit #3 HF Run 3 / 19.8 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Air Quality</b>					
Volume	Sample	mL	360	306	358
Dilution Factor	fluoride	10.00	10.00	10.00	
Fluoride	As Tested	mg/L	<0.3	<0.3	<0.3
Fluoride	Water Soluble	µg/sample	<10	<9	<10

Approved by:



Max Hewitt  
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

## Methodology and Notes

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: HF Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652732**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 25, 2023  
Report Number: 2875817

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Anions by IEC in air (VAN)	EMC	* Determination of Hydrogen Halide & Halogen Emissions from Stationary Sources (Isokinetic), 26A	May 24, 2023	Element Vancouver

*\* Reference Method Modified*

## References

EMC Emission Measurement Center of EPA

## Comments:

- May 24, 2023 - Reduction of analytical volume was necessary for anion analysis due to matrix effects in lot 1652732. Detection limits are adjusted accordingly.

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1653281</b> Control Number: Date Received: May 24, 2023 Date Reported: Jun 15, 2023 Report Number: 2876531
Attn: Missy Sampled By: Company:		

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

**Notes To Clients:**

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Metals and Hg Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653281**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 15, 2023  
Report Number: 2876531

	Reference Number	1653281-1	1653281-2	1653281-3	
	Sample Date	May 15, 2023	May 16, 2023	May 16, 2023	
	Sample Time	NA	NA	NA	
	Sample Location				
	Sample Description	Unit 1 Run 1 ( MV Unit 1 Run 1 + 4 Bottles)	Unit 1 Run 2 ( MV Unit 1 Run 2 + 4 Bottles)	Unit 1 Run 3 ( MV Unit 1 Run 3 + 4 Bottles)	
	Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	26	20	20	5
Antimony	µg	<2	<2	5	2.5
Arsenic	µg	2.9	<1	<1	1
Cadmium	µg	<0.3	0.3	<0.3	0.25
Chromium	µg	2.81	1.6	12.6	0.2
Cobalt	µg	0.7	<0.3	0.4	0.25
Copper	µg	2	2.6	<0.3	0.25
Lead	µg	5.1	<2	<2	1.5
Manganese	µg	2	2	2.7	0.25
Nickel	µg	2.9	15	13	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	10	13	23	1.5
Tellurium	µg	6.2	6.2	<2	2
Thallium	µg	<2	7.9	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	13	25	19	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	40	40	20	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	0.9	3.4	3.1	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	2.46	1.8	2.1	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	3.1	1	2	0.25
Lead	µg	<1	<1	<1	1.5
Manganese	µg	1	1	1	0.25
Nickel	µg	2	1.0	1	0.5
Phosphorus	µg	24	24	22	2.5
Selenium	µg	<1	<1	2	1.5
Tellurium	µg	2.4	2.2	<2	2
Thallium	µg	2	<1	<1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	4.4	3.9	3.7	0.5
Volume	Sample	mL	830	750	
Volume	aliquot volume	mL	780	700	
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	0.05

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Metals and Hg Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653281**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 15, 2023  
Report Number: 2876531

		Reference Number	1653281-1	1653281-2	1653281-3	
		Sample Date	May 15, 2023	May 16, 2023	May 16, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 1 Run 1 ( MV Unit 1 Run 1 + 4 Bottles)	Unit 1 Run 2 ( MV Unit 1 Run 2 + 4 Bottles)	Unit 1 Run 3 ( MV Unit 1 Run 3 + 4 Bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Mercury by CVAA - Continued						
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	830	750	750	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	<0.3	<0.3	<0.3	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	152	144	155	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.01	<0.01	<0.01	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	1000	1000	1000	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.08	<0.08	<0.08	
Mercury	As Tested	µg/L	0.17	0.08	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.055	0.03	<0.02	

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Metals and Hg Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653281**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 15, 2023  
Report Number: 2876531

		Reference Number	1653281-4	1653281-5	1653281-6
		Sample Date	May 16, 2023	May 17, 2023	May 17, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit 2 Run 1 ( MV Unit 2 Run 1 + 4 Bottles)	Unit 2 Run 2 ( Unit-2 Run 2 + 4 Bottles)	Unit 2 Run 3 (Unit -2 Run 3 + 4 Bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	10	10	5	5
Antimony	µg	<2	<2	7	2.5
Arsenic	µg	<1	1	1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	3.40	4.70	2.67	0.2
Cobalt	µg	<0.3	0.6	<0.3	0.25
Copper	µg	<0.3	<0.3	<0.3	0.25
Lead	µg	2	<2	<2	1.5
Manganese	µg	1	2.6	1.0	0.25
Nickel	µg	2.6	13	11	0.5
Phosphorus	µg	10	10	10	2.5
Selenium	µg	12	<2	5.4	1.5
Tellurium	µg	4.6	2.6	<2	2
Thallium	µg	<2	<2	<2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	5.9	6.2	4.8	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	20	20	28	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<0.9	0.9	<0.9	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	1.3	1.4	3.10	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	2.7	2	2	0.25
Lead	µg	2	<1	<1	1.5
Manganese	µg	0.8	0.7	1	0.25
Nickel	µg	0.8	1	1	0.5
Phosphorus	µg	29	25	22	2.5
Selenium	µg	<1	<1	<1	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	6.6	3.0	7.3	0.5
Volume	Sample	mL	850	776	825
Volume	aliquot volume	mL	800	726	775
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	0.05

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Metals and Hg Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653281**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 15, 2023  
Report Number: 2876531

		Reference Number	1653281-4	1653281-5	1653281-6	
		Sample Date	May 16, 2023	May 17, 2023	May 17, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 2 Run 1 ( MV Unit 2 Run 1 + 4 Bottles)	Unit 2 Run 2 ( Unit-2 Run 2 + 4 Bottles)	Unit 2 Run 3 (Unit -2 Run 3 + 4 Bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Mercury by CVAA - Continued						
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	850	776	825	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	<0.3	<0.3	<0.3	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	148	143	162	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.01	<0.01	<0.01	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	1000	1000	1000	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.08	<0.08	<0.08	
Mercury	As Tested	µg/L	<0.05	0.12	0.06	0.05
Dilution Factor	As Tested		1	1	1	
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	<0.02	0.040	0.02	

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Metals and Hg Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653281**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 15, 2023  
Report Number: 2876531

		Reference Number	1653281-7	1653281-8	1653281-9
		Sample Date	May 17, 2023	May 18, 2023	May 18, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit 3 Run 1 (MV Unit 3 Run 1 + 4 Bottles	Unit 3 Run 2 ( MV Unit 3 Run 2 + 4 Bottles)	Unit 3 Run 3 (MF-3 Run 3 + 4 Bottles)
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	20	27	20	5
Antimony	µg	3	<2	10	2.5
Arsenic	µg	<1	4.1	1	1
Cadmium	µg	0.8	1	2.7	0.25
Chromium	µg	1.6	0.87	2.2	0.2
Cobalt	µg	<0.3	0.4	<0.3	0.25
Copper	µg	4.0	4.4	5.0	0.25
Lead	µg	6.1	12	11	1.5
Manganese	µg	2	3.1	2.7	0.25
Nickel	µg	3.0	6.2	4.7	0.5
Phosphorus	µg	10	20	20	2.5
Selenium	µg	2.9	<2	4.7	1.5
Tellurium	µg	3.8	4.9	3.0	2
Thallium	µg	3.4	<2	2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	65.1	96.8	136	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	10	10	20	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	1	2	2.5	1
Cadmium	µg	<0.2	<0.2	<0.2	0.25
Chromium	µg	2.15	1.1	1.9	0.2
Cobalt	µg	<0.2	<0.2	<0.2	0.25
Copper	µg	2	1	0.3	0.25
Lead	µg	2.4	<1	3.6	1.5
Manganese	µg	0.7	0.4	1	0.25
Nickel	µg	1	2	0.9	0.5
Phosphorus	µg	23	20	21	2.5
Selenium	µg	<1	<1	<1	1.5
Tellurium	µg	<2	<2	<2	2
Thallium	µg	<1	<1	<1	1.5
Vanadium	µg	<0.9	<0.9	<0.9	1
Zinc	µg	5.1	2.4	3.5	0.5
Volume	Sample	mL	803	826	828
Volume	aliquot volume	mL	753	776	778
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	0.28	0.20

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Metals and Hg Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653281**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 15, 2023  
Report Number: 2876531

		Reference Number	1653281-7	1653281-8	1653281-9	Nominal Detection Limit
		Sample Date	May 17, 2023	May 18, 2023	May 18, 2023	
		Sample Time	NA	NA	NA	
		Sample Location				
		Sample Description	Unit 3 Run 1 (MV Unit 3 Run 1 + 4 Bottles	Unit 3 Run 2 ( MV Unit 3 Run 2 + 4 Bottles)	Unit 3 Run 3 (MF-3 Run 3 + 4 Bottles)	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte	Units	Results	Results	Results		
<b>Mercury by CVAA - Continued</b>						
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 1B	µg/sample	<0.02	0.11	0.082	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	803	826	828	
Volume	aliquot volume	mL	5.0	5.0	5.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 2B	µg/sample	<0.3	<0.3	<0.3	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	153	166	150	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3A	µg/sample	<0.01	<0.01	<0.01	
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	1000	1000	1000	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3B	µg/sample	<0.08	<0.08	<0.08	
Mercury	As Tested	µg/L	0.07	0.07	0.21	0.05
Dilution Factor	As Tested	1	1	1		
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	µg/sample	0.02	0.02	0.068	

Approved by:



Reena Badwal  
Operations Chemist

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

## Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Metals and Hg Samples Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1653281</b> Control Number: Date Received: May 24, 2023 Date Reported: Jun 15, 2023 Report Number: 2876531
Attn: Missy Sampled By: Company:		

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 25, 2023	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 25, 2023	Element Vancouver

\* Reference Method Modified

## References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: NH3 Blanks Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1652746</b> Control Number: Date Received: May 23, 2023 Date Reported: May 26, 2023 Report Number: 2875839
Attn: Missy Sampled By: Company:		

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

**Notes To Clients:**

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential.  
If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited.  
If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: NH3 Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652746**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 26, 2023  
Report Number: 2875839

		Reference Number	1652746-1	1652746-2	1652746-3
		Sample Date	May 16, 2023	May 17, 2023	May 18, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit #1 NH3 Blk / 19.8 °C	Unit #2 NH3 Blk / 19.8 °C	Unit #3 NH3 Blk / 19.8 °C
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Air Quality</b>					
Ammonium - N	As Tested	µg/L	28	<25	78
Dilution Factor	As Tested		1.00	1.00	1.00
Sample Volume	Sample volume	mL	262	223	300
Ammonium - N		µg/sample	7.3	<5.6	23

Approved by:



Max Hewitt  
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

## Methodology and Notes

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: NH3 Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652746**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 26, 2023  
Report Number: 2875839

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Ammonium in Impingers (VAN)	APHA	* Automated Phenate Method, 4500-NH3 G	May 25, 2023	Element Edmonton - Roper Road

*\* Reference Method Modified*

## References

APHA Standard Methods for the Examination of Water and Wastewater

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: NH3 Samples Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1652742</b> Control Number: Date Received: May 23, 2023 Date Reported: May 26, 2023 Report Number: 2875835
Attn: Missy Sampled By: Company:		

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

**Notes To Clients:**

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: NH3 Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652742**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 26, 2023  
Report Number: 2875835

		Reference Number	1652742-1	1652742-2	1652742-3
		Sample Date	May 16, 2023	May 16, 2023	May 16, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Unit #1 NH3 Run 1 / 19.8 °C	Unit #1 NH3 Run 2 / 19.8 °C	Unit #1 NH3 Run 3 / 19.8 °C
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Air Quality</b>					
Ammonium - N	As Tested	µg/L	1080	1760	4500
Dilution Factor	As Tested		1.00	1.00	1.00
Sample Volume	Sample volume	mL	345	400	354
Ammonium - N		µg/sample	373	702	1590

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: NH3 Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652742**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 26, 2023  
Report Number: 2875835

Reference Number	1652742-4	1652742-5	1652742-6
Sample Date	May 17, 2023	May 17, 2023	May 17, 2023
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit #2 NH3 Run 1 / 19.8 °C	Unit #2 NH3 Run 2 / 19.8 °C	Unit #2 NH3 Run 3 / 19.8 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Air Quality</b>					
Ammonium - N	As Tested	µg/L	1020	3460	102
Dilution Factor	As Tested		1.00	1.00	1.00
Sample Volume	Sample volume	mL	416	378	400
Ammonium - N		µg/sample	426	1310	40.8

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: NH3 Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652742**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 26, 2023  
Report Number: 2875835

Reference Number	1652742-7	1652742-8	1652742-9
Sample Date	May 18, 2023	May 18, 2023	May 18, 2023
Sample Time	NA	NA	NA
Sample Location			
Sample Description	Unit #3 NH3 Run 1 / 19.8 °C	Unit #3 NH3 Run 2 / 19.8 °C	Unit #3 NH3 Run 3 / 19.8 °C
Matrix	Stack Samples	Stack Samples	Stack Samples

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Air Quality</b>					
Ammonium - N	As Tested	µg/L	1440	218	2920
Dilution Factor	As Tested		1.00	1.00	1.00
Sample Volume	Sample volume	mL	354	322	346
Ammonium - N		µg/sample	510	70.2	1010

Approved by:



Max Hewitt  
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Terms and Conditions: <https://www.element.com/terms/terms-and-conditions>

---

**Methodology and Notes**

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: NH3 Samples  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1652742**  
Control Number:  
Date Received: May 23, 2023  
Date Reported: May 26, 2023  
Report Number: 2875835

---

**Method of Analysis**

Method Name	Reference	Method	Date Analysis Started	Location
Ammonium in Impingers (VAN)	APHA	* Automated Phenate Method, 4500-NH3 G	May 25, 2023	Element Edmonton - Roper Road

*\* Reference Method Modified*

**References**

APHA Standard Methods for the Examination of Water and Wastewater

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

**Report Transmission Cover Page**

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Reagent Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653274**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 15, 2023  
Report Number: 2876525

Contact	Company	Address
Mark Lanfranco	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	COA / COC
Email	PDF	COC / Test Report
Missy	A. Lanfranco & Associates	#101, 9488 - 189 Street Surrey, BC V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: missy@alanfranco.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	PDF	Invoice

**Notes To Clients:**

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Reagent Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653274**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 15, 2023  
Report Number: 2876525

		Reference Number	1653274-1	1653274-2	1653274-3
		Sample Date	May 15, 2023	May 15, 2023	May 15, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Reagent Blank Unit 1	Reagent Blank Unit 2	Reagent Blank Unit 3
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Front Half Metals Fraction 1A</b>					
Aluminum	µg	<5	5	<5	5
Antimony	µg	<2	<2	<2	2.5
Arsenic	µg	<1	<1	<1	1
Cadmium	µg	<0.3	0.3	<0.3	0.25
Chromium	µg	0.34	<0.2	0.2	0.2
Cobalt	µg	<0.3	<0.3	0.6	0.25
Copper	µg	<0.3	<0.3	<0.3	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	<0.3	<0.3	<0.3	0.25
Nickel	µg	0.8	0.7	<0.5	0.5
Phosphorus	µg	<2	3	10	2.5
Selenium	µg	<2	<2	<2	1.5
Tellurium	µg	<2	5.4	6.2	2
Thallium	µg	<2	<2	2	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	0.9	1.0	1.0	0.5
<b>Back Half Metals Fraction 2A</b>					
Aluminum	µg	<5	7	6	5
Antimony	µg	<3	<3	<3	2.5
Arsenic	µg	5.3	2	<1	1
Cadmium	µg	<0.3	<0.3	<0.3	0.25
Chromium	µg	0.46	0.70	0.66	0.2
Cobalt	µg	<0.3	<0.3	<0.3	0.25
Copper	µg	2	2	1	0.25
Lead	µg	<2	<2	<2	1.5
Manganese	µg	0.3	<0.3	0.3	0.25
Nickel	µg	0.7	1	0.7	0.5
Phosphorus	µg	20	20	20	2.5
Selenium	µg	3.5	<2	<2	1.5
Tellurium	µg	6.8	5.3	<2	2
Thallium	µg	4.7	<2	3	1.5
Vanadium	µg	<1	<1	<1	1
Zinc	µg	2	2.8	1	0.5
Volume	Sample	mL	201	207	213
Volume	aliquot volume	mL	151	157	163
<b>Mercury by CVAA</b>					
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	250	250	250

## Analytical Report

Bill To: A. Lanfranco & Associates  
#101, 9488 - 189 Street  
Surrey, BC, Canada  
V4N 4W7  
Attn: Missy  
Sampled By:  
Company:

Project ID: Metro Vancouver WTE  
Project Name: Reagent Blanks  
Project Location:  
LSD:  
P.O.:  
Proj. Acct. code:

Lot ID: **1653274**  
Control Number:  
Date Received: May 24, 2023  
Date Reported: Jun 15, 2023  
Report Number: 2876525

		Reference Number	1653274-1	1653274-2	1653274-3
		Sample Date	May 15, 2023	May 15, 2023	May 15, 2023
		Sample Time	NA	NA	NA
		Sample Location			
		Sample Description	Reagent Blank Unit 1	Reagent Blank Unit 2	Reagent Blank Unit 3
		Matrix	Stack Samples	Stack Samples	Stack Samples
Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Mercury by CVAA - Continued</b>					
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 1B	µg/sample	<0.02	<0.02	<0.02
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	201	207	213
Volume	aliquot volume	mL	5.0	5.0	5.0
Volume	Final	mL	50	50	50
Mercury	Fraction 2B	µg/sample	<0.1	<0.1	<0.1
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	100	99	99
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3A	µg/sample	<0.008	<0.008	<0.008
Mercury	As Tested	µg/L	<0.05	<0.05	<0.05
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	500	500	500
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3B	µg/sample	<0.04	<0.04	<0.04
Mercury	As Tested	µg/L	0.11	0.10	0.10
Dilution Factor	As Tested		1	1	1
Volume	Sample	mL	200	200	200
Volume	aliquot volume	mL	25	25	25
Volume	Final	mL	40	40	40
Mercury	Fraction 3C	µg/sample	0.036	0.033	0.03

Approved by:



Reena Badwal  
Operations Chemist

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

## Methodology and Notes

Bill To: A. Lanfranco & Associates #101, 9488 - 189 Street Surrey, BC, Canada V4N 4W7	Project ID: Metro Vancouver WTE Project Name: Reagent Blanks Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: <b>1653274</b> Control Number: Date Received: May 24, 2023 Date Reported: Jun 15, 2023 Report Number: 2876525
Attn: Missy Sampled By: Company:		

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (VAN) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Mercury in Air (VAN) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	Jun 12, 2023	Element Vancouver
Metals in Stack Samples - Back half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 25, 2023	Element Vancouver
Metals in Stack Samples - Front half (VAN)	EMC	* Metals Emissions from Stationary Sources, 29	May 25, 2023	Element Vancouver

\* Reference Method Modified

## References

EMC Emission Measurement Center of EPA

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.



## LABORATORY REPORT

---

June 1, 2023

Mark Lanfranco  
A. Lanfranco and Associates Inc.  
Unit 101 - 9488 189 St.  
Surrey, BC V4N 4W7

**RE: Metro Vacouver W.T.E.**

Dear Mark:

Enclosed are the results of the samples submitted to our laboratory on May 22, 2023. For your reference, these analyses have been assigned our service request number P2302296.

All analyses were performed according to our laboratory's NELAP and DoD-ELAP-approved quality assurance program. The test results meet requirements of the current NELAP and DoD-ELAP standards, where applicable, and except as noted in the laboratory case narrative provided. For a specific list of NELAP and DoD-ELAP-accredited analytes, refer to the certifications section at [www.alsglobal.com](http://www.alsglobal.com). Results are intended to be considered in their entirety and apply only to the samples analyzed and reported herein.

If you have any questions, please call me at (805) 526-7161.

ALS | Environmental



By Nicole.Bryson at 5:57 pm, Jun 01, 2023

for Sue Anderson  
Project Manager



Client: A. Lanfranco and Associates Inc.  
Project: Metro Vacouver W.T.E.

Service Request No: P2302296

## CASE NARRATIVE

---

The samples were received intact under chain of custody on May 22, 2023 and were stored in accordance with the analytical method requirements. Please refer to the sample acceptance check form for additional information. The results reported herein are applicable only to the condition of the samples at the time of sample receipt.

### Methane, Ethene, Ethane, and C3 through C6+ Hydrocarbons Analysis

The samples were analyzed per modified EPA Method TO-3 for methane, ethene, ethane, and C3 through >C6 hydrocarbons using a gas chromatograph equipped with a flame ionization detector (FID). This procedure is described in laboratory SOP VOA-TO3C1C6. This method is included on the laboratory's DoD-ELAP scope of accreditation, however it is not part of the NELAP accreditation.

Manual integration of the chromatographic ranges in each sample with reported concentrations was required to correct the integration performed by the automated data processing program. The raw data states the rationale and specific ranges impacted by the manual integration.

---

*The results of analyses are given in the attached laboratory report. All results are intended to be considered in their entirety, and ALS Environmental (ALS) is not responsible for utilization of less than the complete report.*

*Use of ALS Environmental (ALS)'s Name. Client shall not use ALS's name or trademark in any marketing or reporting materials, press releases or in any other manner ("Materials") whatsoever and shall not attribute to ALS any test result, tolerance or specification derived from ALS's data ("Attribution") without ALS's prior written consent, which may be withheld by ALS for any reason in its sole discretion. To request ALS's consent, Client shall provide copies of the proposed Materials or Attribution and describe in writing Client's proposed use of such Materials or Attribution. If ALS has not provided written approval of the Materials or Attribution within ten (10) days of receipt from Client, Client's request to use ALS's name or trademark in any Materials or Attribution shall be deemed denied. ALS may, in its discretion, reasonably charge Client for its time in reviewing Materials or Attribution requests. Client acknowledges and agrees that the unauthorized use of ALS's name or trademark may cause ALS to incur irreparable harm for which the recovery of money damages will be inadequate. Accordingly, Client acknowledges and agrees that a violation shall justify preliminary injunctive relief. For questions contact the laboratory.*



## CERTIFICATIONS, ACCREDITATIONS, AND REGISTRATIONS

Agency	Web Site	Number
Alaska DEC	<a href="https://dec.alaska.gov/spar/csp/lab-approval/list-of-approved-labs">https://dec.alaska.gov/spar/csp/lab-approval/list-of-approved-labs</a>	17-019
Arizona DHS	<a href="http://www.azdhs.gov/preparedness/state-laboratory/lab-licensure-certification/index.php#laboratory-licensure-home">http://www.azdhs.gov/preparedness/state-laboratory/lab-licensure-certification/index.php#laboratory-licensure-home</a>	AZ0694
Florida DOH (NELAP)	<a href="http://www.floridahealth.gov/licensing-and-regulation/environmental-laboratories/index.html">http://www.floridahealth.gov/licensing-and-regulation/environmental-laboratories/index.html</a>	E871020
Louisiana DEQ (NELAP)	<a href="https://internet.deq.louisiana.gov/portal/divisions/lalap/accredited-laboratories">https://internet.deq.louisiana.gov/portal/divisions/lalap/accredited-laboratories</a>	05071
Maine DHHS	<a href="http://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtm">http://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtm</a>	2022028
Minnesota DOH (NELAP)	<a href="http://www.health.state.mn.us/accreditation">http://www.health.state.mn.us/accreditation</a>	006-999-456
New Jersey DEP (NELAP)	<a href="https://dep.nj.gov/dsr/oqa/certified-laboratories/">https://dep.nj.gov/dsr/oqa/certified-laboratories/</a>	CA009
New York DOH (NELAP)	<a href="http://www.wadsworth.org/labcert/elap/elap.html">http://www.wadsworth.org/labcert/elap/elap.html</a>	11221
Oregon PHD (NELAP)	<a href="http://www.oregon.gov/oha/ph/LaboratoryServices/EnvironmentalLaboratoryAccreditation/Pages/index.aspx">http://www.oregon.gov/oha/ph/LaboratoryServices/EnvironmentalLaboratoryAccreditation/Pages/index.aspx</a>	4068-011
Pennsylvania DEP	<a href="http://www.dep.pa.gov/Business/OtherPrograms/Labs/Pages/Laboratory-Accreditation-Program.aspx">http://www.dep.pa.gov/Business/OtherPrograms/Labs/Pages/Laboratory-Accreditation-Program.aspx</a>	68-03307 (Registration)
PJLA (DoD ELAP)	<a href="http://www.pjlabs.com/search-accredited-labs">http://www.pjlabs.com/search-accredited-labs</a>	65818 (Testing)
Texas CEQ (NELAP)	<a href="http://www.tceq.texas.gov/agency/qa/env_lab_accreditation.html">http://www.tceq.texas.gov/agency/qa/env_lab_accreditation.html</a>	T104704413-22-13
Utah DOH (NELAP)	<a href="https://uphl.utah.gov/certifications/environmental-laboratory-certification/">https://uphl.utah.gov/certifications/environmental-laboratory-certification/</a>	CA016272022-14
Washington DOE	<a href="http://www.ecy.wa.gov/programs/eap/labs/lab-accreditation.html">http://www.ecy.wa.gov/programs/eap/labs/lab-accreditation.html</a>	C946
<p>Analyses were performed according to our laboratory's NELAP and DoD-ELAP approved quality assurance program. A complete listing of specific NELAP and DoD-ELAP certified analytes can be found in the certifications section at <a href="http://www.alsglobal.com">www.alsglobal.com</a>, or at the accreditation body's website.</p> <p>Each of the certifications listed above have an explicit Scope of Accreditation that applies to specific matrices/methods/analytes; therefore, please contact the laboratory for information corresponding to a particular certification.</p>		

# ALS ENVIRONMENTAL

## DETAIL SUMMARY REPORT

Client: A. Lanfranco and Associates Inc.  
Project ID: Metro Vacouver W.T.E.

Service Request: P2302296

Date Received: 5/22/2023  
Time Received: 09:20

Client Sample ID	Lab Code	Matrix	Date Collected	Time Collected	Container ID	P <sub>i</sub> l (psig)	P <sub>f</sub> l (psig)	TO-3 Modified - C1C6+ Can	
								TO-3 Modified - C1C6+ Can	TO-3 Modified - MEEPP Can
Unit 1 Run 1	P2302296-001	Air	5/16/2023	10:50	SC02337	-3.60	3.70	X	X
Unit 1 Run 2	P2302296-002	Air	5/16/2023	12:10	SC01608	-2.30	3.83	X	X
Unit 1 Run 3	P2302296-003	Air	5/16/2023	13:23	SC02191	-2.10	4.55	X	X
Unit 2 Run 1	P2302296-004	Air	5/17/2023	10:58	SC00645	-0.85	3.95	X	X
Unit 2 Run 2	P2302296-005	Air	5/17/2023	12:10	SC02245	-3.43	4.00	X	X
Unit 2 Run 3	P2302296-006	Air	5/17/2023	13:22	SC01596	-3.75	4.15	X	X
Unit 3 Run 1	P2302296-007	Air	5/18/2023	10:09	SC00095	-6.59	3.83	X	X
Unit 3 Run 2	P2302296-008	Air	5/18/2023	11:26	SC01768	0.17	3.81	X	X
Unit 3 Run 3	P2302296-009	Air	5/18/2023	12:40	SC02250	-4.17	4.41	X	X



# Air - Chain of Custody Record & Analytical Service Request

Page 1 of 1

2655 Park Center Drive, Suite A  
Simi Valley, California 93065  
Phone (805) 526-7161

Requested Turnaround Time in Business Days (Surcharges) please circle  
1 Day (100%) 2 Day (75%) 3 Day (50%) 4 Day (35%) 5 Day (25%) 10 Day-Standard

ALS Project No. 8302295

Company Name & Address (Reporting Information) <u>A Lanfranco &amp; Associates Inc.</u> <u>#101-9488 189 Street Surrey, BC, Canada V4N 4W7</u>				Project Name <u>Metro Vancouver W.T.E.</u>				ALS Contact:		Comments e.g. Actual Preservative or specific instructions
								Analysis Method		
Project Manager <u>Mark Lanfranco</u>				Project Number				TO-3 (List on File)		
P.O. # / Billing Information <u>Bill to Account</u>				P.O. # / Billing Information						
Phone <u>604-881-2582</u>				Fax						
Email Address for Result Reporting <u>mark.lanfranco@alanfranco.com</u>				Sampler (Print & Sign) <u>Christian De La O</u>						
Client Sample ID	Laboratory ID Number	Date Collected	Time Collected	Canister ID (Bar code # - AC, SC, etc.)	Flow Controller ID (Bar code # - FC #)	Canister Start Pressure "Hg	Canister End Pressure "Hg/psig	Sample Volume		
Unit 1 Run 1	1	05-16-23	0950-1050	SC02337	0A00804	-27"	-65"	6L		
Unit 1 Run 2	2	05-16-23	1110-1210	SC01608	0A00538	-29.5"	-6"	6L		
Unit 1 Run 3	3	05-16-23	1223-1323	SC02191	0A01426	-28"	-4"	6L		
Unit 2 Run 1	4	05-17-23	0958-1058	SC00645	0A00080	-28.5"	-2.5"	6L		
Unit 2 Run 2	5	05-17-23	1110-1210	SC02245	0A01178	-29.5"	-3"	6L		
Unit 2 Run 3	6	05-17-23	1222-1322	SC01596	0A00936	-26"	-5.5"	6L		
Unit 3 Run 1	7	05-18-23	0904-1004	SC00015	0A00984	-30"	-14.5"	6L		
Unit 3 Run 2	8	05-18-23	1026-1126	SC01768	0A02930	-20"	-6.5"	6L		
Unit 3 Run 3	9	05-18-23	1140-1240	SC02250	0A01669	-30"	-9"	6L		
Report Tier Levels - please select										Project Requirements (MRLs, QAPP)
Tier I - Results (Default if not specified) _____		Tier III (Results + QC & Calibration Summaries) _____		EDD required Yes / No		Chain of Custody Seal: (Circle)				
Tier II (Results + QC Summaries) _____		Tier IV (Data Validation Package) 10% Surcharge _____		Type: _____ Units: _____		INTACT BROKEN ABSENT				
Relinquished by: (Signature)		Date:	Time:	Received by: (Signature)		Date:	Time:			
Relinquished by: (Signature)		Date:	Time:	Received by: (Signature)		Date:	Time:			

# ALS Environmental Sample Acceptance Check Form

Client: A. Lanfranco and Associates Inc. Work order: P2302296  
 Project: Metro Vacouver W.T.E.  
 Sample(s) received on: 5/22/23 Date opened: 5/22/23 by: ADAVID

**Note:** This form is used for all samples received by ALS. The use of this form for custody seals is strictly meant to indicate presence/absence and not as an indication of compliance or nonconformity. Thermal preservation and pH will only be evaluated either at the request of the client and/or as required by the method/SOP.

- |   | <b>Yes</b>                          | <b>No</b>                           | <b>N/A</b>                          |
|---|-------------------------------------|-------------------------------------|-------------------------------------|
| 1 Were <b>sample containers</b> properly marked with client sample ID?  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 2 Did <b>sample containers</b> arrive in good condition?  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 3 Were <b>chain-of-custody</b> papers used and filled out?  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 4 Did <b>sample container labels</b> and/or tags agree with custody papers?                                     | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 5 Was <b>sample volume</b> received adequate for analysis?  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 6 Are samples within specified holding times?   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            |
| 7 Was proper <b>temperature</b> (thermal preservation) of cooler at receipt adhered to?                         | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 8 Were <b>custody seals</b> on outside of cooler/Box/Container?   | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| Location of seal(s)? _____ Sealing Lid?   | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Were signature and date included?   | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Were seals intact?  | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 9 Do containers have appropriate <b>preservation</b> , according to method/SOP or Client specified information? | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Is there a client indication that the submitted samples are <b>pH</b> preserved?                                | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Were <b>VOA vials</b> checked for presence/absence of air bubbles?  | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Does the client/method/SOP require that the analyst check the sample pH and <u>if necessary</u> alter it?       | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 10 <b>Tubes:</b> Are the tubes capped and intact?   | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 11 <b>Badges:</b> Are the badges properly capped and intact?  | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| Are dual bed badges separated and individually capped and intact?   | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |

Lab Sample ID	Container Description	Required pH *	Received pH	Adjusted pH	VOA Headspace (Presence/Absence)	Receipt / Preservation Comments
P2302296-001.01	6.0 L Source Can					
P2302296-002.01	6.0 L Source Can					
P2302296-003.01	6.0 L Source Can					
P2302296-004.01	6.0 L Source Can					
P2302296-005.01	6.0 L Source Can					
P2302296-006.01	6.0 L Source Can					
P2302296-007.01	6.0 L Source Can					
P2302296-008.01	6.0 L Source Can					
P2302296-009.01	6.0 L Source Can					

Explain any discrepancies: (include lab sample ID numbers): \_\_\_\_\_

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 1 Run 1

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-001

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC02337

Date Collected: 5/16/23

Date Received: 5/22/23

Date Analyzed: 5/23/23

Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -3.60      Final Pressure (psig): 3.70

Container Dilution Factor: 1.66

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.2	ND	3.3	
74-85-1	Ethene	ND	1.1	ND	1.0	
74-84-0	Ethane	ND	1.2	ND	1.0	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 1 Run 2

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-002

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890A/GC10/FID

**Analyst:** Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC01608

**Date Collected:** 5/16/23

**Date Received:** 5/22/23

**Date Analyzed:** 5/23/23

**Volume(s) Analyzed:** 0.50 ml(s)

**Initial Pressure (psig):** -2.30      **Final Pressure (psig):** 3.83

**Container Dilution Factor:** 1.49

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.0	ND	3.0	
74-85-1	Ethene	ND	1.0	ND	0.89	
74-84-0	Ethane	ND	1.1	ND	0.89	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 1 Run 3

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-003

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890A/GC10/FID

**Analyst:** Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC02191

**Date Collected:** 5/16/23

**Date Received:** 5/22/23

**Date Analyzed:** 5/23/23

**Volume(s) Analyzed:** 0.50 ml(s)

**Initial Pressure (psig):** -2.10      **Final Pressure (psig):** 4.55

**Container Dilution Factor:** 1.53

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.0	ND	3.1	
74-85-1	Ethene	ND	1.1	ND	0.92	
74-84-0	Ethane	ND	1.1	ND	0.92	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 2 Run 1

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-004

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890A/GC10/FID

**Analyst:** Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC00645

**Date Collected:** 5/17/23

**Date Received:** 5/22/23

**Date Analyzed:** 5/23/23

**Volume(s) Analyzed:** 0.50 ml(s)

**Initial Pressure (psig):** -0.85      **Final Pressure (psig):** 3.95

**Container Dilution Factor:** 1.35

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	1.8	ND	2.7	
74-85-1	Ethene	ND	0.93	ND	0.81	
74-84-0	Ethane	ND	1.0	ND	0.81	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 2 Run 2

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-005

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890A/GC10/FID

**Analyst:** Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC02245

**Date Collected:** 5/17/23

**Date Received:** 5/22/23

**Date Analyzed:** 5/23/23

**Volume(s) Analyzed:** 0.50 ml(s)

**Initial Pressure (psig):** -3.43      **Final Pressure (psig):** 4.00

**Container Dilution Factor:** 1.66

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.2	ND	3.3	
74-85-1	Ethene	ND	1.1	ND	1.0	
74-84-0	Ethane	ND	1.2	ND	1.0	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 2 Run 3

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-006

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC01596

Date Collected: 5/17/23

Date Received: 5/22/23

Date Analyzed: 5/23/23

Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -3.60      Final Pressure (psig): 3.70

Container Dilution Factor: 1.66

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.2	ND	3.3	
74-85-1	Ethene	ND	1.1	ND	1.0	
74-84-0	Ethane	ND	1.2	ND	1.0	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.  
**Client Sample ID:** Unit 3 Run 1  
**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296  
 ALS Sample ID: P2302296-007

**Test Code:** EPA TO-3 Modified  
**Instrument ID:** HP5890A/GC10/FID  
**Analyst:** Gilbert Gutierrez  
**Sampling Media:** 6.0 L Summa Canister  
**Test Notes:**  
**Container ID:** SC00095

**Date Collected:** 5/18/23  
**Date Received:** 5/22/23  
**Date Analyzed:** 5/23/23  
**Volume(s) Analyzed:** 0.50 ml(s)

**Initial Pressure (psig):** -2.30      **Final Pressure (psig):** 3.83

**Container Dilution Factor:** 1.49

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	2.0	ND	3.0	
74-85-1	Ethene	ND	1.0	ND	0.89	
74-84-0	Ethane	ND	1.1	ND	0.89	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 3 Run 2

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-008

Test Code: EPA TO-3 Modified

Instrument ID: HP5890A/GC10/FID

Analyst: Gilbert Gutierrez

Sampling Media: 6.0 L Summa Canister

Test Notes:

Container ID: SC01768

Date Collected: 5/18/23

Date Received: 5/22/23

Date Analyzed: 5/23/23

Volume(s) Analyzed: 0.50 ml(s)

Initial Pressure (psig): -2.10      Final Pressure (psig): 4.55

Container Dilution Factor: 1.53

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	2.2	2.0	3.4	3.1	
74-85-1	Ethene	ND	1.1	ND	0.92	
74-84-0	Ethane	ND	1.1	ND	0.92	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 3 Run 3

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-009

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890A/GC10/FID

**Analyst:** Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC02250

**Date Collected:** 5/18/23

**Date Received:** 5/22/23

**Date Analyzed:** 5/23/23

**Volume(s) Analyzed:** 0.50 ml(s)

**Initial Pressure (psig):** -0.85      **Final Pressure (psig):** 3.95

**Container Dilution Factor:** 1.35

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	1.8	ND	2.7	
74-85-1	Ethene	ND	0.93	ND	0.81	
74-84-0	Ethane	ND	1.0	ND	0.81	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Method Blank

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P230523-MB

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890A/GC10/FID

**Analyst:** Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

Date Collected: NA

Date Received: NA

Date Analyzed: 5/23/23

Volume(s) Analyzed: 0.50 ml(s)

CAS #	Compound	Result mg/m <sup>3</sup>	MRL mg/m <sup>3</sup>	Result ppmV	MRL ppmV	Data Qualifier
74-82-8	Methane	ND	1.3	ND	2.0	
74-85-1	Ethene	ND	0.69	ND	0.60	
74-84-0	Ethane	ND	0.74	ND	0.60	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## DUPLICATE LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Duplicate Lab Control Sample

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P230523-DLCS

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890A/GC10/FID

**Analyst:** Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

Date Collected: NA

Date Received: NA

Date Analyzed: 5/23/23

Volume(s) Analyzed: NA ml(s)

CAS #	Compound	Spike Amount	Result		% Recovery		ALS	RPD	RPD	Data
		LCS / DLCS ppmV	LCS ppmV	DLCS ppmV	LCS	DLCS	Acceptance Limits			
74-82-8	Methane	7.60	7.35	7.19	97	95	70-130	2	15	
74-85-1	Ethene	7.55	7.31	7.04	97	93	70-130	4	15	
74-84-0	Ethane	7.50	7.63	7.31	102	97	70-130	5	15	

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 1 Run 1

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-001

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890 II/GC8/FID

**Analyst:** Kylan Malloy/Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC02337

**Date Collected:** 5/16/23

**Date Received:** 5/22/23

**Date Analyzed:** 5/25/23

**Volume(s) Analyzed:** 1.0 ml(s)

**Initial Pressure (psig):** -3.60

**Final Pressure (psig):** 3.70

**Container Dilution Factor:** 1.66

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	0.83	
C <sub>4</sub> as n-Butane	ND	0.83	
C <sub>5</sub> as n-Pentane	ND	0.83	
C <sub>6</sub> as n-Hexane	ND	0.83	
C <sub>6</sub> + as n-Hexane	ND	1.7	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 1 Run 2

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-002

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890 II/GC8/FID

**Analyst:** Kylan Malloy/Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC01608

Date Collected: 5/16/23

Date Received: 5/22/23

Date Analyzed: 5/25/23

Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -2.30

Final Pressure (psig): 3.83

Container Dilution Factor: 1.49

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	0.75	
C <sub>4</sub> as n-Butane	ND	0.75	
C <sub>5</sub> as n-Pentane	ND	0.75	
C <sub>6</sub> as n-Hexane	ND	0.75	
C <sub>6</sub> + as n-Hexane	ND	1.5	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 1 Run 3

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-003

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890 II/GC8/FID

**Analyst:** Kylan Malloy/Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC02191

Date Collected: 5/16/23

Date Received: 5/22/23

Date Analyzed: 5/25/23

Volume(s) Analyzed: 1.0 ml(s)

Initial Pressure (psig): -2.10

Final Pressure (psig): 4.55

Container Dilution Factor: 1.53

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	0.77	
C <sub>4</sub> as n-Butane	ND	0.77	
C <sub>5</sub> as n-Pentane	ND	0.77	
C <sub>6</sub> as n-Hexane	ND	0.77	
C <sub>6</sub> + as n-Hexane	ND	1.5	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 2 Run 1

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-004

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890 II/GC8/FID

**Analyst:** Kylan Malloy/Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC00645

**Date Collected:** 5/17/23

**Date Received:** 5/22/23

**Date Analyzed:** 5/25/23

**Volume(s) Analyzed:** 1.0 ml(s)

**Initial Pressure (psig):** -0.85      **Final Pressure (psig):** 3.95

**Container Dilution Factor:** 1.35

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	0.68	
C <sub>4</sub> as n-Butane	ND	0.68	
C <sub>5</sub> as n-Pentane	ND	0.68	
C <sub>6</sub> as n-Hexane	ND	0.68	
C <sub>6</sub> + as n-Hexane	ND	1.4	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 2 Run 2

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-005

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890 II/GC8/FID

**Analyst:** Kylan Malloy/Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC02245

**Date Collected:** 5/17/23

**Date Received:** 5/22/23

**Date Analyzed:** 5/25/23

**Volume(s) Analyzed:** 1.0 ml(s)

**Initial Pressure (psig):** -3.43      **Final Pressure (psig):** 4.00

**Container Dilution Factor:** 1.66

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	0.83	
C <sub>4</sub> as n-Butane	ND	0.83	
C <sub>5</sub> as n-Pentane	ND	0.83	
C <sub>6</sub> as n-Hexane	ND	0.83	
C <sub>6</sub> + as n-Hexane	ND	1.7	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 2 Run 3

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-006

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890 II/GC8/FID

**Analyst:** Kylan Malloy/Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC01596

**Date Collected:** 5/17/23

**Date Received:** 5/22/23

**Date Analyzed:** 5/25/23

**Volume(s) Analyzed:** 1.0 ml(s)

**Initial Pressure (psig):** -3.75      **Final Pressure (psig):** 4.15

**Container Dilution Factor:** 1.72

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	0.86	
C <sub>4</sub> as n-Butane	ND	0.86	
C <sub>5</sub> as n-Pentane	ND	0.86	
C <sub>6</sub> as n-Hexane	ND	0.86	
C <sub>6</sub> + as n-Hexane	ND	1.7	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 3 Run 1

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-007

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890 II/GC8/FID

**Analyst:** Kylan Malloy/Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC00095

**Date Collected:** 5/18/23

**Date Received:** 5/22/23

**Date Analyzed:** 5/25/23

**Volume(s) Analyzed:** 1.0 ml(s)

**Initial Pressure (psig):** -6.59 **Final Pressure (psig):** 3.83

**Container Dilution Factor:** 2.28

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	1.1	
C <sub>4</sub> as n-Butane	ND	1.1	
C <sub>5</sub> as n-Pentane	ND	1.1	
C <sub>6</sub> as n-Hexane	ND	1.1	
C <sub>6</sub> + as n-Hexane	ND	2.3	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 3 Run 2

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-008

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890 II/GC8/FID

**Analyst:** Kylan Malloy/Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC01768

**Date Collected:** 5/18/23

**Date Received:** 5/22/23

**Date Analyzed:** 5/25/23

**Volume(s) Analyzed:** 1.0 ml(s)

**Initial Pressure (psig):** 0.17 **Final Pressure (psig):** 3.81

**Container Dilution Factor:** 1.24

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	0.62	
C <sub>4</sub> as n-Butane	ND	0.62	
C <sub>5</sub> as n-Pentane	ND	0.62	
C <sub>6</sub> as n-Hexane	ND	0.62	
C <sub>6</sub> + as n-Hexane	ND	1.2	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Unit 3 Run 3

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P2302296-009

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890 II/GC8/FID

**Analyst:** Kylan Malloy/Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Container ID:** SC02250

**Date Collected:** 5/18/23

**Date Received:** 5/22/23

**Date Analyzed:** 5/25/23

**Volume(s) Analyzed:** 1.0 ml(s)

**Initial Pressure (psig):** -4.17      **Final Pressure (psig):** 4.41

**Container Dilution Factor:** 1.81

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	0.91	
C <sub>4</sub> as n-Butane	ND	0.91	
C <sub>5</sub> as n-Pentane	ND	0.91	
C <sub>6</sub> as n-Hexane	ND	0.91	
C <sub>6</sub> + as n-Hexane	ND	1.8	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## RESULTS OF ANALYSIS

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Method Blank

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P230525-MB

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890 II/GC8/FID

**Analyst:** Kylan Malloy/Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

Date Collected: NA

Date Received: NA

Date Analyzed: 5/25/23

Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
C <sub>3</sub> as Propane	ND	0.50	
C <sub>4</sub> as n-Butane	ND	0.50	
C <sub>5</sub> as n-Pentane	ND	0.50	
C <sub>6</sub> as n-Hexane	ND	0.50	
C <sub>6</sub> + as n-Hexane	ND	1.0	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

# ALS ENVIRONMENTAL

## LABORATORY CONTROL SAMPLE / DUPLICATE LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

**Client:** A. Lanfranco and Associates Inc.

**Client Sample ID:** Duplicate Lab Control Sample

**Client Project ID:** Metro Vacouver W.T.E.

ALS Project ID: P2302296

ALS Sample ID: P230525-DLCS

**Test Code:** EPA TO-3 Modified

**Instrument ID:** HP5890 II/GC8/FID

**Analyst:** Kylan Malloy/Gilbert Gutierrez

**Sampling Media:** 6.0 L Summa Canister

**Test Notes:**

**Date Collected:** NA

**Date Received:** NA

**Date Analyzed:** 5/25/23

**Volume(s) Analyzed:** NA ml(s)

Compound	Spike Amount	Result		% Recovery		ALS	RPD	RPD	Data
	LCS / DLCS ppmV	LCS ppmV	DLCS ppmV	LCS	DLCS	Acceptance Limits			
Propane	1,000	972	952	97	95	92-120	2	6	
n-Butane	1,000	971	949	97	95	91-121	2	6	
n-Pentane	1,000	938	913	94	91	89-118	3	6	
n-Hexane	1,000	967	935	97	94	92-125	3	6	

**APPENDIX - D**

**COMPUTER GENERATED RESULTS**

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, BC)  
**Source:** Unit 1

**Date:** 15-May-23  
**Run:** 1 - Particulate / Metals  
**Run Time:** 11:42 - 13:44

---

**Concentrations:**

<b>Particulate</b>	0.88 mg/dscm	0.00039 gr/dscf
	0.50 mg/Acm	0.00022 gr/Acf
	0.72 mg/dscm (@ 11% O2)	0.00031 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.058 Kg/hr	0.127 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1087 dscm/min	38372 dscf/min
	18.11 dscm/sec	640 dscf/sec
	1926 Acm/min	68022 Acf/min

<b>Velocity</b>	12.604 m/sec	41.35 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	143.8 oC	290.9 oF
--------------------	----------	----------

<b>Moisture</b>	15.8 %
-----------------	--------

<b>Gas Analysis</b>	8.7 % O2
	11.1 % CO2

30.123 Mol. Wt (g/gmole) Dry  
28.204 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.5441 dscm	89.845 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	104.9 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, BC)  
**Source:** Unit 1

**Date:** 15-May-23  
**Run:** 1 - Particulate / Metals  
**Run Time:** 11:10 - 13:15

Control Unit (Y)	0.9818	Collection:	Gas Analysis (Vol. %):	Condensate Collection:
Nozzle Diameter (in.)	0.3058	Filter (grams) 0.00005	CO2 O2	Impinger 1 224.0
Pitot Factor	0.8352	Washings (grams) 0.00220	11.00 8.80	Impinger 2 92.0
Baro. Press. (in. Hg)	29.92	Traverse 1	11.17 8.67	Impinger 3 20.0
Static Press. (in. H2O)	-19.00	Traverse 2		Impinger 4 6.0
Stack Height (ft)	30	<b>Total (grams) 0.00225</b>		Impinger 5 2.0
Stack Diameter (in.)	70.90			Impinger 6 1.0
Stack Area (sq.ft.)	27.417			Gel 14.0
Minutes Per Reading	5.0			
Minutes Per Point	5.0			<b>Gain (grams) 359.0</b>

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	562.401								
1	5.0	565.930	0.28	1.52	93	93	5	289	1.5	105.3
2	10.0	569.570	0.30	1.52	93	93	5	293	4.7	105.2
3	15.0	572.830	0.25	1.30	93	93	6	292	8.4	103.1
4	20.0	576.020	0.23	1.25	94	94	6	293	12.5	105.0
5	25.0	579.280	0.24	1.30	94	94	5	292	17.7	105.0
6	30.0	582.900	0.30	1.63	94	94	5	292	25.2	104.4
7	35.0	587.280	0.46	2.34	95	95	6	292	45.6	102.0
8	40.0	591.980	0.50	2.73	96	96	6	292	53.2	104.9
9	45.0	596.800	0.52	2.83	96	96	8	292	58.3	105.5
10	50.0	601.470	0.49	2.68	97	97	8	292	62.5	105.1
11	55.0	605.600	0.38	2.08	98	98	7	290	66.1	105.0
12	60.0	609.670	0.37	2.03	98	98	7	290	69.4	104.9
Traverse 2	0.0	609.670								
1	5.0	614.030	0.42	2.31	99	99	6	288	1.5	105.2
2	10.0	618.490	0.44	2.42	99	99	6	290	4.7	105.3
3	15.0	622.690	0.39	2.14	99	99	8	290	8.4	105.2
4	20.0	626.980	0.41	2.25	99	99	8	290	12.5	104.9
5	25.0	631.250	0.40	2.20	100	100	8	291	17.7	105.6
6	30.0	635.520	0.40	2.20	100	100	8	291	25.2	105.6
7	35.0	639.560	0.36	1.98	100	100	8	291	45.6	105.2
8	40.0	643.660	0.38	2.03	100	100	8	291	53.2	104.2
9	45.0	647.540	0.33	1.82	101	101	8	291	58.3	105.3
10	50.0	651.300	0.31	1.71	101	101	8	291	62.5	105.3
11	55.0	654.990	0.30	1.65	100	100	7	290	66.1	105.1
12	60.0	658.560	0.28	1.55	101	101	7	289	69.4	105.0
Average:			0.364	1.978	97.5	97.5	6.8	290.9		104.9

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 1

**Date:** 16-May-23  
**Run:** 2 - Particulate / Metals  
**Run Time:** 09:11 - 11:13

---

**Concentrations:**

<b>Particulate</b>	0.64 mg/dscm	0.00028 gr/dscf
	0.37 mg/Acm	0.00016 gr/Acf
	0.55 mg/dscm (@ 11% O2)	0.00024 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.044 Kg/hr	0.098 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1147 dscm/min	40490 dscf/min
	19.11 dscm/sec	675 dscf/sec
	1970 Acm/min	69568 Acf/min

<b>Velocity</b>	12.890 m/sec	42.29 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	142.7 oC	288.8 oF
--------------------	----------	----------

<b>Moisture</b>	13.8 %
-----------------	--------

<b>Gas Analysis</b>	9.3 % O2
	10.9 % CO2

30.118 Mol. Wt (g/gmole) Dry  
28.442 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.6417 dscm	93.290 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	103.2 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

<b>Client:</b>	Metro Vancouver	<b>Date:</b>	16-May-23
<b>Jobsite:</b>	WTE (Burnaby, B.C)	<b>Run:</b>	2 - Particulate / Metals
<b>Source:</b>	Unit 1	<b>Run Time:</b>	09:11 - 11:13

Control Unit (Y)	0.9818	Collection:	Gas Analysis (Vol. %):	Condensate Collection:
Nozzle Diameter (in.)	0.3058	Filter (grams) 0.00030	CO2 O2	Impinger 1 185.0
Pitot Factor	0.8352	Washings (grams) 0.00140	11.50 8.93	Impinger 2 87.0
Baro. Press. (in. Hg)	30.06		10.33 9.63	Impinger 3 18.0
Static Press. (in. H2O)	-19.00	Total (grams) 0.00170		Impinger 4 5.0
Stack Height (ft)	30			Impinger 5 2.0
Stack Diameter (in.)	70.90			Impinger 6 1.0
Stack Area (sq.ft.)	27.417			Gel 20.0
Minutes Per Reading	5.0		10.92 9.28	Gain (grams) 318.0
Minutes Per Point	5.0			

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	659.041								
1	5.0	663.050	0.38	2.02	81	81	7	289	1.5	103.3
2	10.0	666.840	0.34	1.81	83	83	7	293	4.7	103.1
3	15.0	670.160	0.26	1.38	83	83	7	292	8.4	103.1
4	20.0	673.290	0.23	1.23	83	83	7	291	12.5	103.2
5	25.0	676.750	0.28	1.49	84	84	6	292	17.7	103.3
6	30.0	680.320	0.30	1.60	84	84	6	292	25.2	103.0
7	35.0	684.400	0.39	2.09	85	85	6	291	45.6	103.1
8	40.0	688.750	0.44	2.36	86	86	6	289	53.2	103.3
9	45.0	693.050	0.43	2.31	86	86	8	288	58.3	103.2
10	50.0	696.980	0.36	1.95	87	87	8	285	62.5	102.6
11	55.0	701.040	0.38	2.06	87	87	7	284	66.1	103.1
12	60.0	705.180	0.39	2.13	88	88	7	280	69.4	103.3
Traverse 2	0.0	705.180								
1	5.0	709.790	0.49	2.67	89	89	7	284	1.5	102.9
2	10.0	714.510	0.51	2.77	89	89	7	286	4.7	103.4
3	15.0	719.280	0.52	2.81	90	90	8	290	8.4	103.6
4	20.0	723.900	0.49	2.65	90	90	8	291	12.5	103.4
5	25.0	728.420	0.47	2.54	90	90	8	291	17.7	103.3
6	30.0	732.830	0.45	2.43	90	90	8	291	25.2	102.9
7	35.0	737.010	0.40	2.17	91	91	7	289	45.6	103.1
8	40.0	741.100	0.38	2.06	92	92	7	289	53.2	103.3
9	45.0	745.350	0.41	2.23	92	92	6	289	58.3	103.4
10	50.0	749.280	0.35	1.90	92	92	6	290	62.5	103.4
11	55.0	753.030	0.32	1.74	92	92	6	290	66.1	103.2
12	60.0	756.660	0.30	1.64	92	92	6	285	69.4	102.8
Average:			0.386	2.085	87.8	87.8	6.9	288.8		103.2

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 1

**Date:** 16-May-23  
**Run:** 3 - Particulate / Metals  
**Run Time:** 11:29 - 13:31

---

**Concentrations:**

<b>Particulate</b>	0.3 mg/dscm	0.0001 gr/dscf
	0.2 mg/Acm	0.0001 gr/Acf
	0.3 mg/dscm (@ 11% O2)	0.0001 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.022 Kg/hr	0.049 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1184 dscm/min	41827 dscf/min
	19.74 dscm/sec	697 dscf/sec
	2047 Acm/min	72302 Acf/min

<b>Velocity</b>	13.397 m/sec	43.95 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	145.9 oC	294.5 oF
--------------------	----------	----------

<b>Moisture</b>	13.7 %
-----------------	--------

<b>Gas Analysis</b>	10.1 % O2
	10.2 % CO2

30.030 Mol. Wt (g/gmole) Dry  
28.383 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.7226 dscm	96.149 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	103.0 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

<b>Client:</b>	Metro Vancouver	<b>Date:</b>	16-May-23
<b>Jobsite:</b>	WTE (Burnaby, B.C)	<b>Run:</b>	3 - Particulate / Metals
<b>Source:</b>	Unit 1	<b>Run Time:</b>	11:29 - 13:31

<b>Control Unit (Y)</b>	0.9818	<b>Collection:</b>		<b>Gas Analysis (Vol. %):</b>		<b>Condensate Collection:</b>	
<b>Nozzle Diameter (in.)</b>	0.3058	Filter (grams)	0.00005	CO2	O2	Impinger 1	212.0
<b>Pitot Factor</b>	0.8352	Washings (grams)	0.00080	9.5	10.43	Impinger 2	82.0
<b>Baro. Press. (in. Hg)</b>	30.06			10.17	9.70	Impinger 3	6.0
<b>Static Press. (in. H2O)</b>	-19.00	<b>Total (grams)</b>	<b>0.00085</b>			Impinger 4	4.0
<b>Stack Height (ft)</b>	30					Impinger 5	2.0
<b>Stack Diameter (in.)</b>	70.90					Impinger 6	1.0
<b>Stack Area (sq.ft.)</b>	27.417					Gel	17.0
<b>Minutes Per Reading</b>	5.0			<b>10.17</b>	<b>10.07</b>	<b>Gain (grams)</b>	<b>324.0</b>
<b>Minutes Per Point</b>	5.0						

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	757.012								
1	5.0	761.720	0.51	2.75	90	90	4	292	1.5	103.1
2	10.0	766.750	0.58	3.13	90	90	4	292	4.7	103.4
3	15.0	771.850	0.60	3.23	90	90	6	294	8.4	103.2
4	20.0	776.850	0.58	3.11	89	89	6	295	12.5	103.2
5	25.0	781.890	0.59	3.15	89	89	6	297	17.7	103.2
6	30.0	786.680	0.53	2.84	90	90	6	296	25.2	103.2
7	35.0	791.380	0.51	2.74	91	91	7	297	45.6	103.1
8	40.0	795.800	0.45	2.41	91	91	7	297	53.2	103.1
9	45.0	800.080	0.42	2.26	91	91	7	296	58.3	103.2
10	50.0	804.080	0.37	1.99	92	92	7	297	62.5	102.6
11	55.0	807.980	0.35	1.88	92	92	8	298	66.1	102.9
12	60.0	811.660	0.31	1.67	92	92	8	295	69.4	102.9
Traverse 2	0.0	811.660								
1	5.0	815.830	0.40	2.15	92	92	6	297	1.5	102.9
2	10.0	819.790	0.36	1.94	92	92	6	297	4.7	103.0
3	15.0	823.230	0.27	1.45	93	93	6	297	8.4	103.0
4	20.0	826.580	0.26	1.40	93	93	6	297	12.5	102.2
5	25.0	829.950	0.26	1.40	93	93	6	296	17.7	102.7
6	30.0	833.260	0.25	1.35	93	93	6	295	25.2	102.8
7	35.0	837.450	0.40	2.16	93	93	6	294	45.6	103.0
8	40.0	841.750	0.42	2.27	93	93	6	294	53.2	103.2
9	45.0	846.200	0.45	2.44	93	93	7	292	58.3	103.1
10	50.0	850.450	0.41	2.23	93	93	7	290	62.5	103.0
11	55.0	854.500	0.37	2.02	95	95	6	288	66.1	102.7
12	60.0	858.350	0.33	1.81	96	96	6	286	69.4	103.0
Average:			0.416	2.241	91.9	91.9	6.3	294.5		103.0

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)  
**Source:** Unit 1

**Sample Type:** HF

Parameter		Test 1	Test 2	Test 3
Test Date		16-May-23	16-May-23	16-May-23
Test Time		09:54 - 10:54	11:10 - 12:10	12:23 - 13:23
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.06	30.06	30.06
DGM Factor	(Y)	0.9983	0.9983	0.9983
Initial Reading	(m <sup>3</sup> )	572.209	572.678	573.292
Final Reading	(m <sup>3</sup> )	572.672	573.290	573.968
Temp. Outlet	(Avg. oF)	84.5	86.0	88.5
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm <sup>3</sup> )	0.45	0.59	0.65
HF	(mg)	0.005	0.005	0.005
Oxygen	(Vol. %)	8.7	9.3	10.1
HF	(mg/Sm <sup>3</sup> )	0.011	0.009	0.008
HF	(mg/Sm <sup>3</sup> @ 11% O2)	0.009	0.008	0.007
Moisture	(Vol. %)	13.8	13.8	13.7

Tstd. (oF) 68

Pstd. (in. Hg) 29.92

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)  
**Source:** Unit 1

**Sample Type:** NH<sub>3</sub>

Parameter		Test 1	Test 2	Test 3
Test Date		16-May-23	16-May-23	16-May-23
Test Time		09:54 - 10:54	11:10 - 12:10	12:23 - 13:23
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.06	30.06	30.06
DGM Factor	(Y)	1.0609	1.0609	1.0609
Initial Reading	(m <sup>3</sup> )	103.067	103.553	104.163
Final Reading	(m <sup>3</sup> )	103.548	104.158	104.781
Temp. Outlet	(Avg. oF)	82.0	93.5	95.0
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm <sup>3</sup> )	0.50	0.62	0.63
NH <sub>3</sub>	(mg)	0.4	0.8	1.9
Oxygen	(Vol. %)	8.7	9.3	10.1
NH <sub>3</sub>	(mg/Sm <sup>3</sup> )	0.9	1.4	3.1
NH <sub>3</sub>	(mg/Sm <sup>3</sup> @ 11% O2)	0.7	1.2	2.8
Moisture	(Vol. %)	13.8	13.8	13.7

Tstd. (oF) 68

Pstd. (in. Hg) 29.92

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 2

**Date:** 16-May-23  
**Run:** 1 - Particulate / Metals  
**Run Time:** 12:15 - 14:17

---

**Concentrations:**

<b>Particulate</b>	0.0 mg/dscm	0.0000 gr/dscf
	0.0 mg/Acm	0.0000 gr/Acf
	0.0 mg/dscm (@ 11% O2)	0.0000 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.002 Kg/hr	0.006 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1072 dscm/min	37843 dscf/min
	17.86 dscm/sec	631 dscf/sec
	1926 Acm/min	68033 Acf/min

<b>Velocity</b>	12.606 m/sec	41.36 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	156.2 oC	313.2 oF
--------------------	----------	----------

<b>Moisture</b>	14.9 %
-----------------	--------

<b>Gas Analysis</b>	11.0 % O2
	9.9 % CO2

30.020 Mol. Wt (g/gmole) Dry  
28.233 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.5726 dscm	90.852 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	105.9 %	

**\* Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

<b>Client:</b>	Metro Vancouver	<b>Date:</b>	16-May-23
<b>Jobsite:</b>	WTE (Burnaby, B.C)	<b>Run:</b>	1 - Particulate / Metals
<b>Source:</b>	Unit 2	<b>Run Time:</b>	12:15 - 14:17

Control Unit (Y)	0.9976	Collection:	Gas Analysis (Vol. %):		Condensate Collection:			
Nozzle Diameter (in.)	0.3083		CO2	O2	Impinger 1	168.0		
Pitot Factor	0.8461		Filter (grams) 0.00005		Impinger 2	92.0		
Baro. Press. (in. Hg)	30.03		Washings (grams) 0.00005	Traverse 1	9.75	10.75	Impinger 3	39.0
Static Press. (in. H20)	-19.00			Traverse 2	10.00	11.25	Impinger 4	12.0
Stack Height (ft)	30	Total (grams) 0.00010				Impinger 5	4.0	
Stack Diameter (in.)	70.90					Impinger 6	2.0	
Stack Area (sq.ft.)	27.417					Gel	20.2	
Minutes Per Reading	5.0			9.88	11.00	Gain (grams)	337.2	
Minutes Per Point	5.0							

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	817.250								
1	5.0	821.060	0.34	1.83	76	76	5	313	1.5	105.8
2	10.0	825.040	0.37	1.99	76	76	5	313	4.7	106.0
3	15.0	829.070	0.38	2.04	76	76	5	313	8.4	105.9
4	20.0	832.950	0.35	1.88	78	78	5	314	12.5	105.9
5	25.0	836.480	0.29	1.56	78	78	5	315	17.7	105.8
6	30.0	840.370	0.35	1.89	79	79	5	314	25.2	106.0
7	35.0	844.310	0.36	1.94	79	79	5	314	45.6	105.8
8	40.0	848.780	0.46	2.49	81	81	5	314	53.2	106.0
9	45.0	852.950	0.40	2.16	81	81	5	315	58.3	106.0
10	50.0	857.570	0.49	2.65	82	82	5	315	62.5	106.0
11	55.0	861.750	0.40	2.17	83	83	5	315	66.1	105.9
12	60.0	865.930	0.40	2.17	83	83	5	315	69.4	105.9
Traverse 2	0.0	865.930								
1	5.0	870.030	0.38	2.08	85	85	5	311	1.5	105.8
2	10.0	874.070	0.37	2.02	85	85	5	314	4.7	105.9
3	15.0	878.280	0.40	2.19	87	87	5	315	8.4	105.8
4	20.0	882.280	0.36	1.97	87	87	5	315	12.5	105.9
5	25.0	886.400	0.38	2.09	88	88	5	313	17.7	105.9
6	30.0	889.940	0.28	1.54	88	88	5	313	25.2	105.9
7	35.0	893.220	0.24	1.32	88	88	5	312	45.6	105.8
8	40.0	896.430	0.23	1.27	88	88	5	311	53.2	105.7
9	45.0	899.840	0.26	1.43	88	88	5	311	58.3	105.7
10	50.0	903.380	0.28	1.54	88	88	5	311	62.5	105.7
11	55.0	907.050	0.30	1.65	88	88	5	310	66.1	105.9
12	60.0	910.203	0.22	1.21	89	89	5	310	69.4	105.9
Average:			0.345	1.878	83.4	83.4	5.0	313.2		105.9

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 2

**Date:** 17-May-23  
**Run:** 2 - Particulate / Metals  
**Run Time:** 09:11 - 11:12

---

**Concentrations:**

<b>Particulate</b>	0.63 mg/dscm	0.00027 gr/dscf
	0.35 mg/Acm	0.00015 gr/Acf
	0.57 mg/dscm (@ 11% O2)	0.00025 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.041 Kg/hr	0.090 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1087 dscm/min	38390 dscf/min
	18.12 dscm/sec	640 dscf/sec
	1940 Acfm/min	68503 Acf/min

<b>Velocity</b>	12.693 m/sec	41.64 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	146.6 oC	295.9 oF
--------------------	----------	----------

<b>Moisture</b>	15.8 %
-----------------	--------

<b>Gas Analysis</b>	10.0 % O2
	10.0 % CO2

29.998 Mol. Wt (g/gmole) Dry  
28.098 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.4795 dscm	87.563 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	105.1 %	

\* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

<b>Client:</b>	Metro Vancouver	<b>Date:</b>	17-May-23
<b>Jobsite:</b>	WTE (Burnaby, B.C)	<b>Run:</b>	2 - Particulate / Metals
<b>Source:</b>	Unit 2	<b>Run Time:</b>	09:11 - 11:12

Control Unit (Y)	0.9976	Collection:		Gas Analysis (Vol. %):		Condensate Collection:	
Nozzle Diameter (in.)	0.3087	Filter (grams)	0.00150	CO2	O2	Impinger 1	234.0
Pitot Factor	0.8511	Washings (grams)	0.00005	10.00	9.97	Impinger 2	86.0
Baro. Press. (in. Hg)	29.96			10.00	9.93	Impinger 3	12.0
Static Press. (in. H2O)	-19.50					Impinger 4	2.0
Stack Height (ft)	30.16					Impinger 5	0.0
Stack Diameter (in.)	70.90					Impinger 6	0.0
Stack Area (sq.ft.)	27.417					Gel	16.1
Minutes Per Reading	5.0			10.00	9.95	Gain (grams)	350.1
Minutes Per Point	5.0						

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	910.647								
1	5.0	913.960	0.26	1.38	72	72	8	300	1.5	105.0
2	10.0	917.340	0.27	1.44	73	73	8	301	4.7	105.0
3	15.0	920.680	0.26	1.39	74	74	8	299	8.4	105.4
4	20.0	924.080	0.27	1.44	74	74	8	298	12.5	105.2
5	25.0	927.540	0.28	1.50	74	74	7	298	17.7	105.2
6	30.0	932.020	0.47	2.52	75	75	7	298	25.2	105.2
7	35.0	936.280	0.42	2.26	76	76	7	296	45.6	105.4
8	40.0	941.070	0.53	2.87	77	77	7	293	53.2	105.2
9	45.0	945.820	0.52	2.82	78	78	6	294	58.3	105.2
10	50.0	950.500	0.50	2.73	79	79	6	290	62.5	105.2
11	55.0	955.150	0.49	2.68	80	80	6	289	66.1	105.3
12	60.0	959.610	0.45	2.48	81	81	6	285	69.4	104.9
Traverse 2	0.0	959.610								
1	5.0	963.920	0.42	2.28	82	82	8	297	1.5	105.5
2	10.0	968.330	0.44	2.40	84	84	8	298	4.7	105.2
3	15.0	972.650	0.42	2.29	85	85	8	297	8.4	105.2
4	20.0	976.820	0.39	2.14	86	86	8	296	12.5	105.0
5	25.0	980.870	0.37	2.03	87	87	8.5	298	17.7	104.7
6	30.0	984.830	0.35	1.93	88	88	8.5	296	25.2	104.9
7	35.0	988.260	0.26	1.43	89	89	8.5	297	45.6	105.1
8	40.0	991.620	0.25	1.38	89	89	8	297	53.2	105.0
9	45.0	994.920	0.24	1.32	89	89	8	297	58.3	105.3
10	50.0	998.150	0.23	1.27	90	90	8	297	62.5	105.0
11	55.0	1001.320	0.22	1.21	90	90	7.5	297	66.1	105.4
12	60.0	1004.480	0.22	1.22	91	91	7.5	293	69.4	104.6
Average:			0.355	1.934	81.8	81.8	7.5	295.9		105.1

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C)  
**Source:** Unit 2

**Date:** 17-May-23  
**Run:** 3 - Particulate / Metals  
**Run Time:** 11:35 - 13:39

---

**Concentrations:**

<b>Particulate</b>	0.1 mg/dscm	0.0000 gr/dscf
	0.0 mg/Acm	0.0000 gr/Acf
	0.1 mg/dscm (@ 11% O2)	0.0000 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.00 Kg/hr	0.008 lb/hr
--------------------	------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1076 dscm/min	38000 dscf/min
	17.93 dscm/sec	633 dscf/sec
	1917 Acm/min	67689 Acf/min

<b>Velocity</b>	12.542 m/sec	41.15 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	147.5 oC	297.6 oF
--------------------	----------	----------

<b>Moisture</b>	15.5 %
-----------------	--------

<b>Gas Analysis</b>	10.0 % O2 9.8 % CO2
---------------------	------------------------

29.960 Mol. Wt (g/gmole) Dry  
28.106 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.5625 dscm	90.494 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	104.7 %	

**\* Standard Conditions:**

Metric:	20 deg C, 101.325 kPa
Imperial:	68 deg F, 29.92 in.Hg

<b>Client:</b>	Metro Vancouver	<b>Date:</b>	17-May-23
<b>Jobsite:</b>	WTE (Burnaby, B.C)	<b>Run:</b>	3 - Particulate / Metals
<b>Source:</b>	Unit 2	<b>Run Time:</b>	11:35 - 13:39

Control Unit (Y)	0.9976	Collection:		Gas Analysis (Vol. %):		Condensate Collection:			
Nozzle Diameter (in.)	0.3087		Filter (grams)	0.00010	CO2	O2	Impinger 1	222.0	
Pitot Factor	0.8511		Washings (grams)	0.00005	Traverse 1	9.50	10.40	Impinger 2	78.0
Baro. Press. (in. Hg)	29.96				Traverse 2	10.00	9.60	Impinger 3	26.0
Static Press. (in. H2O)	-19.50		Total (grams) 0.0001					Impinger 4	8.0
Stack Height (ft)	30						Impinger 5	3.0	
Stack Diameter (in.)	70.90						Impinger 6	1.0	
Stack Area (sq.ft.)	27.417						Gel	14.7	
Minutes Per Reading	5.0			9.75	10.00		Gain (grams)	352.7	
Minutes Per Point	5.0								

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	4.940								
1	5.0	8.900	0.35	1.92	87	87	5.5	296	1.5	104.7
2	10.0	12.960	0.37	2.03	88	88	5.5	297	4.7	104.3
3	15.0	17.090	0.38	2.09	88	88	5.5	297	8.4	104.7
4	20.0	21.220	0.38	2.09	88	88	5.5	297	12.5	104.7
5	25.0	25.380	0.39	2.14	88	88	5.5	298	17.7	104.1
6	30.0	29.560	0.39	2.14	88	88	5.5	298	25.2	104.6
7	35.0	33.360	0.32	1.76	89	89	5.5	298	45.6	104.7
8	40.0	36.920	0.28	1.54	89	89	5.5	299	53.2	104.9
9	45.0	40.350	0.26	1.43	89	89	5.5	300	58.3	104.9
10	50.0	43.920	0.28	1.54	90	90	5.5	298	62.5	104.9
11	55.0	47.360	0.26	1.44	91	91	4.5	297	66.1	104.7
12	60.0	50.530	0.22	1.22	92	92	4.5	298	69.4	104.7
Traverse 2	0.0	50.530								
1	5.0	54.230	0.30	1.66	93	93	6	300	1.5	104.7
2	10.0	57.800	0.28	1.55	93	93	6	300	4.7	104.5
3	15.0	60.970	0.22	1.21	93	93	6	300	8.4	104.6
4	20.0	64.080	0.21	1.16	93	93	6	299	12.5	105.0
5	25.0	67.330	0.23	1.27	94	94	6.5	299	17.7	104.7
6	30.0	70.780	0.26	1.44	94	94	6.5	299	25.2	104.5
7	35.0	74.950	0.38	2.11	94	94	6.5	298	45.6	104.6
8	40.0	79.680	0.49	2.72	93	93	6.5	297	53.2	104.8
9	45.0	84.460	0.50	2.77	93	93	6.5	297	58.3	104.8
10	50.0	89.430	0.54	3.00	94	94	6	297	62.5	104.7
11	55.0	94.320	0.52	2.90	94	94	6	293	66.1	104.7
12	60.0	99.080	0.49	2.75	95	95	6	290	69.4	104.6
Average:			0.346	1.912	91.3	91.3	3.0	297.6		104.7

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)  
**Source:** Unit 2

Sample Type: HF		Test 1	Test 2	Test 3
Parameter				
Test Date		17-May-23	17-May-23	17-May-23
Test Time		09:58 - 10:58	11:10 - 12:10	12:22 - 13:22
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	29.96	29.96	29.96
DGM Factor	(Y)	0.9983	0.9983	0.9983
Initial Reading	(m <sup>3</sup> )	573.976	574.570	575.186
Final Reading	(m <sup>3</sup> )	574.566	575.180	575.782
Temp. Outlet	(Avg. oF)	72.0	85.5	88.5
Orifice Press.	(ΔH in.H <sub>2</sub> O)	0.50	0.50	0.50
Gas Volume	(Sm <sup>3</sup> )	0.58626	0.59093	0.57421
HF	(mg)	0.005	0.005	0.005
Oxygen	(Vol. %)	11.0	10.0	10.0
<b>HF</b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>0.009</b>	<b>0.009</b>	<b>0.009</b>
<b>HF</b>	<b>(mg/Sm<sup>3</sup> @ 11% O<sub>2</sub>)</b>	<b>0.009</b>	<b>0.008</b>	<b>0.008</b>
<b>Moisture (isokinetic)</b>	<b>(Vol. %)</b>	<b>14.9</b>	<b>15.8</b>	<b>15.5</b>

\*Wet Basis Calculated on moisture from isokinetic tests  
Tstd. (oF) 68

Pstd. (in. Hg) 29.92

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)  
**Source:** Unit 2

Sample Type: NH <sub>3</sub>		Test 1	Test 2	Test 3
Parameter				
Test Date		17-May-23	17-May-23	17-May-23
Test Time		09:58 - 10:58	11:10 - 12:10	12:22 - 13:22
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	29.96	29.96	29.96
DGM Factor	(Y)	1.0320	1.0320	1.0320
Initial Reading	(m <sup>3</sup> )	249.519	250.024	250.597
Final Reading	(m <sup>3</sup> )	250.019	250.591	251.179
Temp. Outlet	(Avg. oF)	71.5	86.0	88.0
Orifice Press.	(ΔH in.H <sub>2</sub> O)	0.50	0.50	0.50
Gas Volume	(Sm <sup>3</sup> )	0.51330	0.56719	0.58008
NH <sub>3</sub>	(mg)	0.5	1.6	0.0
Oxygen	(Vol. %)	11.0	10.0	10.0
<b>NH<sub>3</sub></b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>1.0</b>	<b>2.8</b>	<b>0.1</b>
<b>NH<sub>3</sub></b>	<b>(mg/Sm<sup>3</sup> @ 11% O<sub>2</sub>)</b>	<b>1.0</b>	<b>2.5</b>	<b>0.1</b>
<b>Moisture (isokinetic)</b>	<b>(Vol. %)</b>	<b>14.9</b>	<b>15.8</b>	<b>15.5</b>

\*Wet Basis Calculated on moisture from isokinetic tests  
Tstd. (oF) 68

Pstd. (in. Hg) 29.92

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 3

**Date:** 17-May-23  
**Run:** 1 - Particulate / Metals  
**Run Time:** 11:40 - 13:42

---

**Concentrations:**

<b>Particulate</b>	2.27 mg/dscm	0.00099 gr/dscf
	1.26 mg/Acm	0.00055 gr/Acf
	2.08 mg/dscm (@ 11% O2)	0.00091 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.143 Kg/hr	0.314 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1048 dscm/min	36993 dscf/min
	17.46 dscm/sec	617 dscf/sec
	1891 Acm/min	66780 Acf/min

<b>Velocity</b>	12.374 m/sec	40.60 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	152.7 oC	306.8 oF
--------------------	----------	----------

<b>Moisture</b>	15.9 %
-----------------	--------

<b>Gas Analysis</b>	10.1 % O2
	10.0 % CO2

29.997 Mol. Wt (g/gmole) Dry  
28.094 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.5138 dscm	88.773 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	105.8 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 3

**Date:** 17-May-23  
**Run:** 1 - Particulate / Metals  
**Run Time:** 11:40 - 13:42

Control Unit (Y) 0.9916  
 Nozzle Diameter (in.) 0.3083  
 Pitot Factor 0.8461  
 Baro. Press. (in. Hg) 30.01  
 Static Press. (in. H2O) -19.00  
 Stack Height (ft) 30  
 Stack Diameter (in.) 70.90  
 Stack Area (sq.ft.) 27.417  
 Minutes Per Reading 5.0  
 Minutes Per Point 5.0

**Collection:**  
 Filter (grams) 0.00470  
 Washings (grams) 0.00100  
**Total (grams) 0.00570**

**Gas Analysis (Vol. %):**  

CO2	O2
9.90	10.00
10.00	10.25
<b>9.95</b>	<b>10.13</b>

**Condensate Collection:**  

Impinger 1	232.0
Impinger 2	82.0
Impinger 3	16.0
Impinger 4	9.0
Impinger 5	2.0
Impinger 6	1.0
Gel	13.6
<b>Gain (grams)</b>	<b>355.6</b>

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	966.065								
1	5.0	969.490	0.27	1.56	81	81	5	307	1.5	105.6
2	10.0	972.720	0.24	1.39	81	81	5	307	4.7	105.5
3	15.0	975.890	0.23	1.33	81	81	5	306	8.4	105.7
4	20.0	979.190	0.25	1.45	82	82	5	307	12.5	105.5
5	25.0	982.560	0.26	1.51	82	82	5	306	17.7	105.6
6	30.0	986.700	0.39	2.26	83	83	5	306	25.2	105.9
7	35.0	991.150	0.45	2.61	83	83	5	306	45.6	106.0
8	40.0	995.700	0.47	2.73	84	84	5	307	53.2	106.0
9	45.0	1000.390	0.50	2.90	84	84	6	307	58.3	106.0
10	50.0	1004.800	0.44	2.56	85	85	6	307	62.5	105.9
11	55.0	1009.110	0.42	2.44	85	85	6	307	66.1	106.0
12	60.0	1013.210	0.38	2.22	86	86	6	307	69.4	105.7
Traverse 2	0.0	1013.210								
1	5.0	1017.440	0.40	2.34	88	88	6	307	1.5	105.9
2	10.0	1021.770	0.42	2.46	88	88	6	307	4.7	105.9
3	15.0	1026.200	0.44	2.57	88	88	7	307	8.4	105.8
4	20.0	1030.480	0.41	2.40	88	88	7	307	12.5	105.9
5	25.0	1034.870	0.43	2.52	89	89	7	307	17.7	105.9
6	30.0	1038.990	0.38	2.23	88	88	7	306	25.2	105.8
7	35.0	1042.340	0.25	2.47	89	89	5	307	45.6	106.0
8	40.0	1045.550	0.23	1.35	89	89	5	307	53.2	105.6
9	45.0	1048.540	0.20	1.17	89	89	5	307	58.3	105.4
10	50.0	1051.610	0.21	1.23	89	89	5	307	62.5	105.6
11	55.0	1054.830	0.23	1.35	90	90	4	307	66.1	105.7
12	60.0	1057.900	0.21	1.23	90	90	4	307	69.4	105.4
<b>Average:</b>			0.338	2.012	85.9	85.9	5.5	306.8		105.8

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby, B.C.)  
**Source:** Unit 3

**Date:** 18-May-23  
**Run:** 2 - Particulate / Metals  
**Run Time:** 08:29 - 10:31

---

**Concentrations:**

<b>Particulate</b>	3.92 mg/dscm	0.00171 gr/dscf
	2.25 mg/Acm	0.00098 gr/Acf
	3.15 mg/dscm (@ 11% O2)	0.00138 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.256 Kg/hr	0.564 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1087 dscm/min	38391 dscf/min
	18.12 dscm/sec	640 dscf/sec
	1897 Acm/min	66978 Acf/min

<b>Velocity</b>	12.410 m/sec	40.72 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	154.1 oC	309.4 oF
--------------------	----------	----------

<b>Moisture</b>	12.6 %
-----------------	--------

<b>Gas Analysis</b>	8.6 % O2
	9.6 % CO2

29.884 Mol. Wt (g/gmole) Dry  
28.381 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.5258 dscm	89.198 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	102.4 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

<b>Client:</b>	Metro Vancouver	<b>Date:</b>	18-May-23
<b>Jobsite:</b>	WTE (Burnaby, B.C)	<b>Run:</b>	2 - Particulate / Metals
<b>Source:</b>	Unit 3	<b>Run Time:</b>	08:29 - 10:31

<b>Control Unit (Y)</b>	0.9916	<b>Collection:</b>	<b>Gas Analysis (Vol. %):</b>	<b>Condensate Collection:</b>
<b>Nozzle Diameter (in.)</b>	0.3083	Filter (grams) 0.00840	CO2 O2	Impinger 1 244.0
<b>Pitot Factor</b>	0.8461	Washings (grams) 0.00150	9.75 8.60	Impinger 2 0.9
<b>Baro. Press. (in. Hg)</b>	30.01	Traverse 1	9.50 8.60	Impinger 3 8.0
<b>Static Press. (in. H2O)</b>	-19.00	Traverse 2		Impinger 4 6.0
<b>Stack Height (ft)</b>	30	<b>Total (grams) 0.00990</b>		Impinger 5 2.0
<b>Stack Diameter (in.)</b>	70.90			Impinger 6 1.0
<b>Stack Area (sq.ft.)</b>	27.417			Gel 12.5
<b>Minutes Per Reading</b>	5.0		<b>9.63 8.60</b>	<b>Gain (grams) 274.4</b>
<b>Minutes Per Point</b>	5.0			

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	58.507								
1	5.0	62.650	0.40	2.30	76	76	6	303	1.5	102.4
2	10.0	66.890	0.42	2.34	76	76	6	307	4.7	102.6
3	15.0	71.280	0.45	2.54	77	77	6	309	8.4	102.6
4	20.0	75.600	0.44	2.51	76	76	6	311	12.5	102.4
5	25.0	80.120	0.48	2.73	76	76	6	311	17.7	102.7
6	30.0	84.270	0.40	2.29	78	78	6	308	25.2	102.5
7	35.0	87.920	0.31	1.78	78	78	6	308	45.6	102.3
8	40.0	91.330	0.27	1.55	79	79	6	309	53.2	102.3
9	45.0	94.550	0.24	1.38	79	79	5	309	58.3	102.4
10	50.0	97.700	0.23	1.32	81	81	5	312	62.5	102.1
11	55.0	100.780	0.22	1.26	81	81	5	312	66.1	102.1
12	60.0	103.720	0.20	1.15	81	81	5	312	69.4	102.2
Traverse 2	0.0	103.720								
1	5.0	107.020	0.25	1.44	83	83	6	311	1.5	102.2
2	10.0	110.460	0.27	1.57	83	83	6	307	4.7	102.3
3	15.0	114.030	0.29	1.68	83	83	6	306	8.4	102.4
4	20.0	117.670	0.30	1.74	84	84	6	306	12.5	102.4
5	25.0	120.920	0.24	1.39	84	84	5	309	17.7	102.4
6	30.0	124.550	0.30	1.79	85	85	5	310	25.2	102.3
7	35.0	128.960	0.44	2.56	86	86	7	310	45.6	102.6
8	40.0	133.980	0.57	3.31	86	86	7	310	53.2	102.8
9	45.0	138.290	0.42	2.44	87	87	6	311	58.3	102.5
10	50.0	142.550	0.41	2.38	87	87	6	312	62.5	102.6
11	55.0	146.490	0.35	2.03	87	87	5	311	66.1	102.5
12	60.0	150.073	0.29	1.69	87	87	5	311	69.4	102.3
<b>Average:</b>			0.341	1.966	81.7	81.7	5.8	309.4		102.4

**Client:** Metro Vancouver  
**Jobsite:** WTE(Burnaby,B.C)  
**Source:** Unit 3

**Date:** 18-May-23  
**Run:** 3 - Particulate / Metals  
**Run Time:** 10:41 - 12:43

---

**Concentrations:**

<b>Particulate</b>	3.13 mg/dscm	0.00137 gr/dscf
	1.71 mg/Acm	0.00075 gr/Acf
	2.57 mg/dscm (@ 11% O2)	0.00112 gr/dscf (@ 11% O2)

**Emission Rates:**

<b>Particulate</b>	0.197 Kg/hr	0.434 lb/hr
--------------------	-------------	-------------

**Flue Gas Characteristics:**

<b>Flow</b>	1048 dscm/min	37001 dscf/min
	17.46 dscm/sec	617 dscf/sec
	1922 Acn/min	67859 Acf/min

<b>Velocity</b>	12.574 m/sec	41.25 f/sec
-----------------	--------------	-------------

<b>Temperature</b>	154.6 oC	310.3 oF
--------------------	----------	----------

<b>Moisture</b>	16.8 %
-----------------	--------

<b>Gas Analysis</b>	8.8 % O2
	10.6 % CO2

30.053 Mol. Wt (g/gmole) Dry  
28.028 Mol. Wt (g/gmole) Wet

**Sample Parameters:**

<b>Sample Volume</b>	2.5220 dscm	89.063 dscf
<b>Sample Time</b>	120.0 minutes	
<b>Isokineticity</b>	106.1 %	

**\* Standard Conditions:** Metric: 20 deg C, 101.325 kPa  
Imperial: 68 deg F, 29.92 in.Hg

**Client:** Metro Vancouver  
**Jobsite:** WTE(Burnaby,B.C)  
**Source:** Unit 3

**Date:** 18-May-23  
**Run:** 3 - Particulate / Metals  
**Run Time:** 10:41 - 12:43

Control Unit (Y)	0.9916	Collection:	Gas Analysis (Vol. %):	Condensate Collection:
Nozzle Diameter (in.)	0.3083	Filter (grams) 0.00620	CO2 O2	Impinger 1 254.0
Pitot Factor	0.8511	Washings (grams) 0.00170	Traverse 1 11.00 9.00	Impinger 2 84.0
Baro. Press. (in. Hg)	30.01		Traverse 2 10.25 8.65	Impinger 3 22.0
Static Press. (in. H2O)	-19.00	<b>Total (grams) 0.00790</b>		Impinger 4 6.0
Stack Height (ft)	30			Impinger 5 3.0
Stack Diameter (in.)	70.90			Impinger 6 1.0
Stack Area (sq.ft.)	27.417			Gel 12.2
Minutes Per Reading	5.0		<b>10.63 8.83</b>	<b>Gain (grams) 382.2</b>
Minutes Per Point	5.0			

Traverse / Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Inlet (oF)	Dry Gas Outlet (oF)	Vacuum (in. Hg.)	Stack Temp. (oF)	Wall Dist. (in.)	Isokin. (%)
Traverse 1	0.0	150.492								
1	5.0	154.080	0.29	1.68	89	89	7	311	1.5	105.9
2	10.0	157.790	0.31	1.79	89	89	7	311	4.7	105.9
3	15.0	161.260	0.27	1.56	89	89	8	311	8.4	106.1
4	20.0	164.660	0.26	1.50	89	89	8	312	12.5	106.0
5	25.0	168.240	0.29	1.67	88	88	8	312	17.7	105.9
6	30.0	171.770	0.28	1.62	89	89	8	311	25.2	106.0
7	35.0	176.590	0.52	3.01	90	90	8	312	45.6	106.5
8	40.0	181.080	0.45	2.61	91	91	8	312	53.2	106.3
9	45.0	185.420	0.42	2.44	91	91	8	311	58.3	106.2
10	50.0	189.650	0.40	2.32	91	91	8	311	62.5	106.1
11	55.0	193.780	0.38	2.21	91	91	7	311	66.1	106.2
12	60.0	197.450	0.30	1.74	91	91	7	311	69.4	106.1
Traverse 2	0.0	197.450								
1	5.0	201.750	0.41	2.39	92	92	8	309	1.5	106.2
2	10.0	206.100	0.42	2.45	92	92	8	308	4.7	106.1
3	15.0	210.610	0.45	2.63	92	92	8	308	8.4	106.3
4	20.0	214.960	0.42	2.45	92	92	8	308	12.5	106.1
5	25.0	219.470	0.45	2.62	93	93	8	311	17.7	106.3
6	30.0	223.610	0.38	2.22	93	93	8	311	25.2	106.1
7	35.0	227.290	0.30	1.75	93	93	8	311	45.6	106.0
8	40.0	230.850	0.28	1.63	93	93	8	311	53.2	106.1
9	45.0	234.150	0.24	1.41	94	94	6	309	58.3	105.9
10	50.0	237.380	0.23	1.35	94	94	6	309	62.5	105.9
11	55.0	240.540	0.22	1.29	94	94	7	308	66.1	105.8
12	60.0	243.563	0.20	1.17	94	94	7	308	69.4	106.1
Average:			0.340	1.980	91.4	91.4	7.6	310.3		106.1

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)  
**Source:** Unit 3

**Sample Type:** HF

Parameter		Test 1	Test 2	Test 3
Test Date		18-May-23	18-May-23	18-May-23
Test Time		09:09 - 10:09	10:26 - 11:26	11:40 - 12:40
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.01	30.01	30.01
DGM Factor	(Y)	0.9983	0.9983	0.9983
Initial Reading	(m <sup>3</sup> )	575.795	576.393	576.976
Final Reading	(m <sup>3</sup> )	576.386	576.971	577.518
Temp. Outlet	(Avg. oF)	82.0	93.5	94.5
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm <sup>3</sup> )	0.57738	0.55275	0.51662
HF	(mg)	0.005	0.005	0.005
Oxygen	(Vol. %)	10.1	8.6	8.8
<b>HF</b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>0.009</b>	<b>0.008</b>	<b>0.010</b>
<b>HF</b>	<b>(mg/Sm<sup>3</sup> @ 11% O2)</b>	<b>0.008</b>	<b>0.007</b>	<b>0.008</b>
<b>Moisture (isokinetic)</b>	<b>(Vol. %)</b>	<b>15.9</b>	<b>12.6</b>	<b>16.8</b>

\*Wet Basis Calculated on moisture from isokinetic tests

Tstd. (oF)	68	Pstd. (in. Hg)	29.92
------------	----	----------------	-------

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)  
**Source:** Unit 3

**Sample Type:** NH<sub>3</sub>

Parameter		Test 1	Test 2	Test 3
Test Date		18-May-23	18-May-23	18-May-23
Test Time		09:09 - 10:09	10:26 - 11:26	11:40 - 12:40
Test Duration	(min.)	60	60	60
Baro. Press.	(in. Hg)	30.01	30.01	30.01
DGM Factor	(Y)	1.0320	1.0320	1.0320
Initial Reading	(m <sup>3</sup> )	251.221	251.795	252.384
Final Reading	(m <sup>3</sup> )	251.787	252.376	252.961
Temp. Outlet	(Avg. oF)	81.5	93.5	67.0
Orifice Press.	(ΔH in.H2O)	0.50	0.50	0.50
Gas Volume	(Sm <sup>3</sup> )	0.57256	0.57388	0.59933
NH <sub>3</sub>	(mg)	0.6	0.1	1.2
Oxygen	(Vol. %)	10.1	8.6	8.8
<b>NH<sub>3</sub></b>	<b>(mg/Sm<sup>3</sup>)</b>	<b>1.0</b>	<b>0.1</b>	<b>2.0</b>
<b>NH<sub>3</sub></b>	<b>(mg/Sm<sup>3</sup> @ 11% O2)</b>	<b>1.0</b>	<b>0.1</b>	<b>1.6</b>
<b>Moisture (isokinetic)</b>	<b>(Vol. %)</b>	<b>15.9</b>	<b>12.6</b>	<b>16.8</b>

\*Wet Basis Calculated on moisture from isokinetic tests

Tstd. (oF)	68	Pstd. (in. Hg)	29.92
------------	----	----------------	-------

**Client:** Metro Vancouver  
**Jobsite:** WTE (Burnaby,B.C)

**Parameter:** N<sub>2</sub>O

**Molecular Weight:** 44.00      grams/mol      **Reportable Detection**  
**Lab Detection Limit:** 0.1      ppm      **Limit:** 0.18      mg/Sm<sup>3</sup>

Sample ID	Date	Time	N <sub>2</sub> O ppm	N <sub>2</sub> O mg/Sm <sup>3</sup>	N <sub>2</sub> O mg/Sm <sup>3</sup> @ 11% O <sub>2</sub>
Unit 1 - Run 1	2023-05-16	10:00 - 11:00	0.00	0.18	0.15
Unit 1 - Run 2	2023-05-16	11:15 - 12:15	0.00	0.18	0.16
Unit 1 - Run 3	2023-05-16	12:23 - 13:23	0.00	0.18	0.17
<b>Average</b>					<b>0.16</b>
Unit 2 - Run 1	2023-05-17	09:58 - 10:58	0.00	0.18	0.18
Unit 2 - Run 2	2023-05-17	11:10 - 12:10	0.00	0.18	0.17
Unit 2 - Run 3	2023-05-17	12:22 - 13:22	0.00	0.18	0.17
<b>Average</b>					<b>0.17</b>
Unit 3 - Run 1	2023-05-18	09:09 - 10:09	0.00	0.18	0.17
Unit 3 - Run 2	2023-05-18	10:26 - 11:26	0.00	0.18	0.15
Unit 3 - Run 3	2023-05-18	11:40 - 12:40	0.00	0.18	0.15
<b>Average</b>					<b>0.16</b>

Date:	16-May-23			17-May-23			18-May-23		
	Unit 1			Unit 2			Unit 3		
	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3
<b>Test Times:</b>	09:50 - 10:50	11:10 - 12:10	12:23 - 13:23	09:58 - 10:58	11:10 - 12:10	12:22 - 13:22	09:09 - 10:09	10:26 - 11:26	11:40 - 12:40
<b>Methane (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	3.40	ND
<b>Ethane (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>Ethene (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>C3 as Propane (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>C4 as n-Butane (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>C5 as n-Pentane (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>C6 as n-Hexane (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>C6+ as n-Hexane (ppmv)</b>	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Detection Limits:**

Methane	3.3	3.0	3.1	2.7	3.3	3.3	3.0	3.1	2.7
Ethane	1.00	0.89	0.92	0.81	1.0	1.00	0.89	0.92	0.81
Ethene	1.00	0.89	0.92	0.81	1.0	1.00	0.89	0.92	0.81
C3 as Propane	0.83	0.75	0.77	0.68	0.83	0.86	1.10	0.62	0.91
C4 as n-Butane	0.83	0.75	0.77	0.68	0.83	0.86	1.10	0.62	0.91
C5 as n-Pentane	0.83	0.75	0.77	0.68	0.83	0.86	1.10	0.62	0.91
C6 as n-Hexane	0.83	0.75	0.77	0.68	0.83	0.86	1.10	0.62	0.91
C6+	1.7	1.5	1.5	1.4	1.7	1.7	2.3	1.2	1.8

**Using 1/2 DL Convention**

Sample Date:	16-May-23			17-May-23			18-May-23		
	Unit 1			Unit 2			Unit 3		
	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3
<b>Test Times:</b>	09:50 - 10:50	11:10 - 12:10	12:23 - 13:23	09:58 - 10:58	11:10 - 12:10	12:22 - 13:22	09:09 - 10:09	10:26 - 11:26	11:40 - 12:40
<b>Methane (ppm)</b>	1.65	1.50	1.55	1.35	1.65	1.65	1.50	3.40	1.35
<b>Ethane (ppm)</b>	0.50	0.45	0.46	0.41	0.50	0.50	0.45	0.46	0.41
<b>Ethene (ppm)</b>	0.50	0.45	0.46	0.41	0.50	0.50	0.45	0.46	0.41
<b>C3 as Propane (ppm)</b>	0.42	0.38	0.39	0.34	0.42	0.43	0.55	0.31	0.46
<b>C4 as n-Butane (ppm)</b>	0.42	0.38	0.39	0.34	0.42	0.43	0.55	0.31	0.46
<b>C5 as n-Pentane (ppm)</b>	0.42	0.38	0.39	0.34	0.42	0.43	0.55	0.31	0.46
<b>C6 as n-Hexane (ppm)</b>	0.42	0.38	0.39	0.34	0.42	0.43	0.55	0.31	0.46
<b>C6+ as n-Hexane (ppm)</b>	0.85	0.75	0.75	0.70	0.85	0.85	1.15	0.60	0.90

<b>Methane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	1.10	1.00	1.03	0.90	1.10	1.10	1.00	2.27	0.90
<b>Ethane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.33	0.30	0.31	0.27	0.33	0.33	0.30	0.31	0.27
<b>Ethene (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.33	0.30	0.31	0.27	0.33	0.33	0.30	0.31	0.27
<b>C3 as Propane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.28	0.25	0.26	0.23	0.28	0.29	0.37	0.21	0.30
<b>C4 as n-Butane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.28	0.25	0.26	0.23	0.28	0.29	0.37	0.21	0.30
<b>C5 as n-Pentane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.28	0.25	0.26	0.23	0.28	0.29	0.37	0.21	0.30
<b>C6 as n-Hexane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.28	0.25	0.26	0.23	0.28	0.29	0.37	0.21	0.30
<b>C6+ as n-Hexane (mg/m<sup>3</sup> as CH<sub>4</sub>)</b>	0.57	0.50	0.50	0.47	0.57	0.57	0.77	0.40	0.60
<b>Total mg/Sm<sup>3</sup> @11% O<sub>2</sub> as CH<sub>4</sub></b>	2.82	2.26	2.32	1.88	2.54	2.56	2.50	3.41	2.65

All data is corrected to standard conditions (S) of 20 °C, 101.325 kPa (dry) unless otherwise noted.

**APPENDIX - E**

**FIELD DATA SHEETS**

METRO VANCOUVER WTE - BURNABY B.C.					NOZZLE PROBE	G-309 DIAMETER, IN. 0.3058 FAL GYRO-1 Cp 0.8352		IMPINGER VOLUMES	INITIAL (mL)	FINAL (mL)	TOTAL GAIN (mL)			
SOURCE Unit #1					PORT LENGTH					Imp. #1	0	229	229	
PARAMETER / RUN No Metals / Particulate / R-1					STATIC PRESSURE, IN. H2O -19.0"					Imp. #2	100	192	92	
DATE May. 15, 2023					STACK DIAMETER 30.9"					Imp. #3	100	120	20	
OPERATOR: DS					STACK HEIGHT 30.0'					Imp. #4	0	6	6	
CONTROL UNIT CAE G105 Y 0.9818					INITIAL LEAK TEST 0.002 @ 15"					Imp. #5	100	102	2	
					FINAL LEAK TEST 0.003 @ 15"					Imp. #6	100	101	1	
BAROMETRIC PRESSURE, IN. Hg 29.92										Imp. #8	0.01200			
ASSUMED MOISTURE, Bw 14%														
Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites			
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %		
1		562.401												
2	10	565.93	0.28	1.82	93	289	282	247	91	5				
3		569.57	0.30	1.62	93	293					11.0	8.2		
4	20	572.83	0.24	1.30	93	297	252	252	73	5.5				
5		576.07	0.23	1.75	94	293								
6	30	579.28	0.24	1.30	94	297	252	249	62	5				
7		582.90	0.30	1.63	94	297					10.5	9.3		
8	40	587.78	0.43	2.34	95	292	252	250	59	6				
9		591.98	0.50	2.43	95	292								
10	50	596.80	0.52	2.83	95	292	252	249	56	8				
11		601.47	0.49	2.68	97	292					11.5	8.9		
12	60	605.60	0.38	2.08	98	290	252	249	61	7				
		609.67	0.37	2.03	98	290								
1		614.03	0.42	2.37	99	288	252	250	68	6	11.5	8.4		
2	10	618.44	0.44	2.45	99	290								
3		622.69	0.39	2.14	99	290	252	254	63	8				
4	20	626.98	0.41	2.25	99	290								
5		631.28	0.40	2.20	100	291	252	248	61	8	11.0	8.7		
6	30	635.57	0.40	2.20	100	291								
7		639.56	0.36	1.98	100	291	252	249	63	8				
8	40	643.66	0.37	2.03	100	291								
9		647.54	0.33	1.82	101	291	252	251	64	8				
10	50	651.30	0.31	1.71	101	291					11.0	8.9		
11		654.99	0.30	1.65	100	290	252	248	62	7				
12	13:44	658.56	0.28	1.55	101	289								



METRO VANCOUVER WTE - BURNABY B.C.					NOZZLE	G-309		DIAMETER, IN.	0.3058	IMPINGER	INITIAL	FINAL	TOTAL GAIN
SOURCE					PROBE	F'AL GURD		Cp	0.8352	VOLUMES	(mL)	(mL)	(mL)
PARAMETER / RUN No					PORT LENGTH					Imp. #1			
DATE					STATIC PRESSURE, IN. H2O					Imp. #2			
OPERATOR:					STACK DIAMETER					Imp. #3			
CONTROL UNIT					STACK HEIGHT					Imp. #4			
										Imp. #5			
										Imp. #6			
BAROMETRIC PRESSURE, IN. Hg					INITIAL LEAK TEST					Imp. #7			
ASSUMED MOISTURE, Bw					FINAL LEAK TEST					Imp. #8			
Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites		
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %	
1	11:29	757.012											
2	10	761.77	0.51	2.75	90	292	253	246	65	4			
3		766.75	0.58	3.13	90	292					9.5	10.2	
4	20	771.85	0.60	3.23	90	294	252	252	60	6			
5		776.85	0.58	3.11	89	295							
6	30	781.89	0.59	3.15	89	297	252	250	64	6			
7		786.68	0.53	2.84	90	296							
8	40	791.38	0.51	2.74	91	297	252	250	58	7	9.5	10.6	
9		795.80	0.45	2.41	91	297							
10	50	800.08	0.42	2.26	91	297	252	250	49	7			
11		804.08	0.37	1.99	92	297							
12	60	807.98	0.35	1.88	92	298	252	250	50	8	9.5	10.5	
		811.66	0.31	1.67	92	298							
1		815.83	0.40	2.15	92	297	252	280	82	6			
2	10	819.79	0.36	1.94	92	297					9.5	10.3	
3		823.23	0.27	1.45	93	297	252	281	54	6			
4	20	826.58	0.26	1.40	93	297							
5		829.95	0.26	1.40	93	296	252	249	56	6			
6	30	833.26	0.28	1.35	93	296					10.5	9.5	
7		837.45	0.40	2.16	93	294	252	280	52	6			
8	40	841.75	0.42	2.27	93	294							
9		846.20	0.45	2.44	93	292	252	281	54	7			
10	50	850.45	0.41	2.23	93	290							
11		854.50	0.37	2.07	95	288	252	250	55	6	10.5	9.3	
12	13:31	858.35	0.33	1.81	96	286							



METRO VANCOUVER WTE - BURNABY B.C.					NOZZLE		DIAMETER, IN.		IMPINGER		INITIAL		FINAL		TOTAL GAIN	
					PROBE		Cp		VOLUMES		(mL)		(mL)		(mL)	
SOURCE					PORT LENGTH				Imp. #1							
PARAMETER / RUN No					STATIC PRESSURE, IN. H2O				Imp. #2							
DATE					STACK DIAMETER				Imp. #3							
OPERATOR:					STACK HEIGHT				Imp. #4							
CONTROL UNIT					INITIAL LEAK TEST				Imp. #5							
					FINAL LEAK TEST				Imp. #6							
BAROMETRIC PRESSURE, IN. Hg									Imp. #7							
ASSUMED MOISTURE, Bw									Imp. #8							
											</					

J-H

METRO VANCOUVER WTE - BURNABY B.C.					NOZZLE <i>G-3072</i> DIAMETER, IN. <i>0.3087</i>		PROBE <i>7C</i> Cp <i>0.8311</i>		IMPINGER	INITIAL	FINAL	TOTAL GAIN			
SOURCE <i>Unit #2</i>					PORT LENGTH					Imp. #1	(mL)	(mL)	(mL)		
PARAMETER / RUN No <i>Methane/Particulate/R-3</i>					STATIC PRESSURE, IN. H2O <i>- 19.5"</i>					Imp. #2	<i>0</i>	<i>222</i>	<i>222</i>		
DATE <i>May 17, 2023</i>					STACK DIAMETER <i>70.9"</i>					Imp. #3	<i>100</i>	<i>178</i>	<i>78</i>		
OPERATOR: <i>AS</i>					STACK HEIGHT <i>30.0'</i>					Imp. #4	<i>100</i>	<i>126</i>	<i>26</i>		
CONTROL UNIT <i>AU 15</i> Y <i>0.9976</i>					INITIAL LEAK TEST <i>0.001 @ 15"</i>					Imp. #5	<i>0</i>	<i>8</i>	<i>8</i>		
ΔH@ <i>1.739</i>					FINAL LEAK TEST <i>0.001 @ 15"</i>					Imp. #6	<i>100</i>	<i>103</i>	<i>3</i>		
BAROMETRIC PRESSURE, IN. Hg <i>29.95</i>										Imp. #7	<i>100</i>	<i>101</i>	<i>1</i>		
ASSUMED MOISTURE, Bw <i>14%</i>										Imp. #8	<i>100</i>	<i>101</i>	<i>1</i>		
Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Temperature °F					Pump Vac. IN. Hg	Fyrites				
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %			
1		<i>4.940</i>													
2	10	<i>8.90</i>	<i>0.35</i>	<i>1.92</i>	<i>87</i>	<i>296</i>	<i>250</i>	<i>243</i>	<i>45</i>	<i>7</i>					
3		<i>12.96</i>	<i>0.37</i>	<i>2.03</i>	<i>88</i>	<i>297</i>					<i>9.5</i>	<i>10.4</i>			
4	20	<i>17.09</i>	<i>0.38</i>	<i>2.09</i>	<i>88</i>	<i>297</i>	<i>261</i>	<i>256</i>	<i>48</i>	<i>8</i>					
5		<i>21.22</i>	<i>0.38</i>	<i>2.09</i>	<i>88</i>	<i>297</i>									
6	30	<i>25.38</i>	<i>0.39</i>	<i>2.14</i>	<i>88</i>	<i>298</i>	<i>264</i>	<i>251</i>	<i>49</i>	<i>8</i>					
7		<i>29.56</i>	<i>0.39</i>	<i>2.14</i>	<i>88</i>	<i>298</i>									
8	40	<i>33.36</i>	<i>0.37</i>	<i>1.76</i>	<i>89</i>	<i>298</i>	<i>251</i>	<i>242</i>	<i>50</i>	<i>7</i>	<i>9.5</i>	<i>10.6</i>			
9		<i>36.92</i>	<i>0.28</i>	<i>1.54</i>	<i>89</i>	<i>299</i>									
10	50	<i>40.35</i>	<i>0.26</i>	<i>1.43</i>	<i>89</i>	<i>300</i>	<i>251</i>	<i>245</i>	<i>52</i>	<i>6</i>					
11		<i>43.92</i>	<i>0.28</i>	<i>1.54</i>	<i>90</i>	<i>298</i>									
12	60	<i>47.36</i>	<i>0.26</i>	<i>1.44</i>	<i>91</i>	<i>297</i>	<i>250</i>	<i>262</i>	<i>54</i>	<i>7</i>	<i>9.5</i>	<i>10.2</i>			
		<i>50.53</i>	<i>0.22</i>	<i>1.22</i>	<i>92</i>	<i>298</i>									
1		<i>54.23</i>	<i>0.30</i>	<i>1.66</i>	<i>93</i>	<i>300</i>	<i>247</i>	<i>251</i>	<i>58</i>	<i>7</i>					
2	10	<i>57.80</i>	<i>0.28</i>	<i>1.55</i>	<i>93</i>	<i>300</i>					<i>10.5</i>	<i>9.4</i>			
3		<i>60.97</i>	<i>0.22</i>	<i>1.21</i>	<i>93</i>	<i>300</i>	<i>245</i>	<i>247</i>	<i>59</i>	<i>7</i>					
4	20	<i>64.08</i>	<i>0.21</i>	<i>1.16</i>	<i>93</i>	<i>299</i>									
5		<i>67.33</i>	<i>0.23</i>	<i>1.27</i>	<i>94</i>	<i>299</i>	<i>248</i>	<i>252</i>	<i>60</i>	<i>7</i>	<i>9.5</i>	<i>9.8</i>			
6	30	<i>70.78</i>	<i>0.26</i>	<i>1.44</i>	<i>94</i>	<i>299</i>									
7		<i>74.45</i>	<i>0.38</i>	<i>2.11</i>	<i>94</i>	<i>298</i>	<i>250</i>	<i>252</i>	<i>57</i>	<i>8</i>					
8	40	<i>79.68</i>	<i>0.49</i>	<i>2.72</i>	<i>93</i>	<i>297</i>									
9		<i>84.46</i>	<i>0.50</i>	<i>2.77</i>	<i>93</i>	<i>297</i>	<i>249</i>	<i>253</i>	<i>53</i>	<i>8</i>	<i>10.0</i>	<i>9.6</i>			
10	50	<i>89.43</i>	<i>0.54</i>	<i>3.00</i>	<i>94</i>	<i>297</i>									
11		<i>94.32</i>	<i>0.52</i>	<i>2.90</i>	<i>94</i>	<i>293</i>	<i>252</i>	<i>254</i>	<i>55</i>	<i>8</i>					
12	<i>13:39</i>	<i>99.08</i>	<i>0.49</i>	<i>2.75</i>	<i>95</i>	<i>290</i>									

PA

[illegible]

5#

A. Lanfranco and Associates Inc.

CLIENT <b>MU WTE</b>					NOZZLE <b>4-3121</b>		DIAMETER, IN. <b>3083</b>		IMPINGER		INITIAL	FINAL	TOTAL GAIN		
SOURCE <b>Unit #3</b>					PROBE <b>7A-1</b>		Cp <b>.8461</b>		VOLUMES		(mL)	(mL)	(mL)		
PARAMETER / RUN No <b>metals / part 122</b>					PORT LENGTH				Imp. #1		0	244	244		
DATE <b>5.18.23</b>					STATIC PRESSURE, IN. H2O <b>19</b>				Imp. #2		100	186	86		
OPERATOR <b>SA+7C</b>					STACK DIAMETER				Imp. #3		100	108	8		
CONTROL UNIT <b>STCAE2</b>					STACK HEIGHT				Imp. #4		0	6	6		
Y <b>9916</b>									Imp. #5		100	102	2		
ΔH@ <b>1.873</b>									Imp. #6		100	101	1		
BAROMETRIC PRESSURE, IN. Hg <b>30.01</b>					INITIAL LEAK TEST <b>10000154</b>				Upstream Diameters						
ASSUMED MOISTURE, Bw <b>13%</b>					FINAL LEAK TEST <b>10000154</b>				Downstream Diameters						
									Tests #1						
Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H2O	Orifice ΔH IN. H2O	Temperature °F					Pump Vac. IN. Hg	Fyrites				
					Dry Gas Outlet	Stack	Probe	Box	Impinger Exit		CO <sub>2</sub> Vol. %	O <sub>2</sub> Vol. %			
1	8:29	58.507	1.40	2.30	76	303	280	281	58	6.0					
2	10	66.89	1.42	2.40	76	307									
3		71.28	1.45	2.57	77	309	249	252	58	6.0	10.0	8.7			
4	20	75.60	1.44	2.51	76	311									
5		80.12	1.48	2.73	76	311	287	280	58	6.0					
6	30	84.77	1.40	2.79	78	308									
7		87.92	1.31	1.78	78	308	250	249	58	6.0					
8	40	91.33	1.24	1.53	79	309									
9		94.55	1.24	1.38	79	309	280	281	58	5.0					
10	50	97.90	1.23	1.32	81	312					9.5	8.5			
11		100.78	1.22	1.26	81	312	280	249	58	4.5					
12	60	103.71	1.20	1.15	81	312									
1		107.02	1.25	1.44	83	311	250	249	54	9.8					
2	10	110.44	1.27	1.57	83	307									
3		114.83	1.29	1.68	83	306	257	250	46	5.5	10.0	9.7			
4	20	117.87	1.30	1.74	84	306									
5		120.92	1.24	1.30	84	309	252	248	58	5.0					
6	30	124.55	1.20	1.74	85	310									
7		128.06	1.44	2.56	86	310	253	250	54	6.5					
8	40	133.28	1.27	2.36	86	310									
9		138.29	1.42	2.44	87	311	254	248	58	6.0	9.0	9.5			
10	50	141.55	1.41	2.39	87	312									
11		144.49	1.35	2.03	87	311	250	251	58	4.5					
12	10:31	158.073	1.20	1.69	87	311									
END TEST															

CLIENT <b>MV WTE</b>					NOZZLE <b>G-3121</b> DIAMETER, IN. <b>3083</b>					IMPINGER				INITIAL		FINAL		TOTAL GAIN	
SOURCE <b>Unit #3</b>					PROBE <b>7C</b> Cp <b>18511</b>					VOLUMES				(mL)		(mL)		(mL)	
PARAMETER / RUN No <b>Metals / PMHE R3</b>					PORT LENGTH					Imp. #1				0		184		254	
DATE <b>5/18/23</b>					STATIC PRESSURE, IN. H2O <b>1.19</b>					Imp. #2				100		184		84	
OPERATOR: <b>SG + JC</b>					STACK DIAMETER					Imp. #3				100		172		22	
CONTROL UNIT <b>5+ CAE2</b> Y <b>99/6</b>					STACK HEIGHT <b>30.0</b>					Imp. #4				0		6		9	
BAROMETRIC PRESSURE, IN. Hg <b>30.01</b>					INITIAL LEAK TEST <b>1.0000157</b>					Imp. #5				100		103		3	
ASSUMED MOISTURE, Bw <b>140%</b> ΔH@ <b>1.873</b>					FINAL LEAK TEST <b>1.000015</b>					Imp. #6				100		107		7	
										Upstream Diameters									
										Downstream Diameters									
										Pump Vac.				Fyrites					
										IN. Hg				CO <sub>2</sub> Vol. %					
														O <sub>2</sub> Vol. %					
Point	Clock Time	Dry Gas Meter ft <sup>3</sup>	Pitot ΔP IN. H <sub>2</sub> O	Orifice ΔH IN. H <sub>2</sub> O	Dry Gas Outlet	Stack	Probe	Box	Impinger Exit										
1	10:41	150.492	1.29	1.68	89	311	250	257	58	7.0	11	9							
2	10	157.79	1.31	1.69	89	311	250	257	58	7.0	11	9							
3		161.76	1.27	1.56	89	311	250	250	58	7.5									
4	20	164.66	1.26	1.50	89	312	250	251	58	7.5									
5		168.54	1.28	1.67	89	312	250	251	58	7.5									
6	30	171.77	1.28	1.67	89	311	250	251	58	7.5									
7		176.59	0.82	3.01	90	312	250	250	59	9.0									
8	40	181.08	1.45	2.11	91	312	250	250	59	9.0									
9		185.42	1.42	2.14	91	311	250	249	58	8.0	11	9							
10	50	189.65	1.40	2.32	91	311	250	249	58	8.0									
11		193.78	1.38	2.31	91	311	250	257	58	6.5									
12	60	197.45	1.30	1.74	91	311													
1		201.95	1.11	2.39	92	309	250	299	58	8.0									
2	10	206.10	1.42	2.45	92	308	250	299	58	8.0									
3		210.61	1.45	2.40	92	308	257	248	57	9.0	10.5	8.5							
4	20	214.96	1.42	2.45	92	308	257	248	57	9.0									
5		219.44	1.45	2.40	93	311	250	297	57	9.0									
6	30	223.61	1.38	2.22	93	311	257	254	57	7.5									
7		227.94	1.30	1.75	93	311	257	254	57	7.5									
8	40	230.85	1.28	1.43	93	311	257	254	57	7.5									
9		234.15	1.24	1.41															

A. Lanfranco and Associates Inc.

Client MV WTE Y LMU-A = 0.9983  
 Source Unit 1 Cp  
 Parameter HF Pbar 30.06 Static  
 Date 16-May-23 Operator Christian

Leak Check	Run 1	Run 2	Run 3
Initial	0.0002	0.0001	0.0001
Final	0.0001	0.0001	0.0001

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H <sub>2</sub> O		
			DGM Outlet	Stack		R1	R2	R3
1	0954	572.2081	75					
	1054	572.6716	94					
2	1110	572.6775	82					
	1210	573.2898	90					
3	1223	573.2917	84					
	1323	573.9681	93					

Client MV WTE Y LMU-D = 1.0609  
 Source Unit 1 Cp  
 Parameter NH<sub>3</sub> Pbar 30.06 Static  
 Date 16-May-23 Operator Christian

Leak Check	Run 1	Run 2	Run 3
Initial	0.0001	0.0001	0.0001
Final	0.0001	0.0001	0.0001

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H <sub>2</sub> O		
			DGM Outlet	Stack		R1	R2	R3
4	0954	103.0666	73					
	1054	103.5478	91					
5	1110	103.5527	91					
	1210	104.1584	96					
6	1223	104.1626	88					
	1323	104.7810	102					

A. Lanfranco and Associates Inc.

DS✓

Client MV WTE Y LMU-A = 0.9983  
 Source Unit 2 Cp \_\_\_\_\_  
 Parameter HF Pbar 29.96 Static \_\_\_\_\_  
 Date 17-May-23 Operator Christian

Leak Check	Run 1	Run 2	Run 3
Initial	0.000/	0.000/	0.000/
Final	0.000/	0.000/	0.000/

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H <sub>2</sub> O		
			DGM Outlet	Stack		R1	R2	R3
1	0958	573.9735	60					
	1058	574.5657	84					
2	1110	574.5702	83					
	1210	575.1802	88					
3	1222	575.1860	88					
	1322	575.7820	89					

DS✓

Client MV WTE Y LMU-B = 1.0320  
 Source Unit 2 Cp \_\_\_\_\_  
 Parameter NH<sub>3</sub> Pbar 29.96 Static \_\_\_\_\_  
 Date 17-May-23 Operator Christian

Leak Check	Run 1	Run 2	Run 3
Initial	0.000/	0.000/	0.000/
Final	0.000/	0.000/	0.000/

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H <sub>2</sub> O		
			DGM Outlet	Stack		R1	R2	R3
4	0958	249.5194	60					
	1058	250.0188	83					
5	1110	250.0239	81					
	1210	250.5908	91					
6	1222	250.5972	83					
	1322	251.791	93					

A. Lanfranco and Associates Inc. *DL*

Client MV WTE Y LMU-A = 0.9983  
 Source Unit 3 Cp  
 Parameter H<sub>2</sub>F Pbar 30.01 Static  
 Date 18-May-23 Operator Christian

Leak Check	Run 1	Run 2	Run 3
Initial	0.0001	0.0001	0.0001
Final	0.0001	0.0001	0.0001

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m <sup>3</sup> )	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H <sub>2</sub> O		
			DGM Outlet	Stack		R1	R2	R3
<b>1</b>	0909	575.7945	71					
	1009	576.3857	93					
<b>2</b>	1026	576.3929	91					
	1126	576.9709	96					
<b>3</b>	1140	576.9764	92					
	1240	577.5176	97					

Client MV WTE Y LMU-B = 1.0320  
 Source Unit 3 Cp  
 Parameter NH<sub>3</sub> Pbar 30.01 Static  
 Date 18-May-23 Operator Christian

Leak Check	Run 1	Run 2	Run 3
Initial	0.0001	0.0001	0.0001
Final	0.0001	0.0001	0.0001

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m <sup>3</sup> )	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H <sub>2</sub> O		
			DGM Outlet	Stack		R1	R2	R3
<b>4</b>	0909	251.2205	72					
	1009	251.7871	93					
<b>5</b>	1026	251.7954	91					
	1126	252.3759	96					
<b>6</b>	1140	252.3839	72					
	1240	252.9611	62					

OK ✓  
entire

NO2  
AnalystsM.L

*No2*

## CEM READINGS

[illegible]

**APPENDIX – F**

**CALIBRATION SHEETS and**

**TECHNICIAN CERTIFICATES**

## Pitot Tube Calibration

Date: 11-Jan-23  
Pbar (in.Hg): 29.74

Temp (R): 539  
Dn (in.): 0.25

Pitot ID: **7A-1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.055	0.075	15.7	0.8478	0.0016
0.095	0.130	20.6	0.8463	0.0002
0.420	0.560	43.4	0.8574	0.0112
0.600	0.830	51.9	0.8417	0.0044
0.730	1.020	57.2	0.8375	0.0086
Average :			0.8461	0.0052

Pitot ID: **ST 8A**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.040	0.055	13.4	0.8443	0.0031
0.120	0.170	23.2	0.8318	0.0156
0.300	0.400	36.7	0.8574	0.0100
0.470	0.630	45.9	0.8551	0.0077
0.720	0.980	56.8	0.8486	0.0012
Average :			0.8474	0.0075

Pitot ID: **7B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.030	0.040	11.6	0.8574	0.0151
0.150	0.210	25.9	0.8367	0.0056
0.230	0.320	32.1	0.8393	0.0030
0.430	0.610	43.9	0.8312	0.0111
0.710	0.970	56.4	0.8470	0.0047
Average :			0.8423	0.0079

Pitot ID: **ST 8B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.045	0.060	14.2	0.8574	0.0046
0.230	0.320	32.1	0.8393	0.0135
0.430	0.580	43.9	0.8524	0.0003
0.630	0.840	53.2	0.8574	0.0046
0.690	0.920	55.6	0.8574	0.0046
Average :			0.8528	0.0055

Pitot ID: **7 AL GVRD-1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.050	0.070	16.3	0.8367	0.0015
0.105	0.145	19.9	0.8425	0.0073
0.250	0.350	25.3	0.8367	0.0015
0.430	0.610	35.8	0.8312	0.0040
0.680	0.970	48.4	0.8289	0.0063
Average :			0.8352	0.0041

Pitot ID: **ST 8C**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.055	0.075	14.9	0.8478	0.0021
0.105	0.145	19.4	0.8425	0.0033
0.210	0.290	29.0	0.8425	0.0033
0.500	0.680	43.1	0.8489	0.0032
0.710	0.970	52.8	0.8470	0.0013
Average :			0.8457	0.0026

Pitot ID: **7C**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.040	0.055	13.4	0.8443	0.0069
0.150	0.200	16.3	0.8574	0.0062
0.430	0.580	43.9	0.8524	0.0013
0.480	0.660	30.5	0.8443	0.0069
0.690	0.920	47.0	0.8574	0.0062
Average :			0.8511	0.0055

Pitot ID:

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
Average :				

\* Average absolute deviation must not exceed 0.01.

Calibrated by: Justin Ching

Signature: Carter Lanfranco

Date:

January 11, 2023

# A.Lanfranco & Associates inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

Model #: AU 15  
Serial #: 0028SPC-081915-1

Date: 10-Jan-23  
Barometric Pressure: 29.59 (in. Hg)  
Theoretical Critical Vacuum: 13.96 (in. Hg)

!!!!!!!  
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>((in.Hg)<sup>2</sup>(min)).  
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.40	16.00	250.496	267.425	16.929	75.0	75.0	74.0	74.0	73	0.8185	17.5	83.0	82.0	82.5
1.80	15.00	238.876	250.496	11.620	73.0	73.0	76.0	76.0	63	0.5956	20.0	80.0	84.0	82.0
1.20	15.00	229.882	238.876	8.994	70.0	70.0	73.0	73.0	55	0.4606	22.5	80.0	84.0	82.0
0.60	15.00	223.065	229.882	6.817	67.0	67.0	69.0	69.0	48	0.3560	23.0	71.0	77.0	74.0
0.29	15.00	218.360	223.065	4.705	66.0	66.0	62.0	62.0	40	0.2408	24.5	67.0	74.0	70.5

***** RESULTS *****														
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----					
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y			CALIBRATION FACTOR dH@					
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)		Value (in H2O)	Value (mm H2O)	Variation (in H2O)			Ko (value)
16.672	472.1		16.637	471.2	17.292	0.998	0.000		1.728	43.89	-0.011			0.728
11.398	322.8		11.355	321.6	11.791	0.996	-0.001		1.726	43.84	-0.013			0.731
8.859	250.9		8.781	248.7	9.118	0.991	-0.006		1.935	49.15	0.196			0.694
6.749	191.1		6.838	193.6	6.995	1.013	0.016		1.606	40.80	-0.133			0.746
4.690	132.8		4.640	131.4	4.716	0.989	-0.008		1.699	43.14	-0.040			0.743
Average Y----->						0.9976	Average dH@----->		1.739	44.2	Average Ko----->		0.728	

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Results		
		Variation (degF)	Percent of Absolute	
32	32	0	0.00%	
100	100	0	0.00%	
300	300	0	0.00%	
500	500	0	0.00%	
1000	1000	0	0.00%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.  
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 dm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.  
For Temperature Devices, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Ben Lester

Signature: *Carter Lanfranco*

Date: January 10, 2023

# BAROMETER CALIBRATION FORM

Device	Cal Date	Pbar Env Canada		Device (inches of Hg)		Difference
		(kPa)	(inches of Hg)	Reading	Elevation Corrected	(Env Can - Elv Corr)
LA	10-Jan-23	100.5	29.68	29.56	29.63	0.05
DS	10-Jan-23	100.5	29.68	29.55	29.62	0.06
CL	10-Jan-23	100.5	29.68	29.56	29.63	0.05
JC	10-Jan-23	100.5	29.68	29.53	29.60	0.08
SB (LF)	10-Jan-23	100.5	29.68	29.55	29.62	0.06
SH	10-Jan-23	100.5	29.68	29.58	29.65	0.03
CDO	10-Jan-23	100.5	29.68	29.53	29.60	0.08
JG	10-Jan-23	100.5	29.68	29.51	29.58	0.10

Calibrated by: Louis Agassiz

Signature:



Date:

10-Jan-23

## Performance Specification is

**Device Corrected for Elevation must be +/- 0.1 " Hg of ENV CANADA SEA-LEVEL Pbar**

Enter Environment Canada Pressure from their website for Vancouver (link below)

and the reading from your barometer on the ground floor of the office.

[https://weather.gc.ca/city/pages/bc-74\\_metric\\_e.html](https://weather.gc.ca/city/pages/bc-74_metric_e.html)

# A.Lanfranco & Associates inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

Model #: CAE G10J  
Serial #: 0028-1X1310-1

Date: 10-Jan-23  
Barometric Pressure: 29.55 (in. Hg)  
Theoretical Critical Vacuum: 13.94 (in. Hg)

!!!!!!!  
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>((in.Hg)<sup>2</sup>(min)).  
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.60	17.00	937.261	955.649	18.388	74.0	74.0	75.0	75.0	73	0.8185	15.5	85.5	82.5	84.0
1.90	16.00	924.799	937.261	12.462	73.0	73.0	74.0	74.0	63	0.5956	18.5	87.0	88.0	87.5
1.15	19.00	913.210	924.799	11.589	71.0	71.0	72.0	72.0	55	0.4606	20.0	80.5	81.0	80.8
0.62	16.00	905.781	913.210	7.429	70.0	70.0	71.0	71.0	48	0.3560	22.0	74.0	80.0	77.0
0.33	16.00	900.665	905.781	5.116	67.0	67.0	71.0	71.0	40	0.2408	23.5	64.0	73.0	68.5

***** RESULTS *****													
--- DRY GAS METER ---		----- ORIFICE -----		-- DRY GAS METER --		----- ORIFICE -----							
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y	CALIBRATION FACTOR dH@							
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)	Ko (value)			
18.093	512.4	17.629	499.3	18.398	0.974	-0.007	1.837	46.66	0.015	0.711			
12.234	346.5	12.035	340.8	12.641	0.984	0.002	1.846	46.90	0.024	0.704			
11.398	322.8	11.121	314.9	11.537	0.976	-0.006	1.853	47.06	0.031	0.709			
7.311	207.0	7.263	205.7	7.483	0.994	0.012	1.663	42.25	-0.158	0.736			
5.045	142.9	4.952	140.3	5.021	0.982	0.000	1.910	48.51	0.088	0.695			
Average Y----->					0.9818	Average dH@----->	1.822	46.3	Average Ko----->	0.711			

TEMPERATURE CALIBRATION				
Calibration Standard -----> Omega Model CL23A S/N:T-218768				
Reference Temperature		Temperature Device		Results
Set-Point (deg F)		Reading (deg F)		Variation (deg F)
32		32		0
100		100		0
300		300		0
500		500		0
1000		1000		0

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.  
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 dm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.  
For Temperature Devices, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Ben Lester

Signature: *Carter Lanfranco*

Date: January 10, 2023

# A. LANFRANCO and ASSOCIATES INC.

## ENVIRONMENTAL CONSULTANTS

### GLASS NOZZLE DIAMETER CALIBRATION FORM

Calibrated by: Christian De La O

Date: January 10, 2023

Signature: *Carter Lanfranco*

Nozzle I.D.	d1	d2	d3	difference	average dia.	average area
	(inch)	(inch)	(inch)	(inch)	(inch)	(ft <sup>2</sup> )
A	0.1270	0.1270	0.1255	0.0015	0.1265	0.0000873
G-165	0.1650	0.1660	0.1645	0.0015	0.1652	0.0001488
G-170	0.1700	0.1710	0.1695	0.0015	0.1702	0.0001579
G-178	0.1760	0.1770	0.1790	0.0030	0.1773	0.0001715
E	0.1950	0.1930	0.1960	0.0030	0.1947	0.0002067
L	0.2100	0.2070	0.2090	0.0030	0.2087	0.0002375
Q	0.2110	0.2085	0.2100	0.0025	0.2098	0.0002401
P-2240	0.2160	0.2155	0.2170	0.0015	0.2162	0.0002549
P-224	0.2170	0.2160	0.2180	0.0020	0.2170	0.0002568
G-221	0.2160	0.2185	0.2190	0.0030	0.2178	0.0002588
G-225	0.2190	0.2175	0.2180	0.0015	0.2182	0.0002596
G-2232	0.2210	0.2200	0.2215	0.0015	0.2208	0.0002660
P-223	0.2220	0.2210	0.2200	0.0020	0.2210	0.0002664
G-245	0.2470	0.2455	0.2460	0.0015	0.2462	0.0003305
P-251	0.2545	0.2530	0.2540	0.0015	0.2538	0.0003514
P-254	0.2550	0.2540	0.2535	0.0015	0.2542	0.0003523
P-256	0.2540	0.2550	0.2560	0.0020	0.2550	0.0003547
G-282	0.2820	0.2800	0.2825	0.0025	0.2815	0.0004322
P-281	0.2820	0.2820	0.2815	0.0005	0.2818	0.0004332
G-292	0.2820	0.2840	0.2850	0.0030	0.2837	0.0004389
G-309	0.3045	0.3065	0.3065	0.0020	0.3058	0.0005101
G-3121	0.3090	0.3085	0.3075	0.0015	0.3083	0.0005185
G-3091	0.3080	0.3080	0.3090	0.0010	0.3083	0.0005185
G-3072	0.3090	0.3070	0.3100	0.0030	0.3087	0.0005196
P-313	0.3140	0.3130	0.3130	0.0010	0.3133	0.0005355
P-314	0.3135	0.3135	0.3140	0.0005	0.3137	0.0005366
P-315	0.3145	0.3145	0.3145	0.0000	0.3145	0.0005395
V-06	0.3220	0.3215	0.3200	0.0020	0.3212	0.0005626
P-343	0.3430	0.3440	0.3435	0.0010	0.3435	0.0006435
P-346	0.3465	0.3470	0.3465	0.0005	0.3467	0.0006555
G-345	0.3470	0.3475	0.3475	0.0005	0.3473	0.0006580
P27	0.3490	0.3480	0.3500	0.0020	0.3490	0.0006643
G-367	0.3700	0.3685	0.3690	0.0015	0.3692	0.0007433
P-375	0.3730	0.3750	0.3745	0.0020	0.3742	0.0007636
P-401	0.3980	0.3990	0.4000	0.0020	0.3990	0.0008683
P-407	0.4085	0.4085	0.4090	0.0005	0.4087	0.0009109
G-433	0.4360	0.4360	0.4355	0.0005	0.4358	0.0010360
P-29	0.4690	0.4690	0.4700	0.0010	0.4693	0.0012014
G-468	0.4700	0.4685	0.4720	0.0035	0.4702	0.0012057
P-7	0.4965	0.4945	0.4975	0.0030	0.4962	0.0013427
B	0.5020	0.5030	0.5035	0.0015	0.5028	0.0013790
G-540	0.5400	0.5410	0.5400	0.0010	0.5403	0.0015924
J				0.0000	#DIV/0!	#DIV/0!
G-215				0.0000	#DIV/0!	#DIV/0!
G-218				0.0000	#DIV/0!	#DIV/0!
G-2231				0.0000	#DIV/0!	#DIV/0!
G-2501				0.0000	#DIV/0!	#DIV/0!
P				0.0000	#DIV/0!	#DIV/0!
				0.0000	#DIV/0!	#DIV/0!
				0.0000	#DIV/0!	#DIV/0!
				0.0000	#DIV/0!	#DIV/0!
				0.0000	#DIV/0!	#DIV/0!
				0.0000	#DIV/0!	#DIV/0!

Where:

(a) D1, D2, D3 = three different nozzle diameters; each diameter must be measured to within (0.025mm) 0.001 in.

(b) Difference = maximum difference between any two diameters; must be less than or equal to (0.1mm) 0.004 in.

(c) Average = average of D1, D2 and D3

# A. Lanfranco & Associates inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

Model #: **LMU-A**  
Serial #: **Kimmon 186**

Date: **10-Jan-23**  
Barometric Pressure: **29.52** (in. Hg)  
Theoretical Critical Vacuum: **13.92** (in. Hg)

!!!!!!!

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)\*(min)).

!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (m³)	Volume Final (m³)	Volume Total (cu ft)	Initial Temps. Inlet (deg F)      Outlet (deg F)		Final Temps. Inlet (deg F)      Outlet (deg F)		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature -- Initial (deg F)      Final (deg F)      Average (deg F)		
0.00	15.00	557.8680	558.0660	6.992	68.0	68.0	70.0	70.0	48	0.3560	20.0	65.0	65.0	65.0
0.00	16.00	558.0660	558.2770	7.451	69.0	69.0	65.0	65.0	48	0.3560	20.0	64.0	61.0	62.5
0.00	21.00	558.2770	558.5550	9.817	67.0	67.0	65.0	65.0	48	0.3560	20.0	61.0	58.0	59.5

***** RESULTS *****											
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----		
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y			CALIBRATION FACTOR dH@		
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)		Value (in H2O)	Value (mm H2O)	Variation (in H2O)
6.883	194.9		6.880	194.8	6.936	1.000	0.001		0.000	0.00	0.000
7.363	208.5		7.356	208.3	7.381	0.999	0.001		0.000	0.00	0.000
9.719	275.2		9.683	274.2	9.660	0.996	-0.002		0.000	0.00	0.000
Average Y----->						0.9983		Average dH@----->	0.0000	0.00	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

For Temperature Devicee, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Liam Forrer

Signature: 

Date: January 10, 2023

# A. Lanfranco & Associates inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

Model #: **LMU-B**  
Serial #: **Wizit 6276**

Date: **10-Jan-23**  
Barometric Pressure: **29.58** (in. Hg)  
Theoretical Critical Vacuum: **13.95** (in. Hg)

!!!!!!!

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)\*(min)).

!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (m³)	Volume Final (m³)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
0.00	22.00	232.3240	232.6050	9.923	68.0	68.0	71.0	71.0	48	0.3560	20.0	63.0	65.0	64.0
0.00	18.00	232.6050	232.8370	8.193	70.0	70.0	73.0	73.0	48	0.3560	20.0	64.0	66.0	65.0
0.00	16.00	232.8370	233.0430	7.275	72.0	72.0	76.0	76.0	48	0.3560	20.0	65.0	69.0	67.0

\*\*\*\*\* RESULTS \*\*\*\*\*

--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----		
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y			CALIBRATION FACTOR dH@		
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)		Value (in H2O)	Value (mm H2O)	Variation (in H2O)
9.779	276.9		10.121	286.6	10.163	1.035	0.003		0.000	0.00	0.000
8.043	227.8		8.273	234.3	8.323	1.028	-0.003		0.000	0.00	0.000
7.109	201.3		7.339	207.9	7.413	1.032	0.001		0.000	0.00	0.000
Average Y----->						1.0320		Average dH@----->	0.0000	0.00	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

For Temperature Devicee, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Liam Forrer

Signature: \_\_\_\_\_

Date: January 10, 2023

# A. Lanfranco & Associates inc.

EPA Method 5

Meter Box Calibration

English Meter Box Units, English K' Factor

**Model #:** LMU-D  
**Serial #:** Wizat 4618

Date: 10-Jan-23  
Barometric Pressure: 29.58 (in. Hg)  
Theoretical Critical Vacuum: 13.95 (in. Hg)

!!!!!!!

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)\*(min)).  
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (m <sup>3</sup> )	Volume Final (m <sup>3</sup> )	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
0.00	18.00	96.613	96.838	7.942	72.0	72.0	75.0	75.0	48	0.3560	20.0	64.0	69.0	66.5
0.00	15.00	96.838	97.026	6.653	73.0	73.0	76.0	76.0	48	0.3560	20.0	63.0	68.0	65.5
0.00	20.00	97.026	97.278	8.899	75.0	75.0	76.0	76.0	48	0.3560	20.0	64.0	69.0	66.5

## \*\*\*\*\* RESULTS \*\*\*\*\*

--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----		
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y			CALIBRATION FACTOR dH@		
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)		Value (in H2O)	Value (mm H2O)	Variation (in H2O)
7.768	220.0		8.261	233.9	8.335	1.063	0.003		0.000	0.00	0.000
6.495	183.9		6.891	195.1	6.940	1.061	0.000		0.000	0.00	0.000
8.671	245.6		9.179	259.9	9.261	1.058	-0.002		0.000	0.00	0.000
Average Y----->						1.0609		Average dH@----->	0.0000	0.00	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

For Temperature Devicee, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Liam Forrer

Signature: \_\_\_\_\_



Date: January 10, 2023

# A.Lanfranco & Associates inc.

EPA Method 5  
Meter Box Calibration  
English Meter Box Units, English K' Factor

Model #: **ST CAE2**  
Serial #: **0028-072911-1**

Date: **09-Jan-23**  
Barometric Pressure: **29.33** (in. Hg)  
Theoretical Critical Vacuum: **13.83** (in. Hg)

!!!!!!!  
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>((in.Hg)<sup>2</sup>(min)).  
!!!!!!!

----- DRY GAS METER READINGS -----									-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
3.70	19.00	86.397	106.864	20.467	76.0	76.0	79.0	79.0	73	0.8185	12.5	74.0	76.0	75.0
1.95	16.00	72.580	85.009	12.429	75.0	75.0	76.0	76.0	63	0.5956	15.5	75.0	72.0	73.5
1.18	17.00	62.184	72.515	10.331	73.0	73.0	75.0	75.0	55	0.4606	17.0	79.0	74.0	76.5
0.68	16.00	54.727	62.105	7.378	70.0	70.0	73.0	73.0	48	0.3560	19.5	74.0	79.0	76.5
0.33	15.00	49.950	54.794	4.844	72.0	72.0	70.0	70.0	40	0.2408	21.0	69.0	73.0	71.0

***** RESULTS *****														
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----					
VOLUME CORRECTED	VOLUME CORRECTED		VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR Y			CALIBRATION FACTOR dH@					
Vm(std) (cu ft)	Vm(std) (liters)		Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)		Value (in H2O)	Value (mm H2O)	Variation (in H2O)			Ko (value)
19.884	563.1		19.720	558.5	20.392	0.992	0.000		1.860	47.26	-0.012			0.701
12.067	341.7		12.101	342.7	12.478	1.003	0.011		1.853	47.08	-0.019			0.696
10.039	284.3		9.915	280.8	10.282	0.988	-0.004		1.891	48.04	0.018			0.701
7.194	203.7		7.213	204.3	7.479	1.003	0.011		1.833	46.56	-0.040			0.701
4.724	133.8		4.597	130.2	4.718	0.973	-0.018		1.926	48.92	0.053			0.705
Average Y----->						0.9916	Average dH@----->		1.873	47.6	Average Ko----->		0.701	

TEMPERATURE CALIBRATION				
Calibration Standard ----->		Omega Model CL23A S/N:T-218768		
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Results		
		Variation (degF)	Percent of Absolute	
32	32	0	0.00%	
100	100	0	0.00%	
300	300	0	0.00%	
500	500	0	0.00%	
1000	1000	0	0.00%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.  
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 dm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.  
For Temperature Devices, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

Calibrated by: Liam Forrer

Signature: \_\_\_\_\_

Date: January 9, 2023

# Calibration Certificate

**Date:** 02-Feb-23  
**Calibrated by:** Louis Agassiz  
**Authorizing Signature:** 

**Instrument Calibrated:** Testo 1 (330-2LL)  
**Serial #:** 03101345  
**Customer:** ALA

**Ambient Conditions:** Temperature: 19 °C Barometric Pressure: 101.96 kPa Relative Humidity: 61%

A. Lanfranco and Associates Inc. certifies that the described instrument has been inspected and tested following calibration procedures in the Environment Canada Report EPS 1/PG/7 (Revised 2005). Below are the observed readings after calibrations are complete. Calibration checks should be completed at least every 6 months.

O <sub>2</sub> Gas	Initial Evaluation				After Calibration				Certified Value (vol %)
	Instrument Reading (vol %)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (vol %)	% Calibration Error	Pass/Fail	Notes	
Zero	0.15	0.15	Pass		0.05	0.05	Pass		0
O <sub>2</sub>	11.0	0.00	Pass		11.0	0.00	Pass		11.00
Ambient	20.9	0.05	Pass		20.9	0.05	Pass		20.95

Performance Specification: +/- 1% O<sub>2</sub> (absolute diff)

CO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	-1	0.3%	Pass		0	0.0%	Pass		0
1 Gas	1899	0.4%	Pass	Re-cal on 2 Gas	1915	0.4%	Pass		1907
2 Gas	475	7.1%	Fail		444	0.1%	Pass		444
3 Gas	230	5.9%	Fail		245	0.2%	Pass		245

Performance Specification: +/- 5% of Certified Gas Value

NO Gas	Initial Evaluation				After Calibration				Certified Value (ppm)
	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	Instrument Reading (ppm)	% Calibration Error	Pass/Fail	Notes	
Zero	0	0.0%	Pass		0	0.0%	Pass		0
1 Gas	102	1.6%	Pass	Re-cal on 3 Gas	100	0.4%	Pass		100
2 Gas	460	1.1%	Pass		467	0.4%	Pass		465
3 Gas	55	20.3%	Fail		45	1.6%	Pass		46

Performance Specification: +/- 5% of Certified Gas Value

## NIST Traceable Calibration Gases:

Cylinder	Cylinder ID Number	Certification Date	Expiration Date	Cylinder Pressure (PSI)	NO (ppm)	O <sub>2</sub> (Vol. %)	CO (ppm)
Zero Gas (N <sub>2</sub> )	833435	30-Jan-2021	29-Nov-2026	1000	0	0	0
1 Gas	XC004912B	10-Jun-2021	11-Jun-2029	300	100.4	-	1907
2 Gas	XC015932B	15-Jun-2021	14-Jun-2024	600	465.2	-	443.5
3 Gas	CC101659	21-Jun-2021	22-Jun-2029	1000	45.71	-	244.5
O <sub>2</sub> /CO <sub>2</sub>	CC38269	2-Jun-2021	3-May-2029	500	-	11.00	-

Note: National Institute of Standards and Technology traceable certificates are available upon request.

## Conflict of Interest Disclosure Statement

A qualified professional<sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

### Declaration

I Mark Lanfranco, as a member of Air and Waste Management Association  
declare

#### **Select one of the following:**

- ☒ Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.

☐ Real or perceived conflict of interest

Description and nature of conflict(s):

---

---

---

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

---

---

---

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.


This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

X 

Print name: Mark Lanfranco

Witnessed by:

X 

Print name: Carter Lanfranco

Date: Dec.16, 2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

***Shawn Harrington***

*has met the requirements of*

***Stack Testing for Pollutants***  
***( CHSC 7760 )***

*School of Process, Energy and Natural Resources*  
*Chemical Sciences Program*

*Endorsed by:*




Environment  
Canada

Environnement  
Canada



Province of  
British Columbia  
Ministry of  
Environment,  
Lands and Parks

  
Marsh Hemekey, Dean  
School of Process, Energy and Natural Resources

JUNE 21, 2001  
Dated



## Conflict of Interest Disclosure Statement

A qualified professional <sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

### Declaration

I Shawn Harrington as a member of Air and Waste Management Association  
declare

#### **Select one of the following:**

- ☒ Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas

, erring on the side of caution.



☐ Real or perceived conflict of interest

Description and nature of conflict(s):

---

---

---

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

---

---

---

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

x Shawn Harrington

Print name: Shawn Harrington

Date: Dec. 16, 2020

Witnessed by:

x Mark Lanfranco

Print name: Mark Lanfranco

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.



# **MOUNT ROYAL COLLEGE**

**Faculty of Continuing Education and Extension**

**Carter Lanfranco**

has successfully completed

**Stack Sampling**

**May 2009**

Date

Dean  
Faculty of Continuing Education and Extension

### Conflict of Interest Disclosure Statement

A qualified professional<sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

### Declaration

I Carter Lanfranco, as a member of Air and Waste Management Association  
declare

#### **Select one of the following:**

- ☒ Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.

☐ Real or perceived conflict of interest

Description and nature of conflict(s):

---

---

---

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

---

---

---

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

X

Print name: Carter Lanfranco

Witnessed by:

X

Print name: Mark Lanfranco

Date: Dec. 16, 2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.



# **MOUNT ROYAL COLLEGE**

**Faculty of Continuing Education and Extension**

**Daryl Sampson**

has successfully completed

The program of studies and is awarded the certificate in

**STACK SAMPLING**

**May 2005**

Date

*Donna Spaulding*

Dean  
Faculty of Continuing Education and Extension

## Conflict of Interest Disclosure Statement

A qualified professional <sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

## Declaration

I Daryl Sampson, as a member of Air and Waste Management Association  
declare

### **Select one of the following:**

☒ Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas, erring on the side of caution.

☐ Real or perceived conflict of interest

Description and nature of conflict(s):

---

---

---

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

---

---

---

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

X Daryl Sampson

Print name: Daryl Sampson

Date: Dec.18, 2020

Witnessed by:

X 

Print name: Mark Lanfranco

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

## Conflict of Interest Disclosure Statement

A qualified professional <sup>1</sup> providing services to either the Ministry of Environment and Climate Change Strategy ("ministry"), or to a regulated person for the purpose of obtaining an authorization from the ministry, or pursuant to a requirement imposed under the *Environmental Management Act*, the *Integrated Pest Management Act* or the *Park Act* has a real or perceived conflict of interest when the qualified professional, or their relatives, close associates or personal friends have a financial or other interest in the outcome of the work being performed.

A real or perceived conflict of interest occurs when a qualified professional has

- a) an ownership interest in the regulated person's business;
- b) an opportunity to influence a decision that leads to financial benefits from the regulated person or their business other than a standard fee for service (e.g. bonuses, stock options, other profit sharing arrangements);
- c) a personal or professional interest in a specific outcome;
- d) the promise of a long term or ongoing business relationship with the regulated person, that is contingent upon a specific outcome of work;
- e) a spouse or other family member who will benefit from a specific outcome; or
- f) any other interest that could be perceived as a threat to the independence or objectivity of the qualified professional in performing a duty or function.

Qualified professionals who work under ministry legislation must take care in the conduct of their work that potential conflicts of interest within their control are avoided or mitigated. Precise rules in conflict of interest are not possible and professionals must rely on guidance of their professional associations, their common sense, conscience and sense of personal integrity.

### Declaration

I Jeremy Gibbs, as a member of Air and Waste Management Association  
declare

#### **Select one of the following:**

- ☒ Absence from conflict of interest

Other than the standard fee I will receive for my professional services, I have no financial or other interest in the outcome of this project. I further declare that should a conflict of interest arise in the future during the course of this work, I will fully disclose the circumstances in writing and without delay to

Mr. Sajid Barlas

, erring on the side of caution.

☐ Real or perceived conflict of interest

Description and nature of conflict(s):

---

---

---

I will maintain my objectivity, conducting my work in accordance with my Code of Ethics and standards of practice.

In addition, I will take the following steps to mitigate the real or perceived conflict(s) I have disclosed, to ensure the public interest remains paramount:

---

---

---

Further, I acknowledge that this disclosure may be interpreted as a threat to my independence and will be considered by the statutory decision maker accordingly.

This conflict of interest disclosure statement is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

Signature:

X

Print name:

Jeremy G. B.S.S.

Witnessed by:

X

Print name:

Mark Lanfranco

Date: Dec.16, 2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

# MOUNT ROYAL UNIVERSITY

Faculty of Continuing Education and Extension

**Jeremy Shawn Gibbs**

has successfully completed

**Stack Sampling**

35 Hours / 2019

May 22, 2019

*Date*

*BUM*  
Dean

*Faculty of Continuing Education and Extension*





### Declaration of Competency


The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.


1. Name of Qualified Professional Shawn Harrington  
Title Senior Environmental Technician /Project manager
2. Are you a registered member of a professional association in B.C.? ☐ Yes ☒ No  
Name of Association: \_\_\_\_\_ Registration # \_\_\_\_\_
3. Brief description of professional services:  
Environmental consulting ,specializing in air and atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

### Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature:   
Print Name: Shawn Harrington

Witnessed by:   
Print Name: Mark Lanfranco

Date signed: November 26, 2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.



### Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional

Carter Lanfanco

Title

Chief operations officer / caretaker

2. Are you a registered member of a professional association in B.C.?

☐ Yes

☒ No

Name of Association: \_\_\_\_\_

Registration # \_\_\_\_\_

3. Brief description of professional services:

\_\_\_\_\_  
\_\_\_\_\_

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

### Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature: \_\_\_\_\_

X

Print Name: \_\_\_\_\_

Carter Lanfanco

Witnessed by: \_\_\_\_\_

X

Print Name: \_\_\_\_\_

Shawn Harrington

Date signed: \_\_\_\_\_

Dec. 7/2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

## Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional Daryl Sampson

Title Senior Environmental Technician/Project Manager

2. Are you a registered member of a professional association in B.C.? ☐ Yes ☒ No

Name of Association: \_\_\_\_\_ Registration # \_\_\_\_\_

3. Brief description of professional services:

Environmental consulting, specializing in air and atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

## Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature:

x Daryl Sampson

Print Name: Daryl Sampson

Witnessed by:

x [Signature]

Print Name: Louis Agassiz

Date signed: November 23, 2020

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

### Declaration of Competency

The Ministry of Environment and Climate Change Strategy relies on the work, advice, recommendations and in some cases decision making of qualified professionals<sup>1</sup>, under government's professional reliance regime. With this comes an assumption that professionals who undertake work in relation to ministry legislation, regulations and codes of practice have the knowledge, experience and objectivity necessary to fulfill this role.

1. Name of Qualified Professional

Title

Jeremy Gibbs  
Environmental technician

2. Are you a registered member of a professional association in B.C.?

☐ Yes ☒ No

Name of Association: \_\_\_\_\_ Registration # \_\_\_\_\_

3. Brief description of professional services:

Environmental Consultant Specialize in air and  
atmospheric sciences

This declaration of competency is collected under section 26(c) of the *Freedom of Information and Protection of Privacy Act* for the purposes of increasing government transparency and ensuring professional ethics and accountability. By signing and submitting this statement you consent to its publication and its disclosure outside of Canada. This consent is valid from the date submitted and cannot be revoked. If you have any questions about the collection, use or disclosure of your personal information please contact the Ministry of Environment and Climate Change Strategy Headquarters Office at 1-800-663-7867.

### Declaration

I am a qualified professional with the knowledge, skills and experience to provide expert information, advice and/or recommendations in relation to the specific work described above.

Signature:

X

Print Name:

Jeremy Gibbs  
Nov 1, 2020

Witnessed by:

X

Print Name:

Connor Laan

<sup>1</sup>Qualified Professional, in relation to a duty or function under ministry legislation, means an individual who

- a) is registered in British Columbia with a professional association, is acting under that organization's code of ethics, and is subject to disciplinary action by that association, and
- b) through suitable education, experience, accreditation and knowledge, may reasonably be relied on to provide advice within his or her area of expertise, which area of expertise is applicable to the duty or function.

# Canadian Association for Laboratory Accreditation Inc.

## Certificate of Accreditation

A. Lanfranco and Associates Inc.  
101 - 9488 - 189th Street  
Surrey, British Columbia



This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017.  
This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated April 2017).

Accreditation No.: A4232  
Issued On: February 5, 2021  
Accreditation Date: February 5, 2021  
Expiry Date: August 6, 2023



  
President & CEO

